

## Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at [http://www.cps.edu/About\\_CPS/Policies\\_and\\_guidelines/Pages/facilitystandards.aspx](http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx).

### Condition Rankings and Descriptions

- Rank 7:** The item/system is new or in good condition and no work is required.
- Rank 6:** The item/system requires general cleaning and/or routine maintenance.
- Rank 5:** The item/system requires repairs and has not reached the end of its serviceable life.
- Rank 4:** The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.
- Rank 3:** The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.
- Rank 2:** The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.
- Rank 1:** The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.<sup>1</sup>

### Definitions

- Quantity** means, for each item, the total number (or amount) of that item that exists and was evaluated.
- Unit** means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").
- Cost** means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.
- For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.**
- Total Campus Need** also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

### Building: Main Category: EXTERIOR

| Group      | Sub Group | Item                                      | Location                                    | Rank | Quantity | Unit | Cost     | Reason  |
|------------|-----------|---|---|------|----------|------|----------|---------|
| Chimney    |           | Brick Chimney - Stainless Steel Liner     | boiler house; lower chimney                 | 5    | 20       | LF   | \$24,310 |         |
| Chimney    |           | Brick Chimney - Stainless Steel Liner     | Boiler Room                                 | 6    | 60       | LF   | \$30,030 |         |
| Chimney    |           | Metal Flue                                | Boiler Room                                 | 6    | 26       | LF   | \$1,673  |         |
| Cornice    |           | Cornice - Terra Cotta                     | Entire Building                             | 6    | 354      | LF   | \$10,858 |         |
| Doors      |           | Exterior Steel Door                       | 1st Floor                                   | 6    | 20       | EA   | \$6,607  |         |
| Doors      |           | Transom Lite                              | 1st Floor                                   | 6    | 6        | EA   | \$1,699  |         |
| Entrance   |           | Concrete Exterior Stairs                  | North Entrances                             | 5    | 270      | LF   | \$86,873 |         |
| Entrance   |           | Entrance Controls - Audio and Video       | 1st Floor                                   | 6    | 2        | EA   | \$2,860  |         |
| Entrance   |           | Stair Handrails                           | North Entrances                             | 6    | 80       | LF   | \$0      |         |
| Foundation |           | Concrete Foundation                       | former basement wells & boiler house tunnel | 5    | 26       | LF   | \$11,607 | seepage |
| Foundation |           | Concrete Foundation                       | Entire Building                             | 7    | 1,160    | LF   | \$0      |         |
| Lighting   |           | Exterior Lights - Parapet or Roof Mounted | Roofs                                       | 6    | 21       | EA   | \$10,511 |         |
| Lighting   |           | Exterior Lights - Wall Mounted            | Entire Building                             | 6    | 7        | EA   | \$1,502  |         |
| Lintels    |           | Lintels - Steel                           | Entire Building                             | 6    | 598      | LF   | \$22,576 |         |

**Building: Main**  
**Category: EXTERIOR**

| Group                     | Sub Group | Item                                | Location                      | Rank | Quantity | Unit | Cost               | Reason                                     |
|---------------------------|-----------|-------------------------------------|-------------------------------|------|----------|------|--------------------|--|
| Lintels                   |           | Lintels - Terra Cotta               | entrances                     | 7    | 54       | LF   | \$0                |  |
| Parapet                   |           | Coping - Stone                      | Main Roof                     | 6    | 1,166    | LF   | \$0                |  |
| Parapet                   |           | Coping - Terra Cotta                | boiler house & low north roof | 6    | 242      | LF   | \$0                |  |
| Parapet                   |           | Parapet < 16" Height                | Main Roof                     | 6    | 50       | LF   | \$7,786            |  |
| Parapet                   |           | Parapet < 16" Height                | Boiler Room                   | 5    | 6        | LF   | \$1,444            |  |
| Parapet                   |           | Parapet > 30" Height                | Boiler Room                   | 5    | 152      | LF   | \$60,969           |  |
| Parapet                   |           | Parapet > 30" Height                | Main Roof                     | 6    | 952      | LF   | \$247,087          |  |
| Parapet                   |           | Parapet 16" to 30" Height           | Main Roof                     | 6    | 198      | LF   | \$41,112           |  |
| Parapet                   |           | Parapet 16" to 30" Height           | Boiler Room                   | 5    | 50       | LF   | \$16,045           |  |
| Roof System               |           | Exterior Downspouts                 | Roofs                         | 6    | 50       | LF   | \$930              |  |
| Roof System               |           | Interior Downspouts                 | Roofs                         | 6    | 315      | LF   | \$0                |  |
| Roof System               |           | Modified Bitumen Roof               | Roofs                         | 5    | 31,122   | SF   | \$367,162          | active leaks at NE gym and door 6 stairway |
| Roof System               |           | Roof Structure: Concrete            | Roofs                         | 7    | 31,122   | SF   | \$0                |  |
| Superstructure            |           | Concrete                            | Entire Building               | 7    | 63,602   | SF   | \$0                |  |
| Superstructure            |           | Concrete                            | S half of boiler house tunnel | 5    | 200      | SF   | \$4,362            | portions of ceiling are falling            |
| Walls                     |           | Brick                               | N exterior stairways          | 4    | 40       | SF   | \$3,020            |  |
| Walls                     |           | Brick                               | Entire Building               | 6    | 32,536   | SF   | \$214,952          |  |
| Walls                     |           | Brick                               | boiler house exterior breech  | 4    | 72       | SF   | \$5,436            |  |
| Walls                     |           | Prefabricated Metal Panel Wall      | boiler house, E elevation     | 6    | 120      | SF   | \$1,019            |  |
| Walls                     |           | Prefabricated Metal Panel Wall      | Entire Building               | 6    | 254      | SF   | \$2,158            |  |
| Walls                     |           | Stone - Cast                        | Entire Building               | 6    | 1,186    | SF   | \$16,960           |  |
| Walls                     |           | Terra Cotta                         | Entire Building               | 6    | 1,186    | SF   | \$33,920           |  |
| Windows                   |           | Curtain wall - Insulated panel      | gymnasium                     | 7    | 108      | SF   | \$0                |  |
| Windows                   |           | Window - Guards perforated          | 1st Floor                     | 7    | 3,080    | SF   | \$0                |  |
| Windows                   |           | Windows - Sash Aluminum Double-pane | library                       | 5    | 40       | SF   | \$1,381            | repair balance                             |
| Windows                   |           | Windows - Sash Aluminum Double-pane | Entire Building               | 7    | 5,320    | SF   | \$0                |  |
| Windows                   |           | Windows - Wood - Single-pane        | former basement wells         | 6    | 144      | SF   | \$2,059            |  |
| <b>EXTERIOR Sub Total</b> |           |                                     |                               |      |          |      | <b>\$1,238,906</b> |  |

**Building: Main**  
**Category: ELECTRICAL**

| Group            | Sub Group | Item  | Location        | Rank | Quantity | Unit | Cost | Reason |
|------------------|-----------|---|-----------------|------|----------|------|------|--------|
| Emergency System |           | Automatic Transfer switch                           | Boiler Room     | 7    | 1        | EA   | \$0  |        |
| Emergency System |           | Emergency A/C power - Auditorium and aisle lighting | 1st Floor       | 7    | 2,709    | SF   | \$0  |        |
| Emergency System |           | Emergency A/C power - Corridors and Stairs          | Entire Building | 7    | 13,573   | SF   | \$0  |        |

**Building: Main**  
**Category: ELECTRICAL**

| Group              | Sub Group | Item   | Location        | Rank | Quantity | Unit | Cost     | Reason |
|--------------------|-----------|--|-----------------|------|----------|------|----------|--------|
| Emergency System   |           | Emergency A/C power - Gym and Lunch rooms          | 1st Floor       | 7    | 2,798    | SF   | \$0      |        |
| Emergency System   |           | Emergency A/C power - Students Toilets             | Entire Building | 7    | 2,276    | SF   | \$0      |        |
| Emergency System   |           | Emergency Battery Packs - Corridors and Stairs     | Entire Building | 6    | 3        | EA   | \$322    |        |
| Emergency System   |           | Emergency Battery Packs - Lunchroom and Gym        | 1st Floor       | 6    | 2        | EA   | \$215    |        |
| Emergency System   |           | Exit Signs - Auditorium                            | 1st Floor       | 6    | 5        | EA   | \$1,165  |        |
| Emergency System   |           | Exit Signs - Corridors and Stairs                  | Entire Building | 6    | 15       | EA   | \$3,496  |        |
| Emergency System   |           | Exit Signs - Lunchroom - Gym - multipurpose rooms  | 1st Floor       | 6    | 3        | EA   | \$699    |        |
| Emergency System   |           | Independent Electrical Service for emergency power | Boiler Room     | 7    | 1        | EA   | \$0      |        |
| Emergency System   |           | Public Announcement System                         | 1st Floor       | 6    | 63,802   | SF   | \$38,319 |        |
| Emergency System   |           | Security System - CCTV                             | 1st Floor       | 6    | 63,802   | SF   | \$91,237 |        |
| Emergency System   |           | Security System - Intrusion detection              | 1st Floor       | 6    | 63,802   | SF   | \$59,304 |        |
| Main Service       |           | Main Electrical service 2000 to 3000 A 120/208/3PH | Boiler Room     | 7    | 1        | EA   | \$0      |        |
| Power Distribution |           | Lighting and power panels                          | Entire Building | 7    | 11       | EA   | \$0      |        |
| Power Distribution |           | Main distribution panels 400-600 amp               | Boiler Room     | 7    | 1        | EA   | \$0      |        |
| Power Distribution |           | Main distribution panels above 600 amp             | Boiler Room     | 7    | 1        | EA   | \$0      |        |

**ELECTRICAL Sub Total \$194,758**

**Building: Main**  
**Category: FIRE PROTECTION**

| Group      | Sub Group | Item                     | Location        | Rank | Quantity | Unit | Cost      | Reason   |
|------------|-----------|--------------------------|-----------------|------|----------|------|-----------|--|
| Fire Alarm |           | Fire Alarm Strobe Lights | Entire Building | 3    | 63,802   | SF   | \$135,031 | Strobe lights are not provided or not located in all areas |
| Fire Alarm |           | Fire Alarm System        | Boiler Room     | 4    | 63,802   | SF   | \$225,355 |  |

**FIRE PROTECTION Sub Total \$360,386**

**Building: Main**  
**Category: MECHANICAL**

| Group                | Sub Group | Item   | Location        | Rank | Quantity | Unit | Cost     | Reason |
|----------------------|-----------|--|-----------------|------|----------|------|----------|--------|
| Air Conditioning     |           | Window A/C Unit  | Entire Building | 6    | 37       | EA   | \$7,937  |        |
| Air Handling Systems |           | Air Intake - Built Up Air Handling Unit  | Roof            | 7    | 4        | EA   | \$0      |        |
| Air Handling Systems |           | Multi Zone Built Up Air Handling Unit - Steam 15,001 to 25,000 cfm             | Basement        | 6    | 2        | EA   | \$22,594 |        |
| Air Handling Systems |           | Multi Zone Built Up Air Handling Unit Auxiliaries - Steam 15,001 to 25,000 cfm | Basement        | 6    | 2        | EA   | \$5,720  |        |
| Air Handling Systems |           | Reheat Boxes With Steam Coils  | Air Tunnel      | 6    | 13       | EA   | \$13,571 |        |

**Building: Main**  
**Category: MECHANICAL**

| Group                       | Sub Group | Item  | Location        | Rank | Quantity | Unit | Cost               | Reason |
|-----------------------------|-----------|---|-----------------|------|----------|------|--------------------|--------|
| Air Handling Systems        |           | Return Duct Work - Masonry and Ducts - Existing or Missing Exterior Shaft     | Roof            | 4    | 400      | LF   | \$1,058,200        |        |
| Air Handling Systems        |           | Single Zone Built Up Air Handling Unit - Steam 4,000 to 8,000 cfm             | Basement        | 6    | 2        | EA   | \$10,010           |        |
| Air Handling Systems        |           | Single Zone Built Up Air Handling Unit Auxiliaries - Steam 4,000 to 8,000 cfm | Basement        | 6    | 2        | EA   | \$4,290            |        |
| Boiler Systems              |           | Boiler Assembly - Steam - Low Pressure Scotch Marine Boiler 151 - 200 HP      | Boiler Room     | 6    | 2        | EA   | \$33,176           |        |
| Boiler Systems              |           | Boiler Auxiliary - Steam Boiler 151 - 200 HP                                  | Boiler Room     | 6    | 2        | EA   | \$4,862            |        |
| Boiler Systems              |           | Chemical Feeder - Steam Boiler  | Boiler Room     | 6    | 2        | EA   | \$601              |        |
| Boiler Systems              |           | Combustion Dampers  | Boiler Room     | 6    | 2        | EA   | \$572              |        |
| Boiler Systems              |           | Feed Water Pumps and Tank - Steam Boilers                                     | Boiler Room     | 6    | 1        | EA   | \$8,437            |        |
| Heating Devices             |           | Unit Heater - Gas   | Boiler Room     | 6    | 1        | EA   | \$2,145            |        |
| Heating Devices             |           | Wall Heater - Electric  | Entire Building | 6    | 9        | EA   | \$927              |        |
| Mechanical Plumbing         |           | Piping - Condensate - Steel or Galvanized                                     | Entire Building | 5    | 500      | LF   | \$16,266           |        |
| Mechanical Plumbing         |           | Piping - Steam - Steel or Galvanized  | Entire Building | 5    | 500      | LF   | \$24,739           |        |
| Mechanical Plumbing         |           | Pumps - Vacuum  | Boiler Room     | 7    | 1        | EA   | \$0                |        |
| Temperature Control         |           | Direct Digital Control (DDC) System   | Entire Building | 5    | 63,802   | SF   | \$319,329          |        |
| Temperature Control         |           | Thermostats - Direct Digital Control (DDC)                                    | Entire Building | 6    | 27       | EA   | \$3,861            |        |
| Temperature Control         |           | Zone Dampers  | Air Tunnel      | 6    | 27       | EA   | \$3,861            |        |
| Ventilation                 |           | Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm                                | Roof            | 6    | 2        | EA   | \$858              |        |
| Ventilation                 |           | Type II Exhaust Hood - Warming Kitchen  | 1st Floor       | 7    | 1        | EA   | \$0                |        |
| <b>MECHANICAL Sub Total</b> |           |   |                 |      |          |      | <b>\$1,541,955</b> |        |

**Building: Main**  
**Category: PLUMBING**

| Group     | Sub Group | Item   | Location        | Rank | Quantity | Unit | Cost      | Reason |
|-----------|-----------|--|-----------------|------|----------|------|-----------|--------|
| Hot Water |           | Hot Water Heater - Gas 150,000 -300,000 BTU/HR       | Boiler Room     | 6    | 1        | EA   | \$4,147   |        |
| Piping    |           | Domestic Piping - Cold Water from Risers to Fixtures | Entire Building | 4    | 63,802   | SF   | \$20,984  |        |
| Piping    |           | Domestic Piping - Cold Water Risers                  | Entire Building | 4    | 63,802   | SF   | \$41,057  |        |
| Piping    |           | Domestic Piping - Hot Water from Riser to fixtures   | Entire Building | 4    | 63,802   | SF   | \$13,686  |        |
| Piping    |           | Domestic Piping - Hot Water Return Risers            | Entire Building | 4    | 63,802   | SF   | \$29,196  |        |
| Piping    |           | Domestic Piping - Hot Water Risers                   | Entire Building | 4    | 63,802   | SF   | \$34,670  |        |
| Piping    |           | Domestic Piping Cold Water Horizontal lines          | Entire Building | 4    | 63,802   | SF   | \$152,366 |        |
| Piping    |           | Domestic Piping Hot Water Horizontal lines           | Entire Building | 4    | 63,802   | SF   | \$125,907 |        |
| Piping    |           | Domestic Piping Hot Water Return Lines               | Entire Building | 4    | 63,802   | SF   | \$72,989  |        |
| Piping    |           | Sanitary Piping                                      | Entire Building | 5    | 63,802   | SF   | \$39,232  |        |
| Piping    |           | Storm Piping   | Entire Building | 5    | 63,802   | SF   | \$30,108  |        |

**Building: Main**  
**Category: PLUMBING**

| Group                     | Sub Group | Item                          | Location        | Rank | Quantity | Unit | Cost             | Reason |
|---------------------------|-----------|-------------------------------|-----------------|------|----------|------|------------------|--------|
| Piping                    |           | Vent Piping                   | Entire Building | 5    | 63,802   | SF   | \$22,809         |        |
| Pumps                     |           | Domestic Booster Pump simplex | Boiler Room     | 6    | 1        | EA   | \$1,716          |        |
| Pumps                     |           | Sump Pump                     | Boiler Room     | 6    | 1        | EA   | \$1,359          |        |
| <b>PLUMBING Sub Total</b> |           |                               |                 |      |          |      | <b>\$590,225</b> |        |

**Building: Main**  
**Category: INTERIOR**

| Group                 | Sub Group                     | Item                      | Location  | Rank | Quantity | Unit | Cost    | Reason |
|-----------------------|-------------------------------|---------------------------|---|------|----------|------|---------|--------|
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In          | Assistant Principal's Office                                    | 7    | 159      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In          | Principal's Office  | 7    | 114      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall | Room 116, Office  | 7    | 202      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall | Kitchen Office (Formerly the Men's Room next to the Auditorium) | 7    | 74       | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall | 1st floor west end of corridor                                  | 6    | 597      | SF   | \$1,690 |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall | 1st floor east end of corridor, #101                            | 5    | 478      | SF   | \$2,707 |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall | Room 216, Office  | 7    | 202      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall | Office, Room 200  | 6    | 98       | SF   | \$277   |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall | Room 204, Office  | 7    | 202      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall | Main Office   | 7    | 407      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall | 1st floor engineer's office                                     | 6    | 76       | SF   | \$215   |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall | Room 121, Gym Office (Girl's Locker Room per plan)              | 6    | 630      | SF   | \$1,784 |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet         | Assistant Principal's Office                                    | 7    | 159      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet         | Principal's Office  | 7    | 114      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet         | Main Office   | 7    | 204      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet     | Office, Room 200  | 7    | 98       | SF   | \$0     |        |

**Building: Main**  
**Category: INTERIOR**

| Group                 | Sub Group                     | Item                       | Location  | Rank | Quantity | Unit | Cost    | Reason |
|-----------------------|-------------------------------|----------------------------|---|------|----------|------|---------|--------|
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet      | Room 216, Office  | 7    | 202      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet      | Room 121, Gym Office (Girl's Locker Room per plan)              | 6    | 630      | SF   | \$901   |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet      | Kitchen Office (Formerly the Men's Room next to the Auditorium) | 7    | 74       | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet      | Main Office   | 7    | 204      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet      | 1st floor east end of corridor, #101                            | 6    | 478      | SF   | \$684   |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet      | 1st floor engineer's office                                     | 6    | 76       | SF   | \$109   |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet      | Room 116, Office  | 7    | 202      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet      | Room 204, Office  | 7    | 202      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Wood            | 1st floor west end of corridor                                  | 6    | 597      | SF   | \$4,508 |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | Office, Room 200  | 7    | 2        | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 1st floor engineer's office                                     | 4    | 1        | SF   | \$7     | T-12   |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 1st floor east end of corridor, #101                            | 6    | 9        | SF   | \$6     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | Main Office   | 7    | 5        | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | Principal's Office  | 7    | 2        | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | Assistant Principal's Office                                    | 7    | 2        | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | Kitchen Office (Formerly the Men's Room next to the Auditorium) | 7    | 1        | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | Room 121, Gym Office (Girl's Locker Room per plan)              | 7    | 3        | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | Room 116, Office  | 7    | 4        | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | Room 216, Office  | 7    | 4        | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | Room 204, Office  | 7    | 4        | SF   | \$0     |        |

**Building: Main**  
**Category: INTERIOR**

| Group                  | Sub Group                     | Item                         | Location  | Rank | Quantity | Unit | Cost     | Reason |
|------------------------|-------------------------------|------------------------------|---|------|----------|------|----------|--------|
| Administrative Suites  | Administrative Suites/Offices | Lighting - Pendant/Surface   | 1st floor west end of corridor                                  | 6    | 2        | SF   | \$1      |        |
| Administrative Suites  | Administrative Suites/Offices | Walls - Concrete Block       | Kitchen Office (Formerly the Men's Room next to the Auditorium) | 7    | 147      | SF   | \$0      |        |
| Administrative Suites  | Administrative Suites/Offices | Walls - Concrete Block       | Room 121, Gym Office (Girl's Locker Room per plan)              | 7    | 440      | SF   | \$0      |        |
| Administrative Suites  | Administrative Suites/Offices | Walls - Plaster/Drywall      | Room 121, Gym Office (Girl's Locker Room per plan)              | 6    | 440      | SF   | \$1,038  |        |
| Administrative Suites  | Administrative Suites/Offices | Walls - Plaster/Drywall      | Kitchen Office (Formerly the Men's Room next to the Auditorium) | 7    | 147      | SF   | \$0      |        |
| Administrative Suites  | Administrative Suites/Offices | Walls - Plaster/Drywall      | Office, Room 200  | 6    | 497      | SF   | \$1,173  |        |
| Administrative Suites  | Administrative Suites/Offices | Walls - Plaster/Drywall      | Room 204, Office  | 7    | 658      | SF   | \$0      |        |
| Administrative Suites  | Administrative Suites/Offices | Walls - Plaster/Drywall      | Assistant Principal's Office                                    | 7    | 390      | SF   | \$0      |        |
| Administrative Suites  | Administrative Suites/Offices | Walls - Plaster/Drywall      | Room 116, Office  | 7    | 658      | SF   | \$0      |        |
| Administrative Suites  | Administrative Suites/Offices | Walls - Plaster/Drywall      | Principal's Office  | 6    | 390      | SF   | \$920    |        |
| Administrative Suites  | Administrative Suites/Offices | Walls - Plaster/Drywall      | Main Office   | 7    | 941      | SF   | \$0      |        |
| Administrative Suites  | Administrative Suites/Offices | Walls - Plaster/Drywall      | 1st floor west end of corridor                                  | 6    | 1,134    | SF   | \$2,676  |        |
| Administrative Suites  | Administrative Suites/Offices | Walls - Plaster/Drywall      | 1st floor east end of corridor, #101                            | 5    | 1,124    | SF   | \$5,304  |        |
| Administrative Suites  | Administrative Suites/Offices | Walls - Plaster/Drywall      | 1st floor engineer's office                                     | 5    | 418      | SF   | \$1,973  |        |
| Administrative Suites  | Administrative Suites/Offices | Walls - Plaster/Drywall      | Room 216, Office  | 7    | 658      | SF   | \$0      |        |
| Auditorium - Dedicated | Auditorium - Dedicated        | Balcony Seating              | 1st Floor   | 7    | 90       | EA   | \$0      |        |
| Auditorium - Dedicated | Auditorium - Dedicated        | Sound System                 | 1st Floor   | 7    | 1        | EA   | \$0      |        |
| Auditorium - Dedicated | Auditorium - Dedicated        | Stage Curtains               | 1st Floor   | 6    | 8        | EA   | \$90,605 |        |
| Auditorium - Dedicated | Auditorium - Dedicated        | Stage Lighting System        | 1st Floor   | 7    | 1        | EA   | \$0      |        |
| Corridor               |                               | Stair Handrails              | Basement inside boiler room                                     | 6    | 120      | LF   | \$0      |        |
| Corridor               |                               | Stairs - Tile                | Basement inside boiler room                                     | 6    | 57       | LF   | \$430    |        |
| Doors                  |                               | Interior Steel Doors incl hw | Basement  | 6    | 6        | EA   | \$1,699  |        |
| Doors                  |                               | Interior Steel Doors incl hw | 1st Floor   | 6    | 1        | EA   | \$283    |        |
| Doors                  |                               | Interior Wood Doors incl hw  | Basement  | 5    | 23       | EA   | \$10,854 |        |

**Building: Main**  
**Category: INTERIOR**

| Group                    | Sub Group                    | Item                                 | Location                              | Rank | Quantity | Unit | Cost     | Reason                  |
|--------------------------|------------------------------|--------------------------------------|---------------------------------------|------|----------|------|----------|-------------------------|
| Doors                    |                              | Interior Wood Doors incl hw          | 1st Floor                             | 6    | 54       | EA   | \$15,290 |                         |
| Doors                    |                              | Interior Wood Doors incl hw          | 2nd Floor                             | 6    | 38       | EA   | \$10,759 |                         |
| Doors                    |                              | Transom Window                       | 1st Floor                             | 6    | 140      | SF   | \$2,603  |                         |
| Doors                    |                              | Transom Window                       | 2nd Floor                             | 6    | 140      | SF   | \$2,603  |                         |
| Drinking Fountains       | Corridors                    | Single Fountain                      | 2nd Floor                             | 7    | 4        | EA   | \$0      |                         |
| Drinking Fountains       | Corridors                    | Single Fountain                      | 1st Floor                             | 7    | 4        | EA   | \$0      |                         |
| Gymnasium / Auditorium   | Standard Dedicated Gymnasium | Ceiling - Lay-In                     | 1st Floor                             | 6    | 2,798    | SF   | \$22,006 |                         |
| Gymnasium / Auditorium   | Standard Dedicated Gymnasium | Flooring - Wood                      | 1st Floor                             | 7    | 2,798    | SF   | \$0      |                         |
| Gymnasium / Auditorium   | Standard Dedicated Gymnasium | Lighting - Metal Halide/Sodium Vapor | 1st Floor                             | 7    | 12       | EA   | \$0      |                         |
| Gymnasium / Auditorium   | Standard Dedicated Gymnasium | Scoreboards                          | 1st Floor                             | 7    | 1        | EA   | \$0      |                         |
| Gymnasium / Auditorium   | Standard Dedicated Gymnasium | Walls - Concrete Block               | 1st Floor                             | 7    | 2,007    | SF   | \$0      |                         |
| Gymnasium / Auditorium   | Standard Dedicated Gymnasium | Walls - Plaster/Drywall              | 1st Floor                             | 6    | 3,011    | SF   | \$25,834 |                         |
| Kitchen                  | Warming Kitchen              | Ceiling - Plaster/Drywall            | In the Auditorium Area                | 7    | 177      | SF   | \$0      |                         |
| Kitchen                  | Warming Kitchen              | Flooring - Tile/Sheet                | In the Auditorium Area                | 7    | 177      | SF   | \$0      |                         |
| Kitchen                  | Warming Kitchen              | Lighting - Pendant/Surface           | In the Auditorium Area                | 7    | 2        | SF   | \$0      |                         |
| Kitchen                  | Warming Kitchen              | Wall - Plaster/Drywall               | In the Auditorium Area                | 7    | 422      | SF   | \$0      |                         |
| Library                  | Library                      | Casework                             | 1st Floor                             | 6    | 105      | LF   | \$3,221  |                         |
| Library                  | Library                      | Flooring Carpet                      | 1st Floor                             | 6    | 732      | SF   | \$1,047  |                         |
| Library                  | Library                      | Lighting - Pendant/ Surface          | 1st Floor                             | 6    | 12       | SF   | \$9      |                         |
| Lunchroom                | Multipurpose Room            | Ceiling - Plaster/Drywall            | In the Auditorium                     | 6    | 2,709    | SF   | \$7,670  |                         |
| Lunchroom                | Multipurpose Room            | Flooring - Tile/Sheet                | In the Auditorium                     | 7    | 2,709    | SF   | \$0      |                         |
| Lunchroom                | Multipurpose Room            | Lighting - Pendant/Surface           | In the Auditorium                     | 7    | 32       | SF   | \$0      |                         |
| Lunchroom                | Multipurpose Room            | Serving Line                         | In the Auditorium                     | 7    | 16       | LF   | \$0      |                         |
| Lunchroom                | Multipurpose Room            | Wall - Plaster/Drywall               | In the Auditorium                     | 6    | 5,560    | SF   | \$13,119 |                         |
| MDF/IDF                  |                              | Finishes                             | Room 221                              | 6    | 95       | SF   | \$323    |                         |
| MDF/IDF                  |                              | Ventilation and Cooling              | Room 221                              | 7    | 1        | EA   | \$0      |                         |
| Mechanical/Service Rooms |                              | Boiler Room                          | Basement                              | 5    | 2,444    | SF   | \$27,680 | Water on concrete floor |
| Mechanical/Service Rooms |                              | Crawl Space - Unfinished             | Basement                              | 6    | 14,481   | SF   | \$27,334 |                         |
| Mechanical/Service Rooms |                              | Janitor's Closet                     | Entire Building                       | 6    | 4        | SF   | \$19     |                         |
| Mechanical/Service Rooms |                              | Mechanical/Service Rooms             | In the Multipurpose Room Area         | 7    | 180      | SF   | \$0      |                         |
| Mechanical/Service Rooms |                              | Storage Room                         | Former Girl's Room next to Auditorium | 7    | 134      | SF   | \$0      |                         |
| Mechanical/Service Rooms |                              | Storage Room                         | Room 220, Book Storage                | 7    | 608      | SF   | \$0      |                         |



**Building: Main**  
**Category: INTERIOR**

| Group                    | Sub Group                            | Item                      | Location  | Rank | Quantity | Unit | Cost    | Reason |
|--------------------------|--------------------------------------|---------------------------|---|------|----------|------|---------|--------|
| Mechanical/Service Rooms |                                      | Storage Room              | Basement east of boiler room                    | 6    | 1,580    | SF   | \$7,456 |        |
| Mechanical/Service Rooms |                                      | Storage Room              | Outside the Auditorium                          | 7    | 86       | SF   | \$0     |        |
| Mechanical/Service Rooms |                                      | Storage Room              | 1st floor inside Rm 107                         | 5    | 126      | SF   | \$1,427 | T-12   |
| Staff Restroom           | Children's Standard Student Restroom | Accessories               | 1st Floor North Girl's Room                     | 6    | 296      | SF   | \$2,286 |        |
| Staff Restroom           | Children's Standard Student Restroom | Accessories               | 1st Floor South Girl's Room                     | 6    | 296      | SF   | \$2,286 |        |
| Staff Restroom           | Children's Standard Student Restroom | Accessories               | 2nd Floor South Girl's Room                     | 6    | 296      | SF   | \$2,286 |        |
| Staff Restroom           | Children's Standard Student Restroom | Accessories               | 2nd Floor North Girl's Room                     | 6    | 296      | SF   | \$2,286 |        |
| Staff Restroom           | Staff Restroom                       | Accessories               | In Room 200                                     | 6    | 89       | SF   | \$687   |        |
| Staff Restroom           | Early Childhood Student Restroom     | Accessories               | Boy's Room in Room 114                          | 6    | 29       | SF   | \$224   |        |
| Staff Restroom           | Early Childhood Student Restroom     | Accessories               | 1st floor inside Rm #107                        | 6    | 210      | SF   | \$1,622 |        |
| Staff Restroom           | Children's Standard Student Restroom | Accessories               | 2nd Floor North Boy's Room                      | 6    | 273      | SF   | \$2,108 |        |
| Staff Restroom           | Staff Restroom                       | Accessories               | In Principal's Office                           | 6    | 33       | SF   | \$255   |        |
| Staff Restroom           | Children's Standard Student Restroom | Accessories               | 1st Floor South Boy's Room                      | 6    | 273      | SF   | \$2,108 |        |
| Staff Restroom           | Children's Standard Student Restroom | Accessories               | 2nd Floor South Boy's Room                      | 6    | 273      | SF   | \$2,108 |        |
| Staff Restroom           | Children's Standard Student Restroom | Accessories               | 1st Floor North Boy's Room                      | 6    | 273      | SF   | \$2,108 |        |
| Staff Restroom           | Staff Restroom                       | Accessories               | 1st floor inside office at west end of corridor | 6    | 83       | SF   | \$641   |        |
| Staff Restroom           | Staff Restroom                       | Accessories               | 1st floor next to engineer's office             | 6    | 15       | SF   | \$116   |        |
| Staff Restroom           | Staff Restroom                       | Accessories               | 1st floor inside engineer's office              | 6    | 26       | SF   | \$201   |        |
| Staff Restroom           | Early Childhood Student Restroom     | Accessories               | Girl's Room in Room 114                         | 6    | 29       | SF   | \$224   |        |
| Staff Restroom           | Children's Standard Student Restroom | Ceiling - Plaster/Drywall | 1st Floor South Boy's Room                      | 6    | 273      | SF   | \$773   |        |
| Staff Restroom           | Staff Restroom                       | Ceiling - Plaster/Drywall | 1st floor inside engineer's office              | 6    | 26       | SF   | \$74    |        |
| Staff Restroom           | Staff Restroom                       | Ceiling - Plaster/Drywall | 1st floor next to engineer's office             | 6    | 15       | SF   | \$42    |        |
| Staff Restroom           | Staff Restroom                       | Ceiling - Plaster/Drywall | In Principal's Office                           | 7    | 33       | SF   | \$0     |        |
| Staff Restroom           | Staff Restroom                       | Ceiling - Plaster/Drywall | 1st floor inside office at west end of corridor | 6    | 83       | SF   | \$235   |        |

**Building: Main**  
**Category: INTERIOR**

| Group          | Sub Group                            | Item                      | Location                    | Rank | Quantity | Unit | Cost  | Reason |
|----------------|--------------------------------------|---------------------------|-----------------------------|------|----------|------|-------|--------|
| Staff Restroom | Children's Standard Student Restroom | Ceiling - Plaster/Drywall | 2nd Floor South Boy's Room  | 6    | 273      | SF   | \$773 |        |
| Staff Restroom | Children's Standard Student Restroom | Ceiling - Plaster/Drywall | 1st Floor North Boy's Room  | 6    | 273      | SF   | \$773 |        |
| Staff Restroom | Early Childhood Student Restroom     | Ceiling - Plaster/Drywall | 1st floor inside Rm #107    | 6    | 210      | SF   | \$595 |        |
| Staff Restroom | Children's Standard Student Restroom | Ceiling - Plaster/Drywall | 1st Floor North Girl's Room | 7    | 296      | SF   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Ceiling - Plaster/Drywall | 1st Floor South Girl's Room | 7    | 296      | SF   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Ceiling - Plaster/Drywall | 2nd Floor South Girl's Room | 7    | 296      | SF   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Ceiling - Plaster/Drywall | 2nd Floor North Girl's Room | 7    | 296      | SF   | \$0   |        |
| Staff Restroom | Staff Restroom                       | Ceiling - Plaster/Drywall | In Room 200                 | 7    | 89       | SF   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Ceiling - Plaster/Drywall | 2nd Floor North Boy's Room  | 6    | 273      | SF   | \$773 |        |
| Staff Restroom | Early Childhood Student Restroom     | Ceiling - Plaster/Drywall | Boy's Room in Room 114      | 7    | 29       | SF   | \$0   |        |
| Staff Restroom | Early Childhood Student Restroom     | Ceiling - Plaster/Drywall | Girl's Room in Room 114     | 7    | 29       | SF   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Floor Drain               | 2nd Floor South Girl's Room | 7    | 1        | EA   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Floor Drain               | 1st Floor South Girl's Room | 7    | 1        | EA   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Floor Drain               | 1st Floor North Girl's Room | 7    | 1        | EA   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Floor Drain               | 2nd Floor North Boy's Room  | 7    | 1        | EA   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Floor Drain               | 1st Floor North Boy's Room  | 7    | 1        | EA   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Floor Drain               | 2nd Floor South Boy's Room  | 7    | 1        | EA   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Floor Drain               | 2nd Floor North Girl's Room | 7    | 1        | EA   | \$0   |        |
| Staff Restroom | Early Childhood Student Restroom     | Floor Drain               | Boy's Room in Room 114      | 7    | 1        | EA   | \$0   |        |
| Staff Restroom | Early Childhood Student Restroom     | Floor Drain               | 1st floor inside Rm #107    | 6    | 1        | EA   | \$300 |        |
| Staff Restroom | Early Childhood Student Restroom     | Floor Drain               | Girl's Room in Room 114     | 7    | 1        | EA   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Floor Drain               | 1st Floor South Boy's Room  | 7    | 1        | EA   | \$0   |        |

**Building: Main**  
**Category: INTERIOR**

| Group          | Sub Group                            | Item                              | Location  | Rank | Quantity | Unit | Cost  | Reason |
|----------------|--------------------------------------|-----------------------------------|---|------|----------|------|-------|--------|
| Staff Restroom | Early Childhood Student Restroom     | Flooring - Terrazzo               | 1st floor inside Rm #107                        | 6    | 140      | SF   | \$793 |        |
| Staff Restroom | Children's Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 2nd Floor South Boy's Room                      | 6    | 273      | SF   | \$695 |        |
| Staff Restroom | Children's Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 1st Floor North Boy's Room                      | 6    | 273      | SF   | \$695 |        |
| Staff Restroom | Staff Restroom                       | Flooring - Tile Ceramic/Porcelain | In Room 200                                     | 6    | 89       | SF   | \$227 |        |
| Staff Restroom | Children's Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 1st Floor South Boy's Room                      | 6    | 273      | SF   | \$695 |        |
| Staff Restroom | Children's Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 2nd Floor South Girl's Room                     | 6    | 296      | SF   | \$753 |        |
| Staff Restroom | Children's Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 1st Floor South Girl's Room                     | 6    | 296      | SF   | \$753 |        |
| Staff Restroom | Children's Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 1st Floor North Girl's Room                     | 6    | 296      | SF   | \$753 |        |
| Staff Restroom | Children's Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 2nd Floor North Boy's Room                      | 6    | 273      | SF   | \$695 |        |
| Staff Restroom | Early Childhood Student Restroom     | Flooring - Tile Ceramic/Porcelain | 1st floor inside Rm #107                        | 6    | 70       | SF   | \$178 |        |
| Staff Restroom | Staff Restroom                       | Flooring - Tile Ceramic/Porcelain | 1st floor inside office at west end of corridor | 6    | 83       | SF   | \$211 |        |
| Staff Restroom | Children's Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 2nd Floor North Girl's Room                     | 6    | 296      | SF   | \$753 |        |
| Staff Restroom | Early Childhood Student Restroom     | Flooring - Tile/Sheet             | Boy's Room in Room 114                          | 6    | 29       | SF   | \$41  |        |
| Staff Restroom | Staff Restroom                       | Flooring - Tile/Sheet             | In Principal's Office                           | 7    | 33       | SF   | \$0   |        |
| Staff Restroom | Early Childhood Student Restroom     | Flooring - Tile/Sheet             | Girl's Room in Room 114                         | 6    | 29       | SF   | \$41  |        |
| Staff Restroom | Staff Restroom                       | Flooring - Tile/Sheet             | 1st floor inside engineer's office              | 6    | 26       | SF   | \$37  |        |
| Staff Restroom | Staff Restroom                       | Flooring - Tile/Sheet             | 1st floor next to engineer's office             | 6    | 15       | SF   | \$21  |        |
| Staff Restroom | Children's Standard Student Restroom | Hand Dryer                        | 1st Floor North Girl's Room                     | 7    | 2        | EA   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Hand Dryer                        | 1st Floor South Boy's Room                      | 7    | 2        | EA   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Hand Dryer                        | 2nd Floor North Girl's Room                     | 7    | 2        | EA   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Hand Dryer                        | 2nd Floor South Girl's Room                     | 7    | 2        | EA   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Hand Dryer                        | 1st Floor South Girl's Room                     | 7    | 2        | EA   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Hand Dryer                        | 2nd Floor North Boy's Room                      | 7    | 2        | EA   | \$0   |        |

**Building: Main**  
**Category: INTERIOR**

| Group          | Sub Group                            | Item                        | Location  | Rank | Quantity | Unit | Cost    | Reason |
|----------------|--------------------------------------|-----------------------------|---|------|----------|------|---------|--------|
| Staff Restroom | Children's Standard Student Restroom | Hand Dryer                  | 1st Floor North Boy's Room                      | 7    | 2        | EA   | \$0     |        |
| Staff Restroom | Children's Standard Student Restroom | Hand Dryer                  | 2nd Floor South Boy's Room                      | 7    | 2        | EA   | \$0     |        |
| Staff Restroom | Children's Standard Student Restroom | Lavatory                    | 2nd Floor South Boy's Room                      | 7    | 2        | EA   | \$0     |        |
| Staff Restroom | Children's Standard Student Restroom | Lavatory                    | 1st Floor South Boy's Room                      | 7    | 2        | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                       | Lavatory                    | In Principal's Office                           | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Early Childhood Student Restroom     | Lavatory                    | Girl's Room in Room 114                         | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Children's Standard Student Restroom | Lavatory                    | 1st Floor North Boy's Room                      | 7    | 2        | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                       | Lavatory                    | 1st floor next to engineer's office             | 5    | 1        | EA   | \$1,859 |        |
| Staff Restroom | Children's Standard Student Restroom | Lavatory                    | 2nd Floor South Girl's Room                     | 7    | 2        | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                       | Lavatory                    | 1st floor inside engineer's office              | 5    | 1        | EA   | \$1,859 |        |
| Staff Restroom | Staff Restroom                       | Lavatory                    | 1st floor inside office at west end of corridor | 6    | 1        | EA   | \$372   |        |
| Staff Restroom | Children's Standard Student Restroom | Lavatory                    | 2nd Floor North Boy's Room                      | 7    | 2        | EA   | \$0     |        |
| Staff Restroom | Children's Standard Student Restroom | Lavatory                    | 1st Floor South Girl's Room                     | 7    | 2        | EA   | \$0     |        |
| Staff Restroom | Children's Standard Student Restroom | Lavatory                    | 2nd Floor North Girl's Room                     | 7    | 2        | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                       | Lavatory                    | In Room 200                                     | 7    | 2        | EA   | \$0     |        |
| Staff Restroom | Early Childhood Student Restroom     | Lavatory                    | 1st floor inside Rm #107                        | 6    | 2        | EA   | \$744   |        |
| Staff Restroom | Early Childhood Student Restroom     | Lavatory                    | Boy's Room in Room 114                          | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Children's Standard Student Restroom | Lavatory                    | 1st Floor North Girl's Room                     | 7    | 2        | EA   | \$0     |        |
| Staff Restroom | Early Childhood Student Restroom     | Lighting - Lay-In           | Boy's Room in Room 114                          | 7    | 1        | SF   | \$0     |        |
| Staff Restroom | Early Childhood Student Restroom     | Lighting - Lay-In           | Girl's Room in Room 114                         | 7    | 1        | SF   | \$0     |        |
| Staff Restroom | Staff Restroom                       | Lighting - Pendant/ Surface | 1st floor inside engineer's office              | 4    | 1        | SF   | \$4     | T-12   |
| Staff Restroom | Staff Restroom                       | Lighting - Pendant/ Surface | 1st floor next to engineer's office             | 4    | 1        | SF   | \$4     | T-12   |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Pendant/ Surface | 1st Floor North Girl's Room                     | 7    | 4        | SF   | \$0     |        |

**Building: Main**  
**Category: INTERIOR**

| Group          | Sub Group                            | Item                        | Location  | Rank | Quantity | Unit | Cost  | Reason |
|----------------|--------------------------------------|-----------------------------|---|------|----------|------|-------|--------|
| Staff Restroom | Children's Standard Student Restroom | Lighting - Pendant/ Surface | 2nd Floor North Girl's Room                     | 7    | 4        | SF   | \$0   |        |
| Staff Restroom | Staff Restroom                       | Lighting - Pendant/ Surface | In Room 200                                     | 7    | 1        | SF   | \$0   |        |
| Staff Restroom | Early Childhood Student Restroom     | Lighting - Pendant/ Surface | 1st floor inside Rm #107                        | 6    | 3        | SF   | \$2   |        |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Pendant/ Surface | 2nd Floor South Girl's Room                     | 7    | 4        | SF   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Pendant/ Surface | 1st Floor South Girl's Room                     | 7    | 4        | SF   | \$0   |        |
| Staff Restroom | Staff Restroom                       | Lighting - Pendant/ Surface | 1st floor inside office at west end of corridor | 6    | 1        | SF   | \$1   |        |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Pendant/ Surface | 2nd Floor North Boy's Room                      | 7    | 4        | SF   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Pendant/ Surface | 1st Floor North Boy's Room                      | 7    | 4        | SF   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Pendant/ Surface | 2nd Floor South Boy's Room                      | 7    | 4        | SF   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Pendant/ Surface | 1st Floor South Boy's Room                      | 7    | 4        | SF   | \$0   |        |
| Staff Restroom | Staff Restroom                       | Lighting - Wall Mounted     | In Principal's Office                           | 7    | 1        | EA   | \$0   |        |
| Staff Restroom | Staff Restroom                       | Lighting - Wall Mounted     | In Room 200                                     | 7    | 1        | EA   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Partitions                  | 2nd Floor South Girl's Room                     | 6    | 4        | EA   | \$717 |        |
| Staff Restroom | Children's Standard Student Restroom | Partitions                  | 1st Floor North Boy's Room                      | 7    | 2        | EA   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Partitions                  | 1st Floor South Girl's Room                     | 6    | 4        | EA   | \$717 |        |
| Staff Restroom | Children's Standard Student Restroom | Partitions                  | 1st Floor South Boy's Room                      | 7    | 2        | EA   | \$0   |        |
| Staff Restroom | Staff Restroom                       | Partitions                  | 1st floor inside office at west end of corridor | 6    | 2        | EA   | \$359 |        |
| Staff Restroom | Children's Standard Student Restroom | Partitions                  | 2nd Floor South Boy's Room                      | 7    | 2        | EA   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Partitions                  | 2nd Floor North Boy's Room                      | 7    | 2        | EA   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Partitions                  | 1st Floor North Girl's Room                     | 6    | 4        | EA   | \$717 |        |
| Staff Restroom | Children's Standard Student Restroom | Partitions                  | 2nd Floor North Girl's Room                     | 6    | 4        | EA   | \$717 |        |
| Staff Restroom | Early Childhood Student Restroom     | Partitions                  | 1st floor inside Rm #107                        | 6    | 2        | EA   | \$359 |        |
| Staff Restroom | Staff Restroom                       | Partitions                  | In Room 200                                     | 6    | 2        | EA   | \$359 |        |

**Building: Main**  
**Category: INTERIOR**

| Group          | Sub Group                            | Item                   | Location                    | Rank | Quantity | Unit | Cost    | Reason |
|----------------|--------------------------------------|------------------------|-----------------------------|------|----------|------|---------|--------|
| Staff Restroom | Children's Standard Student Restroom | Urinals                | 2nd Floor South Boy's Room  | 7    | 4        | EA   | \$0     |        |
| Staff Restroom | Children's Standard Student Restroom | Urinals                | 1st Floor South Boy's Room  | 7    | 4        | EA   | \$0     |        |
| Staff Restroom | Children's Standard Student Restroom | Urinals                | 1st Floor North Boy's Room  | 7    | 4        | EA   | \$0     |        |
| Staff Restroom | Children's Standard Student Restroom | Urinals                | 2nd Floor North Boy's Room  | 7    | 4        | EA   | \$0     |        |
| Staff Restroom | Children's Standard Student Restroom | Wall - Concrete Block  | 1st Floor South Boy's Room  | 7    | 365      | SF   | \$0     |        |
| Staff Restroom | Children's Standard Student Restroom | Wall - Concrete Block  | 2nd Floor North Girl's Room | 7    | 413      | SF   | \$0     |        |
| Staff Restroom | Children's Standard Student Restroom | Wall - Concrete Block  | 2nd Floor South Girl's Room | 7    | 413      | SF   | \$0     |        |
| Staff Restroom | Staff Restroom                       | Wall - Concrete Block  | In Room 200                 | 7    | 235      | SF   | \$0     |        |
| Staff Restroom | Children's Standard Student Restroom | Wall - Concrete Block  | 2nd Floor South Boy's Room  | 7    | 365      | SF   | \$0     |        |
| Staff Restroom | Children's Standard Student Restroom | Wall - Concrete Block  | 1st Floor North Boy's Room  | 7    | 365      | SF   | \$0     |        |
| Staff Restroom | Children's Standard Student Restroom | Wall - Concrete Block  | 2nd Floor North Boy's Room  | 7    | 365      | SF   | \$0     |        |
| Staff Restroom | Children's Standard Student Restroom | Wall - Concrete Block  | 1st Floor North Girl's Room | 7    | 413      | SF   | \$0     |        |
| Staff Restroom | Children's Standard Student Restroom | Wall - Concrete Block  | 1st Floor South Girl's Room | 7    | 413      | SF   | \$0     |        |
| Staff Restroom | Children's Standard Student Restroom | Wall - Plaster/Drywall | 2nd Floor South Boy's Room  | 6    | 365      | SF   | \$861   |        |
| Staff Restroom | Early Childhood Student Restroom     | Wall - Plaster/Drywall | 1st floor inside Rm #107    | 5    | 753      | SF   | \$3,553 |        |
| Staff Restroom | Staff Restroom                       | Wall - Plaster/Drywall | In Room 200                 | 6    | 235      | SF   | \$554   |        |
| Staff Restroom | Children's Standard Student Restroom | Wall - Plaster/Drywall | 1st Floor South Girl's Room | 6    | 413      | SF   | \$974   |        |
| Staff Restroom | Children's Standard Student Restroom | Wall - Plaster/Drywall | 2nd Floor South Girl's Room | 6    | 413      | SF   | \$974   |        |
| Staff Restroom | Children's Standard Student Restroom | Wall - Plaster/Drywall | 1st Floor North Girl's Room | 6    | 413      | SF   | \$974   |        |
| Staff Restroom | Children's Standard Student Restroom | Wall - Plaster/Drywall | 2nd Floor North Boy's Room  | 6    | 365      | SF   | \$861   |        |
| Staff Restroom | Children's Standard Student Restroom | Wall - Plaster/Drywall | 1st Floor North Boy's Room  | 6    | 365      | SF   | \$861   |        |
| Staff Restroom | Early Childhood Student Restroom     | Wall - Plaster/Drywall | Boy's Room in Room 114      | 6    | 174      | SF   | \$411   |        |
| Staff Restroom | Children's Standard Student Restroom | Wall - Plaster/Drywall | 2nd Floor North Girl's Room | 6    | 413      | SF   | \$974   |        |

**Building: Main**  
**Category: INTERIOR**

| Group          | Sub Group                            | Item                      | Location  | Rank | Quantity | Unit | Cost    | Reason |
|----------------|--------------------------------------|---------------------------|---|------|----------|------|---------|--------|
| Staff Restroom | Staff Restroom                       | Wall - Plaster/Drywall    | In Principal's Office                           | 7    | 292      | SF   | \$0     |        |
| Staff Restroom | Early Childhood Student Restroom     | Wall - Plaster/Drywall    | Girl's Room in Room 114                         | 6    | 174      | SF   | \$411   |        |
| Staff Restroom | Staff Restroom                       | Wall - Plaster/Drywall    | 1st floor inside office at west end of corridor | 5    | 866      | SF   | \$4,087 |        |
| Staff Restroom | Staff Restroom                       | Wall - Plaster/Drywall    | 1st floor next to engineer's office             | 6    | 208      | SF   | \$491   |        |
| Staff Restroom | Staff Restroom                       | Wall - Plaster/Drywall    | 1st floor inside engineer's office              | 5    | 267      | SF   | \$1,260 |        |
| Staff Restroom | Children's Standard Student Restroom | Wall - Plaster/Drywall    | 1st Floor South Boy's Room                      | 6    | 365      | SF   | \$861   |        |
| Staff Restroom | Children's Standard Student Restroom | Water Closet              | 1st Floor South Boy's Room                      | 7    | 2        | EA   | \$0     |        |
| Staff Restroom | Children's Standard Student Restroom | Water Closet              | 2nd Floor South Boy's Room                      | 7    | 2        | EA   | \$0     |        |
| Staff Restroom | Children's Standard Student Restroom | Water Closet              | 1st Floor North Boy's Room                      | 7    | 2        | EA   | \$0     |        |
| Staff Restroom | Children's Standard Student Restroom | Water Closet              | 2nd Floor North Boy's Room                      | 7    | 2        | EA   | \$0     |        |
| Staff Restroom | Children's Standard Student Restroom | Water Closet              | 1st Floor North Girl's Room                     | 7    | 5        | EA   | \$0     |        |
| Staff Restroom | Children's Standard Student Restroom | Water Closet              | 1st Floor South Girl's Room                     | 7    | 5        | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                       | Water Closet              | In Principal's Office                           | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Children's Standard Student Restroom | Water Closet              | 2nd Floor North Girl's Room                     | 7    | 5        | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                       | Water Closet              | 1st floor next to engineer's office             | 6    | 1        | EA   | \$372   |        |
| Staff Restroom | Early Childhood Student Restroom     | Water Closet              | Boy's Room in Room 114                          | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Early Childhood Student Restroom     | Water Closet              | 1st floor inside Rm #107                        | 6    | 2        | EA   | \$744   |        |
| Staff Restroom | Children's Standard Student Restroom | Water Closet              | 2nd Floor South Girl's Room                     | 7    | 5        | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                       | Water Closet              | 1st floor inside office at west end of corridor | 6    | 2        | EA   | \$744   |        |
| Staff Restroom | Staff Restroom                       | Water Closet              | 1st floor inside engineer's office              | 6    | 1        | EA   | \$372   |        |
| Staff Restroom | Early Childhood Student Restroom     | Water Closet              | Girl's Room in Room 114                         | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                       | Water Closet              | In Room 200                                     | 7    | 2        | EA   | \$0     |        |
| Theater        | Auditorium - Dedicated               | Ceiling - Plaster/Drywall | 1st Floor                                       | 7    | 2,709    | SF   | \$0     |        |
| Theater        | Auditorium - Dedicated               | Flooring - Tile/Sheet     | 1st Floor                                       | 7    | 2,709    | SF   | \$0     |        |

**Building: Main**  
**Category: INTERIOR**

| Group                     | Sub Group              | Item                        | Location  | Rank | Quantity | Unit | Cost             | Reason |
|---------------------------|------------------------|-----------------------------|-----------|------|----------|------|------------------|--------|
| Theater                   | Auditorium - Dedicated | Lighting - Pendant/ Surface | 1st Floor | 7    | 32       | SF   | \$0              |        |
| Theater                   | Auditorium - Dedicated | Stage                       | 1st Floor | 7    | 507      | SF   | \$0              |        |
| Theater                   | Auditorium - Dedicated | Wall - Plaster/Drywall      | 1st Floor | 6    | 5,560    | SF   | \$47,705         |        |
| <b>INTERIOR Sub Total</b> |                        |                             |           |      |          |      | <b>\$408,303</b> |        |

**Building: Main**  
**Category: ROOM**

| Group    | Sub Group | Item     | Location | Rank | Quantity | Unit | Cost  | Reason |
|----------|-----------|----------|----------|------|----------|------|-------|--------|
| Casework | Classroom | Casework |          | 7    | 10       | LF   | \$0   |        |
| Casework | Classroom | Casework |          | 6    | 10       | LF   | \$358 |        |
| Casework | Classroom | Casework |          | 6    | 10       | LF   | \$358 |        |
| Casework | Classroom | Casework |          | 6    | 24       | LF   | \$858 |        |
| Casework | Classroom | Casework |          | 6    | 10       | LF   | \$358 |        |
| Casework | Classroom | Casework |          | 6    | 24       | LF   | \$858 |        |
| Casework | Classroom | Casework |          | 6    | 10       | LF   | \$358 |        |
| Casework | Classroom | Casework |          | 6    | 10       | LF   | \$358 |        |
| Casework | Classroom | Casework |          | 7    | 40       | LF   | \$0   |        |
| Casework | Classroom | Casework |          | 6    | 20       | LF   | \$715 |        |
| Casework | Classroom | Casework |          | 6    | 20       | LF   | \$715 |        |
| Casework | Classroom | Casework |          | 6    | 20       | LF   | \$715 |        |
| Casework | Classroom | Casework |          | 7    | 10       | LF   | \$0   |        |
| Casework | Classroom | Casework |          | 6    | 20       | LF   | \$715 |        |
| Casework | Classroom | Casework |          | 7    | 10       | LF   | \$0   |        |
| Casework | Classroom | Casework |          | 7    | 10       | LF   | \$0   |        |
| Casework | Classroom | Casework |          | 6    | 10       | LF   | \$358 |        |
| Casework | Classroom | Casework |          | 7    | 10       | LF   | \$0   |        |
| Casework | Classroom | Casework |          | 6    | 10       | LF   | \$358 |        |
| Casework | Classroom | Casework |          | 7    | 10       | LF   | \$0   |        |
| Casework | Classroom | Casework |          | 7    | 10       | LF   | \$0   |        |
| Casework | Classroom | Casework |          | 6    | 10       | LF   | \$358 |        |
| Casework | Classroom | Casework |          | 7    | 10       | LF   | \$0   |        |
| Casework | Classroom | Casework |          | 6    | 10       | LF   | \$358 |        |
| Casework | Classroom | Casework |          | 7    | 10       | LF   | \$0   |        |
| Casework | Classroom | Casework |          | 6    | 14       | LF   | \$501 |        |
| Casework | Classroom | Casework |          | 6    | 10       | LF   | \$358 |        |
| Casework | Classroom | Casework |          | 6    | 10       | LF   | \$358 |        |
| Casework | Classroom | Casework |          | 7    | 30       | LF   | \$0   |        |



**Building: Main**  
**Category: ROOM**

| Group       | Sub Group | Item            | Location | Rank | Quantity | Unit | Cost    | Reason |
|-------------|-----------|-----------------|----------|------|----------|------|---------|--------|
| Ceiling     | Classroom | Plaster/Drywall |          | 6    | 652      | SF   | \$1,846 |        |
| Ceiling     | Classroom | Plaster/Drywall |          | 6    | 716      | SF   | \$2,027 |        |
| Ceiling     | Classroom | Plaster/Drywall |          | 6    | 726      | SF   | \$2,056 |        |
| Ceiling     | Classroom | Plaster/Drywall |          | 6    | 726      | SF   | \$2,056 |        |
| Ceiling     | Classroom | Plaster/Drywall |          | 6    | 1,495    | SF   | \$4,233 |        |
| Ceiling     | Classroom | Plaster/Drywall |          | 6    | 726      | SF   | \$2,056 |        |
| Ceiling     | Classroom | Plaster/Drywall |          | 6    | 726      | SF   | \$2,056 |        |
| Ceiling     | Classroom | Plaster/Drywall |          | 5    | 469      | SF   | \$2,656 |        |
| Ceiling     | Classroom | Plaster/Drywall |          | 6    | 716      | SF   | \$2,027 |        |
| Ceiling     | Classroom | Plaster/Drywall |          | 6    | 716      | SF   | \$2,027 |        |
| Ceiling     | Classroom | Plaster/Drywall |          | 6    | 718      | SF   | \$2,033 |        |
| Ceiling     | Classroom | Plaster/Drywall |          | 6    | 716      | SF   | \$2,027 |        |
| Ceiling     | Classroom | Plaster/Drywall |          | 6    | 726      | SF   | \$2,056 |        |
| Ceiling     | Classroom | Plaster/Drywall |          | 7    | 750      | SF   | \$0     |        |
| Ceiling     | Classroom | Plaster/Drywall |          | 7    | 750      | SF   | \$0     |        |
| Ceiling     | Classroom | Plaster/Drywall |          | 6    | 412      | SF   | \$1,167 |        |
| Ceiling     | Classroom | Plaster/Drywall |          | 6    | 726      | SF   | \$2,056 |        |
| Ceiling     | Classroom | Plaster/Drywall |          | 7    | 716      | SF   | \$0     |        |
| Ceiling     | Classroom | Plaster/Drywall |          | 6    | 726      | SF   | \$2,056 |        |
| Ceiling     | Classroom | Plaster/Drywall |          | 7    | 750      | SF   | \$0     |        |
| Ceiling     | Classroom | Plaster/Drywall |          | 6    | 688      | SF   | \$1,948 |        |
| Ceiling     | Classroom | Plaster/Drywall |          | 6    | 718      | SF   | \$2,033 |        |
| Ceiling     | Classroom | Plaster/Drywall |          | 6    | 652      | SF   | \$1,846 |        |
| Ceiling     | Classroom | Plaster/Drywall |          | 6    | 652      | SF   | \$1,846 |        |
| Ceiling     | Classroom | Plaster/Drywall |          | 6    | 652      | SF   | \$1,846 |        |
| Ceiling     | Classroom | Plaster/Drywall |          | 6    | 652      | SF   | \$1,846 |        |
| Ceiling     | Classroom | Plaster/Drywall |          | 6    | 652      | SF   | \$1,846 |        |
| Ceiling     | Classroom | Plaster/Drywall |          | 7    | 597      | SF   | \$0     |        |
| Ceiling     | Classroom | Plaster/Drywall |          | 6    | 726      | SF   | \$2,056 |        |
| Chalk Board | Classroom | Chalk Board     |          | 4    | 16       | LF   | \$1,945 |        |
| Chalk Board | Classroom | Chalk Board     |          | 4    | 18       | LF   | \$2,188 |        |
| Chalk Board | Classroom | Chalk Board     |          | 4    | 27       | LF   | \$3,282 |        |
| Chalk Board | Classroom | Chalk Board     |          | 4    | 27       | LF   | \$3,282 |        |
| Chalk Board | Classroom | Chalk Board     |          | 4    | 16       | LF   | \$1,945 |        |
| Chalk Board | Classroom | Chalk Board     |          | 4    |          | LF   |         |        |
| Chalk Board | Classroom | Chalk Board     |          | 4    | 16       | LF   | \$1,945 |        |
| Chalk Board | Classroom | Chalk Board     |          | 4    | 18       | LF   | \$2,188 |        |

**Building: Main**  
**Category: ROOM**

| Group       | Sub Group | Item                    | Location   | Rank | Quantity | Unit | Cost     | Reason   |
|-------------|-----------|-------------------------|--|------|----------|------|----------|--|
| Chalk Board | Classroom | Chalk Board             |  | 4    | 18       | LF   | \$2,188  |  |
| Chalk Board | Classroom | Chalk Board             |  | 4    | 8        | LF   | \$972    |  |
| Chalk Board | Classroom | Chalk Board             |  | 4    | 27       | LF   | \$3,282  |  |
| Chalk Board | Classroom | Chalk Board             |  | 4    | 18       | LF   | \$2,188  |  |
| Chalk Board | Classroom | Chalk Board             |  | 4    | 24       | LF   | \$2,917  |  |
| Chalk Board | Classroom | Chalk Board             |  | 4    | 28       | LF   | \$3,403  |  |
| Chalk Board | Classroom | Chalk Board             |  | 4    | 6        | LF   | \$729    |  |
| Chalk Board | Classroom | Chalk Board             |  | 4    | 27       | LF   | \$3,282  |  |
| CLASSROOM   | Classroom | Laptop Charging Station |  | 7    | 1        | EA   | \$0      |  |
| CLASSROOM   | Classroom | Laptop Charging Station |  | 7    | 1        | EA   | \$0      |  |
| CLASSROOM   | Classroom | Laptop Charging Station |  | 7    | 1        | EA   | \$0      |  |
| CLASSROOM   | Classroom | Laptop Charging Station |  | 7    | 1        | EA   | \$0      |  |
| Corridors   | Corridors | Concrete Block          | Basement tunnel linking boiler room to main building | 3    | 414      | SF   | \$17,761 | Concrete wall leaking water, rusting metal electric conduits mounted on walls. |
| Corridors   | Corridors | Concrete Epoxy/Painted  | Basement tunnel linking boiler room to main building | 5    | 427      | SF   | \$2,015  | Leaking water  |
| Corridors   | Corridors | Exposed                 | Basement tunnel linking boiler room to main building | 3    | 427      | SF   | \$2,015  | Concrete slab eroded. Concrete debris falling. Rusted steel bars exposed.      |
| Corridors   | Corridors | Pendant/Surface         | Entire building stairwells                           | 6    | 2,632    | EA   | \$1,882  |  |
| Corridors   | Corridors | Pendant/Surface         | Basement tunnel linking boiler room to main building | 6    | 427      | EA   | \$305    |  |
| Corridors   | Corridors | Pendant/Surface         | 2nd Floor  | 7    | 5,773    | EA   | \$0      |  |
| Corridors   | Corridors | Pendant/Surface         | 1st Floor  | 7    | 5,773    | EA   | \$0      |  |
| Corridors   | Corridors | Plaster/Drywall         | Entire building stairwells                           | 5    | 7,875    | SF   | \$37,162 |  |
| Corridors   | Corridors | Plaster/Drywall         | 1st Floor  | 6    | 11,075   | SF   | \$26,131 |  |
| Corridors   | Corridors | Plaster/Drywall         | 2nd Floor  | 6    | 11,075   | SF   | \$26,131 |  |
| Corridors   | Corridors | Stair Handrails         | Entire building stairwells                           | 6    | 305      | LF   | \$0      |  |
| Corridors   | Corridors | Student Lockers         | 1st Floor  | 6    | 275      | EA   | \$39,325 |  |
| Corridors   | Corridors | Student Lockers         | 2nd Floor  | 6    | 275      | EA   | \$39,325 |  |
| Corridors   | Corridors | Terrazzo                | Entire building stairwells                           | 6    | 1,840    | SF   | \$10,420 |  |
| Corridors   | Corridors | Terrazzo                | 1st Floor  | 6    | 577      | SF   | \$3,267  |  |
| Corridors   | Corridors | Terrazzo                | 2nd Floor  | 6    | 577      | SF   | \$3,267  |  |
| Corridors   | Corridors | Tile/Sheet Flooring     | 2nd Floor  | 6    | 5,196    | SF   | \$7,430  |  |
| Corridors   | Corridors | Tile/Sheet Flooring     | 1st Floor  | 6    | 5,196    | SF   | \$7,430  |  |
| Corridors   | Corridors | Tile/Sheet Flooring     | Entire building stairwells                           | 6    | 280      | SF   | \$400    |  |

**Building: Main**  
**Category: ROOM**

| Group             | Sub Group | Item            | Location                   | Rank | Quantity | Unit | Cost    | Reason |
|-------------------|-----------|-----------------|----------------------------|------|----------|------|---------|--------|
| Corridors Ceiling | Corridors | Plaster/Drywall | 2nd Floor                  | 7    | 5,773    | SF   | \$0     |        |
| Corridors Ceiling | Corridors | Plaster/Drywall | Entire building stairwells | 6    | 2,632    | SF   | \$7,452 |        |
| Corridors Ceiling | Corridors | Plaster/Drywall | 1st Floor                  | 7    | 5,773    | SF   | \$0     |        |
| Stairs            | Corridors | Terrazzo        | Entire building stairwells | 6    | 145      | SF   | \$1,642 |        |
| Floor             | Classroom | Carpet          |                            | 6    | 249      | SF   | \$356   |        |
| Floor             | Classroom | Tile/Sheet      |                            | 5    | 652      | SF   | \$3,692 |        |
| Floor             | Classroom | Tile/Sheet      |                            | 5    | 652      | SF   | \$3,692 |        |
| Floor             | Classroom | Tile/Sheet      |                            | 5    | 652      | SF   | \$3,692 |        |
| Floor             | Classroom | Tile/Sheet      |                            | 5    | 652      | SF   | \$3,692 |        |
| Floor             | Classroom | Tile/Sheet      |                            | 5    | 652      | SF   | \$3,692 |        |
| Floor             | Classroom | Tile/Sheet      |                            | 6    | 469      | SF   | \$671   |        |
| Floor             | Classroom | Tile/Sheet      |                            | 5    | 652      | SF   | \$3,692 |        |
| Floor             | Classroom | Tile/Sheet      |                            | 6    | 1,246    | SF   | \$1,782 |        |
| Floor             | Classroom | Wood            |                            | 7    | 716      | SF   | \$0     |        |
| Floor             | Classroom | Wood            |                            | 6    | 726      | SF   | \$5,482 |        |
| Floor             | Classroom | Wood            |                            | 6    | 688      | SF   | \$5,195 |        |
| Floor             | Classroom | Wood            |                            | 6    | 726      | SF   | \$5,482 |        |
| Floor             | Classroom | Wood            |                            | 6    | 412      | SF   | \$3,111 |        |
| Floor             | Classroom | Wood            |                            | 6    | 718      | SF   | \$5,421 |        |
| Floor             | Classroom | Wood            |                            | 6    | 718      | SF   | \$5,421 |        |
| Floor             | Classroom | Wood            |                            | 7    | 716      | SF   | \$0     |        |
| Floor             | Classroom | Wood            |                            | 7    | 597      | SF   | \$0     |        |
| Floor             | Classroom | Wood            |                            | 7    | 716      | SF   | \$0     |        |
| Floor             | Classroom | Wood            |                            | 6    | 726      | SF   | \$5,482 |        |
| Floor             | Classroom | Wood            |                            | 6    | 726      | SF   | \$5,482 |        |
| Floor             | Classroom | Wood            |                            | 7    | 716      | SF   | \$0     |        |
| Floor             | Classroom | Wood            |                            | 7    | 716      | SF   | \$0     |        |
| Floor             | Classroom | Wood            |                            | 7    | 716      | SF   | \$0     |        |
| Floor             | Classroom | Wood            |                            | 7    | 716      | SF   | \$0     |        |
| Floor             | Classroom | Wood            |                            | 7    | 716      | SF   | \$0     |        |
| Floor             | Classroom | Wood            |                            | 7    | 750      | SF   | \$0     |        |
| Floor             | Classroom | Wood            |                            | 7    | 716      | SF   | \$0     |        |
| Floor             | Classroom | Wood            |                            | 7    | 750      | SF   | \$0     |        |
| Floor             | Classroom | Wood            |                            | 7    | 750      | SF   | \$0     |        |
| Floor             | Classroom | Wood            |                            | 7    | 716      | SF   | \$0     |        |
| LIBRARY_CEILING   | Library   | Plaster/Drywall | 1st Floor                  | 6    | 732      | SF   | \$2,073 |        |
| LIBRARY_WALL      | Library   | Plaster/Drywall | 1st Floor                  | 6    | 1,388    | SF   | \$3,275 |        |
| Lighting          | Classroom | Pendant/Surface |                            | 7    | 12       | EA   | \$0     |        |

**Building: Main**  
**Category: ROOM**

| Group        | Sub Group | Item            | Location | Rank | Quantity | Unit | Cost    | Reason |
|--------------|-----------|-----------------|----------|------|----------|------|---------|--------|
| Lighting     | Classroom | Pendant/Surface |          | 4    | 3        | EA   | \$1,180 | T-12   |
| Lighting     | Classroom | Pendant/Surface |          | 6    | 12       | EA   | \$858   |        |
| Lighting     | Classroom | Pendant/Surface |          | 6    | 10       | EA   | \$715   |        |
| Lighting     | Classroom | Pendant/Surface |          | 6    | 12       | EA   | \$858   |        |
| Lighting     | Classroom | Pendant/Surface |          | 7    | 12       | EA   | \$0     |        |
| Lighting     | Classroom | Pendant/Surface |          | 6    | 4        | EA   | \$286   |        |
| Lighting     | Classroom | Pendant/Surface |          | 7    | 12       | EA   | \$0     |        |
| Lighting     | Classroom | Pendant/Surface |          | 6    | 12       | EA   | \$858   |        |
| Lighting     | Classroom | Pendant/Surface |          | 7    | 12       | EA   | \$0     |        |
| Lighting     | Classroom | Pendant/Surface |          | 7    | 12       | EA   | \$0     |        |
| Lighting     | Classroom | Pendant/Surface |          | 7    | 12       | EA   | \$0     |        |
| Lighting     | Classroom | Pendant/Surface |          | 7    | 12       | EA   | \$0     |        |
| Lighting     | Classroom | Pendant/Surface |          | 7    | 12       | EA   | \$0     |        |
| Lighting     | Classroom | Pendant/Surface |          | 6    | 20       | EA   | \$1,430 |        |
| Lighting     | Classroom | Pendant/Surface |          | 6    | 12       | EA   | \$858   |        |
| Lighting     | Classroom | Pendant/Surface |          | 6    | 12       | EA   | \$858   |        |
| Lighting     | Classroom | Pendant/Surface |          | 6    | 10       | EA   | \$715   |        |
| Lighting     | Classroom | Pendant/Surface |          | 7    | 12       | EA   | \$0     |        |
| Lighting     | Classroom | Pendant/Surface |          | 7    | 12       | EA   | \$0     |        |
| Lighting     | Classroom | Pendant/Surface |          | 7    | 12       | EA   | \$0     |        |
| Lighting     | Classroom | Pendant/Surface |          | 6    | 12       | EA   | \$858   |        |
| Lighting     | Classroom | Pendant/Surface |          | 6    | 12       | EA   | \$858   |        |
| Lighting     | Classroom | Pendant/Surface |          | 4    | 4        | EA   | \$1,573 | T-12   |
| Lighting     | Classroom | Pendant/Surface |          | 7    | 12       | EA   | \$0     |        |
| Lighting     | Classroom | Pendant/Surface |          | 7    | 12       | EA   | \$0     |        |
| Lighting     | Classroom | Pendant/Surface |          | 6    | 12       | EA   | \$858   |        |
| Lighting     | Classroom | Pendant/Surface |          | 6    | 20       | EA   | \$1,430 |        |
| Lighting     | Classroom | Pendant/Surface |          | 6    | 19       | EA   | \$1,359 |        |
| Lighting     | Classroom | Pendant/Surface |          | 6    | 19       | EA   | \$1,359 |        |
| Lighting     | Classroom | Pendant/Surface |          | 6    | 8        | EA   | \$572   |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 18       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 6    | 12       | LF   | \$343   |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 24       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 24       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 12       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 18       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 18       | LF   | \$0     |        |

**Building: Main**  
**Category: ROOM**

| Group        | Sub Group | Item                | Location | Rank | Quantity | Unit | Cost    | Reason |
|--------------|-----------|---------------------|----------|------|----------|------|---------|--------|
| Marker Board | Classroom | Marker Board        |          | 6    | 12       | LF   | \$343   |        |
| Marker Board | Classroom | Marker Board        |          | 7    | 18       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board        |          | 7    | 18       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board        |          | 6    | 16       | LF   | \$458   |        |
| Marker Board | Classroom | Marker Board        |          | 6    | 20       | LF   | \$572   |        |
| Marker Board | Classroom | Marker Board        |          | 6    | 15       | LF   | \$429   |        |
| Marker Board | Classroom | Marker Board        |          | 6    | 15       | LF   | \$429   |        |
| Marker Board | Classroom | Marker Board        |          | 6    | 15       | LF   | \$429   |        |
| Marker Board | Classroom | Marker Board        |          | 6    | 15       | LF   | \$429   |        |
| Marker Board | Classroom | Marker Board        |          | 7    | 18       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board        |          | 6    | 12       | LF   | \$343   |        |
| Marker Board | Classroom | Marker Board        |          | 6    | 15       | LF   | \$429   |        |
| Marker Board | Classroom | Marker Board        |          | 6    | 15       | LF   | \$429   |        |
| Marker Board | Classroom | Marker Board        |          | 6    | 15       | LF   | \$429   |        |
| Marker Board | Classroom | Marker Board        |          | 6    | 20       | LF   | \$572   |        |
| Marker Board | Classroom | Marker Board        |          | 6    | 15       | LF   | \$429   |        |
| Marker Board | Classroom | Marker Board        |          | 6    | 8        | LF   | \$229   |        |
| Marker Board | Classroom | Marker Board        |          | 6    | 15       | LF   | \$429   |        |
| Marker Board | Classroom | Marker Board        |          | 6    | 12       | LF   | \$343   |        |
| Marker Board | Classroom | Marker Board        |          | 6    | 12       | LF   | \$343   |        |
| Marker Board | Classroom | Marker Board        |          | 6    | 12       | LF   | \$343   |        |
| Marker Board | Classroom | Marker Board        |          | 6    | 12       | LF   | \$343   |        |
| Wall         | Classroom | Metal/Folding Panel |          | 6    | 775      | SF   | \$1,829 |        |
| Wall         | Classroom | Metal/Folding Panel |          | 6    | 775      | SF   | \$1,829 |        |
| Wall         | Classroom | Metal/Folding Panel |          | 6    | 775      | SF   | \$1,829 |        |
| Wall         | Classroom | Metal/Folding Panel |          | 6    | 775      | SF   | \$1,829 |        |
| Wall         | Classroom | Metal/Folding Panel |          | 6    | 775      | SF   | \$1,829 |        |
| Wall         | Classroom | Metal/Folding Panel |          | 6    | 775      | SF   | \$1,829 |        |
| Wall         | Classroom | Plaster/Drywall     |          | 6    | 891      | SF   | \$2,102 |        |
| Wall         | Classroom | Plaster/Drywall     |          | 7    | 835      | SF   | \$0     |        |
| Wall         | Classroom | Plaster/Drywall     |          | 7    | 804      | SF   | \$0     |        |
| Wall         | Classroom | Plaster/Drywall     |          | 5    | 1,182    | SF   | \$5,578 |        |
| Wall         | Classroom | Plaster/Drywall     |          | 7    | 835      | SF   | \$0     |        |
| Wall         | Classroom | Plaster/Drywall     |          | 7    | 891      | SF   | \$0     |        |
| Wall         | Classroom | Plaster/Drywall     |          | 6    | 1,084    | SF   | \$2,558 |        |
| Wall         | Classroom | Plaster/Drywall     |          | 6    | 1,182    | SF   | \$2,789 |        |
| Wall         | Classroom | Plaster/Drywall     |          | 6    | 1,182    | SF   | \$2,789 |        |

**Building: Main**  
**Category: ROOM**

| Group                 | Sub Group | Item            | Location | Rank | Quantity | Unit | Cost             | Reason |
|-----------------------|-----------|-----------------|----------|------|----------|------|------------------|--------|
| Wall                  | Classroom | Plaster/Drywall |          | 5    | 1,182    | SF   | \$5,578          |        |
| Wall                  | Classroom | Plaster/Drywall |          | 6    | 1,159    | SF   | \$2,735          |        |
| Wall                  | Classroom | Plaster/Drywall |          | 6    | 891      | SF   | \$2,102          |        |
| Wall                  | Classroom | Plaster/Drywall |          | 7    | 835      | SF   | \$0              |        |
| Wall                  | Classroom | Plaster/Drywall |          | 5    | 1,182    | SF   | \$5,578          |        |
| Wall                  | Classroom | Plaster/Drywall |          | 7    | 835      | SF   | \$0              |        |
| Wall                  | Classroom | Plaster/Drywall |          | 5    | 1,054    | SF   | \$4,974          |        |
| Wall                  | Classroom | Plaster/Drywall |          | 5    | 1,182    | SF   | \$5,578          |        |
| Wall                  | Classroom | Plaster/Drywall |          | 5    | 1,182    | SF   | \$5,578          |        |
| Wall                  | Classroom | Plaster/Drywall |          | 6    | 1,182    | SF   | \$2,789          |        |
| Wall                  | Classroom | Plaster/Drywall |          | 6    | 1,182    | SF   | \$2,789          |        |
| Wall                  | Classroom | Plaster/Drywall |          | 5    | 1,182    | SF   | \$5,578          |        |
| Wall                  | Classroom | Plaster/Drywall |          | 7    | 835      | SF   | \$0              |        |
| Wall                  | Classroom | Plaster/Drywall |          | 6    | 1,182    | SF   | \$2,789          |        |
| <b>ROOM Sub Total</b> |           |                 |          |      |          |      | <b>\$497,620</b> |        |

**Building Main Sub Total \$4,832,151**

**Building: Annex**  
**Category: EXTERIOR**

| Group          | Sub Group | Item  | Location        | Rank | Quantity | Unit | Cost    | Reason       |
|----------------|-----------|---|-----------------|------|----------|------|---------|--------------|
| Canopy         |           | Metal Canopy                                      | entrances       | 7    | 64       | SF   | \$0     |              |
| Chimney        |           | Metal Flue  | Roof            | 7    | 55       | LF   | \$0     |              |
| Doors          |           | Exterior Steel Door                               | 1st Floor       | 6    | 6        | EA   | \$1,982 |              |
| Entrance       |           | Entrance Controls - Audio and Video               | 1st Floor       | 6    | 1        | EA   | \$1,430 |              |
| Foundation     |           | Concrete Foundation                               | Entire Building | 7    | 612      | LF   | \$0     |              |
| Lighting       |           | Exterior Lights - Wall Mounted                    | Entire Building | 6    | 6        | EA   | \$1,287 |              |
| Lintels        |           | Lintels - Steel                                   | Entire Building | 7    | 259      | LF   | \$0     |              |
| Roof System    |           | Exterior Downspouts                               | Roof            | 6    | 72       | LF   | \$1,338 |              |
| Roof System    |           | Metal Roof  | Roof            | 7    | 18,640   | SF   | \$0     |              |
| Roof System    |           | Roof Structure: Steel/Metal Deck/Concrete Topping | Roof            | 7    | 17,022   | SF   | \$0     |              |
| Superstructure |           | Steel   | Entire Building | 7    | 17,022   | SF   | \$0     |              |
| Walls          |           | Brick   | Entire Building | 7    | 5,861    | SF   | \$0     |              |
| Walls          |           | Prefabricated Metal Panel Wall                    | Entire Building | 7    | 918      | SF   | \$0     |              |
| Walls          |           | Stone - Cut                                       | Entire Building | 7    | 259      | SF   | \$0     |              |
| Windows        |           | Curtain wall - Louver                             | Entire Building | 6    | 144      | SF   | \$1,359 | seal to wall |

**Building: Annex**  
**Category: EXTERIOR**

| Group                     | Sub Group | Item                                | Location        | Rank | Quantity | Unit | Cost           | Reason                          |
|---------------------------|-----------|-------------------------------------|-----------------|------|----------|------|----------------|---------------------------------|
| Windows                   |           | Window - Guards perforated          | Entire Building | 7    | 1,850    | SF   | \$0            |                                 |
| Windows                   |           | Windows - Sash Aluminum Double-pane | room 311        | 5    | 25       | SF   | \$863          | Poor condition. Balance issues. |
| Windows                   |           | Windows - Sash Aluminum Double-pane | Entire Building | 7    | 1,825    | SF   | \$0            |                                 |
| <b>EXTERIOR Sub Total</b> |           |                                     |                 |      |          |      | <b>\$8,260</b> |                                 |

**Building: Annex**  
**Category: ELECTRICAL**

| Group                       | Sub Group | Item   | Location        | Rank | Quantity | Unit | Cost            | Reason |
|-----------------------------|-----------|--|-----------------|------|----------|------|-----------------|--------|
| Emergency System            |           | Automatic Transfer switch                            | Electrical Room | 7    | 1        | EA   | \$0             |        |
| Emergency System            |           | Emergency A/C power - Corridors and Stairs           | Entire Building | 7    | 2,523    | SF   | \$0             |        |
| Emergency System            |           | Emergency A/C power - Students Toilets               | Entire Building | 7    | 870      | SF   | \$0             |        |
| Emergency System            |           | Exit Signs - Corridors and Stairs                    | Entire Building | 6    | 5        | EA   | \$1,165         |        |
| Emergency System            |           | Independent Electrical Service for emergency power   | Electrical Room | 7    | 1        | EA   | \$0             |        |
| Emergency System            |           | Security System - CCTV                               | 1st Floor       | 6    | 17,022   | SF   | \$24,341        |        |
| Emergency System            |           | Security System - CCTV                               | 1st Floor       | 6    | 17,022   | SF   | \$24,341        |        |
| Emergency System            |           | Security System - Intrusion detection                | 1st Floor       | 6    | 17,022   | SF   | \$15,822        |        |
| Main Service                |           | Main Electrical service 1000 A and below 120/208/3PH | Electrical Room | 7    | 1        | EA   | \$0             |        |
| Power Distribution          |           | Lighting and power panels                            | Electrical Room | 7    | 5        | EA   | \$0             |        |
| <b>ELECTRICAL Sub Total</b> |           |  |                 |      |          |      | <b>\$65,670</b> |        |

**Building: Annex**  
**Category: FIRE PROTECTION**

| Group                            | Sub Group | Item                     | Location        | Rank | Quantity | Unit | Cost            | Reason   |
|----------------------------------|-----------|--------------------------|-----------------|------|----------|------|-----------------|--|
| Fire Alarm                       |           | Fire Alarm Strobe Lights | Entire Building | 3    | 17,022   | SF   | \$36,025        | Strobe lights are not provided or not located in all areas |
| Fire Alarm                       |           | Fire Alarm System        | Electrical Room | 6    | 17,022   | SF   | \$20,690        |  |
| Sprinkler System                 |           | Sprinkler Heads          | Entire Building | 7    | 17,022   | SF   | \$0             |  |
| Sprinkler System                 |           | Wet Sprinkler System     | Entire Building | 7    | 17,022   | SF   | \$0             |  |
| <b>FIRE PROTECTION Sub Total</b> |           |                          |                 |      |          |      | <b>\$56,716</b> |  |

**Building: Annex**  
**Category: MECHANICAL**

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-------|-----------|------|----------|------|----------|------|------|--------|
|-------|-----------|------|----------|------|----------|------|------|--------|

**Building: Annex**  
**Category: MECHANICAL**

| Group                       | Sub Group | Item   | Location        | Rank | Quantity | Unit | Cost            | Reason |
|-----------------------------|-----------|--|-----------------|------|----------|------|-----------------|--------|
| Air Handling Systems        |           | Air Handling Unit Package - Multi Zone - Hot Water less than 6,000 cfm             | Mechanical Room | 5    | 1        | EA   | \$15,730        |        |
| Air Handling Systems        |           | Air intake for all Air Handling Units except built up AHU                          | Roof            | 6    | 1        | EA   | \$1,430         |        |
| Air Handling Systems        |           | Return Duct Work - Indoor - Vertical Shaft and Ducts                               | Entire Building | 6    | 100      | LF   | \$6,292         |        |
| Boiler Systems              |           | Boiler Assembly - Non-Condensing Scotch Marine Hot Water Boiler less than 1,000MBH | Mechanical Room | 6    | 2        | EA   | \$20,020        |        |
| Boiler Systems              |           | Boiler Auxiliary - Non- Condensing Flexible Tube Hot Water Boiler less than 500MBH | Mechanical Room | 6    | 2        | EA   | \$7,150         |        |
| Boiler Systems              |           | Chemical Pot Feeder - Hot Water  | Mechanical Room | 6    | 1        | EA   | \$300           |        |
| Boiler Systems              |           | Combustion Dampers   | Mechanical Room | 6    | 2        | EA   | \$572           |        |
| Boiler Systems              |           | Glycol Feed System   | Mechanical Room | 6    | 1        | EA   | \$1,087         |        |
| Heating Devices             |           | Cabinet Heaters With Hot Water Coils   | Entire Building | 6    | 4        | EA   | \$2,002         |        |
| Mechanical Plumbing         |           | Piping - Hydronic Supply and Return - Steel or Galvanized                          | Mechanical Room | 6    | 300      | LF   | \$2,660         |        |
| Mechanical Plumbing         |           | Pumps - Hot Water 5 to 10 HP   | Mechanical Room | 6    | 2        | EA   | \$4,004         |        |
| Unit Ventilation            |           | Packaged Terminal Air Conditioner (PTAC)   | MDF Room        | 6    | 1        | EA   | \$1,430         |        |
| Unit Ventilation            |           | Unit Ventilators - Hot Water-Heating   | Entire Building | 6    | 13       | EA   | \$18,590        |        |
| Ventilation                 |           | Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm                                     | Roof            | 6    | 1        | EA   | \$429           |        |
| Ventilation                 |           | Exhaust Fans - Roof Mounted 500 to 1,500 cfm                                       | Roof            | 6    | 1        | EA   | \$229           |        |
| Ventilation                 |           | Exhaust Fans - Roof mounted less than 500 CFM                                      | Roof            | 6    | 1        | EA   | \$157           |        |
| <b>MECHANICAL Sub Total</b> |           |  |                 |      |          |      | <b>\$82,082</b> |        |

**Building: Annex**  
**Category: PLUMBING**

| Group                     | Sub Group | Item  | Location        | Rank | Quantity | Unit | Cost            | Reason |
|---------------------------|-----------|---|-----------------|------|----------|------|-----------------|--------|
| Hot Water                 |           | Hot Water Heater - Gas less than 150,000 BTU/HR | Mechanical Room | 4    | 1        | EA   | \$14,872        |        |
| Piping                    |           | Domestic Piping Cold Water Horizontal lines     | Entire Building | 7    | 17,022   | SF   | \$0             |        |
| Piping                    |           | Domestic Piping Hot Water Horizontal lines      | Entire Building | 7    | 17,022   | SF   | \$0             |        |
| Piping                    |           | Domestic Piping Hot Water Return Lines          | Entire Building | 7    | 17,022   | SF   | \$0             |        |
| Piping                    |           | Sanitary Piping                                 | Entire Building | 7    | 17,022   | SF   | \$0             |        |
| Piping                    |           | Storm Piping                                    | Entire Building | 7    | 17,022   | SF   | \$0             |        |
| Piping                    |           | Vent Piping                                     | Entire Building | 7    | 17,022   | SF   | \$0             |        |
| <b>PLUMBING Sub Total</b> |           |   |                 |      |          |      | <b>\$14,872</b> |        |

**Building: Annex**  
**Category: INTERIOR**

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-------|-----------|------|----------|------|----------|------|------|--------|
|-------|-----------|------|----------|------|----------|------|------|--------|



**Building: Annex**  
**Category: INTERIOR**

| Group                    | Sub Group                            | Item                         | Location                         | Rank | Quantity | Unit | Cost    | Reason |
|--------------------------|--------------------------------------|------------------------------|----------------------------------|------|----------|------|---------|--------|
| Administrative Suites    | Administrative Suites/Offices        | Ceiling - Lay-In             | 1st floor middle of corridor#306 | 6    | 369      | SF   | \$792   |        |
| Administrative Suites    | Administrative Suites/Offices        | Flooring - Tile/Sheet        | 1st floor middle of corridor#306 | 6    | 369      | SF   | \$528   |        |
| Administrative Suites    | Administrative Suites/Offices        | Lighting - Lay-In            | 1st floor middle of corridor#306 | 6    | 4        | SF   | \$3     |        |
| Administrative Suites    | Administrative Suites/Offices        | Walls - Concrete Block       | 1st floor middle of corridor#306 | 6    | 424      | SF   | \$1,213 |        |
| Administrative Suites    | Administrative Suites/Offices        | Walls - Plaster/Drywall      | 1st floor middle of corridor#306 | 6    | 424      | SF   | \$1,000 |        |
| Doors                    |                                      | Interior Steel Doors incl hw | 1st Floor                        | 6    | 26       | EA   | \$7,362 |        |
| Drinking Fountains       | Corridors                            | Single Fountain              | 1st Floor                        | 7    | 2        | EA   | \$0     |        |
| MDF/IDF                  |                                      | Finishes                     | 1st Floor                        | 7    | 85       | SF   | \$0     |        |
| MDF/IDF                  |                                      | Ventilation and Cooling      | 1st Floor                        | 7    | 1        | EA   | \$0     |        |
| Mechanical/Service Rooms |                                      | Janitor's Closet             | 1st Floor                        | 6    | 1        | SF   | \$5     |        |
| Mechanical/Service Rooms |                                      | Mechanical/Service Rooms     | 1st Floor                        | 7    | 275      | SF   | \$0     |        |
| Mechanical/Service Rooms |                                      | Mechanical/Service Rooms     | 1st Floor                        | 7    | 64       | SF   | \$0     |        |
| Mechanical/Service Rooms |                                      | Mechanical/Service Rooms     | 1st Floor                        | 7    | 427      | SF   | \$0     |        |
| Staff Restroom           | Children's Standard Student Restroom | Accessories                  | Girl's Room                      | 6    | 435      | SF   | \$3,359 |        |
| Staff Restroom           | Children's Standard Student Restroom | Accessories                  | Boy's Room                       | 6    | 435      | SF   | \$3,359 |        |
| Staff Restroom           | Staff Restroom                       | Accessories                  | Men's Room                       | 6    | 43       | SF   | \$332   |        |
| Staff Restroom           | Staff Restroom                       | Accessories                  | Women's Room                     | 6    | 43       | SF   | \$332   |        |
| Staff Restroom           | Staff Restroom                       | Ceiling - Plaster/Drywall    | Women's Room                     | 7    | 43       | SF   | \$0     |        |
| Staff Restroom           | Children's Standard Student Restroom | Ceiling - Plaster/Drywall    | Boy's Room                       | 6    | 435      | SF   | \$1,232 |        |
| Staff Restroom           | Staff Restroom                       | Ceiling - Plaster/Drywall    | Men's Room                       | 7    | 43       | SF   | \$0     |        |
| Staff Restroom           | Children's Standard Student Restroom | Ceiling - Plaster/Drywall    | Girl's Room                      | 6    | 435      | SF   | \$1,232 |        |
| Staff Restroom           | Staff Restroom                       | Floor Drain                  | Men's Room                       | 7    | 1        | EA   | \$0     |        |
| Staff Restroom           | Staff Restroom                       | Floor Drain                  | Women's Room                     | 7    | 1        | EA   | \$0     |        |
| Staff Restroom           | Children's Standard Student Restroom | Floor Drain                  | Girl's Room                      | 7    | 2        | EA   | \$0     |        |
| Staff Restroom           | Children's Standard Student Restroom | Floor Drain                  | Boy's Room                       | 7    | 2        | EA   | \$0     |        |
| Staff Restroom           | Children's Standard Student Restroom | Flooring - Terrazzo          | Girl's Room                      | 7    | 435      | SF   | \$0     |        |
| Staff Restroom           | Children's Standard Student Restroom | Flooring - Terrazzo          | Boy's Room                       | 7    | 435      | SF   | \$0     |        |
| Staff Restroom           | Staff Restroom                       | Flooring - Tile/Sheet        | Men's Room                       | 6    | 43       | SF   | \$61    |        |

**Building: Annex**  
**Category: INTERIOR**

| Group                     | Sub Group                            | Item                  | Location     | Rank | Quantity | Unit | Cost            | Reason |
|---------------------------|--------------------------------------|-----------------------|--------------|------|----------|------|-----------------|--------|
| Staff Restroom            | Staff Restroom                       | Flooring - Tile/Sheet | Women's Room | 6    | 43       | SF   | \$61            |        |
| Staff Restroom            | Children's Standard Student Restroom | Hand Dryer            | Boy's Room   | 7    | 4        | EA   | \$0             |        |
| Staff Restroom            | Children's Standard Student Restroom | Hand Dryer            | Girl's Room  | 7    | 4        | EA   | \$0             |        |
| Staff Restroom            | Staff Restroom                       | Lavatory              | Women's Room | 7    | 1        | EA   | \$0             |        |
| Staff Restroom            | Children's Standard Student Restroom | Lavatory              | Boy's Room   | 7    | 3        | EA   | \$0             |        |
| Staff Restroom            | Children's Standard Student Restroom | Lavatory              | Girl's Room  | 7    | 3        | EA   | \$0             |        |
| Staff Restroom            | Staff Restroom                       | Lavatory              | Men's Room   | 7    | 1        | EA   | \$0             |        |
| Staff Restroom            | Children's Standard Student Restroom | Lighting - Lay-In     | Boy's Room   | 7    | 5        | SF   | \$0             |        |
| Staff Restroom            | Staff Restroom                       | Lighting - Lay-In     | Women's Room | 7    | 1        | SF   | \$0             |        |
| Staff Restroom            | Staff Restroom                       | Lighting - Lay-In     | Men's Room   | 7    | 1        | SF   | \$0             |        |
| Staff Restroom            | Children's Standard Student Restroom | Lighting - Lay-In     | Girl's Room  | 7    | 5        | SF   | \$0             |        |
| Staff Restroom            | Children's Standard Student Restroom | Partitions            | Girl's Room  | 7    | 10       | EA   | \$0             |        |
| Staff Restroom            | Children's Standard Student Restroom | Partitions            | Boy's Room   | 7    | 3        | EA   | \$0             |        |
| Staff Restroom            | Children's Standard Student Restroom | Urinals               | Boy's Room   | 7    | 8        | EA   | \$0             |        |
| Staff Restroom            | Children's Standard Student Restroom | Wall - Concrete Block | Boy's Room   | 6    | 680      | SF   | \$1,945         |        |
| Staff Restroom            | Children's Standard Student Restroom | Wall - Concrete Block | Girl's Room  | 6    | 680      | SF   | \$1,945         |        |
| Staff Restroom            | Staff Restroom                       | Wall - Concrete Block | Men's Room   | 7    | 214      | SF   | \$0             |        |
| Staff Restroom            | Staff Restroom                       | Wall - Concrete Block | Women's Room | 7    | 214      | SF   | \$0             |        |
| Staff Restroom            | Staff Restroom                       | Water Closet          | Women's Room | 7    | 2        | EA   | \$0             |        |
| Staff Restroom            | Staff Restroom                       | Water Closet          | Men's Room   | 7    | 2        | EA   | \$0             |        |
| Staff Restroom            | Children's Standard Student Restroom | Water Closet          | Boy's Room   | 7    | 3        | EA   | \$0             |        |
| Staff Restroom            | Children's Standard Student Restroom | Water Closet          | Girl's Room  | 7    | 11       | EA   | \$0             |        |
| <b>INTERIOR Sub Total</b> |                                      |                       |              |      |          |      | <b>\$24,760</b> |        |

**Building: Annex**  
**Category: ROOM**

| Group    | Sub Group | Item     | Location | Rank | Quantity | Unit | Cost  | Reason |
|----------|-----------|----------|----------|------|----------|------|-------|--------|
| Casework | Classroom | Casework |          | 6    | 24       | LF   | \$858 |        |

**Building: Annex**  
**Category: ROOM**

| Group       | Sub Group | Item           | Location  | Rank | Quantity | Unit | Cost    | Reason |
|-------------|-----------|----------------|-----------|------|----------|------|---------|--------|
| Casework    | Classroom | Casework       |           | 6    | 24       | LF   | \$858   |        |
| Casework    | Classroom | Casework       |           | 6    | 24       | LF   | \$858   |        |
| Casework    | Classroom | Casework       |           | 6    | 24       | LF   | \$858   |        |
| Casework    | Classroom | Casework       |           | 6    | 24       | LF   | \$858   |        |
| Casework    | Classroom | Casework       |           | 6    | 24       | LF   | \$858   |        |
| Casework    | Classroom | Casework       |           | 6    | 24       | LF   | \$858   |        |
| Casework    | Classroom | Casework       |           | 7    | 36       | LF   | \$0     |        |
| Casework    | Classroom | Casework       |           | 7    | 36       | LF   | \$0     |        |
| Casework    | Classroom | Casework       |           | 7    | 36       | LF   | \$0     |        |
| Casework    | Classroom | Casework       |           | 7    | 24       | LF   | \$0     |        |
| Casework    | Classroom | Casework       |           | 6    | 24       | LF   | \$858   |        |
| Ceiling     | Classroom | Lay-In/Drop    |           | 6    | 850      | SF   | \$1,823 |        |
| Ceiling     | Classroom | Lay-In/Drop    |           | 6    | 865      | SF   | \$1,855 |        |
| Ceiling     | Classroom | Lay-In/Drop    |           | 6    | 850      | SF   | \$1,823 |        |
| Ceiling     | Classroom | Lay-In/Drop    |           | 6    | 865      | SF   | \$1,855 |        |
| Ceiling     | Classroom | Lay-In/Drop    |           | 6    | 865      | SF   | \$1,855 |        |
| Ceiling     | Classroom | Lay-In/Drop    |           | 6    | 865      | SF   | \$1,855 |        |
| Ceiling     | Classroom | Lay-In/Drop    |           | 6    | 865      | SF   | \$1,855 |        |
| Ceiling     | Classroom | Lay-In/Drop    |           | 6    | 865      | SF   | \$1,855 |        |
| Ceiling     | Classroom | Lay-In/Drop    |           | 6    | 865      | SF   | \$1,855 |        |
| Ceiling     | Classroom | Lay-In/Drop    |           | 6    | 850      | SF   | \$1,823 |        |
| Ceiling     | Classroom | Lay-In/Drop    |           | 6    | 850      | SF   | \$1,823 |        |
| Ceiling     | Classroom | Lay-In/Drop    |           | 6    | 865      | SF   | \$1,855 |        |
| Chalk Board | Classroom | Chalk Board    |           | 4    | 12       | LF   | \$1,459 |        |
| Chalk Board | Classroom | Chalk Board    |           | 4    | 12       | LF   | \$1,459 |        |
| Chalk Board | Classroom | Chalk Board    |           | 4    | 12       | LF   | \$1,459 |        |
| Chalk Board | Classroom | Chalk Board    |           | 4    | 12       | LF   | \$1,459 |        |
| Chalk Board | Classroom | Chalk Board    |           | 4    | 12       | LF   | \$1,459 |        |
| Chalk Board | Classroom | Chalk Board    |           | 4    | 12       | LF   | \$1,459 |        |
| Chalk Board | Classroom | Chalk Board    |           | 4    | 12       | LF   | \$1,459 |        |
| Chalk Board | Classroom | Chalk Board    |           | 4    | 12       | LF   | \$1,459 |        |
| Chalk Board | Classroom | Chalk Board    |           | 4    | 8        | LF   | \$972   |        |
| Chalk Board | Classroom | Chalk Board    |           | 4    | 8        | LF   | \$972   |        |
| Chalk Board | Classroom | Chalk Board    |           | 4    | 8        | LF   | \$972   |        |
| Chalk Board | Classroom | Chalk Board    |           | 4    | 8        | LF   | \$972   |        |
| Chalk Board | Classroom | Chalk Board    |           | 4    | 8        | LF   | \$972   |        |
| Chalk Board | Classroom | Chalk Board    |           | 4    | 12       | LF   | \$1,459 |        |
| Corridors   | Corridors | Concrete Block | 1st Floor | 7    | 4,004    | SF   | \$0     |        |
| Corridors   | Corridors | Drop/Lay-In    | 1st Floor | 6    | 2,523    | SF   | \$5,412 |        |

**Building: Annex**  
**Category: ROOM**

| Group        | Sub Group | Item                | Location  | Rank | Quantity | Unit | Cost    | Reason |
|--------------|-----------|---------------------|-----------|------|----------|------|---------|--------|
| Corridors    | Corridors | Lay-In              | 1st Floor | 7    | 2,523    | EA   | \$0     |        |
| Corridors    | Corridors | Tile/Sheet Flooring | 1st Floor | 7    | 2,523    | SF   | \$0     |        |
| Floor        | Classroom | Tile/Sheet          |           | 6    | 865      | SF   | \$1,237 |        |
| Floor        | Classroom | Tile/Sheet          |           | 6    | 850      | SF   | \$1,216 |        |
| Floor        | Classroom | Tile/Sheet          |           | 6    | 850      | SF   | \$1,216 |        |
| Floor        | Classroom | Tile/Sheet          |           | 6    | 865      | SF   | \$1,237 |        |
| Floor        | Classroom | Tile/Sheet          |           | 6    | 865      | SF   | \$1,237 |        |
| Floor        | Classroom | Tile/Sheet          |           | 6    | 865      | SF   | \$1,237 |        |
| Floor        | Classroom | Tile/Sheet          |           | 6    | 865      | SF   | \$1,237 |        |
| Floor        | Classroom | Tile/Sheet          |           | 6    | 865      | SF   | \$1,237 |        |
| Floor        | Classroom | Tile/Sheet          |           | 6    | 865      | SF   | \$1,237 |        |
| Floor        | Classroom | Tile/Sheet          |           | 6    | 865      | SF   | \$1,237 |        |
| Floor        | Classroom | Tile/Sheet          |           | 6    | 850      | SF   | \$1,216 |        |
| Floor        | Classroom | Tile/Sheet          |           | 6    | 850      | SF   | \$1,216 |        |
| Floor        | Classroom | Tile/Sheet          |           | 6    | 865      | SF   | \$1,237 |        |
| Lighting     | Classroom | Lay-In              |           | 6    | 9        | EA   | \$644   |        |
| Lighting     | Classroom | Lay-In              |           | 7    | 9        | EA   | \$0     |        |
| Lighting     | Classroom | Lay-In              |           | 7    | 9        | EA   | \$0     |        |
| Lighting     | Classroom | Lay-In              |           | 7    | 9        | EA   | \$0     |        |
| Lighting     | Classroom | Lay-In              |           | 7    | 9        | EA   | \$0     |        |
| Lighting     | Classroom | Lay-In              |           | 6    | 9        | EA   | \$644   |        |
| Lighting     | Classroom | Lay-In              |           | 6    | 9        | EA   | \$644   |        |
| Lighting     | Classroom | Lay-In              |           | 6    | 9        | EA   | \$644   |        |
| Lighting     | Classroom | Lay-In              |           | 6    | 9        | EA   | \$644   |        |
| Lighting     | Classroom | Lay-In              |           | 6    | 9        | EA   | \$644   |        |
| Lighting     | Classroom | Lay-In              |           | 6    | 9        | EA   | \$644   |        |
| Lighting     | Classroom | Lay-In              |           | 6    | 9        | EA   | \$644   |        |
| Lighting     | Classroom | Lighting            |           | 6    | 9        | EA   | \$837   |        |
| Marker Board | Classroom | Marker Board        |           | 6    | 12       | LF   | \$343   |        |
| Marker Board | Classroom | Marker Board        |           | 7    | 12       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board        |           | 7    | 12       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board        |           | 7    | 12       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board        |           | 6    | 12       | LF   | \$343   |        |
| Marker Board | Classroom | Marker Board        |           | 6    | 12       | LF   | \$343   |        |
| Marker Board | Classroom | Marker Board        |           | 6    | 12       | LF   | \$343   |        |
| Marker Board | Classroom | Marker Board        |           | 6    | 12       | LF   | \$343   |        |
| Marker Board | Classroom | Marker Board        |           | 6    | 12       | LF   | \$343   |        |
| Marker Board | Classroom | Marker Board        |           | 6    | 12       | LF   | \$343   |        |
| Marker Board | Classroom | Marker Board        |           | 6    | 12       | LF   | \$343   |        |
| Marker Board | Classroom | Marker Board        |           | 6    | 12       | LF   | \$343   |        |
| Marker Board | Classroom | Marker Board        |           | 6    | 12       | LF   | \$343   |        |

**Building: Annex  
Category: ROOM**

| Group                           | Sub Group | Item            | Location | Rank | Quantity | Unit | Cost             | Reason |
|---------------------------------|-----------|-----------------|----------|------|----------|------|------------------|--------|
| Marker Board                    | Classroom | Marker Board    |          | 7    | 12       | LF   | \$0              |        |
| Wall                            | Classroom | Concrete Block  |          | 7    | 477      | SF   | \$0              |        |
| Wall                            | Classroom | Concrete Block  |          | 6    | 785      | SF   | \$2,245          |        |
| Wall                            | Classroom | Concrete Block  |          | 7    | 477      | SF   | \$0              |        |
| Wall                            | Classroom | Concrete Block  |          | 7    | 477      | SF   | \$0              |        |
| Wall                            | Classroom | Concrete Block  |          | 6    | 523      | SF   | \$1,496          |        |
| Wall                            | Classroom | Concrete Block  |          | 6    | 523      | SF   | \$1,496          |        |
| Wall                            | Classroom | Concrete Block  |          | 6    | 523      | SF   | \$1,496          |        |
| Wall                            | Classroom | Concrete Block  |          | 7    | 477      | SF   | \$0              |        |
| Wall                            | Classroom | Concrete Block  |          | 6    | 523      | SF   | \$1,496          |        |
| Wall                            | Classroom | Concrete Block  |          | 6    | 785      | SF   | \$2,245          |        |
| Wall                            | Classroom | Concrete Block  |          | 6    | 785      | SF   | \$2,245          |        |
| Wall                            | Classroom | Concrete Block  |          | 6    | 523      | SF   | \$1,496          |        |
| Wall                            | Classroom | Plaster/Drywall |          | 6    | 523      | SF   | \$1,234          |        |
| Wall                            | Classroom | Plaster/Drywall |          | 6    | 262      | SF   | \$618            |        |
| Wall                            | Classroom | Plaster/Drywall |          | 6    | 523      | SF   | \$1,234          |        |
| Wall                            | Classroom | Plaster/Drywall |          | 6    | 523      | SF   | \$1,234          |        |
| Wall                            | Classroom | Plaster/Drywall |          | 6    | 523      | SF   | \$1,234          |        |
| Wall                            | Classroom | Plaster/Drywall |          | 6    | 477      | SF   | \$1,125          |        |
| Wall                            | Classroom | Plaster/Drywall |          | 6    | 523      | SF   | \$1,234          |        |
| Wall                            | Classroom | Plaster/Drywall |          | 6    | 477      | SF   | \$1,125          |        |
| Wall                            | Classroom | Plaster/Drywall |          | 6    | 477      | SF   | \$1,125          |        |
| Wall                            | Classroom | Plaster/Drywall |          | 6    | 477      | SF   | \$1,125          |        |
| Wall                            | Classroom | Plaster/Drywall |          | 6    | 262      | SF   | \$618            |        |
| Wall                            | Classroom | Plaster/Drywall |          | 6    | 262      | SF   | \$618            |        |
| <b>ROOM Sub Total</b>           |           |                 |          |      |          |      | <b>\$99,556</b>  |        |
| <b>Building Annex Sub Total</b> |           |                 |          |      |          |      | <b>\$351,915</b> |        |

**Building: SITE  
Category: SITE**

| Group          | Sub Group | Item         | Location    | Rank | Quantity | Unit | Cost    | Reason |
|----------------|-----------|--------------|-------------|------|----------|------|---------|--------|
| Civil/Drainage |           | Catch Basin  | Entire Site | 7    | 3        | EA   | \$0     |        |
| Civil/Drainage |           | Site Manhole | Entire Site | 7    | 6        | EA   | \$0     |        |
| Fencing        |           | Chain Link   | Entire Site | 7    | 1,421    | LF   | \$0     |        |
| Fencing        |           | Chain Link   | N & S site  | 6    | 140      | LF   | \$2,008 |        |

**Building: SITE**  
**Category: SITE**

| Group                 | Sub Group | Item                                 | Location      | Rank | Quantity | Unit | Cost             | Reason        |
|-----------------------|-----------|--------------------------------------|---------------|------|----------|------|------------------|---------------|
| Landscape             |           | Asphalt Play Area/Hardscape          | Entire Site   | 5    | 24,995   | SF   | \$70,771         |               |
| Landscape             |           | Grass                                | Entire Site   | 6    | 12,631   | SF   | \$5,057          |               |
| Landscape             |           | Hardscape - Concrete                 | Entire Site   | 7    | 2,523    | SF   | \$0              |               |
| Landscape             |           | Parkway trees                        | Entire Site   | 7    | 33       | EA   | \$0              |               |
| Landscape             |           | Planting Beds/ Areas                 | Entire Site   | 6    | 1,432    | SF   | \$0              |               |
| Modular               |           | 2-Classroom Modular Building         | Site 2 West   | 6    | 3        | EA   | \$0              |               |
| Parking Lot           |           | Asphalt                              | Parking Lot   | 7    | 25,171   | SF   | \$0              |               |
| Parking Lot           |           | Asphalt                              | Main Entrance | 5    | 600      | SF   | \$1,699          | Water ponding |
| Parking Lot           |           | Concrete                             | Boiler Room   | 6    | 1,704    | SF   | \$0              |               |
| Sidewalks             |           | Internal Walks                       | Entire Site   | 6    | 111      | LF   | \$1,048          |               |
| Sidewalks             |           | Perimeter Sidewalks                  | Entire Site   | 6    | 13,920   | SF   | \$26,275         |               |
| Signage               |           | Flag Pole                            | North Façade  | 7    | 1        | EA   | \$0              |               |
| Signage               |           | Marquee - Free Standing Back Lighted | NE site       | 6    | 1        | EA   | \$0              |               |
| <b>SITE Sub Total</b> |           |                                      |               |      |          |      | <b>\$106,858</b> |               |
| <b>SITE Sub Total</b> |           |                                      |               |      |          |      | <b>\$106,858</b> |               |

**Total Campus Need <sup>2 3</sup> \$5,290,925**

<sup>1</sup> It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

<sup>2</sup> As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

<sup>3</sup> The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.

**Room Summary**

| Room Number           | Room Size | Voice Outlet | Data Outlet | Elect Outlet | Noise Level | Glaze Window Area | Operable Window Area | No. of Window AC | Window Stop | Smart Board | Power Strip | Room Type                     | Room Sub Type                        | Location                    |
|-----------------------|-----------|--------------|-------------|--------------|-------------|-------------------|----------------------|------------------|-------------|-------------|-------------|-------------------------------|--------------------------------------|-----------------------------|
| <b>Building: Main</b> |           |              |             |              |             |                   |                      |                  |             |             |             |                               |                                      |                             |
| 103                   | 718       | 1            | 2           | 12           | 40          | 150               | 75                   | 1                | N           | N           | Y           | Classroom                     |                                      |                             |
| 105                   | 718       | 1            | 2           | 12           | 40          | 150               | 75                   | 1                | N           | Y           | Y           | Classroom                     |                                      |                             |
| 107                   | 1495      | 1            | 2           | 16           | 40          | 240               | 120                  | 2                | N           | N           | Y           | Classroom                     |                                      |                             |
| 108                   | 750       | 1            | 2           | 10           | 40          | 160               | 80                   | 1                | N           | Y           | Y           | Classroom                     |                                      |                             |
| 109                   | 726       | 1            | 2           | 16           | 40          | 150               | 75                   | 1                | N           | Y           | Y           | Classroom                     |                                      |                             |
| 110                   | 750       | 1            | 2           | 10           | 40          | 160               | 80                   | 1                | N           | Y           | Y           | Classroom                     |                                      |                             |
| 111                   | 726       | 1            | 2           | 16           | 40          | 150               | 75                   | 2                | N           | Y           | Y           | Classroom                     |                                      |                             |
| 112                   | 750       | 1            | 2           | 10           | 40          | 160               | 80                   | 1                | N           | Y           | Y           | Classroom                     |                                      |                             |
| 114                   | 597       | 1            | 2           | 8            | 40          | 160               | 80                   | 1                | N           | N           | N           | Classroom                     |                                      |                             |
| 201                   | 469       | 1            | 1           | 8            | 40          | 60                | 30                   | 1                | N           | N           | Y           | Classroom                     |                                      |                             |
| 203                   | 726       | 1            | 2           | 16           | 40          | 150               | 75                   | 1                | N           | Y           | Y           | Classroom                     |                                      |                             |
| 205                   | 726       | 1            | 2           | 16           | 40          | 150               | 75                   |                  | N           | Y           | Y           | Classroom                     |                                      |                             |
| 206                   | 716       | 1            | 2           | 10           | 40          | 160               | 80                   | 1                | N           | Y           | Y           | Classroom                     |                                      |                             |
| 207                   | 726       | 1            | 2           | 16           | 40          | 150               | 75                   |                  | N           | Y           | Y           | Classroom                     |                                      |                             |
| 208                   | 716       | 1            | 2           | 10           | 40          | 160               | 80                   | 1                | N           | Y           | Y           | Classroom                     |                                      |                             |
| 209                   | 726       | 1            | 2           | 16           | 40          | 150               | 75                   | 1                | N           | Y           | Y           | Classroom                     |                                      |                             |
| 210                   | 716       | 1            | 2           | 10           | 40          | 160               | 80                   | 1                | N           | Y           | Y           | Classroom                     |                                      |                             |
| 211                   | 726       | 1            | 2           | 16           | 40          | 150               | 75                   | 1                | N           | Y           | Y           | Classroom                     |                                      |                             |
| 212                   | 716       | 1            | 2           | 10           | 40          | 160               | 80                   | 1                | N           | Y           | Y           | Classroom                     |                                      |                             |
| 213                   | 726       | 1            | 2           | 16           | 40          | 150               | 75                   | 1                | N           | Y           | Y           | Classroom                     |                                      |                             |
| 214                   | 716       | 1            | 2           | 10           | 40          | 160               | 80                   | 1                | N           | N           | Y           | Classroom                     |                                      |                             |
| 215A                  | 688       | 1            | 2           | 10           | 40          | 150               | 75                   | 2                | N           | Y           | Y           | Classroom                     |                                      |                             |
| 215B                  | 412       | 1            | 2           | 10           | 40          | 150               | 75                   | 1                | N           | Y           | Y           | Classroom                     |                                      |                             |
| M001                  | 652       | 1            | 2           | 10           | 40          | 42                | 24                   |                  | N           | N           | Y           | Classroom                     |                                      |                             |
| M002                  | 652       | 1            | 2           | 10           | 40          | 42                | 24                   |                  | N           | N           | Y           | Classroom                     |                                      |                             |
| M003                  | 674       | 1            | 2           | 10           | 40          | 14                | 8                    |                  | N           | N           | Y           | Classroom                     |                                      |                             |
| M004                  | 674       | 1            | 2           | 10           | 40          | 14                | 8                    |                  | N           | N           | Y           | Classroom                     |                                      |                             |
| M005                  | 674       | 1            | 2           | 10           | 40          | 14                | 8                    |                  | N           | N           | Y           | Classroom                     |                                      |                             |
| M006                  | 674       | 1            | 2           | 10           | 40          | 14                | 8                    |                  | N           | N           | Y           | Classroom                     |                                      |                             |
| Other                 | 296       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Children's Standard Student Restroom | 1st Floor North Girl's Room |
| Other                 | 2709      |              |             |              |             |                   |                      |                  | N           | N           | N           | Auditorium & Theater          | Auditorium - Dedicated               | 1st Floor                   |
| Other                 | 202       |              |             | 6            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                      | Room 216, Office            |
| Other                 | 202       |              |             | 6            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                      | Room 204, Office            |
| Other                 | 273       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Children's Standard Student Restroom | 1st Floor South Boy's Room  |
| Other                 | 273       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Children's Standard Student Restroom | 2nd Floor South Boy's Room  |
| Other                 | 273       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Children's Standard Student Restroom | 2nd Floor North Boy's Room  |

**Room Summary**

| Room Number | Room Size | Voice Outlet | Data Outlet | Elect Outlet | Noise Level | Glaze Window Area | Operable Window Area | No. of Window AC | Window Stop | Smart Board | Power Strip | Room Type                     | Room Sub Type                        | Location  |
|-------------|-----------|--------------|-------------|--------------|-------------|-------------------|----------------------|------------------|-------------|-------------|-------------|-------------------------------|--------------------------------------|---|
| Other       | 296       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Children's Standard Student Restroom | 1st Floor South Girl's Room                                     |
| Other       | 296       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Children's Standard Student Restroom | 2nd Floor South Girl's Room                                     |
| Other       | 296       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Children's Standard Student Restroom | 2nd Floor North Girl's Room                                     |
| Other       | 89        |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom                       | In Room 200   |
| Other       | 202       |              |             | 6            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                      | Room 116, Office  |
| Other       | 98        |              |             | 2            |             |                   |                      |                  | N           | N           | N           | Administrative Suites/Offices |                                      | Office, Room 200  |
| Other       | 273       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Children's Standard Student Restroom | 1st Floor North Boy's Room                                      |
| Other       | 26        |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom                       | 1st floor inside engineer's office                              |
| Other       | 427       |              |             |              |             |                   |                      |                  | N           | N           | N           | Corridors                     |                                      | Basement tunnel linking boiler room to main building            |
| Other       | 2798      |              |             |              |             |                   |                      |                  | N           | N           | N           | Gymnasia                      | Standard Dedicated Gymnasium         | 1st Floor   |
| Other       | 76        |              |             | 6            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                      | 1st floor engineer's office                                     |
| Other       | 15        |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom                       | 1st floor next to engineer's office                             |
| Other       | 478       |              |             | 6            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                      | 1st floor east end of corridor, #101                            |
| Other       | 210       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Early Childhood Student Restroom     | 1st floor inside Rm #107  |
| Other       | 732       |              |             |              |             |                   |                      |                  | N           | N           | N           | Library                       |                                      | 1st Floor   |
| Other       | 597       |              |             | 6            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                      | 1st floor west end of corridor                                  |
| Other       | 83        |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom                       | 1st floor inside office at west end of corridor                 |
| Other       | 5773      |              |             |              |             |                   |                      |                  | N           | N           | N           | Corridors                     |                                      | 1st Floor   |
| Other       | 177       |              |             |              |             |                   |                      |                  | N           | N           | N           | Kitchen                       | Warming Kitchen                      | In the Auditorium Area  |
| Other       | 1600      |              |             |              |             |                   |                      |                  | N           | N           | N           | Corridors                     |                                      | Entire building stairwells                                      |
| Other       | 5773      |              |             |              |             |                   |                      |                  | N           | N           | N           | Corridors                     |                                      | 2nd Floor   |
| Other       | 630       |              |             | 2            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                      | Room 121, Gym Office (Girl's Locker Room per plan)              |
| Other       | 2709      |              |             |              |             |                   |                      |                  | N           | N           | N           | Lunch & Multipurpose Room     | Multipurpose Room                    | In the Auditorium   |
| Other       | 74        |              |             | 2            |             |                   |                      |                  | N           | N           | N           | Administrative Suites/Offices |                                      | Kitchen Office (Formerly the Men's Room next to the Auditorium) |
| Other       | 159       |              |             | 6            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                      | Assistant Principal's Office                                    |
| Other       | 114       |              |             | 4            |             |                   |                      |                  | N           | N           | N           | Administrative Suites/Offices |                                      | Principal's Office  |
| Other       | 33        |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom                       | In Principal's Office   |
| Other       | 407       |              |             | 8            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                      | Main Office   |
| Other       | 29        |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Early Childhood Student Restroom     | Girl's Room in Room 114   |
| Other       | 29        |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Early Childhood Student Restroom     | Boy's Room in Room 114  |

**Building: Annex**

|     |     |   |   |    |    |     |     |   |   |   |   |           |  |  |
|-----|-----|---|---|----|----|-----|-----|---|---|---|---|-----------|--|--|
| 300 | 850 | 1 | 6 | 14 | 40 | 300 | 150 | 0 | N | N | N | Classroom |  |  |
| 301 | 850 | 1 | 6 | 14 | 40 | 300 | 150 | 0 | N | N | N | Classroom |  |  |



**Room Summary**

| Room Number | Room Size | Voice Outlet | Data Outlet | Elect Outlet | Noise Level | Glaze Window Area | Operable Window Area | No. of Window AC | Window Stop | Smart Board | Power Strip | Room Type                     | Room Sub Type                        | Location                         |
|-------------|-----------|--------------|-------------|--------------|-------------|-------------------|----------------------|------------------|-------------|-------------|-------------|-------------------------------|--------------------------------------|----------------------------------|
| 302         | 850       | 1            | 6           | 14           | 40          | 300               | 150                  | 0                | N           | N           | N           | Classroom                     |                                      |                                  |
| 303         | 850       | 1            | 6           | 14           | 40          | 300               | 150                  | 0                | N           | N           | N           | Classroom                     |                                      |                                  |
| 304         | 865       | 1            | 6           | 12           | 40          | 120               | 60                   | 0                | N           | N           | Y           | Classroom                     |                                      |                                  |
| 305         | 865       | 1            | 6           | 12           | 40          | 120               | 60                   | 0                | N           | N           | Y           | Classroom                     |                                      |                                  |
| 307         | 865       | 1            | 6           | 12           | 40          | 120               | 60                   | 0                | N           | N           | Y           | Classroom                     |                                      |                                  |
| 308         | 865       | 1            | 6           | 12           | 40          | 120               | 60                   | 0                | N           | N           | Y           | Classroom                     |                                      |                                  |
| 309         | 865       | 1            | 6           | 12           | 40          | 120               | 60                   | 0                | N           | N           | Y           | Classroom                     |                                      |                                  |
| 310         | 865       | 1            | 6           | 12           | 40          | 120               | 60                   | 0                | N           | N           | Y           | Classroom                     |                                      |                                  |
| 311         | 865       | 1            | 6           | 12           | 40          | 120               | 60                   | 0                | N           | N           | Y           | Classroom                     |                                      |                                  |
| 312         | 865       | 1            | 6           | 12           | 40          | 120               | 60                   | 0                | N           | N           | Y           | Classroom                     |                                      |                                  |
| Other       | 2523      |              |             |              |             |                   |                      |                  | N           | N           | N           | Corridors                     |                                      | 1st Floor                        |
| Other       | 43        |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom                       | Women's Room                     |
| Other       | 43        |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom                       | Men's Room                       |
| Other       | 435       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Children's Standard Student Restroom | Girl's Room                      |
| Other       | 435       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Children's Standard Student Restroom | Boy's Room                       |
| Other       | 369       |              |             | 6            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                      | 1st floor middle of corridor#306 |