

Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx.

Condition Rankings and Descriptions

- Rank 7:** The item/system is new or in good condition and no work is required.
- Rank 6:** The item/system requires general cleaning and/or routine maintenance.
- Rank 5:** The item/system requires repairs and has not reached the end of its serviceable life.
- Rank 4:** The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.
- Rank 3:** The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.
- Rank 2:** The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.
- Rank 1:** The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.¹

Definitions

- Quantity** means, for each item, the total number (or amount) of that item that exists and was evaluated.
- Unit** means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").
- Cost** means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.
- For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.**
- Total Campus Need** also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

Building: Main Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chimney		Brick Chimney - Concrete/ Mortar Liner	Boiler Room	6	102	LF	\$51,051	
Cornice		Cornice - Terra Cotta	Entire Building	6	2,040	LF	\$62,574	
Doors		Exterior Steel Door	Entire Building	6	16	EA	\$5,285	
Doors		Exterior Steel Door	Boiler Room	6	2	EA	\$661	
Doors		Transom Lite	Fire escape	6	2	EA	\$566	
Entrance		Entrance Controls - Audio and Video	Entire Building	6	2	EA	\$2,860	
Entrance		Stair Handrails	West Entrances	6	30	LF	\$0	
Entrance		Stone Stairs	West Entrances	6	392	LF	\$70,070	Recaulk/repair joints
Fire Escape		Fire Escapes	Auditorium	5	53	LF	\$16,882	
Foundation		Concrete Foundation	Entire Building	7	1,248	LF	\$0	
Lighting		Exterior Lights - Parapet or Roof Mounted	Roof	6	11	EA	\$5,506	
Lighting		Exterior Lights - Wall Mounted	Boiler Room	6	4	EA	\$858	
Lintels		Lintels - Steel	Entire Building	6	828	LF	\$31,259	
Parapet		Coping - Stone	Areaways, north intake	6	122	LF	\$0	

Building: Main
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Parapet		Coping - Terra Cotta	Roof	6	1,428	LF	\$0	
Parapet		Parapet < 16" Height	Roof	6	171	LF	\$26,629	
Parapet		Parapet > 30" Height	Roof	6	1,114	LF	\$289,133	
Parapet		Parapet 16" to 30" Height	Roof	6	143	LF	\$29,692	
Roof System		Asphalt Shingle Roof	Main roof - west elevation	6	2,108	SF	\$8,350	
Roof System		Interior Downspouts	Boiler Room	5	21	LF	\$2,252	Clogged, ponding around drain
Roof System		Interior Downspouts	Roof	6	365	LF	\$0	
Roof System		Modified Bitumen Roof	Roof	6	29,103	SF	\$206,006	
Roof System		Roof Structure: Concrete	Roof	7	31,209	SF	\$0	
Superstructure		Concrete	Entire Building	7	75,820	SF	\$0	
Walls		Brick	Entire Building	6	39,779	SF	\$262,804	
Walls		Stone - Cast	Entire building - stone base	6	832	SF	\$11,898	
Walls		Terra Cotta	Entire Building	6	2,825	SF	\$80,795	
Windows		Curtain wall - Insulated panel	Boiler Room	6	147	SF	\$1,387	
Windows		Window - Guards perforated	1st Floor	6	1,116	SF	\$0	
Windows		Window - Guards wire guard	Basement	5	329	SF	\$8,299	
Windows		Window - Guards wire guard	Gym	6	329	SF	\$0	
Windows		Windows - Sash Aluminum Double-pane	Entire Building	5	7,190	SF	\$248,303	
Windows		Windows - Sash Aluminum Double-pane	Boiler Room	4	197	SF	\$34,025	
Windows		Windows - Wood - Single-pane	Areaway	4	49	SF	\$10,511	
EXTERIOR Sub Total							\$1,467,655	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Emergency A/C power - Auditorium and aisle lighting	Auditorium	2	3,949	SF	\$27,388	The emergency lights do not work. Aisle Lights inoperative
Emergency System		Emergency A/C power - Corridors and Stairs	Corridors and Stairs	7	11,008	SF	\$0	
Emergency System		Emergency A/C power - Gym and Lunch rooms	Gym	7	2,803	SF	\$0	
Emergency System		Emergency A/C power - Students Toilets	Student Toilets	7	2,124	SF	\$0	
Emergency System		Exit Signs - Auditorium	Auditorium	7	7	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	Corridors and Stairs	7	19	EA	\$0	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	Gym	7	2	EA	\$0	
Emergency System		Public Announcement System	Entire Building	4	75,820	SF	\$268,888	
Emergency System		Security System - CCTV	Entire Building	6	75,820	SF	\$108,423	
Emergency System		Security System - Intrusion detection	Entire Building	6	75,820	SF	\$70,475	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Main Service		Main Electrical service - Live Front - 1200 A 120/208/3PH	Mechanical Room	4	1	EA	\$113,256	
Power Distribution		Lighting and power panels	Entire Building	6	13	EA	\$9,295	
Power Distribution		Lighting and power panels	Entire Building	4	2	EA	\$10,868	
Power Distribution		Main distribution panels 400-600 amp	Entire Building	6	1	EA	\$1,430	
Power Distribution		Main distribution panels above 600 amp	Entire Building	6	5	EA	\$10,725	
Power Distribution		Main distribution panels less than 400 amp	Boiler Room	4	1	EA	\$6,578	
Power Distribution		Transformers 277/480-120/208	Entire Building	6	2	EA	\$2,288	

ELECTRICAL Sub Total \$629,614

Building: Main
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Entire Building	6	75,820	SF	\$27,106	
Fire Alarm		Fire Alarm System	Classroom next to Engineers Office - No Room Number	7	75,820	SF	\$0	

FIRE PROTECTION Sub Total \$27,106

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Chillers - Air Cooled - Rotary/Screw type - Roof Mounted 201 to 300 tons	Roof	6	1	EA	\$60,060	
Air Conditioning		Chillers - Water Cooled - Absorber 50 to 100 tons	Boiler Room	2	2	EA	\$297,440	The unit is inoperable (unit cannot maintain the vacuum pressure, the bromine is crystallized, overall condition of the unit is very poor). Vacuum Pump is missing on one unit and electrical is cut off and exposed. One Burner is inoperative.
Air Conditioning		Condensing Unit - Roof Mounted less than 5 tons	Areaway	6	2	EA	\$1,716	
Air Conditioning		Cooling Tower - Spray Type - 101 to 200 tons	Roof	5	2	EA	\$37,180	Not being used due to condition of absorbers
Air Conditioning		Window A/C Unit	Engineers Office	5	1	EA	\$1,073	
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water 4,000 to 8,000 cfm	Basement	6	2	EA	\$10,010	
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water 12,001 to 20,000 cfm	Basement	6	4	EA	\$30,316	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Handling Systems		Air intake for all Air Handling Units except built up AHU	Roof	6	2	EA	\$2,860	
Air Handling Systems		Return Fans - Indoor 10,001 to 20,000 CFM	Basement	5	4	EA	\$48,620	
Air Handling Systems		Return Fans - Indoor 5,000 to 10,000 CFM	Basement	5	1	EA	\$5,720	
Boiler Systems		Boiler Assembly - Steam - Low Pressure Scotch Marine Boiler 101-150 HP	Boiler Room	6	2	EA	\$29,458	No High Level traps installed on either boiler.
Boiler Systems		Boiler Auxiliary - Steam Boiler 101-150 HP	Boiler Room	7	2	EA	\$0	
Boiler Systems		Chemical Feed System (Steam Boilers)	Boiler Room	6	2	EA	\$4,290	
Boiler Systems		Chemical Pot Feeder - Hot Water	Boiler Room	6	2	EA	\$601	
Boiler Systems		Combustion Dampers	Boiler Room	2	2	EA	\$11,154	Boiler cannot be properly fired due to lack of combustion air (combustion is provided by a make-up air unit and the unit is inoperable, combustion dampers are closed)
Boiler Systems		Combustion Dampers	Boiler Room	3	2	EA	\$11,154	Combustion intake damper is inoperable and has failed in the open position,
Boiler Systems		Combustion Dampers	Boiler Room	6	2	EA	\$572	
Boiler Systems		Feed Water Pumps and Tank - Steam Boilers	Boiler Room	6	1	EA	\$8,437	
Boiler Systems		Gas Boosters	Boiler Room	6	2	EA	\$2,603	
Boiler Systems		Glycol Feed System	Boiler Room	6	1	EA	\$1,087	
Boiler Systems		Glycol Feed System	Boiler Room	2	1	EA	\$3,861	Glycol feed system is not working and proper glycol levels cannot be maintained. Pump is inoperative
Heat Exchangers		Heat Exchanger - Steam to Hot Water Shell Type	Boiler Room	7	1	EA	\$0	
Heating Devices		Radiators - Steam	Boiler Room	4	1	EA	\$1,401	Radiator is more than 30 years of age and is not working. Unit is valved off due to leaks. Lower Level - Radiator Shell is cracked/rusted through.
Heating Devices		Radiators - Steam	Entire Building	4	30	EA	\$42,042	
Heating Devices		Unit Heater - Gas	Boiler Room	2	1	EA	\$11,440	Gas Train has failed.
Heating Devices		Unit Heater - Hot Water	Entire Building	6	3	EA	\$4,290	
Heating Devices		Wall Heater - Electric	Entire Building	6	22	EA	\$2,265	
Mechanical Plumbing		Condensate Assembly - Pumps and Tank	Boiler Room	5	1	EA	\$9,438	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Mechanical Plumbing		Piping - Condensate - Steel or Galvanized	Basement	5	250	LF	\$8,133	Condensate Piping in trenches is in poor shape.
Mechanical Plumbing		Piping - Hydronic Supply and Return - Steel or Galvanized	Entire Building	5	500	LF	\$24,739	Noted leaking glycol in Boiler Room Piping 4 pipe system
Mechanical Plumbing		Piping - Steam - Steel or Galvanized	Boiler Room	7	250	LF	\$0	
Mechanical Plumbing		Pumps - Chilled Water 21-50 HP	Boiler Room	6	2	EA	\$11,440	
Mechanical Plumbing		Pumps - Condenser Water 10 to 20 HP	Boiler Room	6	2	EA	\$5,148	
Mechanical Plumbing		Pumps - Hot Water 5 to 10 HP	Boiler Room	6	3	EA	\$6,006	
Temperature Control		Direct Digital Control (DDC) System	Entire Building	6	75,820	SF	\$75,896	
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	6	34	EA	\$4,862	
Temperature Control		Zone Dampers	Plenum	7	31	EA	\$0	
Ventilation		Exhaust Fan - Indoor	Basement	6	2	EA	\$1,001	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Entire Building	6	3	EA	\$1,287	
Ventilation		Exhaust Fans - Roof mounted less than 500 CFM	Roof	6	2	EA	\$315	
MECHANICAL Sub Total							\$777,914	

Building: Main
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas more than 300,000 BTU/HR	Boiler Room	6	1	EA	\$6,721	
Hot Water		Hot Water Heater - Gas more than 300,000 BTU/HR	Boiler Room	3	1	EA	\$32,032	Unit 6 yrs Old Vessel has failed, burner is disconnected and gas plugged
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	4	75,820	SF	\$24,937	
Piping		Domestic Piping - Cold Water Risers	Entire Building	4	75,820	SF	\$48,790	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	4	75,820	SF	\$16,263	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	4	75,820	SF	\$34,695	
Piping		Domestic Piping - Hot Water Risers	Entire Building	4	75,820	SF	\$41,201	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	7	75,820	SF	\$0	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	7	75,820	SF	\$0	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	7	75,820	SF	\$0	
Piping		Sanitary Piping	Entire Building	4	75,820	SF	\$72,643	
Piping		Storm Piping	Entire Building	4	75,820	SF	\$54,211	
Piping		Vent Piping	Entire Building	4	75,820	SF	\$43,369	
Pumps		Ejector Pump	Mechanical Room	6	1	EA	\$3,003	

Building: Main
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
PLUMBING Sub Total							\$377,866	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	1st floor SE corner, used to be Boy's Locker Room	6	424	SF	\$909	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	2nd floor SE corner, used to be Girl's Locker Room	5	630	SF	\$3,568	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	1st floor rm #113	5	468	SF	\$2,650	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	1st floor main office suite	5	690	SF	\$3,907	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	1st floor engineer's office	5	130	SF	\$736	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	1st floor main office suite	6	345	SF	\$493	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	1st floor rm #113	6	468	SF	\$669	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	1st floor engineer's office	4	130	SF	\$1,350	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	2nd floor SE corner, used to be Girl's Locker Room	6	630	SF	\$901	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	1st floor SE corner, used to be Boy's Locker Room	6	424	SF	\$606	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	1st floor main office suite	6	173	SF	\$247	
Administrative Suites	Administrative Suites/Offices	Flooring - Wood	1st floor main office suite	6	173	SF	\$1,306	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	1st floor SE corner, used to be Boy's Locker Room	6	4	SF	\$3	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	1st floor main office suite	6	6	SF	\$4	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	1st floor rm #113	6	6	SF	\$4	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	2nd floor SE corner, used to be Girl's Locker Room	6	6	SF	\$4	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	1st floor engineer's office	4	2	SF	\$13	T-12
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	1st floor engineer's office	5	663	SF	\$3,129	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	1st floor main office suite	5	2,702	SF	\$12,751	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	1st floor rm #113	6	1,115	SF	\$2,631	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	1st floor SE corner, used to be Boy's Locker Room	6	513	SF	\$1,210	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	2nd floor SE corner, used to be Girl's Locker Room	5	1,484	SF	\$7,003	
Administrative Suites	Administrative Suites/Offices	Walls - Structural Glazed Tile	1st floor SE corner, used to be Boy's Locker Room	6	513	SF	\$3,668	
Administrative Suites	Administrative Suites/Offices	Walls - Structural Glazed Tile	2nd floor SE corner, used to be Girl's Locker Room	6	742	SF	\$5,305	
Auditorium - Dedicated	Auditorium - Dedicated	Balcony Seating	1st Floor	6	98	EA	\$3,607	
Auditorium - Dedicated	Auditorium - Dedicated	Main Floor Seating	1st Floor	6	280	EA	\$10,306	
Auditorium - Dedicated	Auditorium - Dedicated	Sound System	1st Floor	6	1	EA	\$35,750	
Auditorium - Dedicated	Auditorium - Dedicated	Stage Curtains	1st Floor	6	2	EA	\$22,651	
Auditorium - Dedicated	Auditorium - Dedicated	Stage Lighting System	1st Floor	6	1	EA	\$114,400	
Corridor		Stair Handrails	Basement inside boiler room 2 steel stairs	6	108	LF	\$0	
Corridor		Stair Handrails	Basement inside mechanical spaces	6	128	LF	\$0	
Corridor		Stairs - Tile	Basement inside boiler room 2 steel stairs	6	50	LF	\$378	
Corridor		Stairs - Tile	Basement inside mechanical spaces	6	60	LF	\$453	
Doors		Interior Steel Doors incl hw	1st Floor	6	4	EA	\$1,133	
Doors		Interior Steel Doors incl hw	2nd Floor	6	2	EA	\$566	
Doors		Interior Wood Doors incl hw	2nd Floor	5	35	EA	\$16,517	
Doors		Interior Wood Doors incl hw	Basement	5	6	EA	\$2,831	
Doors		Interior Wood Doors incl hw	1st Floor	5	55	EA	\$25,955	
Doors		Side-lite	2nd Floor	6	40	SF	\$744	
Doors		Side-lite	1st Floor	6	40	SF	\$744	
Doors		Transom Window	2nd Floor	6	200	SF	\$3,718	
Doors		Transom Window	1st Floor	6	250	SF	\$4,648	
Drinking Fountains	Corridors	Double Fountain	1st Floor	6	1	EA	\$658	
Drinking Fountains	Corridors	Double Fountain	2nd Floor	6	2	EA	\$1,316	
Drinking Fountains	Corridors	Triple Fountain	1st Floor	6	1	EA	\$972	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Ceiling - Plaster/Drywall	1st Floor	5	2,803	SF	\$28,058	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Flooring - Wood	1st Floor	6	2,803	SF	\$21,164	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Lighting - Pendant/Surface	1st Floor	6	12	EA	\$1,459	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Scoreboards	1st Floor	6	1	EA	\$2,076	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Sound System	1st Floor	6	1	EA	\$5,005	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Plaster/Drywall	1st Floor	6	3,528	SF	\$30,270	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Structural Glazed Tile	1st Floor	6	1,764	SF	\$12,613	
MDF/IDF		Finishes	2nd floor inside Classroom #200	6	105	SF	\$357	
MDF/IDF		Ventilation and Cooling	2nd floor inside Classroom #200	6	1	EA	\$1,401	
Mechanical/Service Rooms		Boiler Room	Basement	5	2,407	SF	\$27,261	There was water leaked from mechanical pipes sitting on the floor.
Mechanical/Service Rooms		Crawl Space - Unfinished	Basement	6	14,043	SF	\$26,508	
Mechanical/Service Rooms		Janitor's Closet	Entire Building	6	4	SF	\$19	
Mechanical/Service Rooms		Mechanical/Service Rooms	Basement	5	11,430	SF	\$129,452	Some water on floor from leaking from mechanical equipment
Mechanical/Service Rooms		Storage Room	Basement next to boiler room	6	1,633	SF	\$7,706	
Mechanical/Service Rooms		Storage Room	1st floor west of auditorium 2 storages	6	266	SF	\$1,255	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor boy's at south	6	232	SF	\$1,792	
Staff Restroom	Staff Restroom	Accessories	1st floor at auditorium, woman's	5	154	SF	\$3,924	
Staff Restroom	Staff Restroom	Accessories	1st floor inside Rm #102	6	222	SF	\$1,714	
Staff Restroom	Staff Restroom	Accessories	1st floor 2 toilets next to engineer's office	5	30	SF	\$764	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor boy's at north	6	232	SF	\$1,792	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd floor boy's at south	6	232	SF	\$1,792	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd floor boy's at north	6	232	SF	\$1,792	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd floor girl's at north	6	299	SF	\$2,309	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd floor girl's at south	6	299	SF	\$2,309	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor girl's at south	6	299	SF	\$2,309	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor girl's at north	6	299	SF	\$2,309	
Staff Restroom	Staff Restroom	Accessories	1st floor inside office suite next to classroom #104	6	30	SF	\$232	
Staff Restroom	Staff Restroom	Accessories	1st floor at auditorium, men's & women's	5	88	SF	\$2,242	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor girl's at north	5	299	SF	\$1,693	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor girl's at south	5	299	SF	\$1,693	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st floor at auditorium, woman's	5	154	SF	\$872	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor girl's at south	5	299	SF	\$1,693	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st floor inside office suite next to classroom #104	5	30	SF	\$170	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor girl's at north	5	299	SF	\$1,693	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor boy's at north	5	232	SF	\$1,314	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor boy's at south	5	232	SF	\$1,314	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st floor 2 toilets next to engineer's office	5	30	SF	\$170	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st floor inside Rm #102	5	222	SF	\$1,257	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st floor at auditorium, men's & women's	5	88	SF	\$498	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor boy's at north	5	232	SF	\$1,314	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor boy's at south	5	232	SF	\$1,314	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor girl's at south	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor boy's at south	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor boy's at north	6	1	EA	\$300	
Staff Restroom	Staff Restroom	Floor Drain	1st floor inside Rm #102	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd floor boy's at north	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd floor girl's at north	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd floor boy's at south	6	1	EA	\$300	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd floor girl's at south	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor girl's at north	6	1	EA	\$300	
Staff Restroom	Staff Restroom	Flooring - Concrete	1st floor 2 toilets next to engineer's office	5	30	SF	\$142	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	1st floor inside Rm #102	6	148	SF	\$838	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	1st floor inside office suite next to classroom #104	6	30	SF	\$76	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor girl's at south	6	299	SF	\$761	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor boy's at north	6	232	SF	\$591	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor girl's at south	6	299	SF	\$761	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	1st floor at auditorium, men's & women's	6	88	SF	\$224	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	1st floor inside Rm #102	6	74	SF	\$188	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor boy's at north	6	232	SF	\$591	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor boy's at south	6	232	SF	\$591	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor boy's at south	6	232	SF	\$591	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	1st floor at auditorium, woman's	6	154	SF	\$392	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor girl's at north	6	299	SF	\$761	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor girl's at north	6	299	SF	\$761	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor boy's at south	6	1	EA	\$217	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor girl's at north	6	1	EA	\$217	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor girl's at south	6	1	EA	\$217	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd floor girl's at south	6	1	EA	\$217	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd floor girl's at north	6	1	EA	\$217	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor boy's at north	6	1	EA	\$217	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd floor boy's at south	6	1	EA	\$217	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd floor boy's at north	6	1	EA	\$217	
Staff Restroom	Staff Restroom	Lavatory	1st floor inside office suite next to classroom #104	6	1	EA	\$372	
Staff Restroom	Staff Restroom	Lavatory	1st floor at auditorium, men's & women's	6	2	EA	\$744	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor girl's at south	6	2	EA	\$744	
Staff Restroom	Staff Restroom	Lavatory	1st floor at auditorium, woman's	6	2	EA	\$744	
Staff Restroom	Staff Restroom	Lavatory	1st floor 2 toilets next to engineer's office	5	1	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor boy's at north	6	2	EA	\$744	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor boy's at south	6	2	EA	\$744	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor boy's at south	6	2	EA	\$744	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor boy's at north	6	2	EA	\$744	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor girl's at north	6	2	EA	\$744	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor girl's at south	6	2	EA	\$744	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor girl's at north	6	2	EA	\$744	
Staff Restroom	Staff Restroom	Lavatory	1st floor inside Rm #102	6	2	EA	\$744	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd floor boy's at south	6	4	SF	\$3	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st floor boy's at south	6	4	SF	\$3	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	1st floor at auditorium, men's & women's	4	1	SF	\$4	T-12
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	1st floor inside Rm #102	4	3	SF	\$13	T-12
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	1st floor at auditorium, woman's	4	1	SF	\$4	T-12
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st floor boy's at north	6	4	SF	\$3	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	1st floor 2 toilets next to engineer's office	6	2	SF	\$1	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd floor boy's at north	6	4	SF	\$3	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	1st floor inside office suite next to classroom #104	6	1	SF	\$1	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st floor girl's at north	6	4	SF	\$3	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st floor girl's at south	6	4	SF	\$3	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd floor girl's at north	6	4	SF	\$3	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd floor girl's at south	6	4	SF	\$3	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd floor boy's at north	6	1	EA	\$179	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor girl's at north	6	6	EA	\$1,076	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor girl's at south	6	7	EA	\$1,255	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd floor girl's at south	6	7	EA	\$1,255	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor boy's at north	6	2	EA	\$359	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd floor girl's at north	6	6	EA	\$1,076	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd floor boy's at south	6	2	EA	\$359	
Staff Restroom	Staff Restroom	Partitions	1st floor at auditorium, woman's	6	2	EA	\$359	
Staff Restroom	Staff Restroom	Partitions	1st floor inside Rm #102	6	2	EA	\$359	
Staff Restroom	Staff Restroom	Partitions	1st floor at auditorium, men's & women's	6	2	EA	\$359	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor boy's at south	6	2	EA	\$359	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st floor girl's at south	6	584	SF	\$1,378	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	1st floor inside Rm #102	6	788	SF	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd floor boy's at south	6	569	SF	\$1,343	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	1st floor inside office suite next to classroom #104	5	275	SF	\$1,298	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st floor girl's at north	6	584	SF	\$1,378	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd floor girl's at north	6	584	SF	\$1,378	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd floor boy's at north	6	569	SF	\$1,343	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st floor boy's at south	6	569	SF	\$1,343	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st floor boy's at north	6	569	SF	\$1,343	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	1st floor at auditorium, men's & women's	5	398	SF	\$1,878	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	1st floor 2 toilets next to engineer's office	5	464	SF	\$2,190	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd floor girl's at south	6	584	SF	\$1,378	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd floor girl's at north	6	390	SF	\$2,789	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st floor girl's at north	6	390	SF	\$2,789	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st floor girl's at south	6	390	SF	\$2,789	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd floor girl's at south	6	390	SF	\$2,789	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd floor boy's at north	6	379	SF	\$2,710	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd floor boy's at south	6	379	SF	\$2,710	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st floor boy's at south	6	379	SF	\$2,710	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st floor boy's at north	6	379	SF	\$2,710	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor girl's at south	6	7	EA	\$2,603	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor girl's at south	6	7	EA	\$2,603	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor girl's at north	6	6	EA	\$2,231	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor boy's at north	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor boy's at south	6	2	EA	\$744	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor boy's at south	6	2	EA	\$744	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor boy's at north	6	2	EA	\$744	
Staff Restroom	Staff Restroom	Water Closet	1st floor at auditorium, men's & women's	6	2	EA	\$744	
Staff Restroom	Staff Restroom	Water Closet	1st floor 2 toilets next to engineer's office	5	2	EA	\$3,718	
Staff Restroom	Staff Restroom	Water Closet	1st floor inside Rm #102	6	2	EA	\$744	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Water Closet	1st floor at auditorium, woman's	6	2	EA	\$744	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor girl's at north	6	6	EA	\$2,231	
Staff Restroom	Staff Restroom	Water Closet	1st floor inside office suite next to classroom #104	6	1	EA	\$372	
Theater	Auditorium - Dedicated	Ceiling - Plaster/Drywall	1st Floor	5	3,949	SF	\$39,529	
Theater	Auditorium - Dedicated	Flooring - Concrete	1st Floor	6	3,409	SF	\$16,087	
Theater	Auditorium - Dedicated	Flooring - Wood	1st Floor	6	540	SF	\$4,077	
Theater	Auditorium - Dedicated	Lighting - Pendant/ Surface	1st Floor	6	8	SF	\$13	
Theater	Auditorium - Dedicated	Stage	1st Floor	6	540	SF	\$2,293	
Theater	Auditorium - Dedicated	Wall - Plaster/Drywall	1st Floor	6	6,003	SF	\$51,506	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
INTERIOR Sub Total							\$837,417	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		6	13	LF	\$465	
Casework	Classroom	Casework		6	19	LF	\$679	
Casework	Classroom	Casework		6	16	LF	\$572	
Casework	Classroom	Casework		6	20	LF	\$715	
Casework	Classroom	Casework		6	20	LF	\$715	
Casework	Classroom	Casework		6	20	LF	\$715	
Casework	Classroom	Casework		6	20	LF	\$715	
Casework	Classroom	Casework		6	16	LF	\$572	
Casework	Classroom	Casework		6	13	LF	\$465	
Casework	Classroom	Casework		6	13	LF	\$465	
Casework	Classroom	Casework		6	20	LF	\$715	
Casework	Classroom	Casework		6	16	LF	\$572	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	40	LF	\$1,430	
Casework	Classroom	Casework		6	16	LF	\$572	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		6	16	LF	\$572	
Casework	Classroom	Casework		6	16	LF	\$572	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		6	5	LF	\$179	
Casework	Classroom	Casework		6	16	LF	\$572	
Casework	Classroom	Casework		6	16	LF	\$572	
Casework	Classroom	Casework		6	16	LF	\$572	
Ceiling	Classroom	Lay-In/Drop		6	577	SF	\$1,238	
Ceiling	Classroom	Lay-In/Drop		6	737	SF	\$1,581	
Ceiling	Classroom	Lay-In/Drop		6	1,651	SF	\$3,541	
Ceiling	Classroom	Plaster/Drywall		5	699	SF	\$3,958	
Ceiling	Classroom	Plaster/Drywall		5	740	SF	\$4,190	
Ceiling	Classroom	Plaster/Drywall		5	1,225	SF	\$6,937	
Ceiling	Classroom	Plaster/Drywall		5	821	SF	\$4,649	
Ceiling	Classroom	Plaster/Drywall		5	737	SF	\$4,173	
Ceiling	Classroom	Plaster/Drywall		5	737	SF	\$4,173	
Ceiling	Classroom	Plaster/Drywall		6	90	SF	\$255	
Ceiling	Classroom	Plaster/Drywall		5	737	SF	\$4,173	
Ceiling	Classroom	Plaster/Drywall		5	715	SF	\$4,049	
Ceiling	Classroom	Plaster/Drywall		5	472	SF	\$2,673	
Ceiling	Classroom	Plaster/Drywall		5	811	SF	\$4,593	
Ceiling	Classroom	Plaster/Drywall		5	740	SF	\$4,190	
Ceiling	Classroom	Plaster/Drywall		5	740	SF	\$4,190	
Ceiling	Classroom	Plaster/Drywall		5	740	SF	\$4,190	
Ceiling	Classroom	Plaster/Drywall		5	740	SF	\$4,190	
Ceiling	Classroom	Plaster/Drywall		5	470	SF	\$2,662	
Ceiling	Classroom	Plaster/Drywall		5	740	SF	\$4,190	
Ceiling	Classroom	Plaster/Drywall		5	740	SF	\$4,190	
Ceiling	Classroom	Plaster/Drywall		5	740	SF	\$4,190	
Ceiling	Classroom	Plaster/Drywall		5	740	SF	\$4,190	
Ceiling	Classroom	Plaster/Drywall		5	740	SF	\$4,190	
Ceiling	Classroom	Plaster/Drywall		5	740	SF	\$4,190	
Ceiling	Classroom	Plaster/Drywall		5	740	SF	\$4,190	
Ceiling	Classroom	Plaster/Drywall		5	740	SF	\$4,190	
Chalk Board	Classroom	Chalk Board		4	10	LF	\$1,216	
Chalk Board	Classroom	Chalk Board		4	22	LF	\$2,674	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	10	LF	\$1,216	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	5	LF	\$608	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		6	24	LF	\$686	
Chalk Board	Classroom	Chalk Board		4	6	LF	\$729	
Chalk Board	Classroom	Chalk Board		4	32	LF	\$3,890	
Corridors	Corridors	Lay-In	Entire building stair wells	6	2,511	EA	\$1,795	
Corridors	Corridors	Pendant/Surface	2nd Floor	6	4,602	EA	\$3,290	
Corridors	Corridors	Pendant/Surface	1st Floor	6	4,755	EA	\$3,400	
Corridors	Corridors	Plaster/Drywall	1st Floor	6	5,671	SF	\$13,381	
Corridors	Corridors	Plaster/Drywall	2nd Floor	6	4,692	SF	\$11,071	
Corridors	Corridors	Plaster/Drywall	Entire building stair wells	6	8,817	SF	\$20,804	
Corridors	Corridors	Stair Handrails	Entire building stair wells	6	320	LF	\$0	
Corridors	Corridors	Student Lockers	2nd Floor	6	269	EA	\$38,467	
Corridors	Corridors	Student Lockers	1st Floor	6	205	EA	\$29,315	
Corridors	Corridors	Terrazzo	Entire building stair wells	6	1,976	SF	\$11,190	
Corridors	Corridors	Terrazzo	2nd Floor	6	920	SF	\$5,210	
Corridors	Corridors	Terrazzo	1st Floor	6	1,073	SF	\$6,076	
Corridors	Corridors	Tile/Sheet Flooring	2nd Floor	6	3,682	SF	\$5,265	
Corridors	Corridors	Tile/Sheet Flooring	1st Floor	6	3,682	SF	\$5,265	
Corridors Ceiling	Corridors	Plaster/Drywall	Entire building stair wells	6	2,511	SF	\$7,110	
Corridors Ceiling	Corridors	Plaster/Drywall	1st Floor	5	4,755	SF	\$26,927	
Corridors Ceiling	Corridors	Plaster/Drywall	2nd Floor	6	4,602	SF	\$13,030	
Stairs	Corridors	Terrazzo	Entire building stair wells	6	150	SF	\$1,699	
Floor	Classroom	Tile/Sheet		6	821	SF	\$1,174	
Floor	Classroom	Tile/Sheet		6	470	SF	\$672	
Floor	Classroom	Tile/Sheet		6	1,451	SF	\$2,075	
Floor	Classroom	Wood		6	715	SF	\$5,399	
Floor	Classroom	Wood		6	1,225	SF	\$9,249	
Floor	Classroom	Wood		6	740	SF	\$5,587	
Floor	Classroom	Wood		6	737	SF	\$5,565	
Floor	Classroom	Wood		6	811	SF	\$6,123	
Floor	Classroom	Wood		6	740	SF	\$5,587	
Floor	Classroom	Wood		6	737	SF	\$5,565	
Floor	Classroom	Wood		6	740	SF	\$5,587	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Floor	Classroom	Wood		6	737	SF	\$5,565	
Floor	Classroom	Wood		5	737	SF	\$10,434	
Floor	Classroom	Wood		6	472	SF	\$3,564	
Floor	Classroom	Wood		6	699	SF	\$5,278	
Floor	Classroom	Wood		6	740	SF	\$5,587	
Floor	Classroom	Wood		6	740	SF	\$5,587	
Floor	Classroom	Wood		6	740	SF	\$5,587	
Floor	Classroom	Wood		6	667	SF	\$5,036	
Floor	Classroom	Wood		6	740	SF	\$5,587	
Floor	Classroom	Wood		6	740	SF	\$5,587	
Floor	Classroom	Wood		6	740	SF	\$5,587	
Floor	Classroom	Wood		6	740	SF	\$5,587	
Floor	Classroom	Wood		6	740	SF	\$5,587	
Lighting	Classroom	Pendant/Surface		6	12	EA	\$858	
Lighting	Classroom	Pendant/Surface		4	2	EA	\$787	T-12
Lighting	Classroom	Pendant/Surface		6	18	EA	\$1,287	
Lighting	Classroom	Pendant/Surface		6	12	EA	\$858	
Lighting	Classroom	Pendant/Surface		6	10	EA	\$715	
Lighting	Classroom	Pendant/Surface		6	12	EA	\$858	
Lighting	Classroom	Pendant/Surface		6	6	EA	\$429	
Lighting	Classroom	Pendant/Surface		6	12	EA	\$858	
Lighting	Classroom	Pendant/Surface		6	23	EA	\$1,645	
Lighting	Classroom	Pendant/Surface		6	12	EA	\$858	
Lighting	Classroom	Pendant/Surface		6	12	EA	\$858	
Lighting	Classroom	Pendant/Surface		6	12	EA	\$858	
Lighting	Classroom	Pendant/Surface		6	12	EA	\$858	
Lighting	Classroom	Pendant/Surface		6	12	EA	\$858	
Lighting	Classroom	Pendant/Surface		6	12	EA	\$858	
Lighting	Classroom	Pendant/Surface		6	10	EA	\$715	
Lighting	Classroom	Pendant/Surface		6	12	EA	\$858	
Lighting	Classroom	Pendant/Surface		6	12	EA	\$858	
Lighting	Classroom	Pendant/Surface		6	12	EA	\$858	
Lighting	Classroom	Pendant/Surface		6	13	EA	\$930	
Lighting	Classroom	Pendant/Surface		6	12	EA	\$858	
Lighting	Classroom	Pendant/Surface		6	6	EA	\$429	
Lighting	Classroom	Pendant/Surface		6	10	EA	\$715	
Lighting	Classroom	Pendant/Surface		6	8	EA	\$572	
Lighting	Classroom	Pendant/Surface		6	12	EA	\$858	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting	Classroom	Pendant/Surface		6	12	EA	\$858	
Marker Board	Classroom	Marker Board		6	12	LF	\$343	
Marker Board	Classroom	Marker Board		6	18	LF	\$515	
Marker Board	Classroom	Marker Board		6	16	LF	\$458	
Marker Board	Classroom	Marker Board		6	16	LF	\$458	
Marker Board	Classroom	Marker Board		6	12	LF	\$343	
Marker Board	Classroom	Marker Board		6	28	LF	\$801	
Marker Board	Classroom	Marker Board		6	10	LF	\$286	
Marker Board	Classroom	Marker Board		6	12	LF	\$343	
Marker Board	Classroom	Marker Board		6	20	LF	\$572	
Marker Board	Classroom	Marker Board		6	10	LF	\$286	
Marker Board	Classroom	Marker Board		6	8	LF	\$229	
Marker Board	Classroom	Marker Board		6	30	LF	\$858	
Marker Board	Classroom	Marker Board		6	20	LF	\$572	
Marker Board	Classroom	Marker Board		6	18	LF	\$515	
Marker Board	Classroom	Marker Board		6	18	LF	\$515	
Marker Board	Classroom	Marker Board		6	10	LF	\$286	
Marker Board	Classroom	Marker Board		6	38	LF	\$1,087	
Marker Board	Classroom	Marker Board		6	22	LF	\$629	
Marker Board	Classroom	Marker Board		6	12	LF	\$343	
Marker Board	Classroom	Marker Board		6	12	LF	\$343	
Marker Board	Classroom	Marker Board		6	28	LF	\$801	
Marker Board	Classroom	Marker Board		6	20	LF	\$572	
RESTROOM_WALL	Staff Restroom	Restroom Walls	1st floor at auditorium, woman's	5	450	SF	\$7,079	
Wall	Classroom	Plaster/Drywall		6	1,651	SF	\$3,896	
Wall	Classroom	Plaster/Drywall		5	1,216	SF	\$5,738	
Wall	Classroom	Plaster/Drywall		5	1,210	SF	\$5,710	
Wall	Classroom	Plaster/Drywall		5	1,210	SF	\$5,710	
Wall	Classroom	Plaster/Drywall		5	1,210	SF	\$5,710	
Wall	Classroom	Plaster/Drywall		5	1,210	SF	\$5,710	
Wall	Classroom	Plaster/Drywall		5	1,210	SF	\$5,710	
Wall	Classroom	Plaster/Drywall		5	1,210	SF	\$5,710	
Wall	Classroom	Plaster/Drywall		5	1,210	SF	\$5,710	
Wall	Classroom	Plaster/Drywall		5	1,210	SF	\$5,710	
Wall	Classroom	Plaster/Drywall		5	1,599	SF	\$7,546	
Wall	Classroom	Plaster/Drywall		5	1,210	SF	\$5,710	
Wall	Classroom	Plaster/Drywall		5	1,210	SF	\$5,710	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Plaster/Drywall		5	1,078	SF	\$5,087	
Wall	Classroom	Plaster/Drywall		5	1,316	SF	\$6,210	
Wall	Classroom	Plaster/Drywall		5	1,173	SF	\$5,535	
Wall	Classroom	Plaster/Drywall		5	1,160	SF	\$5,474	
Wall	Classroom	Plaster/Drywall		5	1,247	SF	\$5,885	
Wall	Classroom	Plaster/Drywall		5	1,424	SF	\$6,720	
Wall	Classroom	Plaster/Drywall		5	1,188	SF	\$5,606	
Wall	Classroom	Plaster/Drywall		5	1,173	SF	\$5,535	
Wall	Classroom	Plaster/Drywall		5	1,201	SF	\$5,668	
Wall	Classroom	Plaster/Drywall		5	1,040	SF	\$4,908	
Wall	Classroom	Plaster/Drywall		5	1,210	SF	\$5,710	
ROOM Sub Total							\$645,504	
Building Main Sub Total							\$4,763,075	

Building: Addition
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Canopy		Concrete/ Stucco Canopy	Main Entrance	7	143	SF	\$0	
Doors		Exterior Steel Door	Entire Building	6	8	EA	\$2,643	
Doors		Store Front Door	Entire Building	6	11	EA	\$5,710	
Entrance		Entrance Controls - Audio and Video	Entire Building	6	2	EA	\$2,860	
Entrance		Power Door Operator and Controls	Main, south entrances	7	3	EA	\$0	
Foundation		Concrete Foundation	Entire Building	7	902	LF	\$0	
Foundation		Concrete Foundation	Trash enclosure	7	91	LF	\$0	
Lighting		Exterior Lights - Parapet or Roof Mounted	Entire Building	7	14	EA	\$0	
Lighting		Exterior Lights - Parapet or Roof Mounted	Main Entrance	6	2	EA	\$1,001	
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	12	EA	\$2,574	
Lintels		Lintels - Steel	Entire Building	7	853	LF	\$0	
Parapet		Coping - Stone	Entire Building	7	978	LF	\$0	
Parapet		Coping - Stone	Trash enclosure	7	91	LF	\$0	
Parapet		Parapet > 30" Height	Main Roof	7	827	LF	\$0	
Parapet		Parapet 16" to 30" Height	Low roof, main roof crenels	7	149	LF	\$0	
Roof System		Interior Downspouts	Entire Building	6	929	LF	\$0	
Roof System		Modified Bitumen Roof	Roof	6	32,978	SF	\$233,435	
Roof System		Roof Structure: Steel/Metal Deck/Concrete Topping	Entire Building	7	32,835	SF	\$0	

Building: Addition
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Superstructure		Steel	Entire Building	7	64,346	SF	\$0	
Walls		Brick	Entire Building	7	29,819	SF	\$0	
Walls		Brick	Trash enclosure	6	819	SF	\$5,411	
Walls		Stone - Cast	Entire Building	7	4,510	SF	\$0	
Windows		Storefront Windows	Entrances	7	170	SF	\$0	
Windows		Window - Guards perforated	1st Floor	7	711	SF	\$0	
Windows		Windows - Sash Aluminum Double-pane	Entire Building	7	6,968	SF	\$0	
EXTERIOR Sub Total							\$253,633	

Building: Addition
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	Electrical Room	6	2	EA	\$2,860	
Emergency System		Emergency A/C power - Corridors and Stairs	Corridors and Stairs	7	15,093	SF	\$0	
Emergency System		Emergency A/C power - Gym and Lunch rooms	Lunch Room	7	5,166	SF	\$0	
Emergency System		Emergency A/C power - Students Toilets	Student Toilets	7	1,952	SF	\$0	
Emergency System		Emergency generator 100 to 150 KW diesel - Outdoor	Courtyard	6	1	EA	\$11,440	
Emergency System		Exit Signs - Corridors and Stairs	Corridors and Stairs	7	19	EA	\$0	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	Lunch Room	7	5	EA	\$0	
Emergency System		Public Announcement System	Main Office	4	64,346	SF	\$228,197	
Emergency System		Security System - CCTV	Entire Building	5	64,346	SF	\$184,030	
Emergency System		Security System - Intrusion detection	MDF Room	6	64,346	SF	\$59,810	
Main Service		Main Electrical service - Live Front - 2000 A 277/480/3PH	Electrical Room	6	1	EA	\$15,194	
Power Distribution		Lighting and power panels	Entire Building	6	22	EA	\$15,730	
Power Distribution		Main distribution panels 400-600 amp	Electrical Room	6	4	EA	\$5,720	
Power Distribution		Main distribution panels above 600 amp	Electrical Room	6	3	EA	\$6,435	
Power Distribution		Main distribution panels less than 400 amp	Electrical Room	6	1	EA	\$1,216	
Power Distribution		Transformers 277/480-120/208	Entire Building	7	4	EA	\$0	
ELECTRICAL Sub Total							\$530,630	

Building: Addition
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Entire Building	7	64,346	SF	\$0	
Fire Alarm		Fire Alarm System	Mechanical Room	7	64,346	SF	\$0	

Building: Addition
Category: FIRE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Pump Controller	Mechanical Room	7	1	EA	\$0	
Pump Room Assembly		Fire Pump 25-50hp	Mechanical Room	7	1	EA	\$0	
Pump Room Assembly		Jockey Pump	Mechanical Room	7	1	EA	\$0	
Sprinkler System		Sprinkler Heads	Entire Building	7	64,346	SF	\$0	
Sprinkler System		Wet Sprinkler System	Entire Building	7	64,346	SF	\$0	
FIRE PROTECTION Sub Total							\$0	

Building: Addition
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Condensing Unit - Roof Mounted less than 5 tons	Roof	6	2	EA	\$1,716	
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water 4,000 to 8,000 cfm	Mechanical Room	6	1	EA	\$5,005	VFD Module on Supply Fan has failed.
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water 12,001 to 20,000 cfm	Mechanical Room	6	1	EA	\$7,579	
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water above 30,000 cfm	Mechanical Room	6	1	EA	\$21,450	
Air Handling Systems		Air intake for all Air Handling Units except built up AHU	Roof	7	3	EA	\$0	
Air Handling Systems		Variable Air Volume (VAV) Box With Hot Water Coil	Entire Building	6	48	EA	\$15,787	
Heating Devices		Cabinet Heaters With Hot Water Coils	Entire Building	6	8	EA	\$4,004	
Heating Devices		Unit Heater - Electric	Mechanical Room	6	2	EA	\$2,860	
Heating Devices		Unit Heater - Hot Water	Mechanical Room	6	2	EA	\$2,860	
Mechanical Plumbing		Piping - Hydronic Supply and Return - Steel or Galvanized	Entire Building	6	1,000	LF	\$8,866	Glycol Leaks at piping joints in Boiler Room 4 pipe system
Temperature Control		Direct Digital Control (DDC) System	Entire Building	7	64,346	SF	\$0	
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	6	57	EA	\$8,151	
Ventilation		Exhaust Fan - Indoor	Mechanical Room	6	2	EA	\$1,001	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	6	3	EA	\$1,287	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	6	1	EA	\$229	
Ventilation		Exhaust Fans - Roof mounted less than 500 CFM	Roof	6	2	EA	\$315	
Ventilation		Type I Exhaust Hood - Kitchen or Culinary Arts	Kitchen	7	1	EA	\$0	
Ventilation		Type II Exhaust Hood - Warming Kitchen	Kitchen	7	1	EA	\$0	
MECHANICAL Sub Total							\$81,110	

Building: Addition
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
-------	-----------	------	----------	------	----------	------	------	--------

Building: Addition
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	7	64,346	SF	\$0	
Piping		Domestic Piping - Cold Water Risers	Entire Building	7	64,346	SF	\$0	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	7	64,346	SF	\$0	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	7	64,346	SF	\$0	
Piping		Domestic Piping - Hot Water Risers	Entire Building	7	64,346	SF	\$0	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	7	64,346	SF	\$0	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	7	64,346	SF	\$0	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	7	64,346	SF	\$0	
Piping		Sanitary Piping	Entire Building	7	64,346	SF	\$0	
Piping		Storm Piping	Entire Building	7	64,346	SF	\$0	
Piping		Vent Piping	Entire Building	7	64,346	SF	\$0	
Pumps		Domestic Booster Pump duplex	Mechanical Room	7	1	EA	\$0	
Pumps		Sump Pump	Elevator Pit	7	1	EA	\$0	

PLUMBING Sub Total \$0

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	First floor, main office, principal office	7	171	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Second floor, inside library	7	219	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	First floor, South end, engineer's office	7	207	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	First floor, kitchen office	7	94	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	First floor, main office, teachers lounge	7	298	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	First floor, main office, asst. principal office	7	171	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	First floor, north end, student services	7	136	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	First floor, main office	7	732	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	First floor, main office	7	602	SF	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	First floor, main office, principal office	7	171	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Second floor, inside library	7	219	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	First floor, north end, student services	7	136	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	First floor, main office,asst. principal office	7	171	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	First floor, kitchen office	7	94	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	First floor, main office, teachers lounge	7	298	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	First floor, main office	6	130	SF	\$186	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	First floor,South end, engineer's office	6	207	SF	\$296	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	First floor, main office, principal office	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	First floor, north end, student services	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	First floor, main office	7	17	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	First floor, main office,asst. principal office	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Second floor, inside library	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	First floor, kitchen office	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	First floor, main office, teachers lounge	7	6	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	First floor,South end, engineer's office	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	First floor, north end, student services	6	283	SF	\$809	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	First floor, main office	6	802	SF	\$2,294	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	First floor, main office, principal office	6	179	SF	\$512	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	First floor, main office,asst. principal office	6	179	SF	\$512	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	First floor, main office, teachers lounge	6	216	SF	\$618	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	First floor,South end, engineer's office	6	520	SF	\$1,487	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Second floor, inside library	6	684	SF	\$1,956	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	First floor, kitchen office	6	448	SF	\$1,281	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	First floor, main office	6	1,200	SF	\$2,831	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	First floor, north end, student services	6	283	SF	\$668	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	First floor, main office, principal office	6	455	SF	\$1,074	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	First floor, main office, asst. principal office	6	455	SF	\$1,074	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	First floor, main office, teachers lounge	6	698	SF	\$1,647	
Doors		Interior Steel Doors incl hw	1st Floor	6	6	EA	\$1,699	
Doors		Interior Steel Doors incl hw	2nd Floor	7	4	EA	\$0	
Doors		Interior Wood Doors incl hw	1st Floor	7	63	EA	\$0	
Doors		Interior Wood Doors incl hw	2nd Floor	7	35	EA	\$0	
Doors		Side-lite	2nd Floor	7	192	SF	\$0	
Doors		Side-lite	1st Floor	7	103	SF	\$0	
Doors		Store Front Door	1st Floor	7	3	EA	\$0	
Drinking Fountains	Corridors	Triple Fountain	1st Floor	7	1	EA	\$0	
Kitchen	Cooking Kitchen	Ceiling - Lay-In	1st Floor	6	2,335	SF	\$6,678	
Kitchen	Cooking Kitchen	Flooring - Concrete	1st Floor	6	2,335	SF	\$11,019	
Kitchen	Cooking Kitchen	Lighting - Lay-In	1st Floor	6	29	SF	\$21	
Kitchen	Cooking Kitchen	Wall - Concrete Block	1st Floor	6	3,132	SF	\$8,958	
Library	Library	Flooring Carpet	2nd Floor	7	2,756	SF	\$0	
Library	Library	Lighting - Lay-In	2nd Floor	6	59	SF	\$42	
Lunchroom	Lunchroom	Ceiling - Lay-In	1st Floor	7	5,166	SF	\$0	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	1st Floor	6	5,166	SF	\$7,387	
Lunchroom	Lunchroom	Lighting - Lay-In	1st Floor	6	67	SF	\$48	
Lunchroom	Cooking Kitchen	Serving Line	1st Floor	6	60	LF	\$2,574	
Lunchroom	Lunchroom	Wall - Concrete Block	1st Floor	6	3,922	SF	\$11,217	
MDF/IDF		Finishes	Second floor, north end	6	108	SF	\$368	
MDF/IDF		Ventilation and Cooling	Second floor, north end	7	1	EA	\$0	
Mechanical/Service Rooms		Janitor's Closet	2nd Floor	6	1	SF	\$5	
Mechanical/Service Rooms		Janitor's Closet	1st Floor	6	2	SF	\$9	
Mechanical/Service Rooms		Mechanical/Service Rooms	First floor, south end	6	481	SF	\$2,270	
Mechanical/Service Rooms		Mechanical/Service Rooms	First floor, kitchen, electrical room	6	298	SF	\$1,406	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Mechanical/Service Rooms		Mechanical/Service Rooms	Second floor, north end	6	70	SF	\$330	
Mechanical/Service Rooms		Mechanical/Service Rooms	First floor, kitchen, ATS room	6	114	SF	\$538	
Mechanical/Service Rooms		Mechanical/Service Rooms	First floor, kitchen, dish wash room	6	57	SF	\$269	
Mechanical/Service Rooms		Mechanical/Service Rooms	Second floor, north end	6	2,728	SF	\$12,873	
Mechanical/Service Rooms		Mechanical/Service Rooms	First floor, North end	6	115	SF	\$543	
Mechanical/Service Rooms		Storage Room	First floor, room 165	7	58	SF	\$0	
Mechanical/Service Rooms		Storage Room	Second floor, north end	6	80	SF	\$378	
Mechanical/Service Rooms		Storage Room	Second floor, inside library	7	153	SF	\$0	
Mechanical/Service Rooms		Storage Room	First floor, North end	6	80	SF	\$378	
Mechanical/Service Rooms		Storage Room	Second floor, inside of room 260	6	184	SF	\$868	
Mechanical/Service Rooms		Storage Room	First floor, room 162	7	196	SF	\$0	
Mechanical/Service Rooms		Storage Room	First floor, room 168	6	58	SF	\$274	
Mechanical/Service Rooms		Storage Room	First floor, room 167	7	60	SF	\$0	
Mechanical/Service Rooms		Storage Room	First floor, room 166	6	60	SF	\$283	
Mechanical/Service Rooms		Storage Room	First floor, room 169	6	58	SF	\$274	
Mechanical/Service Rooms		Storage Room	First floor, south end, yard storage	6	228	SF	\$1,076	
Mechanical/Service Rooms		Storage Room	main office, storage room	6	253	SF	\$1,194	
Mechanical/Service Rooms		Storage Room	First floor, lunchroom	6	70	SF	\$330	
Mechanical/Service Rooms		Storage Room	kitchen sstorage	6	361	SF	\$1,704	
Staff Restroom	Staff Restroom	Accessories	First floor, kitchen bathroom, Womens	6	57	SF	\$440	
Staff Restroom	Staff Restroom	Accessories	Second floor, north end, staff bathroom	6	60	SF	\$463	
Staff Restroom	Staff Restroom	Accessories	First floor, kitchen bathroom, Men's	6	57	SF	\$440	
Staff Restroom	Early Childhood Student Restroom	Accessories	first floor, room 167	6	70	SF	\$541	
Staff Restroom	Early Childhood Student Restroom	Accessories	first floor, room 165	6	70	SF	\$541	
Staff Restroom	Staff Restroom	Accessories	First floor, main office	6	44	SF	\$340	
Staff Restroom	Early Childhood Student Restroom	Accessories	first floor, room 169	6	70	SF	\$541	
Staff Restroom	Children's Standard Student Restroom	Accessories	Second floor, south end, boys	6	280	SF	\$2,162	
Staff Restroom	Early Childhood Student Restroom	Accessories	first floor, room 166	6	70	SF	\$541	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Accessories	Second floor, north end, girls	6	351	SF	\$2,710	
Staff Restroom	Children's Standard Student Restroom	Accessories	Second floor, north end, boys	6	345	SF	\$2,664	
Staff Restroom	Early Childhood Student Restroom	Accessories	first floor, room 168	6	70	SF	\$541	
Staff Restroom	Children's Standard Student Restroom	Accessories	First floor, north end, girls	6	351	SF	\$2,710	
Staff Restroom	Children's Standard Student Restroom	Accessories	Second floor, south end, Girls	6	280	SF	\$2,162	
Staff Restroom	Staff Restroom	Accessories	First floor, north end, staff bathroom	6	60	SF	\$463	
Staff Restroom	Children's Standard Student Restroom	Accessories	first floor, north end, boys	6	345	SF	\$2,664	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	Second floor, north end, staff bathroom	7	60	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	first floor, room 165	7	70	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	First floor, north end, staff bathroom	7	60	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	first floor, room 166	7	70	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	first floor, room 168	7	70	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	First floor, kitchen bathroom, Womens	7	57	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	First floor, main office	7	44	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	first floor, room 169	7	70	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	First floor, kitchen bathroom, Men's	7	57	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	first floor, room 167	7	70	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	Second floor, north end, girls	7	351	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	first floor, north end, boys	7	345	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	Second floor, south end, Girls	7	280	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	First floor, north end, girls	7	351	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	Second floor, north end, boys	7	345	SF	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	Second floor, south end, boys	7	280	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	Second floor, north end, girls	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	First floor, main office	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	First floor, kitchen bathroom, Men's	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	First floor, kitchen bathroom, Womens	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	first floor, room 169	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	first floor, room 166	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	first floor, room 167	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	first floor, room 168	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	Second floor, north end, boys	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	Second floor, north end, staff bathroom	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	Second floor, south end, boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	Second floor, south end, Girls	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	First floor, north end, staff bathroom	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	first floor, north end, boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	First floor, north end, girls	7	2	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	first floor, room 165	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	Second floor, north end, girls	6	351	SF	\$893	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	First floor, north end, staff bathroom	6	60	SF	\$153	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	first floor, north end, boys	6	345	SF	\$878	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	First floor, north end, girls	6	351	SF	\$893	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	First floor, main office	6	44	SF	\$112	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	First floor, kitchen bathroom, Men's	6	57	SF	\$145	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	First floor, kitchen bathroom, Womens	6	57	SF	\$145	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile Ceramic/Porcelain	first floor, room 169	6	70	SF	\$178	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile Ceramic/Porcelain	first floor, room 166	6	70	SF	\$178	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile Ceramic/Porcelain	first floor, room 167	6	70	SF	\$178	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile Ceramic/Porcelain	first floor, room 168	6	70	SF	\$178	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	Second floor, north end, boys	6	345	SF	\$878	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	Second floor, north end, staff bathroom	6	60	SF	\$153	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	Second floor, south end, boys	6	280	SF	\$713	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	Second floor, south end, Girls	6	280	SF	\$713	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile Ceramic/Porcelain	first floor, room 165	6	70	SF	\$178	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	first floor, north end, boys	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	Second floor, south end, Girls	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	Second floor, south end, boys	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	Second floor, north end, boys	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	Second floor, north end, girls	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	First floor, north end, girls	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	First floor, main office	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Lavatory	First floor, north end, girls	6	4	EA	\$1,487	
Staff Restroom	Early Childhood Student Restroom	Lavatory	first floor, room 168	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	Second floor, north end, girls	6	4	EA	\$1,487	
Staff Restroom	Staff Restroom	Lavatory	Second floor, north end, staff bathroom	6	1	EA	\$372	
Staff Restroom	Early Childhood Student Restroom	Lavatory	first floor, room 169	7	1	EA	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Early Childhood Student Restroom	Lavatory	first floor, room 166	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	Second floor, north end, boys	6	4	EA	\$1,487	
Staff Restroom	Staff Restroom	Lavatory	First floor, kitchen bathroom, Men's	6	1	EA	\$372	
Staff Restroom	Staff Restroom	Lavatory	First floor, north end, staff bathroom	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Lavatory	Second floor, south end, boys	6	4	EA	\$1,487	
Staff Restroom	Early Childhood Student Restroom	Lavatory	first floor, room 167	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	first floor, room 165	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	first floor, north end, boys	6	4	EA	\$1,487	
Staff Restroom	Children's Standard Student Restroom	Lavatory	Second floor, south end, Girls	6	4	EA	\$1,487	
Staff Restroom	Staff Restroom	Lavatory	First floor, kitchen bathroom, Womens	6	1	EA	\$372	
Staff Restroom	Staff Restroom	Lighting - Lay-In	First floor, kitchen bathroom, Womens	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	first floor, north end, boys	7	11	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	First floor, north end, staff bathroom	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	Second floor, south end, boys	7	9	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	Second floor, south end, Girls	7	9	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	First floor, kitchen bathroom, Men's	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	First floor, north end, girls	7	11	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	first floor, room 169	7	1	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	first floor, room 166	7	1	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	first floor, room 167	7	1	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	first floor, room 165	7	1	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	first floor, room 168	7	1	SF	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	Second floor, north end, girls	7	11	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	Second floor, north end, boys	7	11	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	Second floor, north end, staff bathroom	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	First floor, main office	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	Second floor, south end, Girls	7	7	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	Second floor, south end, boys	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	Second floor, north end, boys	7	6	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	Second floor, north end, girls	7	9	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	first floor, north end, boys	7	6	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	First floor, north end, girls	7	9	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	Second floor, south end, boys	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	Second floor, north end, staff bathroom	6	248	SF	\$709	
Staff Restroom	Staff Restroom	Wall - Concrete Block	First floor, kitchen bathroom, Men's	6	240	SF	\$686	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	Second floor, north end, girls	6	654	SF	\$1,870	
Staff Restroom	Early Childhood Student Restroom	Wall - Concrete Block	first floor, room 168	6	266	SF	\$761	
Staff Restroom	Early Childhood Student Restroom	Wall - Concrete Block	first floor, room 165	6	266	SF	\$761	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	Second floor, north end, boys	6	654	SF	\$1,870	
Staff Restroom	Early Childhood Student Restroom	Wall - Concrete Block	first floor, room 167	6	266	SF	\$761	
Staff Restroom	Early Childhood Student Restroom	Wall - Concrete Block	first floor, room 166	6	266	SF	\$761	
Staff Restroom	Staff Restroom	Wall - Concrete Block	First floor, kitchen bathroom, Womens	6	240	SF	\$686	
Staff Restroom	Staff Restroom	Wall - Concrete Block	First floor, main office	6	216	SF	\$618	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	First floor, north end, girls	6	654	SF	\$1,870	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	first floor, north end, boys	6	654	SF	\$1,870	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Wall - Concrete Block	First floor, north end, staff bathroom	6	248	SF	\$709	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	Second floor, south end, boys	6	570	SF	\$1,630	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	Second floor, south end, Girls	6	570	SF	\$1,630	
Staff Restroom	Early Childhood Student Restroom	Wall - Concrete Block	first floor, room 169	6	266	SF	\$761	
Staff Restroom	Children's Standard Student Restroom	Water Closet	Second floor, north end, boys	7	6	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	Second floor, south end, Girls	7	7	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	first floor, room 169	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	Second floor, north end, staff bathroom	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	First floor, kitchen bathroom, Womens	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	Second floor, north end, girls	5	1	EA	\$1,859	Out of order
Staff Restroom	Children's Standard Student Restroom	Water Closet	Second floor, north end, girls	7	8	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	first floor, room 168	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	first floor, room 165	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	first floor, room 167	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	First floor, north end, staff bathroom	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	First floor, north end, girls	5	1	EA	\$1,859	Out of order
Staff Restroom	Early Childhood Student Restroom	Water Closet	first floor, room 166	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	First floor, main office	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	first floor, north end, boys	7	6	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	First floor, kitchen bathroom, Men's	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	Second floor, south end, boys	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	First floor, north end, girls	7	8	EA	\$0	
Vertical Conveyance		Elevator - Roped Holeless Hydraulic	North end of building	7	1	EA	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		6	2	EA	\$772	
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	

INTERIOR Sub Total \$151,973

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		7	50	LF	\$0	
Casework	Classroom	Casework		7	50	LF	\$0	
Casework	Classroom	Casework		7	45	LF	\$0	
Casework	Classroom	Casework		7	50	LF	\$0	
Casework	Classroom	Casework		7	50	LF	\$0	
Casework	Classroom	Casework		7	44	LF	\$0	
Casework	Classroom	Casework		7	50	LF	\$0	
Casework	Classroom	Casework		7	45	LF	\$0	
Casework	Classroom	Casework		7	50	LF	\$0	
Casework	Classroom	Casework		7	50	LF	\$0	
Casework	Classroom	Casework		7	50	LF	\$0	
Casework	Classroom	Casework		7	50	LF	\$0	
Casework	Classroom	Casework		7	50	LF	\$0	
Casework	Classroom	Casework		7	27	LF	\$0	
Casework	Classroom	Casework		7	50	LF	\$0	
Casework	Classroom	Casework		7	50	LF	\$0	
Casework	Classroom	Casework		7	26	LF	\$0	
Casework	Classroom	Casework		7	26	LF	\$0	
Casework	Classroom	Casework		7	26	LF	\$0	
Casework	Classroom	Casework		7	26	LF	\$0	
Casework	Classroom	Casework		7	26	LF	\$0	
Casework	Classroom	Casework		7	26	LF	\$0	
Casework	Classroom	Casework		7	50	LF	\$0	
Casework	Classroom	Casework		7	50	LF	\$0	
Casework	Classroom	Casework		7	50	LF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,213	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	900	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	900	SF	\$0	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Ceiling	Classroom	Lay-In/Drop		7	1,365	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	923	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,213	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	960	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,213	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,213	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	920	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	900	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,340	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	905	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	890	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	954	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,213	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	925	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	900	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	900	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	925	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	920	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	890	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	925	SF	\$0	
Chalk Board	Classroom	Chalk Board		4		LF		
CLASSROOM	Classroom	Eye Wash Station		7	2	EA	\$0	
CLASSROOM	Classroom	Science Lab Elements		7	1,365	SF	\$0	
Corridors	Corridors	Ceiling	Stairs entire building		1,344	SF	\$0	
Corridors	Corridors	Concrete Block	1st Floor	6	9,616	SF	\$27,502	
Corridors	Corridors	Concrete Block	2nd Floor	6	9,804	SF	\$28,039	
Corridors	Corridors	Concrete Block	Stairs entire building	7	7,151	SF	\$0	
Corridors	Corridors	Drop/Lay-In	2nd Floor	7	5,709	SF	\$0	
Corridors	Corridors	Drop/Lay-In	1st Floor	6	7,443	SF	\$15,965	
Corridors	Corridors	Lay-In	1st Floor	6	8,040	EA	\$5,749	
Corridors	Corridors	Lay-In	2nd Floor	6	5,709	EA	\$4,082	
Corridors	Corridors	Lay-In	Stairs entire building	7	1,344	EA	\$0	
Corridors	Corridors	Stair Handrails	Stairs entire building	7	225	LF	\$0	
Corridors	Corridors	Student Lockers	2nd Floor	7	268	EA	\$0	
Corridors	Corridors	Terrazzo	1st Floor	7	8,040	SF	\$0	
Corridors	Corridors	Terrazzo	Stairs entire building	7	2,113	SF	\$0	
Corridors	Corridors	Terrazzo	2nd Floor	7	5,709	SF	\$0	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Triple Water Cooler	2nd Floor	7	2	EA	\$0	
Corridors	Corridors	Wall Mounted	Stairs entire building	6	1,344	EA	\$518,918	
Corridors Ceiling	Corridors	Plaster/Drywall	1st Floor	7	597	SF	\$0	
Stairs	Corridors	Terrazzo	Stairs entire building	7	85	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,213	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,213	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,213	SF	\$0	
Floor	Classroom	Tile/Sheet		7	923	SF	\$0	
Floor	Classroom	Tile/Sheet		7	920	SF	\$0	
Floor	Classroom	Tile/Sheet		7	954	SF	\$0	
Floor	Classroom	Tile/Sheet		7	900	SF	\$0	
Floor	Classroom	Tile/Sheet		6	890	SF	\$1,273	
Floor	Classroom	Tile/Sheet		7	925	SF	\$0	
Floor	Classroom	Tile/Sheet		6	920	SF	\$1,316	
Floor	Classroom	Tile/Sheet		6	925	SF	\$1,323	
Floor	Classroom	Tile/Sheet		6	890	SF	\$1,273	
Floor	Classroom	Tile/Sheet		6	905	SF	\$1,294	
Floor	Classroom	Tile/Sheet		6	925	SF	\$1,323	
Floor	Classroom	Tile/Sheet		7	900	SF	\$0	
Floor	Classroom	Tile/Sheet		6	1,340	SF	\$1,916	
Floor	Classroom	Tile/Sheet		7	1,213	SF	\$0	
Floor	Classroom	Tile/Sheet		6	900	SF	\$1,287	
Floor	Classroom	Tile/Sheet		7	900	SF	\$0	
Floor	Classroom	Tile/Sheet		7	900	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,213	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,365	SF	\$0	
Floor	Classroom	Tile/Sheet		6	960	SF	\$1,373	
LIBRARY_CEILING	Library	Drop/Lay-In	2nd Floor	7	2,756	SF	\$0	
LIBRARY_WALL	Library	Concrete Block	2nd Floor	6	2,626	SF	\$7,510	
Lighting	Classroom	Lay-In		7	11	EA	\$0	
Lighting	Classroom	Lay-In		7	14	EA	\$0	
Lighting	Classroom	Lay-In		7	14	EA	\$0	
Lighting	Classroom	Lay-In		7	14	EA	\$0	
Lighting	Classroom	Lay-In		7	14	EA	\$0	
Lighting	Classroom	Lay-In		7	11	EA	\$0	
Lighting	Classroom	Lay-In		7	11	EA	\$0	
Lighting	Classroom	Lay-In		7	11	EA	\$0	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting	Classroom	Lay-In		7	11	EA	\$0	
Lighting	Classroom	Lay-In		7	11	EA	\$0	
Lighting	Classroom	Lay-In		7	14	EA	\$0	
Lighting	Classroom	Lay-In		7	11	EA	\$0	
Lighting	Classroom	Lay-In		6	18	EA	\$1,287	
Lighting	Classroom	Lay-In		7	11	EA	\$0	
Lighting	Classroom	Lay-In		7	11	EA	\$0	
Lighting	Classroom	Lay-In		7	11	EA	\$0	
Lighting	Classroom	Lay-In		7	11	EA	\$0	
Lighting	Classroom	Lay-In		7	11	EA	\$0	
Lighting	Classroom	Lay-In		7	11	EA	\$0	
Lighting	Classroom	Lay-In		7	11	EA	\$0	
Lighting	Classroom	Lay-In		7	18	EA	\$0	
Lighting	Classroom	Lay-In		7	11	EA	\$0	
Lighting	Classroom	Lay-In		7	11	EA	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		6	24	LF	\$686	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Wall	Classroom	Concrete Block		6	1,223	SF	\$3,498	
Wall	Classroom	Concrete Block		6	502	SF	\$1,436	
Wall	Classroom	Concrete Block		6	873	SF	\$2,497	
Wall	Classroom	Concrete Block		6	502	SF	\$1,436	
Wall	Classroom	Concrete Block		6	490	SF	\$1,401	
Wall	Classroom	Concrete Block		6	502	SF	\$1,436	
Wall	Classroom	Concrete Block		6	502	SF	\$1,436	
Wall	Classroom	Concrete Block		6	1,224	SF	\$3,501	
Wall	Classroom	Concrete Block		6	851	SF	\$2,434	
Wall	Classroom	Concrete Block		6	496	SF	\$1,419	
Wall	Classroom	Concrete Block		6	837	SF	\$2,394	
Wall	Classroom	Concrete Block		6	1,224	SF	\$3,501	
Wall	Classroom	Concrete Block		6	1,264	SF	\$3,615	
Wall	Classroom	Concrete Block		6	502	SF	\$1,436	
Wall	Classroom	Concrete Block		6	1,746	SF	\$4,994	
Wall	Classroom	Concrete Block		6	1,224	SF	\$3,501	
Wall	Classroom	Concrete Block		6	1,234	SF	\$3,529	
Wall	Classroom	Concrete Block		6	1,224	SF	\$3,501	
Wall	Classroom	Concrete Block		6	1,516	SF	\$4,336	
Wall	Classroom	Concrete Block		6	851	SF	\$2,434	
Wall	Classroom	Concrete Block		6	597	SF	\$1,707	
Wall	Classroom	Concrete Block		6	1,223	SF	\$3,498	
Wall	Classroom	Concrete Block		6	1,503	SF	\$4,299	
Wall	Classroom	Plaster/Drywall		6	742	SF	\$1,751	
Wall	Classroom	Plaster/Drywall		6	742	SF	\$1,751	
Wall	Classroom	Plaster/Drywall		6	279	SF	\$658	
Wall	Classroom	Plaster/Drywall		6	279	SF	\$658	
Wall	Classroom	Plaster/Drywall		6	861	SF	\$2,032	
Wall	Classroom	Plaster/Drywall		6	742	SF	\$1,751	
Wall	Classroom	Plaster/Drywall		6	742	SF	\$1,751	
Wall	Classroom	Plaster/Drywall		6	742	SF	\$1,751	
Wall	Classroom	Plaster/Drywall		6	742	SF	\$1,751	
Wall	Classroom	Plaster/Drywall		6	371	SF	\$875	
Wall	Classroom	Plaster/Drywall		6	742	SF	\$1,751	
Wall	Classroom	Plaster/Drywall		6	371	SF	\$875	
Wall	Classroom	Plaster/Drywall		6	371	SF	\$875	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Plaster/Drywall		6	279	SF	\$658	
Wall	Classroom	Plaster/Drywall		6	279	SF	\$658	
Wall	Classroom	Plaster/Drywall		6	371	SF	\$875	
ROOM Sub Total							\$705,772	
Building Addition Sub Total							\$1,723,118	

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Civil/Drainage		Catch Basin	Entire Site	6	13	EA	\$7,064	
Civil/Drainage		Site Manhole	Entire Site	7	12	EA	\$0	
Fencing		Guard Rail	North areaway	6	51	LF	\$1,444	
Fencing		Ornamental Iron	Entire Site	6	1,806	LF	\$34,090	
Landscape		Grass	Entire Site	6	49,312	SF	\$19,745	
Landscape		Hardscape - Concrete	Entire Site	6	6,932	SF	\$13,085	
Landscape		Parkway trees	Entire Site	6	51	EA	\$14,586	
Landscape		Planting Beds/ Areas	West perimeter	6	1,245	SF	\$0	
Parking Lot		Asphalt	Parking Lot	6	15,870	SF	\$13,616	
Parking Lot		Concrete	Parking Lot	6	6,062	SF	\$0	
Parking Lot		Concrete Curbs	Parking Lot	6	1,054	LF	\$6,360	
Parking Lot		Lights, Pole Mounted	Parking Lot	6	9	EA	\$10,296	
Parking Lot		Trash Compactor	Parking Lot	6	1	EA	\$3,575	
Parking Lot		Vehicular Screening	Parking Lot	6	323	LF	\$0	
Playground		Playground Equipment - Combo 3-12	Playground	7	1	EA	\$0	
Playground		Playground Surfacing - Poured Surface	Playground	6	3,526	SF	\$9,328	
Sidewalks		Internal Walks	Entire Site	6	486	LF	\$4,587	
Sidewalks		Perimeter Sidewalks	Entire Site	6	15,207	SF	\$28,705	
Signage		Flag Pole	West center	6	1	EA	\$0	
Signage		Monument Sign	Northeast corner	7	1	EA	\$0	
SITE Sub Total							\$166,481	
SITE Sub Total							\$166,481	

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Total Campus Need ^{2 3}							\$6,652,674	

¹ It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

² As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

³ The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Building: Main														
100	472	2	4	8	40	80	20		N	N	Y	Classroom		
101	715	2	4	8	40	180	60		N	N	Y	Classroom		
102	667	2	4	8	40	144	48		N	N	Y	Classroom		
103	737	2	4	8	40	180	60		N	N	Y	Classroom		
104	811	2	4	8	40	144	48		N	N	Y	Classroom		
105	737	2	4	8	40	144	48		N	N	Y	Classroom		
106	699	2	4	8	40	180	60		N	N	Y	Classroom		
107	737	2	4	8	40	180	60		N	N	Y	Classroom		
108	1451	2	42	84	40	360	48		N	N	Y	Classroom		
109	737	2	4	8	40	180	60		N	N	Y	Classroom		
111	821	2	4	8	40	180	60		N	N	Y	Classroom		
200	470	2	4	8	40	48	8		N	N	Y	Classroom		
201	740	2	4	8	40	180	60		N	N	Y	Classroom		
202	740	2	4	8	40	180	60		N	N	Y	Classroom		
203	740	2	4	8	40	180	60		N	N	Y	Classroom		
204	740	2	4	8	40	180	60		N	N	Y	Classroom		
205	740	2	4	8	40	180	60		N	N	Y	Classroom		
206	740	2	4	8	40	180	60		N	N	Y	Classroom		
207	740	2	4	8	40	180	60		N	N	Y	Classroom		
208	740	2	4	8	40	180	60		N	N	Y	Classroom		
209	740	2	4	8	40	180	60		N	N	Y	Classroom		
210	740	2	4	8	40	180	60		N	N	Y	Classroom		
211	740	2	4	8	40	180	60		N	N	Y	Classroom		
213+215	1225	2	8	16	40	288	96		N	N	Y	Classroom		
Other	299								N	N	N	Restroom	Children's Standard Student Restroom	1st floor girl's at north
Other	299								N	N	N	Restroom	Children's Standard Student Restroom	1st floor girl's at south
Other	232								N	N	N	Restroom	Children's Standard Student Restroom	2nd floor boy's at north
Other	299								N	N	N	Restroom	Children's Standard Student Restroom	2nd floor girl's at south
Other	154								N	N	N	Restroom	Staff Restroom	1st floor at auditorium, woman's
Other	630			6					N	N	Y	Administrative Suites/Offices		2nd floor SE corner, used to be Girl's Locker Room
Other	468			6					N	N	Y	Administrative Suites/Offices		1st floor rm #113
Other	30								N	N	N	Restroom	Staff Restroom	1st floor inside office suite next to classroom #104
Other	1651								N	N	N	Corridors		Entire building stair wells
Other	690			12					N	N	Y	Administrative Suites/Offices		1st floor main office suite
Other	232								N	N	N	Restroom	Children's Standard Student Restroom	2nd floor boy's at south

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	232								N	N	N	Restroom	Children's Standard Student Restroom	1st floor boy's at south
Other	232								N	N	N	Restroom	Children's Standard Student Restroom	1st floor boy's at north
Other	88								N	N	N	Restroom	Staff Restroom	1st floor at auditorium, men's & women's
Other	424			8					N	N	Y	Administrative Suites/Offices		1st floor SE corner, used to be Boy's Locker Room
Other	4602								N	N	N	Corridors		2nd Floor
Other	222								N	N	N	Restroom	Staff Restroom	1st floor inside Rm #102
Other	3949								N	N	N	Auditorium & Theater	Auditorium - Dedicated	1st Floor
Other	2803								N	N	N	Gymnasia	Standard Dedicated Gymnasium	1st Floor
Other	299								N	N	N	Restroom	Children's Standard Student Restroom	2nd floor girl's at north
Other	30								N	N	N	Restroom	Staff Restroom	1st floor 2 toilets next to engineer's office
Other	130			4					N	N	Y	Administrative Suites/Offices		1st floor engineer's office
Other	4755								N	N	N	Corridors		1st Floor

Building: Addition

159	890	1	11	34	40	98	8		Y	N	N	Classroom		
162	1340	1	11	34	40	129	12		Y	N	N	Classroom		
164	905	1	11	34	40	113	11		Y	N	N	Classroom		
165	1213	1	2	30	40	148	13		Y	N	N	Classroom		
166	1213	1	2	30	40	148	13		Y	N	N	Classroom		
167	1213	1	2	30	40	148	13		Y	N	N	Classroom		
168	1213	1	2	30	40	148	13		Y	N	N	Classroom		
169	1213	1	2	30	40	148	13		Y	N	N	Classroom		
250	900	1	11	34	40	113	11		Y	N	N	Classroom		
251	900	1	11	34	40	113	11		Y	N	N	Classroom		
255	960	1	11	34	40	113	11		Y	N	N	Classroom		
257	890	1	11	34	40	113	11		Y	N	N	Classroom		
259	925	1	11	34	40	113	11		Y	N	N	Classroom		
260	1365	1	12	38	40	149	17		Y	N	N	Classroom		
261	920	1	11	34	40	113	11		Y	N	N	Classroom		
262	900	1	11	34	40	113	11		Y	N	N	Classroom		
263	925	1	11	34	40	113	11		Y	N	N	Classroom		
264	900	1	11	34	40	113	11		Y	N	N	Classroom		
265	925	1	11	34	40	113	11		Y	N	N	Classroom		
266	920	1	11	34	40	113	11		Y	N	N	Classroom		
267	923	1	11	34	40	113	11		Y	N	N	Classroom		

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
268	900	1	11	34	40	113	11		Y	N	N	Classroom		
269	954	1	11	32	40	113	11		Y	N	N	Classroom		
Other	207			8					N	N	N	Administrative Suites/Offices		First floor,South end, engineer's office
Other	298			14					N	N	N	Administrative Suites/Offices		First floor, main office, teachers lounge
Other	44								N	N	N	Restroom	Staff Restroom	First floor, main office
Other	5166								N	N	N	Lunch & Multipurpose Room	Lunchroom	1st Floor
Other	2335								N	N	N	Kitchen	Cooking Kitchen	1st Floor
Other	57								N	N	N	Restroom	Staff Restroom	First floor, kitchen bathroom, Men's
Other	94			10					N	N	N	Administrative Suites/Offices		First floor, kitchen office
Other	732			24					N	N	N	Administrative Suites/Offices		First floor, main office
Other	70								N	N	N	Restroom	Early Childhood Student Restroom	first floor, room 168
Other	70								N	N	N	Restroom	Early Childhood Student Restroom	first floor, room 169
Other	70								N	N	N	Restroom	Early Childhood Student Restroom	first floor, room 166
Other	70								N	N	N	Restroom	Early Childhood Student Restroom	first floor, room 167
Other	70								N	N	N	Restroom	Early Childhood Student Restroom	first floor, room 165
Other	8040								N	N	N	Corridors		1st Floor
Other	57								N	N	N	Restroom	Staff Restroom	First floor, kitchen bathroom, Womens
Other	171			14					N	N	N	Administrative Suites/Offices		First floor, main office, principal office
Other	136			8					N	N	N	Administrative Suites/Offices		First floor, north end, student services
Other	351								N	N	N	Restroom	Children's Standard Student Restroom	First floor, north end, girls
Other	345								N	N	N	Restroom	Children's Standard Student Restroom	first floor, north end, boys
Other	60								N	N	N	Restroom	Staff Restroom	First floor, north end, staff bathroom
Other	5709								N	N	N	Corridors		2nd Floor
Other	280								N	N	N	Restroom	Children's Standard Student Restroom	Second floor, south end, Girls
Other	280								N	N	N	Restroom	Children's Standard Student Restroom	Second floor, south end, boys
Other	60								N	N	N	Restroom	Staff Restroom	Second floor, north end, staff bathroom
Other	345								N	N	N	Restroom	Children's Standard Student Restroom	Second floor, north end, boys
Other	351								N	N	N	Restroom	Children's Standard Student Restroom	Second floor, north end, girls
Other	219			14					N	N	N	Administrative Suites/Offices		Second floor, inside library
Other	2756								N	N	N	Library		2nd Floor
Other	1344								N	N	N	Corridors		Stairs entire building
Other	171			14					N	N	N	Administrative Suites/Offices		First floor, main office,asst. principal office

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
-------------	-----------	--------------	-------------	--------------	-------------	-------------------	----------------------	------------------	-------------	-------------	-------------	-----------	---------------	----------