

Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx.

Condition Rankings and Descriptions

- Rank 7:** The item/system is new or in good condition and no work is required.
- Rank 6:** The item/system requires general cleaning and/or routine maintenance.
- Rank 5:** The item/system requires repairs and has not reached the end of its serviceable life.
- Rank 4:** The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.
- Rank 3:** The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.
- Rank 2:** The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.
- Rank 1:** The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.¹

Definitions

Quantity means, for each item, the total number (or amount) of that item that exists and was evaluated.

Unit means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").

Cost means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.

For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.

Total Campus Need also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

Building: Main
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chimney		Brick Chimney - Concrete/ Mortar Liner	West Façade	6	10	LF	\$5,005	
Chimney		Brick Chimney - Concrete/ Mortar Liner	West Façade	7	57	LF	\$0	
Cornice		Cornice - Cast Stone	West and South	6	241	LF	\$12,965	
Cornice		Cornice - Metal Projecting	Entire Building	6	770	LF	\$69,039	
Doors		Exterior Steel Door	Entire Building	6	11	EA	\$3,634	
Doors		Transom Lite	Doors 1,2,4	7	9	EA	\$0	
Entrance		Concrete Exterior Stairs	Door 1	5	20	LF	\$6,435	
Entrance		Concrete Exterior Stairs	Doors 1 and 3	6	156	LF	\$16,731	
Entrance		Concrete Ramp	Doors 3	6	12	LF	\$1,673	
Entrance		Entrance Controls - Audio and Video	Door 1 and 3	7	2	EA	\$0	
Entrance		Ramp Handrails	Door 3	6	25	LF	\$0	
Entrance		Stair Handrails	Door 3	6	20	LF	\$0	
Entrance		Stone Stairs	Doors 1 and 6	6	50	LF	\$8,938	
Foundation		Concrete Foundation	Southwest Corner	6	10	LF	\$1,557	

Building: Main
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Foundation		Concrete Foundation	Entire Building	7	450	LF	\$0	
Lighting		Exterior Lights - Wall Mounted	Entire Building	7	7	EA	\$0	
Lintels		Lintels - Steel	Entire Building	7	517	LF	\$0	
Parapet		Coping - Stone	Entire Building	7	688	LF	\$0	
Parapet		Parapet < 16" Height	Entire Building	6	330	LF	\$51,390	
Parapet		Parapet > 30" Height	3-Story Roof	6	284	LF	\$73,711	
Parapet		Parapet 16" to 30" Height	Lower Roof	6	74	LF	\$15,365	
Roof System		Asphalt Gravel Ballast Roof	Entire Building	7	13,414	SF	\$0	
Roof System		Interior Downspouts	Entire Building	6	150	LF	\$0	
Roof System		Metal Roof	On 3-Story	6	36	SF	\$272	
Roof System		Roof Structure: Steel with Clay Tile Arch	Entire Building	7	13,414	SF	\$0	
Superstructure		Steel with Clay Tile Arch	Entire Building	7	33,562	SF	\$0	
Walls		Brick	Entire Building	7	18,634	SF	\$0	
Walls		Stone - Cast	Entire Building	7	499	SF	\$0	
Windows		Skylite - Glass Single-Pane	3-Story Roof	6	100	SF	\$944	
Windows		Window - Guards perforated	Entire Building	7	1,199	SF	\$0	
Windows		Window - Guards wire guard	Courtyard and South	6	112	SF	\$0	
Windows		Windows - Decorative	South Façade	6	40	SF	\$229	
Windows		Windows - Sash Aluminum Double-pane	Entire Building	7	4,542	SF	\$0	

EXTERIOR Sub Total **\$267,887**

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	Boiler Room	7	1	EA	\$0	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	7	33,562	SF	\$0	
Emergency System		Emergency A/C power - Students Toilets	Entire Building	7	33,562	SF	\$0	
Emergency System		Emergency Battery Packs - Corridors and Stairs	2nd Floor	7	2	EA	\$0	
Emergency System		Emergency Battery Packs - Corridors and Stairs	3rd Floor	7	2	EA	\$0	
Emergency System		Emergency Battery Packs - Corridors and Stairs	1st Floor	7	2	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	1st Floor	7	5	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	2nd Floor	7	2	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	3rd Floor	7	2	EA	\$0	
Emergency System		Public Announcement System	Main Office	7	39,981	SF	\$0	
Emergency System		Security System - CCTV	Main Office	7	39,981	SF	\$0	
Emergency System		Security System - Intrusion detection	Main Office	7	39,981	SF	\$0	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		UPS 30 KW and below	Coal Room	2	1	EA	\$50,050	UPS System removed. Installed Independent Emergency Service meter has also been removed and not replaced.
Main Service		Main Electrical service 1200 A 120/208/3PH	Electrical Room	6	1	EA	\$7,150	
Power Distribution		Lighting and power panels	Boiler Room	6	1	EA	\$715	
Power Distribution		Lighting and power panels	MDF Room	7	1	EA	\$0	
Power Distribution		Main distribution panels above 600 amp	Electrical Room	4	2	EA	\$37,180	
ELECTRICAL Sub Total							\$95,095	

Building: Main
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm System	Boiler Room	6	32,562	SF	\$39,579	
FIRE PROTECTION Sub Total							\$39,579	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Window A/C Unit	1st Floor	6	7	EA	\$1,502	
Air Conditioning		Window A/C Unit	2nd Floor	6	5	EA	\$1,073	
Air Conditioning		Window A/C Unit	3rd Floor	6	5	EA	\$1,073	
Air Handling Systems		Air Intake - Built Up Air Handling Unit	Boiler Room - South Wall	6	1	EA	\$1,430	
Air Handling Systems		Fan Coil Unit - Electric	MDF Room	7	1	EA	\$0	
Air Handling Systems		Multi Zone Built Up Air Handling Unit - Steam 15,001 to 25,000 cfm	Boiler Room	4	1	EA	\$92,950	
Air Handling Systems		Multi Zone Built Up Air Handling Unit Auxiliaries - Steam 15,001 to 25,000 cfm	Boiler Room	5	1	EA	\$12,870	
Air Handling Systems		Return Duct Work - Masonry and Ducts - Existing or Missing Exterior Shaft	Entire Building	4	100	LF	\$264,550	Missing system.
Boiler Systems		Boiler Assembly - Steam - Low Pressure Scotch Marine Boiler 76-100 HP	Boiler Room	6	1	EA	\$11,869	
Boiler Systems		Boiler Assembly - Steam - Low Pressure Scotch Marine Boiler 76-100 HP	Boiler Room	5	1	EA	\$57,200	
Boiler Systems		Boiler Auxiliary - Steam Boiler 76-100 HP	Boiler Room	6	2	EA	\$4,004	
Boiler Systems		Chemical Feed System (Steam Boilers)	Boiler Room	6	1	EA	\$2,145	
Boiler Systems		Chemical Pot Feeder - Hot Water	Boiler Room	6	2	EA	\$601	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Boiler Systems		Feed Water Pumps and Tank - Steam Boilers	Boiler Room	5	1	EA	\$19,305	
Heating Devices		Cabinet Heaters With Steam Coils	1st Floor	6	1	EA	\$501	
Heating Devices		Unit Heater - Gas	Boiler Room	6	1	EA	\$2,145	
Heating Devices		Wall Heater - Electric	2nd Floor	6	3	EA	\$309	
Heating Devices		Wall Heater - Electric	1st Floor	6	6	EA	\$618	
Heating Devices		Wall Heater - Electric	3rd Floor	6	3	EA	\$309	
Mechanical Plumbing		Condensate Assembly - Pumps and Tank	Boiler Room	6	1	EA	\$715	
Mechanical Plumbing		Condensate Assembly - Pumps and Tank	Boiler Room	5	1	EA	\$9,438	
Mechanical Plumbing		Piping - Condensate - Steel or Galvanized	Entire Building	6	100	LF	\$686	
Mechanical Plumbing		Piping - Steam - Steel or Galvanized	Entire Building	6	100	LF	\$887	
Temperature Control		Pneumatic System	Boiler Room	6	39,981	SF	\$14,293	
Temperature Control		Thermostats - Direct Digital Control (DDC)	1st Floor	7	6	EA	\$0	
Temperature Control		Thermostats - Pneumatic	3rd Floor	7	5	EA	\$0	
Temperature Control		Thermostats - Pneumatic	2nd Floor	7	5	EA	\$0	
Temperature Control		Thermostats - Pneumatic	Boiler Room	7	1	EA	\$0	
Temperature Control		Zone Dampers	Boiler Room	4	1	EA	\$844	
Temperature Control		Zone Dampers	Boiler Room	6	17	EA	\$2,431	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	7	1	EA	\$0	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	6	1	EA	\$429	

MECHANICAL Sub Total \$504,174

Building: Main
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas 150,000 -300,000 BTU/HR	Boiler Room	7	1	EA	\$0	
Hot Water		Storage Tank less than 500 gallons	Boiler Room	5	1	EA	\$7,436	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	6	33,562	SF	\$3,839	
Piping		Domestic Piping - Cold Water Risers	Entire Building	6	33,562	SF	\$5,279	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	6	33,562	SF	\$5,279	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	6	33,562	SF	\$5,279	
Piping		Domestic Piping - Hot Water Risers	Entire Building	6	33,562	SF	\$5,279	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	6	33,562	SF	\$7,679	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	6	33,562	SF	\$6,719	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	6	33,562	SF	\$5,279	
Piping		Sanitary Piping	Entire Building	7	33,562	SF	\$0	
Piping		Storm Piping	Entire Building	7	33,562	SF	\$0	

Building: Main
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Piping		Vent Piping	Entire Building	7	33,562	SF	\$0	
Pumps		Domestic Booster Pump simplex	Boiler Room	6	1	EA	\$1,716	
Pumps		Sump Pump	Boiler Room	7	1	EA	\$0	
PLUMBING Sub Total							\$53,786	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	1st Floor Main Office	7	646	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	1st Floor Principal's Office	7	288	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	1st Floor Principal's Office	7	288	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	1st Floor Main Office	7	646	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	1st Floor Main Office	7	6	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	1st Floor Principal's Office	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	1st Floor Main Office	7	1,344	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	1st Floor Principal's Office	7	1,008	SF	\$0	
Doors		Interior Steel Doors incl hw	Entire Building	7	8	EA	\$0	
Doors		Interior Wood Doors incl hw	Entire Building	6	27	EA	\$7,645	
Doors		Interior Wood Doors incl hw	Entire Building	7	28	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	1st Floor	7	2	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	3rd Floor	7	2	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	2nd Floor	7	2	EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd Floor Girls			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st Floor Main Office			LF	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Benches	kindergarten 102			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd Floor Girls			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st Floor Girls			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd Floor Boys			LF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd Floor Boys			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd Floor			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st Floor			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st Floor Boys			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	3rd Floor			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd Floor Girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st Floor Main Office			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd Floor Boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd Floor Boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st Floor Girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st Floor			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st Floor Boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	3rd Floor			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd Floor Girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd Floor			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Lockers	kindergarten 102			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd Floor Girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd Floor Boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd Floor Girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st Floor Girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st Floor Boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st Floor			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd Floor			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st Floor Main Office			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Showers	kindergarten 102			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	3rd Floor			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd Floor Boys			EA	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	Boiler/Elect	6	1,638	SF	\$7,730	
Mechanical/Service Rooms		Mechanical/Service Rooms	Tank & Engineer's Room	6	1,680	SF	\$7,928	
Mechanical/Service Rooms		Storage Room	Office Storage	7	24	SF	\$0	
Mechanical/Service Rooms		Storage Room	Mechanical Storage	6	120	SF	\$566	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd Floor Girls	7	372	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st Floor Boys	7	372	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd Floor Boys	7	372	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st Floor Main Office	7	42	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	3rd Floor	7	36	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st Floor			SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st Floor Girls	7	372	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd Floor Boys	7	372	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd Floor Girls	7	372	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	kindergarten 102	7	30	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd Floor	7	36	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st Floor Boys	7	372	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st Floor Main Office	7	42	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd Floor Girls	7	372	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Plaster/Drywall	kindergarten 102	7	30	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd Floor Boys	7	372	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd Floor Boys	7	372	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st Floor Girls	7	372	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd Floor	7	36	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	3rd Floor	7	36	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st Floor	7	42	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd Floor Girls	7	372	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd Floor Girls	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd Floor Girls	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st Floor Main Office			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd Floor Boys	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd Floor Boys	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st Floor Boys	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	kindergarten 102			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st Floor			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	3rd Floor			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st Floor Girls	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	2nd Floor			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd Floor Girls	7	372	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile Ceramic/Porcelain	kindergarten 102	7	30	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd Floor Boys	7	372	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd Floor Boys	7	372	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st Floor Girls	7	372	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st Floor Boys	7	372	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	1st Floor	7	42	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	3rd Floor	7	36	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd Floor Girls	7	372	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	2nd Floor	7	36	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	1st Floor Main Office	7	42	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Hand Dryer	kindergarten 102			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	1st Floor			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	3rd Floor			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd Floor			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st Floor Girls	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd Floor Boys	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd Floor Boys	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd Floor Girls	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	1st Floor Main Office			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st Floor Boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd Floor Girls	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st Floor Main Office	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd Floor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st Floor			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st Floor Boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st Floor Girls	7	2	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	kindergarten 102	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd Floor Girls	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd Floor Girls	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd Floor Boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd Floor Boys	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	3rd Floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st Floor Girls	7	7	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	3rd Floor	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	2nd Floor	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st Floor Boys	7	7	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	3rd Floor Boys	7	7	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd Floor Boys	7	7	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	3rd Floor Girls	7	7	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd Floor Girls	7	7	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	1st Floor Main Office	7	1	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Pendant/ Surface	kindergarten 102	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	1st Floor	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Partitions	2nd Floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd Floor Boys	6	2	EA	\$359	
Staff Restroom	Staff Restroom	Partitions	3rd Floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd Floor Girls	6	5	EA	\$897	
Staff Restroom	Early Childhood Student Restroom	Partitions	kindergarten 102			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st Floor Girls	6	5	EA	\$897	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd Floor Girls	6	5	EA	\$897	
Staff Restroom	Staff Restroom	Partitions	1st Floor			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd Floor Boys	6	2	EA	\$359	
Staff Restroom	Staff Restroom	Partitions	1st Floor Main Office	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st Floor Boys	6	2	EA	\$359	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st Floor Boys	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd Floor Girls			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st Floor			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd Floor			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	3rd Floor			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd Floor Boys	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd Floor Boys	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd Floor Girls			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st Floor Main Office			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Urinals	kindergarten 102			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st Floor Girls			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	1st Floor	6	334	SF	\$788	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	3rd Floor Girls	7	578	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	3rd Floor	7	364	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	2nd Floor	7	364	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st Floor Boys	7	578	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st Floor Girls	7	578	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	3rd Floor Boys	7	578	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd Floor Boys	7	578	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Wall - Plaster/Drywall	kindergarten 102	7	155	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd Floor Girls	7	578	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	1st Floor Main Office	7	364	SF	\$0	
Staff Restroom	Staff Restroom	Water Closet	3rd Floor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd Floor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st Floor			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st Floor Boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd Floor Girls	7	5	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	kindergarten 102	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st Floor Girls	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd Floor Girls	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd Floor Boys	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st Floor Main Office	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd Floor Boys	7	2	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	

INTERIOR Sub Total \$28,423

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
-------	-----------	------	----------	------	----------	------	------	--------

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		6	7	LF	\$250	
Casework	Classroom	Casework		6	7	LF	\$250	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework		7	35	LF	\$0	
Casework	Classroom	Casework		6	7	LF	\$250	
Casework	Classroom	Casework		6	7	LF	\$250	
Casework	Classroom	Casework		6	7	LF	\$250	
Casework	Classroom	Casework		6	61	LF	\$2,181	
Casework	Classroom	Casework		6	7	LF	\$250	
Casework	Classroom	Casework		6	7	LF	\$250	
Casework	Classroom	Casework		6	7	LF	\$250	
Casework	Classroom	Casework		6	7	LF	\$250	
Casework	Classroom	Casework		6	7	LF	\$250	
Casework	Classroom	Casework		7	34	LF	\$0	
Casework	Classroom	Casework		6	31	LF	\$1,108	
Ceiling	Classroom	Plaster/Drywall		7	288	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	815	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		6	815	SF	\$2,308	
Ceiling	Classroom	Plaster/Drywall		6	815	SF	\$2,308	
Ceiling	Classroom	Plaster/Drywall		7	815	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		6	815	SF	\$2,308	
Ceiling	Classroom	Plaster/Drywall		6	815	SF	\$2,308	
Ceiling	Classroom	Plaster/Drywall		7	815	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		6	815	SF	\$2,308	
Ceiling	Classroom	Plaster/Drywall		6	815	SF	\$2,308	
Ceiling	Classroom	Plaster/Drywall		7	504	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	1,108	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	815	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		6	815	SF	\$2,308	
Ceiling	Classroom	Plaster/Drywall		6	815	SF	\$2,308	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		7	8	LF	\$0	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Corridors	Corridors	Concrete Epoxy/Painted	Stair 2	7	225	SF	\$0	
Corridors	Corridors	Drinking Fountains	Stair 1			EA	\$0	
Corridors	Corridors	Drinking Fountains	Stair 2			EA	\$0	
Corridors	Corridors	Drop/Lay-In	Stair 2	7	75	SF	\$0	
Corridors	Corridors	Drop/Lay-In	Stair 1	7	75	SF	\$0	
Corridors	Corridors	Drop/Lay-In	3rd Floor	7	1,904	SF	\$0	
Corridors	Corridors	Drop/Lay-In	2nd Floor	7	1,904	SF	\$0	
Corridors	Corridors	Drop/Lay-In	1st Floor	7	1,904	SF	\$0	
Corridors	Corridors	Lay-In	1st Floor	7	1,904	EA	\$0	
Corridors	Corridors	Lay-In	2nd Floor	7	1,904	EA	\$0	
Corridors	Corridors	Lay-In	3rd Floor	7	1,904	EA	\$0	
Corridors	Corridors	Pendant/Surface	Stair 2	7	345	EA	\$0	
Corridors	Corridors	Pendant/Surface	Stair 1	7	345	EA	\$0	
Corridors	Corridors	Plaster/Drywall	Stair 1	7	2,743	SF	\$0	
Corridors	Corridors	Plaster/Drywall	Stair 2	7	2,743	SF	\$0	
Corridors	Corridors	Plaster/Drywall	3rd Floor	7	4,004	SF	\$0	
Corridors	Corridors	Plaster/Drywall	2nd Floor	7	4,004	SF	\$0	
Corridors	Corridors	Plaster/Drywall	1st Floor	7	4,004	SF	\$0	
Corridors	Corridors	Single Water Cooler	3rd Floor	7	2	EA	\$0	
Corridors	Corridors	Single Water Cooler	2nd Floor	7	2	EA	\$0	
Corridors	Corridors	Single Water Cooler	1st Floor	7	1	EA	\$0	
Corridors	Corridors	Stair Handrails	2nd Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	Stair 2	7	73	LF	\$0	
Corridors	Corridors	Stair Handrails	Stair 1	7	73	LF	\$0	
Corridors	Corridors	Stair Handrails	3rd Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	1st Floor			LF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Stairs	Stair 2	7	60	EA	\$0	
Corridors	Corridors	Stairs	Stair 1	7	60	EA	\$0	
Corridors	Corridors	Stairs	3rd Floor			EA	\$0	
Corridors	Corridors	Stairs	2nd Floor			EA	\$0	
Corridors	Corridors	Stairs	1st Floor			EA	\$0	
Corridors	Corridors	Student Lockers	2nd Floor			EA	\$0	
Corridors	Corridors	Student Lockers	Stair 2			EA	\$0	
Corridors	Corridors	Student Lockers	3rd Floor			EA	\$0	
Corridors	Corridors	Student Lockers	1st Floor			EA	\$0	
Corridors	Corridors	Student Lockers	Stair 1			EA	\$0	
Corridors	Corridors	Tile/Sheet Flooring	Stair 2	7	708	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	Stair 1	7	933	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	3rd Floor	7	1,904	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	1st Floor	5	42	SF	\$238	
Corridors	Corridors	Tile/Sheet Flooring	2nd Floor	7	1,904	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	1st Floor	7	1,862	SF	\$0	
Corridors	Corridors	Walls	Stair 2	7	80	SF	\$0	
Corridors	Corridors	Walls	Stair 1	7	80	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	Stair 1	7	270	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	Stair 2	7	270	SF	\$0	
Floor	Classroom	Tile/Sheet		7	288	SF	\$0	
Floor	Classroom	Tile/Sheet		7	504	SF	\$0	
Floor	Classroom	Tile/Sheet		7	815	SF	\$0	
Floor	Classroom	Tile/Sheet		7	815	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,108	SF	\$0	
Floor	Classroom	Wood		6	815	SF	\$6,154	
Floor	Classroom	Wood		6	815	SF	\$6,154	
Floor	Classroom	Wood		7	815	SF	\$0	
Floor	Classroom	Wood		6	815	SF	\$6,154	
Floor	Classroom	Wood		6	815	SF	\$6,154	
Floor	Classroom	Wood		6	815	SF	\$6,154	
Floor	Classroom	Wood		6	815	SF	\$6,154	
Floor	Classroom	Wood		6	815	SF	\$6,154	
Floor	Classroom	Wood		6	815	SF	\$6,154	
Floor	Classroom	Wood		6	815	SF	\$6,154	
Floor	Classroom	Wood		6	815	SF	\$6,154	
Floor	Classroom	Wood		6	815	SF	\$6,154	
Lighting	Classroom	Pendant/Surface		6	16	EA	\$1,144	cracked covers
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	cracked covers

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting	Classroom	Pendant/Surface		6	16	EA	\$1,144	cracked covers
Lighting	Classroom	Pendant/Surface		6	16	EA	\$1,144	cracked covers
Lighting	Classroom	Pendant/Surface		6	16	EA	\$1,144	cracked covers
Lighting	Classroom	Pendant/Surface		6	16	EA	\$1,144	cracked covers
Lighting	Classroom	Pendant/Surface		6	16	EA	\$1,144	cracked covers
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	cracked covers
Lighting	Classroom	Pendant/Surface		6	16	EA	\$1,144	cracked covers
Lighting	Classroom	Pendant/Surface		6	16	EA	\$1,144	cracked covers
Lighting	Classroom	Pendant/Surface		6	16	EA	\$1,144	cracked covers
Lighting	Classroom	Pendant/Surface		6	16	EA	\$1,144	cracked covers
Lighting	Classroom	Pendant/Surface		7	4	EA	\$0	
Lighting	Classroom	Pendant/Surface		6	16	EA	\$1,144	cracked covers
Lighting	Classroom	Pendant/Surface		7	8	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		6	8	LF	\$229	
Marker Board	Classroom	Marker Board		6	16	LF	\$458	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		6	16	LF	\$458	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		6	16	LF	\$458	
Marker Board	Classroom	Marker Board		6	16	LF	\$458	
Marker Board	Classroom	Marker Board		6	8	LF	\$229	
Marker Board	Classroom	Marker Board		6	8	LF	\$229	
Marker Board	Classroom	Marker Board		6	8	LF	\$229	
Marker Board	Classroom	Marker Board		6	16	LF	\$458	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	3rd Floor Girls	7	320	SF	\$0	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	1st Floor Girls	7	578	SF	\$0	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	2nd Floor Girls	7	578	SF	\$0	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	3rd Floor Girls	7	578	SF	\$0	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	2nd Floor Boys	7	320	SF	\$0	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	2nd Floor Boys	7	578	SF	\$0	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	3rd Floor Boys	7	320	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	3rd Floor Boys	7	578	SF	\$0	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	2nd Floor Girls	7	320	SF	\$0	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	1st Floor Girls	7	320	SF	\$0	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	1st Floor Boys	7	320	SF	\$0	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	1st Floor Boys	7	578	SF	\$0	
RESTROOM_WALL	Staff Restroom	Restroom Walls	1st Floor	7	30	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,230	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,065	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,230	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,230	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,230	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,230	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,230	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	1,230	SF	\$2,902	
Wall	Classroom	Plaster/Drywall		7	1,230	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,740	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,230	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	1,230	SF	\$2,902	
Wall	Classroom	Plaster/Drywall		7	1,230	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,230	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,230	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	945	SF	\$0	
ROOM Sub Total							\$132,466	
Building Main Sub Total							\$1,121,410	

Building:
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Canopy		Concrete/ Stucco Canopy	East Façade	7	75	SF	\$0	
Canopy		Metal Canopy	On Roof, South Face	6	12	SF	\$289	
Doors		Exterior FRP Door	Door 7	7	3	EA	\$0	
Doors		Exterior Steel Door	Door 5,6	6	2	EA	\$661	
Doors		Transom Lite	Door 7	7	3	EA	\$0	

Building:
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Entrance		Concrete Exterior Stairs	Door 7	6	85	LF	\$9,116	
Entrance		Concrete Exterior Stairs	Door 7	5	8	LF	\$2,574	
Entrance		Concrete Ramp	Door 6	6	10	LF	\$1,394	
Entrance		Ramp Handrails	Door 6	5	5	LF	\$50	
Entrance		Ramp Handrails	Door 6	6	25	LF	\$0	
Foundation		Concrete Foundation	Entire Building	7	225	LF	\$0	
Lighting		Exterior Lights - Wall Mounted	Entire Building	7	1	EA	\$0	
Lintels		Lintels - Steel	Entire Building	7	107	LF	\$0	
Parapet		Coping - Stone	Entire Building	7	199	LF	\$0	
Parapet		Coping - Terra Cotta	Around Courtyard and Two-Story	7	156	LF	\$0	
Parapet		Parapet < 16" Height	Entire Building	7	169	LF	\$0	
Parapet		Parapet 16" to 30" Height	Two-Story	7	186	LF	\$0	
Roof System		Asphalt Gravel Ballast Roof	Entire Building	7	5,582	SF	\$0	
Roof System		Exterior Downspouts	North, on Roof	7	49	LF	\$0	
Roof System		Interior Downspouts	Entire Building	6	86	LF	\$0	
Roof System		Modified Bitumen Roof	3-Story	7	279	SF	\$0	
Roof System		Roof Structure: Concrete	Entire Building	7	5,861	SF	\$0	
Superstructure		Concrete	Entire Building	7	6,419	SF	\$0	
Walls		Brick	Entire Building	7	8,570	SF	\$0	
Walls		Concrete Block	East Entrance	7	500	SF	\$0	
Walls		Stone - Cast	Entire Building	7	218	SF	\$0	
Walls		Terra Cotta	North and West	7	110	SF	\$0	
Windows		Window - Guards perforated	Entire Building	7	235	SF	\$0	
Windows		Windows - Casement Aluminum Double-pane	East Façade	7	35	SF	\$0	
Windows		Windows - Sash Aluminum Double-pane	Courtyard	5	9	SF	\$311	
Windows		Windows - Sash Aluminum Double-pane	Entire Building	7	375	SF	\$0	
EXTERIOR Sub Total							\$14,394	

Building:
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	7	6,419	SF	\$0	
Emergency System		Emergency A/C power - Gym and Lunch rooms	Entire Building	7	6,419	SF	\$0	
Emergency System		Exit Signs - Corridors and Stairs	1st Floor	7	1	EA	\$0	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st Floor	7	5	EA	\$0	
Power Distribution		Lighting and power panels	1st Floor	6	3	EA	\$2,145	

Building:
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
ELECTRICAL Sub Total							\$2,145	

Building:
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Entire Building	7	6,419	SF	\$0	
FIRE PROTECTION Sub Total							\$0	

Building:
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Condensing Unit - Roof Mounted less than 5 tons	Roof	7	1	EA	\$0	
Air Conditioning		Window A/C Unit	Engineer's Office	6	1	EA	\$215	
Air Handling Systems		Air Handling Unit Package - Single Zone - Steam 4,000 to 8,000 cfm	Mezzanine	6	1	EA	\$5,005	
Air Handling Systems		Air intake for all Air Handling Units except built up AHU	Gym - South Wall Second Floor	7	1	EA	\$0	
Air Handling Systems		Return Fans - Indoor less than 5,000 CFM	Mezzanine	6	1	EA	\$715	
Heating Devices		Cabinet Heaters With Steam Coils	1st Floor	6	9	EA	\$4,505	
Heating Devices		Wall Heater - Electric	1st Floor	6	4	EA	\$412	
Mechanical Plumbing		Piping - Condensate - Steel or Galvanized	Entire Building	6	100	LF	\$686	
Mechanical Plumbing		Piping - Steam - Steel or Galvanized	Entire Building	6	100	LF	\$887	
Temperature Control		Thermostats - Pneumatic	Gym	4	1	EA	\$658	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	7	1	EA	\$0	
MECHANICAL Sub Total							\$13,082	

Building:
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	6	6,419	SF	\$734	
Piping		Domestic Piping - Cold Water Risers	Entire Building	6	6,419	SF	\$1,010	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	6	6,419	SF	\$1,010	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	6	6,419	SF	\$1,010	
Piping		Domestic Piping - Hot Water Risers	Entire Building	6	6,419	SF	\$1,010	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	6	6,419	SF	\$1,469	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	6	6,419	SF	\$1,285	

Building:
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Piping		Domestic Piping Hot Water Return Lines	Entire Building	6	6,419	SF	\$1,010	
Piping		Sanitary Piping	Entire Building	7	6,419	SF	\$0	
Piping		Storm Piping	Entire Building	7	6,419	SF	\$0	
Piping		Vent Piping	Entire Building	7	6,419	SF	\$0	
PLUMBING Sub Total							\$8,537	

Building:
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	1st Floor Gym Office	7	88	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	1st Floor Helpers Office	7	128	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	1st Floor Teachers' Lounge	7	388	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	1st Floor Assistant Principal	7	168	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Gym Vestibule Men's Restroom Fixtures Removed	7	90	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Gym Vestibule Women's Restroom Fixtures Removed	7	90	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	1st Floor Gym Office	7	88	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	1st Floor Helpers Office	7	128	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Gym Vestibule Men's Restroom Fixtures Removed	7	90	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	1st Floor Assistant Principal	7	168	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	1st Floor Teachers' Lounge	7	388	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Gym Vestibule Women's Restroom Fixtures Removed	7	90	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	1st Floor Gym Office	7	1	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	1st Floor Assistant Principal	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Gym Vestibule Men's Restroom Fixtures Removed	7	1	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	1st Floor Teachers' Lounge	7	5	SF	\$0	

Building:
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Gym Vestibule Women's Restroom Fixtures Removed	7	1	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	1st Floor Helpers Office	7	1	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Gym Vestibule Women's Restroom Fixtures Removed	7	105	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	1st Floor Assistant Principal	7	468	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	1st Floor Teachers' Lounge	7	900	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	1st Floor Gym Office	7	380	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	1st Floor Helpers Office	7	440	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Gym Vestibule Men's Restroom Fixtures Removed	7	105	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	1st Floor Helpers Office	7	170	SF	\$0	
Corridor		Stairs - Wood	Boiler/Electrical Room	7	4	LF	\$0	
Doors		Interior Steel Doors incl hw	Entire Building	7	4	EA	\$0	
Doors		Interior Wood Doors incl hw	Entire Building	6	9	EA	\$2,548	
Doors		Interior Wood Doors incl hw	Entire Building	7	27	EA	\$0	
Gymnasium / Auditorium	Gymnasium/Cafeteria	Bleacher Seating	Stage			EA	\$0	
Gymnasium / Auditorium	Gymnasium/Cafeteria	Bleacher Seating	1st Floor			EA	\$0	
Gymnasium / Auditorium	Gymnasium/Cafeteria	Ceiling - Plaster/Drywall	Stage	7	720	SF	\$0	
Gymnasium / Auditorium	Gymnasium/Cafeteria	Ceiling - Splined	1st Floor	7	2,400	SF	\$0	
Gymnasium / Auditorium	Gymnasium/Cafeteria	Flooring - Wood	Stage	7	450	SF	\$0	
Gymnasium / Auditorium	Gymnasium/Cafeteria	Flooring - Wood	1st Floor	7	2,400	SF	\$0	
Gymnasium / Auditorium	Gymnasium/Cafeteria	Lighting - Metal Halide/Sodium Vapor	1st Floor	7	12	EA	\$0	
Gymnasium / Auditorium	Gymnasium/Cafeteria	Lighting - Pendant/Surface	Stage	7	2	EA	\$0	
Gymnasium / Auditorium	Gymnasium/Cafeteria	Scoreboards	1st Floor			EA	\$0	
Gymnasium / Auditorium	Gymnasium/Cafeteria	Scoreboards	Stage			EA	\$0	
Gymnasium / Auditorium	Gymnasium/Cafeteria	Sound System	1st Floor			EA	\$0	
Gymnasium / Auditorium	Gymnasium/Cafeteria	Sound System	Stage			EA	\$0	
Gymnasium / Auditorium	Gymnasium/Cafeteria	Stage Curtain	Stage	7	2	EA	\$0	
Gymnasium / Auditorium	Gymnasium/Cafeteria	Stage Curtain	1st Floor			EA	\$0	
Gymnasium / Auditorium	Gymnasium/Cafeteria	Walls - Concrete Block	Stage	7	2,790	SF	\$0	
Gymnasium / Auditorium	Gymnasium/Cafeteria	Walls - Concrete Block	1st Floor	7	2,136	SF	\$0	
Kitchen	Warming Kitchen	Ceiling - Lay-In	1st Floor	7	429	SF	\$0	
Kitchen	Warming Kitchen	Flooring - Tile Ceramic/Porcelain	1st Floor	7	429	SF	\$0	

Building:
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Kitchen	Warming Kitchen	Lighting - Lay-In	1st Floor	7	6	SF	\$0	
Kitchen	Warming Kitchen	Wall - Plaster/Drywall	1st Floor	7	1,000	SF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st Floor Teachers Lounge			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	Engineer's Restroom			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	asst principals			LF	\$0	
Locker/Shower Room	Staff Restroom	Lockers	asst principals			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st Floor Teachers Lounge			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Engineer's Restroom			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	asst principals			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st Floor Teachers Lounge			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	Engineer's Restroom			EA	\$0	
Lunchroom	Warming Kitchen	Serving Line	1st Floor	7	6	LF	\$0	
MDF/IDF		Finishes	MDF Roof	7	88	SF	\$0	
MDF/IDF		Ventilation and Cooling	MDF Room	7	88	EA	\$0	
Mechanical/Service Rooms		Storage Room	Assistant Principal	7	40	SF	\$0	
Mechanical/Service Rooms		Storage Room	Outside Storage	6	126	SF	\$595	
Mechanical/Service Rooms		Storage Room	Teachers' Lounge	7	96	SF	\$0	
Mechanical/Service Rooms		Storage Room	Mechanical	7	40	SF	\$0	
Mechanical/Service Rooms		Storage Room	Gym	7	16	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	Engineer's Restroom	6	36	SF	\$278	
Staff Restroom	Staff Restroom	Accessories	1st Floor Teachers Lounge	7	84	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	asst principals			SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	asst principals	7	30	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	Engineer's Restroom	7	36	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st Floor Teachers Lounge	7	84	SF	\$0	
Staff Restroom	Staff Restroom	Floor Drain	Engineer's Restroom			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st Floor Teachers Lounge			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	asst principals			EA	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	1st Floor Teachers Lounge	7	84	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	Engineer's Restroom	7	36	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	asst principals	6	30	SF	\$43	
Staff Restroom	Staff Restroom	Hand Dryer	asst principals			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	1st Floor Teachers Lounge	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	Engineer's Restroom			EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Engineer's Restroom	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	asst principals	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st Floor Teachers Lounge	7	1	EA	\$0	

Building:
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st Floor Teachers Lounge	4	1	SF	\$4	
Staff Restroom	Staff Restroom	Lighting - Lay-In	asst principals	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	Engineer's Restroom	4	1	EA	\$322	
Staff Restroom	Staff Restroom	Partitions	1st Floor Teachers Lounge			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	asst principals			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	Engineer's Restroom			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	asst principals			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	Engineer's Restroom			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st Floor Teachers Lounge			EA	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	Engineer's Restroom	7	192	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	1st Floor Teachers Lounge	7	380	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	asst principals	7	155	SF	\$0	
Staff Restroom	Staff Restroom	Water Closet	asst principals	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st Floor Teachers Lounge	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	Engineer's Restroom	7	1	EA	\$0	
INTERIOR Sub Total							\$3,789	

Building:
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	Gym Vestibule Women's Restroom Fixtures Removed	7	266	SF	\$0	
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	Gym Vestibule Men's Restroom Fixtures Removed	7	266	SF	\$0	
Corridors	Corridors	Concrete Block	Gym Vestibule	7	310	SF	\$0	
Corridors	Corridors	Drinking Fountains	Gym Vestibule			EA	\$0	
Corridors	Corridors	Drinking Fountains	1st Floor			EA	\$0	
Corridors	Corridors	Drop/Lay-In	1st Floor	7	256	SF	\$0	
Corridors	Corridors	Lay-In	1st Floor	7	256	EA	\$0	
Corridors	Corridors	Lay-In	Gym Vestibule	4	2	EA	\$12	
Corridors	Corridors	Plaster/Drywall	1st Floor	7	648	SF	\$0	
Corridors	Corridors	Stair Handrails	1st Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	Gym Vestibule			LF	\$0	
Corridors	Corridors	Stairs	1st Floor			EA	\$0	
Corridors	Corridors	Stairs	Gym Vestibule			EA	\$0	
Corridors	Corridors	Student Lockers	1st Floor			EA	\$0	
Corridors	Corridors	Student Lockers	Gym Vestibule			EA	\$0	
Corridors	Corridors	Tile Ceramic/Porcelain	Gym Vestibule	7	220	SF	\$0	

Building:
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Tile/Sheet Flooring	1st Floor	7	256	SF	\$0	
Corridors	Corridors	Walls	Gym Vestibule	7	310	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	Gym Vestibule	7	220	SF	\$0	
GYM_FLOOR	Gymnasium/Cafeteria	Gymnasia Floor	Stage	7	270	SF	\$0	
GYM_WALL	Gymnasium/Cafeteria	Gymnasia Walls	1st Floor	7	1,400	SF	\$0	
ROOM Sub Total							\$12	
Building Sub Total							\$41,959	

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Civil/Drainage		Catch Basin	Entire Site	7	3	EA	\$0	
Civil/Drainage		Site Drain	Courtyard	7	1	EA	\$0	
Civil/Drainage		Site Manhole	Entire Site	7	12	EA	\$0	
Fencing		Chain Link	Site - East	6	686	LF	\$9,839	
Fencing		Iron and Concrete Post	Site ∩ South	5	45	LF	\$2,252	
Landscape		Grass	Entire Site	7	18,234	SF	\$0	
Landscape		Hardscape - Concrete	Site ∩ South	5	1,100	SF	\$6,858	
Landscape		Hardscape - Concrete	Entire Site	6	1,560	SF	\$2,945	
Landscape		Parkway trees	Entire Site	7	23	EA	\$0	
Landscape		Retaining Wall - Concrete	Southeast Site	5	10	SF	\$779	
Landscape		Retaining Wall - Concrete	Site - East	6	724	SF	\$17,083	
Parking Lot		Asphalt	Site ∩ West	5	23,882	SF	\$67,619	
Parking Lot		Trash Enclosure	Site ∩ West	7	748	SF	\$0	
Playground		Playground Equipment - School Age 5-12	Site ∩ West	7	1	EA	\$0	
Playground		Playground Surfacing - Poured Surface	Site ∩ West	7	2,632	SF	\$0	
Sidewalks		Perimeter Sidewalks	Entire Site	7	9,249	SF	\$0	
Signage		Flag Pole	Site - East	6	1	EA	\$0	
Signage		Marquee - Free Standing Back Lighted	Site - East	6	1	EA	\$0	
SITE Sub Total							\$107,375	
SITE Sub Total							\$107,375	

Building: SITE
 Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Total Campus Need ^{2 3}							\$1,270,744	

¹ It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

² As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

³ The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Building: Main														
102	815	1		6	40	154	70	1	N	N	Y	Classroom		
103	504		1	44	40	28		2	N	N	Y	Classroom		
104	288			10	40	14		1	N	N	Y	Classroom		
104	815	1		6	40	154	70	1	N	N	Y	Classroom		
105	1108			6	40	70	28	1	N	N	Y	Classroom		
200	815	1	1	6	40	154	70	1	N	N	Y	Classroom		
201	815	1		6	40	168	84		N	N	Y	Classroom		
202	815	1		6	40	168	84		N	N	Y	Classroom		
203	815	1		6	40	168	84		N	N	Y	Classroom		
205	815	1		6	40	168	84		N	N	Y	Classroom		
300	815	1		6	40	154	70	1	N	N	Y	Classroom		
301	815	1		6	40	154	70	1	N	N	Y	Classroom		
302	815	1		6	40	168	84		N	N	Y	Classroom		
303	815	1		6	40	154	70	1	N	Y	Y	Classroom		
305	815	1		6	40	154	70	1	N	N	Y	Classroom		
Other	36								N	N	N	Restroom	Staff Restroom	3rd Floor
Other	36								N	N	N	Restroom	Staff Restroom	2nd Floor
Other	42								N	N	N	Restroom	Staff Restroom	1st Floor
Other	372								N	N	N	Restroom	Children's Standard Student Restroom	1st Floor Boys
Other	372								N	N	N	Restroom	Children's Standard Student Restroom	1st Floor Girls
Other	288			6					N	N	Y	Administrative Suites/Offices		1st Floor Principal's Office
Other	30								N	N	N	Restroom	Early Childhood Student Restroom	kindergarten 102
Other	372								N	N	N	Restroom	Children's Standard Student Restroom	3rd Floor Girls
Other	646			8					N	N	Y	Administrative Suites/Offices		1st Floor Main Office
Other	933								N	N	N	Corridors		Stair 1
Other	42								N	N	N	Restroom	Staff Restroom	1st Floor Main Office
Other	372								N	N	N	Restroom	Children's Standard Student Restroom	2nd Floor Girls
Other	933								N	N	N	Corridors		Stair 2
Other	1904								N	N	N	Corridors		3rd Floor
Other	1904								N	N	N	Corridors		2nd Floor
Other	1904								N	N	N	Corridors		1st Floor
Other	372								N	N	N	Restroom	Children's Standard Student Restroom	3rd Floor Boys
Other	372								N	N	N	Restroom	Children's Standard Student Restroom	2nd Floor Boys

Building:

Other	388			4					N	N	Y	Administrative Suites/Offices		1st Floor Teachers' Lounge
-------	-----	--	--	---	--	--	--	--	---	---	---	-------------------------------	--	----------------------------

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	90								N	N	N	Administrative Suites/Offices		Gym Vestibule Women's Restroom Fixtures Removed
Other	168			6					N	N	Y	Administrative Suites/Offices		1st Floor Assistant Principal
Other	36								N	N	N	Restroom	Staff Restroom	Engineer's Restroom
Other	429								N	N	N	Kitchen	Warming Kitchen	1st Floor
Other	720								N	N	N	Gymnasia	Gymnasium/Cafeteria	Stage
Other	84								N	N	N	Restroom	Staff Restroom	1st Floor Teachers Lounge
Other	90								N	N	N	Administrative Suites/Offices		Gym Vestibule Men's Restroom Fixtures Removed
Other	220								N	N	N	Corridors		Gym Vestibule
Other	2400								N	N	N	Gymnasia	Gymnasium/Cafeteria	1st Floor
Other	88			2					N	N	Y	Administrative Suites/Offices		1st Floor Gym Office
Other	30								N	N	N	Restroom	Staff Restroom	asst principals
Other	256								N	N	N	Corridors		1st Floor
Other	128			4					N	N	Y	Administrative Suites/Offices		1st Floor Helpers Office