

Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx.

Condition Rankings and Descriptions

Rank 7: The item/system is new or in good condition and no work is required.

Rank 6: The item/system requires general cleaning and/or routine maintenance.

Rank 5: The item/system requires repairs and has not reached the end of its serviceable life.

Rank 4: The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.

Rank 3: The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.

Rank 2: The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.

Rank 1: The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.¹

Definitions

Quantity means, for each item, the total number (or amount) of that item that exists and was evaluated.

Unit means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").

Cost means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.

For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.

Total Campus Need also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

Building: Main

Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Canopy		Concrete/ Stucco Canopy	Entire Building	6	465	SF	\$13,166	
Chimney		Brick Chimney - Concrete/ Mortar Liner	South Façade	4	3	LF	\$16,517	
Chimney		Brick Chimney - Concrete/ Mortar Liner	South Façade	6	60	LF	\$30,030	
Doors		Exterior FRP Door	Entire Building	7	33	EA	\$0	
Doors		Side Lite	Entire Building	7	8	EA	\$0	
Doors		Transom Lite	Entire Building	7	7	EA	\$0	
Entrance		Concrete Exterior Stairs	Entire Building	6	68	LF	\$7,293	
Entrance		Concrete Ramp	West Entrances	7	13	LF	\$0	
Entrance		Entrance Controls - Audio and Video	Entire Building	7	3	EA	\$0	
Entrance		Power Door Operator and Controls	West Entrances	7	1	EA	\$0	
Foundation		Concrete Foundation	Entire Building	7	1,450	LF	\$0	
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	5	EA	\$1,073	
Lighting		Exterior Lights - Wall Mounted	Entire Building	7	18	EA	\$0	
Lintels		Lintels - Steel	Entire Building	6	162	LF	\$6,116	

Building: Main
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Parapet		Coping - Metal	Entire Building	6	1,835	LF	\$0	
Parapet		Coping - Stone	Chiller Enclosure - West	7	90	LF	\$0	
Roof System		Asphalt Gravel Ballast Roof	Main Roofs - North	4	15,440	SF	\$393,451	
Roof System		Asphalt Gravel Ballast Roof	Lower Roof - West	4	6,080	SF	\$154,934	Significant Ponding & water infiltration. Vegetation on roof.
Roof System		Exterior Downspouts	North Façade	6	12	LF	\$223	
Roof System		Interior Downspouts	Main Roofs - South	5	80	LF	\$8,580	Ponding @ all locations
Roof System		Interior Downspouts	Main Roofs - North	6	150	LF	\$0	
Roof System		Modified Bitumen Roof	Main Roofs - South	5	16,480	SF	\$194,423	
Roof System		Roof Structure: Concrete	Main Buildings - North	7	21,520	SF	\$0	
Roof System		Roof Structure: Steel/Metal Deck/Concrete Topping	Main Building - South	7	16,480	SF	\$0	
Superstructure		Concrete	Entire Building	7	61,200	SF	\$0	
Walls		Brick	Entire Building	6	22,850	SF	\$150,961	
Walls		Brick	North Façade	4	300	SF	\$22,651	
Walls		Brick	West Façade	7	1,080	SF	\$0	
Walls		Concrete Block	West Façade	6	288	SF	\$1,903	
Windows		Curtain wall - Glazed Double Pane	Entire Building	6	7,513	SF	\$70,908	Interior deterioration noted at 3 story classroom wing. See interior assessment for locations.
Windows		Curtain wall - Insulated panel	Entire Building	6	4,694	SF	\$44,302	
Windows		Curtain wall - Louver	Entire Building	6	185	SF	\$1,746	
Windows		Curtain wall - Windows	Entire Building	6	2,310	SF	\$21,802	Interior deterioration noted at 3 story classroom wing, ceiling. See interior assessment for locations. Operable windows.
Windows		Skylite - Lexan	Main Roof - Gym	4	500	SF	\$106,649	
Windows		Window - Guards perforated	Entire Building	7	5,180	SF	\$0	
Windows		Windows - Sash Aluminum Double-pane	South Building	6	368	SF	\$3,157	
EXTERIOR Sub Total							\$1,249,884	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	Electrical Room	7	3	EA	\$0	
Emergency System		Automatic Transfer switch	Assembly Hall	7	1	EA	\$0	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Emergency A/C power - Auditorium and aisle lighting	1st Floor	7	4,000	SF	\$0	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	7	61,200	SF	\$0	
Emergency System		Emergency A/C power - Gym and Lunch rooms	1st Floor	7	6,918	SF	\$0	
Emergency System		Emergency A/C power - Students Toilets	Entire Building	7	2,084	SF	\$0	
Emergency System		Emergency Battery Packs - Corridors and Stairs	Entire Building	7	1	EA	\$0	
Emergency System		Emergency Battery Packs - Lunchroom and Gym	1st Floor	7	4	EA	\$0	
Emergency System		Emergency generator 60 to 100 KW diesel - Outdoor	Outside, next to Chiller	7	1	EA	\$0	
Emergency System		Exit Signs - Auditorium	1st Floor	7	4	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	7	24	EA	\$0	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st Floor	7	1	EA	\$0	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st Floor	7	4	EA	\$0	
Emergency System		Public Announcement System	Entire Building	4	61,200	SF	\$217,040	
Emergency System		Security System - Intrusion detection	Entire Building	6	61,200	SF	\$56,885	
Main Service		Main Electrical service 2000 to 3000 A 120/208/3PH	Electrical Room	7	1	EA	\$0	
Power Distribution		Lighting and power panels	Electrical Room	7	3	EA	\$0	
Power Distribution		Lighting and power panels	Boiler Room	7	1	EA	\$0	
Power Distribution		Lighting and power panels	Entire Building	7	2	EA	\$0	
Power Distribution		Lighting and power panels	Boiler Room	4	1	EA	\$5,434	
Power Distribution		Lighting and power panels	Electrical Room	4	1	EA	\$5,434	
Power Distribution		Lighting and power panels	Entire Building	4	5	EA	\$27,170	
Power Distribution		Main distribution panels 400-600 amp	Electrical Room	4	1	EA	\$12,155	
Power Distribution		Main distribution panels 400-600 amp	Boiler Room	7	1	EA	\$0	
Power Distribution		Main distribution panels 400-600 amp	Electrical Room	7	1	EA	\$0	
Power Distribution		Main distribution panels less than 400 amp	Entire Building	4	2	EA	\$13,156	
ELECTRICAL Sub Total							\$337,274	

Building: Main
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Entire Building	4	61,200	SF	\$129,524	
Fire Alarm		Fire Alarm System	Electrical Room	5	66,300	SF	\$144,110	
FIRE PROTECTION Sub Total							\$273,633	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
-------	-----------	------	----------	------	----------	------	------	--------

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Chillers - Air Cooled - Screw Type - Ground Mounted greater than 200 tons	Outside, next to Generator	7	1	EA	\$0	
Air Conditioning		Condensing Unit - Roof Mounted less than 5 tons	Roof	7	1	EA	\$0	
Air Conditioning		Condensing Unit - Roof Mounted less than 5 tons	Roof	6	1	EA	\$858	
Air Conditioning		Window A/C Unit	Entire Building	6	3	EA	\$644	
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water 4,000 to 8,000 cfm	MEZZANINE MECHANICAL ROOM	7	1	EA	\$0	
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water 12,001 to 20,000 cfm	MEZZANINE MECHANICAL ROOM	7	1	EA	\$0	
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water 8,001 to 12,000 cfm	MEZZANINE MECHANICAL ROOM	7	1	EA	\$0	
Air Handling Systems		Air intake for all Air Handling Units except built up AHU	MEZZANINE MECHANICAL ROOM	7	3	EA	\$0	
Air Handling Systems		Fan Coil Unit - Electric	Entire Building	7	7	EA	\$0	
Air Handling Systems		Return Duct Work - Indoor - Vertical Shaft and Ducts	MEZZANINE MECHANICAL ROOM	7	40	LF	\$0	
Air Handling Systems		Return Duct Work - Indoor - Vertical Shaft and Ducts	MEZZANINE MECHANICAL ROOM	7	40	LF	\$0	
Air Handling Systems		Return Duct Work - Indoor - Vertical Shaft and Ducts	MEZZANINE MECHANICAL ROOM	7	40	LF	\$0	
Boiler Systems		Boiler Assembly - Condensing Hot Water Boiler 2,001MBH-3,000 MBH	Boiler Room	5	3	EA	\$182,325	
Boiler Systems		Boiler Auxiliary - Condensing Hot Water Boiler 2,001MBH-3,000 MBH	Boiler Room	7	3	EA	\$0	
Boiler Systems		Chemical Pot Feeder - Hot Water	Boiler Room	7	1	EA	\$0	
Boiler Systems		Combustion Dampers	Boiler Room	7	1	EA	\$0	
Boiler Systems		Gas Boosters	Boiler Room	4	2	EA	\$26,026	GAS BOOSTERS IN PLACE BUT NO POWER
Boiler Systems		Glycol Feed System	Boiler Room	7	1	EA	\$0	
Heating Devices		Cabinet Heaters With Hot Water Coils	1st Floor	7	2	EA	\$0	
Heating Devices		Cabinet Heaters With Hot Water Coils	Entire Building	7	14	EA	\$0	
Heating Devices		Fin Tube Hot Water	Entire Building	6	54	LF	\$927	
Heating Devices		Wall Heater - Electric	Entire Building	7	3	EA	\$0	
Heating Devices		Wall Heater - Electric	Electrical Room	2	1	EA	\$1,030	UNIT NOT WORKING
Mechanical Plumbing		Piping - Hydronic Supply and Return - Steel or Galvanized	Entire Building	7	100	LF	\$0	
Mechanical Plumbing		Pumps - Dual Temperature Water 11 to 20 HP	Boiler Room	7	2	EA	\$0	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Temperature Control		Direct Digital Control (DDC) System	Engineer's office in boiler room	7	61,200	SF	\$0	
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	7	4	EA	\$0	
Unit Ventilation		Unit Ventilators - Hot Water and Chilled Water	Entire Building	7	37	EA	\$0	
Ventilation		Exhaust Fan - Indoor	1st Floor	6	1	EA	\$501	
Ventilation		Exhaust Fan - Indoor	Electrical Room	5	1	EA	\$1,859	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	7	8	EA	\$0	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	NORTH OUTSIDE WALL BY ALLEY OUTSIDE OF KITCHEN	7	1	EA	\$0	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	7	5	EA	\$0	
Ventilation		Type II Exhaust Hood - Warming Kitchen	1st Floor	2	1	EA	\$6,149	
Ventilation		Type II Exhaust Hood - Warming Kitchen	1st Floor	7	1	EA	\$0	
MECHANICAL Sub Total							\$220,317	

Building: Main
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas 150,000 -300,000 BTU/HR	Boiler Room	7	2	EA	\$0	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	6	61,200	SF	\$7,001	
Piping		Domestic Piping - Cold Water Risers	Entire Building	7	61,200	SF	\$0	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	6	61,200	SF	\$9,627	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	7	61,200	SF	\$0	
Piping		Domestic Piping - Hot Water Risers	Entire Building	7	61,200	SF	\$0	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	7	61,200	SF	\$0	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	7	61,200	SF	\$0	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	7	61,200	SF	\$0	
Piping		Sanitary Piping	Entire Building	7	61,200	SF	\$0	
Piping		Storm Piping	Entire Building	7	61,200	SF	\$0	
Piping		Vent Piping	Entire Building	5	61,200	SF	\$21,879	
Pumps		Domestic Booster Pump duplex	Boiler Room	7	1	EA	\$0	
PLUMBING Sub Total							\$38,507	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
-------	-----------	------	----------	------	----------	------	------	--------

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Reception/office	7	504	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Assistant Principal	7	200	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	principal office	7	192	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	CounselorOffice	7	336	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Gym Office	7	90	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Splined	Engineers Office	7	64	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Assistant Principal	7	200	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	CounselorOffice	7	336	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Engineers Office	7	64	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Reception/office	7	504	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Gym Office	7	90	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	principal office	7	192	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Reception/office	7	12	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Assistant Principal	7	5	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	CounselorOffice	7	12	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	principal office	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Gym Office	7	1	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Engineers Office	4	1	SF	\$7	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Reception/office	7	648	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	principal office	7	312	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	CounselorOffice	7	544	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Assistant Principal	7	420	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Gym Office	7	304	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Engineers Office	7	256	SF	\$0	
Auditorium - Dedicated	Auditorium - Dedicated	Balcony Seating	1st Floor			EA	\$0	
Auditorium - Dedicated	Auditorium - Dedicated	Main Floor Seating	1st Floor	7	360	EA	\$0	
Auditorium - Dedicated	Auditorium - Dedicated	Sound System	1st Floor	7	1	EA	\$0	
Auditorium - Dedicated	Auditorium - Dedicated	Stage Curtains	1st Floor	7	4	EA	\$0	
Auditorium - Dedicated	Auditorium - Dedicated	Stage Lighting System	1st Floor	7	1	EA	\$0	
Doors		Interior Steel Doors incl hw	2nd Floor	7	1	EA	\$0	
Doors		Interior Steel Doors incl hw	1st Floor	6	2	EA	\$566	
Doors		Interior Steel Doors incl hw	1st Floor	7	6	EA	\$0	
Doors		Interior Wood Doors incl hw	2nd Floor	6	9	EA	\$2,548	
Doors		Interior Wood Doors incl hw	3rd Floor	7	39	EA	\$0	
Doors		Interior Wood Doors incl hw	1st Floor	7	105	EA	\$0	
Doors		Interior Wood Doors incl hw	1st Floor	6	27	EA	\$7,645	
Doors		Interior Wood Doors incl hw	1st Floor	5	2	EA	\$944	
Doors		Interior Wood Doors incl hw	2nd Floor	7	50	EA	\$0	
Doors		Interior Wood Doors incl hw	3rd Floor	6	11	EA	\$3,115	
Doors		Side-lite	Entire Building	7	875	SF	\$0	
Doors		Store Front Door	1st Floor	7	4	EA	\$0	
Drinking Fountains		Single Water Cooler	Entire Building	7	10	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Bleacher Seating	1st Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Ceiling - Exposed	1st Floor	7	4,212	SF	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Flooring - Wood	1st Floor	7	4,212	SF	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Lighting - Metal Halide/Sodium Vapor	1st Floor	7	12	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Scoreboards	1st Floor	7	1	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Sound System	1st Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Stage Curtain	1st Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Concrete Block	1st Floor	7	6,118	SF	\$0	
Kitchen	Cooking Kitchen	Ceiling - Lay-In	1st Floor	7	564	SF	\$0	
Kitchen	Warming Kitchen	Ceiling - Splined	dish cleaning room off of lunch room	7	100	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Kitchen	Cooking Kitchen	Flooring - Tile Quarry	1st Floor	7	564	SF	\$0	
Kitchen	Warming Kitchen	Flooring - Tile Quarry	dish cleaning room off of lunch room	7	100	SF	\$0	
Kitchen	Cooking Kitchen	Lighting - Lay-In	1st Floor	7	16	SF	\$0	
Kitchen	Warming Kitchen	Lighting - Pendant/Surface	dish cleaning room off of lunch room	7	2	SF	\$0	
Kitchen	Warming Kitchen	Wall - Structural Glazed Tile	dish cleaning room off of lunch room	7	320	SF	\$0	
Kitchen	Cooking Kitchen	Wall - Structural Glazed Tile	1st Floor	7	1,090	SF	\$0	
Library	Library	Casework	Library support room	7	1	LF	\$0	
Library	Library	Casework	Library support room	7	20	LF	\$0	
Library	Library	Ceiling - Splined	Library support room	7	165	SF	\$0	
Library	Library	Flooring Tile/ Sheet	Library support room	7	165	SF	\$0	
Library	Library	Lighting - Pendant/ Surface	Library support room	7	4	SF	\$0	
Locker/Shower Room	Staff Restroom	Benches	mens - 3ed floor			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	Girls -East - 1st floor			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	womens 3ed floor			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	womens at Gym			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	mens - 2ed floor			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	mens at Gym			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	Boys -East - 1st floor			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	West - Boys 3ed floor			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	West -Girls 3ed floor			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	West -Girls 2ed floor			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	West - Boys 2ed floor			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	assist principle			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	womens 2ed floor			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	West -Girls 1st floor			LF	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Benches	112			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	Principals			LF	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Benches	110			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	Kitchen locker			LF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Staff Restroom	Benches	Engineers toilet			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	Boys at Gym			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	Girls at Gym			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	West - Boys 1st floor			LF	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Lockers	110			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	Boys at Gym			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	West -Girls 1st floor			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	West - Boys 1st floor			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	Girls at Gym			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	West - Boys 2ed floor			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Engineers toilet			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Kitchen locker	6	4	EA	\$196	
Locker/Shower Room	Staff Restroom	Lockers	assist principle			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Lockers	112			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	West -Girls 2ed floor			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	West -Girls 3ed floor			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Principals			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	Girls -East - 1st floor			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	mens at Gym			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	womens 2ed floor			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	mens - 2ed floor			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	mens - 3ed floor			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	womens at Gym			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	womens 3ed floor			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	West - Boys 3ed floor			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	Boys -East - 1st floor			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	mens - 3ed floor			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Early Childhood Student Restroom	Showers	110			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Showers	112			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	Principals			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	assist principle			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	womens at Gym			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	West - Boys 3ed floor			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	Kitchen locker			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	Engineers toilet	7	1	EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	Boys at Gym			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	Girls at Gym			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	West - Boys 1st floor			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	West -Girls 1st floor			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	West - Boys 2ed floor			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	womens 3ed floor			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	West -Girls 3ed floor			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	mens - 2ed floor			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	Boys -East - 1st floor			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	Girls -East - 1st floor			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	mens at Gym			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	womens 2ed floor			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	West -Girls 2ed floor			EA	\$0	
Lunchroom	Lunchroom	Ceiling - Lay-In	teachers lunch room	7	486	SF	\$0	
Lunchroom	Lunchroom	Ceiling - Splined	1st Floor	7	2,220	SF	\$0	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	1st Floor	7	2,220	SF	\$0	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	teachers lunch room	6	486	SF	\$695	
Lunchroom	Lunchroom	Lighting - Lay-In	teachers lunch room	7	9	SF	\$0	
Lunchroom	Lunchroom	Lighting - Pendant/Surface	1st Floor	7	20	SF	\$0	
Lunchroom	Warming Kitchen	Serving Line	dish cleaning room off of lunch room			LF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lunchroom	Cooking Kitchen	Serving Line	1st Floor			LF	\$0	
Lunchroom	Lunchroom	Serving Line	1st Floor	7	20	LF	\$0	
Lunchroom	Lunchroom	Serving Line	teachers lunch room			LF	\$0	
Lunchroom	Lunchroom	Wall - Concrete Block	teachers lunch room	7	855	SF	\$0	
Lunchroom	Lunchroom	Wall - Concrete Block	1st Floor	7	2,256	SF	\$0	
MDF/IDF		Ventilation and Cooling	1st Floor	7	1	EA	\$0	
Mechanical/Service Rooms		Boiler Room	1st Floor	7	1,008	SF	\$0	
Mechanical/Service Rooms		Boiler Room	1st Floor	7	150	SF	\$0	
Mechanical/Service Rooms		Janitor's Closet	Mechanical Room	6	3	SF	\$14	
Mechanical/Service Rooms		Mechanical/Service Rooms	1st Floor	7	270	SF	\$0	
Mechanical/Service Rooms		Storage Room	Entire Building	7	1,340	SF	\$0	
Mechanical/Service Rooms		Vaults	1st Floor	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	Boys at Gym	6	130	SF	\$1,004	
Staff Restroom	Children's Standard Student Restroom	Accessories	West -Girls 1st floor	6	234	SF	\$1,807	
Staff Restroom	Staff Restroom	Accessories	Engineers toilet	6	40	SF	\$309	
Staff Restroom	Staff Restroom	Accessories	Kitchen locker	6	55	SF	\$425	
Staff Restroom	Staff Restroom	Accessories	assist principle	7	25	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	womens at Gym	7	112	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	112	7	20	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	Girls at Gym	6	130	SF	\$1,004	
Staff Restroom	Staff Restroom	Accessories	Principals	7	25	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	Girls -East - 1st floor	6	190	SF	\$1,467	
Staff Restroom	Staff Restroom	Accessories	mens - 3ed floor	6	50	SF	\$386	
Staff Restroom	Staff Restroom	Accessories	mens - 2ed floor	6	50	SF	\$386	
Staff Restroom	Staff Restroom	Accessories	womens 2ed floor	7	99	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	mens at Gym	7	112	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	womens 3ed floor	7	99	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	Boys -East - 1st floor	6	190	SF	\$1,467	
Staff Restroom	Children's Standard Student Restroom	Accessories	West - Boys 3ed floor	6	234	SF	\$1,807	
Staff Restroom	Children's Standard Student Restroom	Accessories	West -Girls 2ed floor	6	234	SF	\$1,807	
Staff Restroom	Children's Standard Student Restroom	Accessories	West -Girls 3ed floor	6	234	SF	\$1,807	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Accessories	West - Boys 2ed floor	6	234	SF	\$1,807	
Staff Restroom	Children's Standard Student Restroom	Accessories	West - Boys 1st floor	6	234	SF	\$1,807	
Staff Restroom	Early Childhood Student Restroom	Accessories	110	7	20	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	Engineers toilet	7	40	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	West - Boys 3ed floor	7	234	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Plaster/Drywall	112	7	20	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	Boys at Gym	7	130	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	Girls at Gym	7	130	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	West - Boys 1st floor	7	234	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	West -Girls 1st floor	7	234	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	West -Girls 3ed floor	7	234	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	West -Girls 2ed floor	7	234	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Plaster/Drywall	110	7	20	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	womens 3ed floor	7	99	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	Girls -East - 1st floor	7	190	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	mens at Gym	7	112	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	womens 2ed floor	7	99	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	mens - 2ed floor	7	50	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	mens - 3ed floor	7	50	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	womens at Gym	7	112	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	West - Boys 2ed floor	7	234	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	Boys -East - 1st floor	7	190	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	West - Boys 1st floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	West -Girls 1st floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	West - Boys 2ed floor	7	1	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Floor Drain	West -Girls 2ed floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	West -Girls 3ed floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	Girls at Gym	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	mens at Gym	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	West - Boys 3ed floor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	womens at Gym	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	Boys -East - 1st floor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	Principals			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	Girls -East - 1st floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	Boys at Gym	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	110			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	112			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	assist principle			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	Engineers toilet			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	Kitchen locker			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	West - Boys 1st floor	7	234	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	womens at Gym	7	112	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	mens - 3ed floor	7	50	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	mens - 2ed floor	7	50	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	womens 2ed floor	7	99	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	Boys -East - 1st floor	6	190	SF	\$484	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	Girls -East - 1st floor	6	190	SF	\$484	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	West -Girls 2ed floor	7	234	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	womens 3ed floor	7	99	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	West -Girls 1st floor	7	234	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile Ceramic/Porcelain	110	7	20	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	West - Boys 3ed floor	6	234	SF	\$596	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	West - Boys 2ed floor	6	234	SF	\$596	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	West -Girls 3ed floor	7	234	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	mens at Gym	7	112	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	Girls at Gym	7	130	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	Engineers toilet	7	40	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	Kitchen locker	7	55	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile Ceramic/Porcelain	112	7	20	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	Boys at Gym	7	130	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	Principals	7	25	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	assist principle	7	25	SF	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	womens at Gym	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	mens - 3ed floor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	womens 3ed floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	Boys -East - 1st floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	West -Girls 3ed floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	West - Boys 3ed floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	West -Girls 2ed floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	West - Boys 2ed floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	Boys at Gym	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	Principals			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	Girls at Gym	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	mens - 2ed floor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	Engineers toilet			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	Kitchen locker			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	assist principle			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	womens 2ed floor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	mens at Gym	5	1	EA	\$716	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	Girls -East - 1st floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	West -Girls 1st floor	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Hand Dryer	110			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	West - Boys 1st floor	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Hand Dryer	112			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	110	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	mens at Gym	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	mens - 2ed floor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	mens - 3ed floor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	womens at Gym	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	womens 3ed floor	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	Boys at Gym	6	1	EA	\$372	
Staff Restroom	Early Childhood Student Restroom	Lavatory	112	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	womens 2ed floor	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	West - Boys 1st floor	6	2	EA	\$744	
Staff Restroom	Children's Standard Student Restroom	Lavatory	West - Boys 3ed floor	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	Girls -East - 1st floor	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Engineers toilet	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Principals	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	West - Boys 2ed floor	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	West -Girls 1st floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	Boys -East - 1st floor	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	West - Boys 1st floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	West -Girls 2ed floor	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	Girls at Gym	7	1	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Lavatory	Girls at Gym	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Lavatory	West -Girls 3ed floor	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	Boys at Gym	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Kitchen locker	6	1	EA	\$372	
Staff Restroom	Staff Restroom	Lavatory	assist principle	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	West -Girls 1st floor	6	2	EA	\$744	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	Boys -East - 1st floor	7	4	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	Girls -East - 1st floor	7	4	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	West -Girls 3ed floor	6	4	SF	\$3	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	West - Boys 1st floor	7	4	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	womens at Gym	7	3	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	mens - 3ed floor	7	2	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	mens - 2ed floor	7	2	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	womens 2ed floor	7	2	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	mens at Gym	7	3	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	West - Boys 3ed floor	7	4	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	Kitchen locker	7	2	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	West - Boys 2ed floor	7	4	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Pendant/ Surface	112	4	1	SF	\$4	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	West -Girls 2ed floor	6	4	SF	\$3	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	Engineers toilet	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	Boys at Gym	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	Girls at Gym	4	1	SF	\$4	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	Girls at Gym	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	womens 3ed floor	7	2	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	West -Girls 1st floor	7	4	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	Boys at Gym	4	1	SF	\$4	
Staff Restroom	Early Childhood Student Restroom	Lighting - Pendant/ Surface	110	4	1	SF	\$4	
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	Principals	4	1	EA	\$322	incandescent
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	assist principle	4	1	EA	\$322	incandescent
Staff Restroom	Children's Standard Student Restroom	Partitions	Girls -East - 1st floor	7	5	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	mens at Gym	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	womens 2ed floor	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	mens - 2ed floor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	mens - 3ed floor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	womens 3ed floor	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	Boys -East - 1st floor	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	womens at Gym	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	assist principle			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Partitions	112			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	Principals			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	West - Boys 3ed floor	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	Kitchen locker			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	Engineers toilet			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	Boys at Gym	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	Girls at Gym	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	West - Boys 1st floor	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	West -Girls 1st floor	7	6	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	West - Boys 2ed floor	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	West -Girls 2ed floor	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	West -Girls 3ed floor	7	5	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Partitions	110			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	mens - 3ed floor	7	1	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Urinals	mens - 2ed floor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Urinals	mens at Gym	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	Boys -East - 1st floor	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	West - Boys 3ed floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	West - Boys 3ed floor	5	2	EA	\$3,718	
Staff Restroom	Children's Standard Student Restroom	Urinals	West - Boys 2ed floor	5	2	EA	\$3,718	
Staff Restroom	Children's Standard Student Restroom	Urinals	West -Girls 3ed floor			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	Principals			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	West - Boys 2ed floor	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Urinals	112			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	West -Girls 2ed floor			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	assist principle			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	Kitchen locker			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	Engineers toilet			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	Boys at Gym	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	Boys at Gym	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Urinals	West - Boys 1st floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	West -Girls 1st floor			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	West - Boys 1st floor	5	2	EA	\$3,718	
Staff Restroom	Early Childhood Student Restroom	Urinals	110			EA	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	Engineers toilet	7	208	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Wall - Concrete Block	110	7	54	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Wall - Concrete Block	112	7	54	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	Principals	7	160	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	assist principle	7	160	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	Boys -East - 1st floor	7	666	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	West -Girls 3ed floor	6	738	SF	\$5,277	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	West -Girls 2ed floor	7	738	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	West - Boys 2ed floor	6	738	SF	\$5,277	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	West -Girls 1st floor	6	738	SF	\$5,277	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	West - Boys 1st floor	6	738	SF	\$5,277	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	Kitchen locker	7	336	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	womens 2ed floor	7	400	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Wall - Structural Glazed Tile	110	7	90	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	Girls -East - 1st floor	7	666	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Wall - Structural Glazed Tile	112	7	90	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	mens - 3ed floor	7	240	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	West - Boys 3ed floor	6	738	SF	\$5,277	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	womens 3ed floor	7	400	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	mens - 2ed floor	7	240	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	Girls at Gym	7	442	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	mens at Gym	6	384	SF	\$977	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	Boys at Gym	7	442	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	womens at Gym	6	384	SF	\$977	
Staff Restroom	Staff Restroom	Water Closet	womens 3ed floor	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	assist principle	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	Principals	5	1	EA	\$1,859	Broken sewer vent
Staff Restroom	Staff Restroom	Water Closet	Kitchen locker	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	110	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	womens at Gym	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	mens - 3ed floor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	mens - 2ed floor	7	1	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Water Closet	Boys -East - 1st floor	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	mens at Gym	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	Girls -East - 1st floor	7	5	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	112	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	Engineers toilet	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	Boys at Gym	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	Girls at Gym	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	West - Boys 1st floor	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	West -Girls 1st floor	7	6	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	West - Boys 2ed floor	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	West -Girls 2ed floor	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	West -Girls 3ed floor	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	West - Boys 3ed floor	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	womens 2ed floor	7	2	EA	\$0	
Theater	Auditorium - Dedicated	Ceiling - Plaster/Drywall	1st Floor	7	750	SF	\$0	
Theater	Auditorium - Dedicated	Ceiling - Splined	1st Floor	7	3,250	SF	\$0	
Theater	Auditorium - Dedicated	Flooring - Tile/Sheet	1st Floor	7	3,250	SF	\$0	
Theater	Auditorium - Dedicated	Flooring - Wood	1st Floor	7	750	SF	\$0	
Theater	Auditorium - Dedicated	Lighting - Lay-In	1st Floor	7	45	SF	\$0	
Theater	Auditorium - Dedicated	Lighting - Wall Mounted	1st Floor	7	18	EA	\$0	
Theater	Auditorium - Dedicated	Stage	1st Floor	7	630	SF	\$0	
Theater	Auditorium - Dedicated	Wall - Concrete Block	1st Floor	7	1,296	SF	\$0	
Theater	Auditorium - Dedicated	Wall - Concrete Block	1st Floor	7	3,200	SF	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
INTERIOR Sub Total							\$81,272	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		6	4	LF	\$143	
Casework	Classroom	Casework		6	4	LF	\$143	
Casework	Classroom	Casework		6	4	LF	\$143	
Casework	Classroom	Casework		6	4	LF	\$143	
Casework	Classroom	Casework		6	4	LF	\$143	
Casework	Classroom	Casework		5	34	LF	\$6,078	Wall cabinets are pulling away from the wall. Should be replaced or at least re installed.
Casework	Classroom	Casework		7	70	LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework		6	4	LF	\$143	
Casework	Classroom	Casework		6	4	LF	\$143	
Casework	Classroom	Casework		6	4	LF	\$143	
Casework	Classroom	Casework		6	4	LF	\$143	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework		6	4	LF	\$143	
Casework	Classroom	Casework		6	4	LF	\$143	
Casework	Classroom	Casework		6	4	LF	\$143	
Casework	Classroom	Casework		6	20	LF	\$715	
Casework	Classroom	Casework		6	20	LF	\$715	
Casework	Classroom	Casework		7	70	LF	\$0	
Casework	Classroom	Casework		6	4	LF	\$143	
Casework	Classroom	Casework		6	4	LF	\$143	
Casework	Classroom	Casework		6	4	LF	\$143	
Casework	Classroom	Casework		6	32	LF	\$1,144	
Casework	Classroom	Casework		6	32	LF	\$1,144	
Casework	Classroom	Casework		6	4	LF	\$143	
Casework	Classroom	Casework		6	20	LF	\$715	
Casework	Classroom	Casework		6	4	LF	\$143	
Casework	Classroom	Casework		6	4	LF	\$143	
Casework	Classroom	Casework		6	4	LF	\$143	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		6	4	LF	\$143	
Casework	Classroom	Casework		6	4	LF	\$143	
Casework	Classroom	Casework		6	4	LF	\$143	
Casework	Classroom	Casework		6	4	LF	\$143	
Casework	Classroom	Casework		6	4	LF	\$143	
Casework	Classroom	Casework		6	4	LF	\$143	
Casework	Classroom	Casework		6	4	LF	\$143	
Casework	Classroom	Casework		6	4	LF	\$143	
Ceiling	Classroom	Ceiling		7	837	SF	\$0	
Ceiling	Classroom	Splined Ceiling		6	837	SF	\$1,795	
Ceiling	Classroom	Splined Ceiling		7	837	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	837	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	837	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	837	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	837	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	837	SF	\$0	
Ceiling	Classroom	Splined Ceiling		6	837	SF	\$1,795	
Ceiling	Classroom	Splined Ceiling		7	180	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	1,150	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	837	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	332	SF	\$0	
Ceiling	Classroom	Splined Ceiling		6	837	SF	\$1,795	
Ceiling	Classroom	Splined Ceiling		7	853	SF	\$0	
Ceiling	Classroom	Splined Ceiling		6	837	SF	\$1,795	
Ceiling	Classroom	Splined Ceiling		6	837	SF	\$1,795	
Ceiling	Classroom	Splined Ceiling		7	837	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	837	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	837	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	837	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	837	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	837	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	837	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	837	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	837	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	837	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	1,269	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	837	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	853	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	853	SF	\$0	
Ceiling	Classroom	Splined Ceiling		6	837	SF	\$1,795	
Ceiling	Classroom	Splined Ceiling		6	837	SF	\$1,795	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Ceiling	Classroom	Splined Ceiling		7	837	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	837	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	837	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	837	SF	\$0	
Ceiling	Classroom	Splined Ceiling		6	837	SF	\$1,795	
Ceiling	Classroom	Splined Ceiling		7	1,269	SF	\$0	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	0	LF	\$0	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	0	LF	\$0	
Chalk Board	Classroom	Chalk Board		4	0	LF	\$0	
Chalk Board	Lunchroom	Chalk Board	1st Floor	4		LF		
Chalk Board	Lunchroom	Chalk Board	teachers lunch room	4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	0	LF	\$0	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	0	LF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
CLASSROOM	Classroom	Science Lab Elements		7	2	SF	\$0	
Corridors	Corridors	Concrete Block	stair 2	7	162	SF	\$0	
Corridors	Corridors	Concrete Block	corr7	7	3,663	SF	\$0	
Corridors	Corridors	Concrete Block	stair 2	7	162	SF	\$0	
Corridors	Corridors	Concrete Block	vest 3	7	112	SF	\$0	
Corridors	Corridors	Concrete Block	Lobby	7	1,008	SF	\$0	
Corridors	Corridors	Concrete Block	Corr 3	7	612	SF	\$0	
Corridors	Corridors	Concrete Block	corr 8	7	3,663	SF	\$0	
Corridors	Corridors	Concrete Block	vest 1	7	144	SF	\$0	
Corridors	Corridors	Concrete Block	vest 2	7	180	SF	\$0	
Corridors	Corridors	Concrete Block	Corr 1	7	2,025	SF	\$0	
Corridors	Corridors	Concrete Block	corr 6	7	1,335	SF	\$0	
Corridors	Corridors	Concrete Block	corr 5	7	1,290	SF	\$0	
Corridors	Corridors	Drinking Fountains	vest 2			EA	\$0	
Corridors	Corridors	Drinking Fountains	corr 6			EA	\$0	
Corridors	Corridors	Drinking Fountains	Corr 2			EA	\$0	
Corridors	Corridors	Drinking Fountains	Corr 3			EA	\$0	
Corridors	Corridors	Drinking Fountains	Lobby			EA	\$0	
Corridors	Corridors	Drinking Fountains	corr 5			EA	\$0	
Corridors	Corridors	Drinking Fountains	vest 1			EA	\$0	
Corridors	Corridors	Drinking Fountains	vest 3			EA	\$0	
Corridors	Corridors	Drinking Fountains	stair 2			EA	\$0	
Corridors	Corridors	Drinking Fountains	stair 2			EA	\$0	
Corridors	Corridors	Drinking Fountains	Corr 1			EA	\$0	
Corridors	Corridors	Drinking Fountains	corr7			EA	\$0	
Corridors	Corridors	Drinking Fountains	corr 8			EA	\$0	
Corridors	Corridors	Floors	stair 2	7	891	SF	\$0	
Corridors	Corridors	Metal Panel	corr7	7	170	SF	\$0	
Corridors	Corridors	Metal Panel	corr 8	7	170	SF	\$0	
Corridors	Corridors	Pendant/Surface	Lobby	7	420	EA	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Pendant/Surface	corr 5	7	722	EA	\$0	
Corridors	Corridors	Pendant/Surface	Corr 2	7	1,818	EA	\$0	
Corridors	Corridors	Pendant/Surface	Corr 3	7	1,040	EA	\$0	
Corridors	Corridors	Pendant/Surface	Corr 1	7	900	EA	\$0	
Corridors	Corridors	Pendant/Surface	stair 2	7	63	EA	\$0	
Corridors	Corridors	Pendant/Surface	corr7	7	1,647	EA	\$0	
Corridors	Corridors	Pendant/Surface	corr 6	7	680	EA	\$0	
Corridors	Corridors	Pendant/Surface	stair 2	7	63	EA	\$0	
Corridors	Corridors	Pendant/Surface	corr 8	7	1,647	EA	\$0	
Corridors	Corridors	Pendant/Surface	vest 1	7	100	EA	\$0	
Corridors	Corridors	Pendant/Surface	vest 2	7	100	EA	\$0	
Corridors	Corridors	Pendant/Surface	vest 3	7	63	EA	\$0	
Corridors	Corridors	Plaster/Drywall	Lobby	7	64	SF	\$0	
Corridors	Corridors	Splined	stair 2	7	286	SF	\$0	
Corridors	Corridors	Splined	stair 2	7	286	SF	\$0	
Corridors	Corridors	Splined	corr 5	7	722	SF	\$0	
Corridors	Corridors	Splined	corr 6	7	680	SF	\$0	
Corridors	Corridors	Splined	vest 1	7	100	SF	\$0	
Corridors	Corridors	Splined	vest 2	7	140	SF	\$0	
Corridors	Corridors	Splined	vest 3	7	63	SF	\$0	
Corridors	Corridors	Stair Handrails	corr7			LF	\$0	
Corridors	Corridors	Stair Handrails	corr 6			LF	\$0	
Corridors	Corridors	Stair Handrails	corr 5			LF	\$0	
Corridors	Corridors	Stair Handrails	Corr 3			LF	\$0	
Corridors	Corridors	Stair Handrails	stair 2	7	55	LF	\$0	
Corridors	Corridors	Stair Handrails	Lobby			LF	\$0	
Corridors	Corridors	Stair Handrails	corr 8			LF	\$0	
Corridors	Corridors	Stair Handrails	vest 1			LF	\$0	
Corridors	Corridors	Stair Handrails	vest 2			LF	\$0	
Corridors	Corridors	Stair Handrails	Corr 2			LF	\$0	
Corridors	Corridors	Stair Handrails	stair 2	7	65	LF	\$0	
Corridors	Corridors	Stair Handrails	Corr 1			LF	\$0	
Corridors	Corridors	Stair Handrails	vest 3			LF	\$0	
Corridors	Corridors	Stairs	corr 8			EA	\$0	
Corridors	Corridors	Stairs	Corr 3			EA	\$0	
Corridors	Corridors	Stairs	Lobby			EA	\$0	
Corridors	Corridors	Stairs	corr 5			EA	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Stairs	corr7			EA	\$0	
Corridors	Corridors	Stairs	vest 1			EA	\$0	
Corridors	Corridors	Stairs	vest 2			EA	\$0	
Corridors	Corridors	Stairs	vest 3			EA	\$0	
Corridors	Corridors	Stairs	Corr 1			EA	\$0	
Corridors	Corridors	Stairs	corr 6			EA	\$0	
Corridors	Corridors	Stairs	Corr 2			EA	\$0	
Corridors	Corridors	Structural Glazed Tile	stair 2	7	1,705	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	stair 2	7	1,705	SF	\$0	
Corridors	Corridors	Student Lockers	corr 8			EA	\$0	
Corridors	Corridors	Student Lockers	stair 2			EA	\$0	
Corridors	Corridors	Student Lockers	stair 2			EA	\$0	
Corridors	Corridors	Student Lockers	Corr 2			EA	\$0	
Corridors	Corridors	Student Lockers	vest 3			EA	\$0	
Corridors	Corridors	Student Lockers	vest 2			EA	\$0	
Corridors	Corridors	Student Lockers	vest 1			EA	\$0	
Corridors	Corridors	Student Lockers	Corr 1			EA	\$0	
Corridors	Corridors	Student Lockers	corr7			EA	\$0	
Corridors	Corridors	Student Lockers	corr 6			EA	\$0	
Corridors	Corridors	Student Lockers	corr 5			EA	\$0	
Corridors	Corridors	Student Lockers	Lobby			EA	\$0	
Corridors	Corridors	Student Lockers	Corr 3			EA	\$0	
Corridors	Corridors	Terrazzo	vest 2	7	140	SF	\$0	
Corridors	Corridors	Terrazzo	vest 3	7	63	SF	\$0	
Corridors	Corridors	Terrazzo	stair 2	7	70	SF	\$0	
Corridors	Corridors	Terrazzo	vest 1	7	100	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	Corr 2	7	1,818	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	Corr 1	7	900	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	stair 2	7	821	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	corr 8	7	1,647	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	corr7	7	1,647	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	corr 6	7	680	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	corr 5	7	722	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	Lobby	7	420	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	Corr 3	7	1,040	SF	\$0	
Corridors	Corridors	Walls	Corr 2	7	4,086	SF	\$0	
Corridors	Corridors	Walls	Corr 2	7	90	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors Ceiling	Corridors	Plaster/Drywall	corr7	7	1,647	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	Lobby	7	420	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	corr 8	7	1,647	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	Corr 2	7	1,818	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	stair 2	7	242	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	Corr 3	7	1,040	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	Corr 1	7	900	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	stair 2	7	242	SF	\$0	
Stairs	Corridors	Tile	stair 2	5	40	SF	\$755	
Stairs	Corridors	Tile	stair 2	5	40	SF	\$755	
Floor	Classroom	Carpet		7	332	SF	\$0	
Floor	Classroom	Carpet		7	1,269	SF	\$0	
Floor	Classroom	Carpet		7	853	SF	\$0	
Floor	Classroom	Carpet		7	1,269	SF	\$0	
Floor	Classroom	Floor		7	927	SF	\$0	
Floor	Classroom	Tile/Sheet		7	837	SF	\$0	
Floor	Classroom	Tile/Sheet		7	837	SF	\$0	
Floor	Classroom	Tile/Sheet		7	837	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,269	SF	\$0	
Floor	Classroom	Tile/Sheet		7	837	SF	\$0	
Floor	Classroom	Tile/Sheet		7	837	SF	\$0	
Floor	Classroom	Tile/Sheet		7	837	SF	\$0	
Floor	Classroom	Tile/Sheet		7	837	SF	\$0	
Floor	Classroom	Tile/Sheet		7	837	SF	\$0	
Floor	Classroom	Tile/Sheet		7	180	SF	\$0	
Floor	Classroom	Tile/Sheet		7	837	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,150	SF	\$0	
Floor	Classroom	Tile/Sheet		6	837	SF	\$1,197	
Floor	Classroom	Tile/Sheet		6	837	SF	\$1,197	
Floor	Classroom	Tile/Sheet		6	837	SF	\$1,197	
Floor	Classroom	Tile/Sheet		6	837	SF	\$1,197	
Floor	Classroom	Tile/Sheet		6	837	SF	\$1,197	
Floor	Classroom	Tile/Sheet		6	837	SF	\$1,197	
Floor	Classroom	Tile/Sheet		7	837	SF	\$0	
Floor	Classroom	Tile/Sheet		7	837	SF	\$0	
Floor	Classroom	Tile/Sheet		7	853	SF	\$0	
Floor	Classroom	Tile/Sheet		7	837	SF	\$0	
Floor	Classroom	Tile/Sheet		7	837	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting	Classroom	Pendant/Surface		7	20	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	20	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	20	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	20	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	20	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	20	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	20	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	20	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	20	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	20	EA	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	0	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Lunchroom	Marker Board	1st Floor			LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	0	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	0	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Lunchroom	Marker Board	teachers lunch room			LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
RESTROOM_CEILING	Staff Restroom	Restroom Ceiling	Principals		25	SF	\$0	
RESTROOM_CEILING	Staff Restroom	Restroom Ceiling	assist principle		25	SF	\$0	
RESTROOM_CEILING	Staff Restroom	Restroom Ceiling	Kitchen locker		55	SF	\$0	
Wall	Classroom	Concrete Block		7	1,213	SF	\$0	
Wall	Classroom	Concrete Block		7	877	SF	\$0	
Wall	Classroom	Concrete Block		5	243	SF	\$1,835	
Wall	Classroom	Concrete Block		7	634	SF	\$0	
Wall	Classroom	Concrete Block		7	877	SF	\$0	
Wall	Classroom	Concrete Block		7	835	SF	\$0	
Wall	Classroom	Concrete Block		7	835	SF	\$0	
Wall	Classroom	Concrete Block		7	1,213	SF	\$0	
Wall	Classroom	Concrete Block		7	877	SF	\$0	
Wall	Classroom	Concrete Block		7	844	SF	\$0	
Wall	Classroom	Concrete Block		7	877	SF	\$0	
Wall	Classroom	Concrete Block		7	680	SF	\$0	
Wall	Classroom	Concrete Block		7	877	SF	\$0	
Wall	Classroom	Concrete Block		7	877	SF	\$0	
Wall	Classroom	Concrete Block		7	568	SF	\$0	
Wall	Classroom	Concrete Block		7	877	SF	\$0	
Wall	Classroom	Concrete Block		7	835	SF	\$0	
Wall	Classroom	Concrete Block		7	637	SF	\$0	
Wall	Classroom	Concrete Block		5	243	SF	\$1,835	
Wall	Classroom	Concrete Block		7	877	SF	\$0	
Wall	Classroom	Concrete Block		7	877	SF	\$0	
Wall	Classroom	Concrete Block		5	243	SF	\$1,835	
Wall	Classroom	Concrete Block		5	339	SF	\$2,560	
Wall	Classroom	Concrete Block		7	945	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Concrete Block		6	985	SF	\$2,817	
Wall	Classroom	Concrete Block		5	243	SF	\$1,835	
Wall	Classroom	Concrete Block		7	702	SF	\$0	
Wall	Classroom	Concrete Block		7	877	SF	\$0	
Wall	Classroom	Concrete Block		7	877	SF	\$0	
Wall	Classroom	Concrete Block		7	877	SF	\$0	
Wall	Classroom	Concrete Block		7	877	SF	\$0	
Wall	Classroom	Concrete Block		7	877	SF	\$0	
Wall	Classroom	Concrete Block		7	877	SF	\$0	
Wall	Classroom	Concrete Block		7	877	SF	\$0	
Wall	Classroom	Concrete Block		7	877	SF	\$0	
Wall	Classroom	Concrete Block		7	877	SF	\$0	
Wall	Classroom	Concrete Block		7	877	SF	\$0	
Wall	Classroom	Concrete Block		7	877	SF	\$0	
Wall	Classroom	Concrete Block		7	877	SF	\$0	
Wall	Classroom	Concrete Block		7	877	SF	\$0	
Wall	Classroom	Concrete Block		7	877	SF	\$0	
Wall	Classroom	Concrete Block		7	877	SF	\$0	
Wall	Classroom	Concrete Block		7	877	SF	\$0	
Wall	Classroom	Concrete Block		7	877	SF	\$0	
Wall	Classroom	Wall		5	243	SF	\$1,147	
Wall	Classroom	Wall		7	538	SF	\$0	
Wall	Classroom	Wall		7	538	SF	\$0	
Wall	Classroom	Wall		7	634	SF	\$0	
ROOM Sub Total							\$97,878	
Building Main Sub Total							\$2,298,766	

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Athletic		Basketball - Asphalt	Site ζ West	6	9,630	SF	\$7,299	
Civil/Drainage		Catch Basin	Entire Site	7	5	EA	\$0	
Civil/Drainage		Site Manhole	Entire Site	7	5	EA	\$0	
Fencing		Chain Link	Site ζ West	4	318	LF	\$34,106	
Fencing		Chain Link	Parking Lot	7	122	LF	\$0	
Fencing		Chain Link	Site - South & Courtyard	5	354	LF	\$12,656	
Fencing		Ornamental Iron	Entire Site	6	1,416	LF	\$26,728	Rusty / Needs refinishing
Fencing		Wood Fencing w/ Steel Frame	Parking Lot	7	100	LF	\$0	
Landscape		Asphalt Play Area/Hardscape	Site ζ West	6	29,960	SF	\$25,706	
Landscape		Benches	Courtyard	7	5	EA	\$0	

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Landscape		Grass	Site - East & North	7	14,305	SF	\$0	
Landscape		Hardscape - Concrete	Site ζ West	4	920	SF	\$17,366	
Landscape		Hardscape - Concrete	Entire Site	7	6,720	SF	\$0	
Landscape		Parkway trees	Entire Site	7	17	EA	\$0	
Landscape		Planting Beds/ Areas	Entire Site	7	10,340	SF	\$0	
Parking Lot		Asphalt	Site ζ South	6	14,520	SF	\$12,458	
Parking Lot		Trash Enclosure	Site ζ South	7	888	SF	\$0	
Playground		Playground Equipment - Combo 3-12	Site ζ West	7	1	EA	\$0	
Playground		Playground Surfacing - Poured Surface	Site ζ West	6	2,400	SF	\$6,349	Holes need repair
Sidewalks		Internal Walks	Courtyard	5	70	LF	\$2,180	
Sidewalks		Internal Walks	Site - East	7	90	LF	\$0	
Sidewalks		Perimeter Sidewalks	Entire Site	7	10,435	SF	\$0	
Signage		Flag Pole	Site ζ North	7	1	EA	\$0	
Signage		Marquee - Free Standing Back Lighted	Site - Northeast	6	1	EA	\$0	
SITE Sub Total							\$144,847	
SITE Sub Total							\$144,847	

Total Campus Need ^{2 3} \$2,443,613

¹ It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

² As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

³ The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Building: Main														
101	837		7	14	46	167	56		N	N	Y	Classroom		
102	837		7	14	46	167	56		N	N	Y	Classroom		
103	837		7	14	46	167	56		N	N	Y	Classroom		
104	837		7	14	46	167	56	1	N	N	Y	Classroom		
105	837		7	14	46	167	56		N	N	Y	Classroom		
106	837		7	14	46	167	56		N	N	Y	Classroom		
107	837		7	14	46	167	56		N	N	Y	Classroom		
108	837		7	14	46	167	56		N	N	Y	Classroom		
109	837		7	14	46	167	56		N	N	Y	Classroom		
110	1269			6	40	191	56		N	N	Y	Classroom		
111	837		7	14	46	167	56		N	N	Y	Classroom		
112	1269			6	40	191	56		N	N	Y	Classroom		
113	837		6	14	40	191	56		N	N	Y	Classroom		
115	837		6	14	40	191	56		N	N	Y	Classroom		
117	837		6	14	40	191	56		N	N	Y	Classroom		
200	332		15	30	40	62	12		N	N	N	Classroom		
201	837		7	14	40	167	56		N	N	Y	Classroom		
202	837		7	14	40	167	56		N	N	Y	Classroom		
203	837		7	14	40	167	56		N	N	Y	Classroom		
204	837		7	14	40	167	56		N	N	Y	Classroom		
205	1269		0	12	40	387	132		N	N	N	Classroom		
206	837		7	14	40	167	56		N	N	Y	Classroom		
207	927			14	46	167	56		N	N	Y	Classroom		
208	837		7	14	40	167	56		N	N	Y	Classroom		
209	837		7	14	40	167	56		N	N	Y	Classroom		
300	180		5		40	62	12		N	N	N	Classroom		
301	837		7	14	40	167	56		N	N	Y	Classroom		
302	1150		6	12	40	387	132		N	Y	Y	Classroom		
303	837		7	14	40	167	56		N	N	Y	Classroom		
304	837		7	14	40	167	56		N	N	Y	Classroom		
305	837		10	14	46	167	56		N	N	Y	Classroom		
306	837		7	14	40	167	56		N	N	Y	Classroom		
307	837		7	14	40	167	56		N	N	Y	Classroom		
308	837		7	14	40	167	56		N	N	Y	Classroom		
309	837		7	14	40	167	56		N	N	Y	Classroom		
311	837		7	14	40	167	56		N	N	Y	Classroom		

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	336			6					N	N	Y	Administrative Suites/Offices		CounselorOffice
Other	200			6					N	N	Y	Administrative Suites/Offices		Assistant Principal
Other	165								N	N	N	Library		Library support room
Other	20								N	N	N	Restroom	Early Childhood Student Restroom	112
Other	504			14					N	N	Y	Administrative Suites/Offices		Reception/office
Other	20								N	N	N	Restroom	Early Childhood Student Restroom	110
Other	420								N	N	N	Corridors		Lobby
Other	192			6					N	N	Y	Administrative Suites/Offices		principal office
Other	112								N	N	N	Restroom	Staff Restroom	mens at Gym
Other	50								N	N	N	Restroom	Staff Restroom	mens - 2ed floor
Other	50								N	N	N	Restroom	Staff Restroom	mens - 3ed floor
Other	112								N	N	N	Restroom	Staff Restroom	womens at Gym
Other	99								N	N	N	Restroom	Staff Restroom	womens 3ed floor
Other	99								N	N	N	Restroom	Staff Restroom	womens 2ed floor
Other	900								N	N	N	Corridors		Corr 1
Other	190								N	N	N	Restroom	Children's Standard Student Restroom	Boys -East - 1st floor
Other	1040								N	N	N	Corridors		Corr 3
Other	234								N	N	N	Restroom	Children's Standard Student Restroom	West - Boys 3ed floor
Other	722								N	N	N	Corridors		corr 5
Other	680								N	N	N	Corridors		corr 6
Other	1647								N	N	N	Corridors		corr7
Other	1647								N	N	N	Corridors		corr 8
Other	100								N	N	N	Corridors		vest 1
Other	140								N	N	N	Corridors		vest 2
Other	63								N	N	N	Corridors		vest 3
Other	286								N	N	N	Corridors		stair 2
Other	1818								N	N	N	Corridors		Corr 2
Other	486								N	N	N	Lunch & Multipurpose Room	Lunchroom	teachers lunch room
Other	25								N	N	N	Restroom	Staff Restroom	Principals
Other	25								N	N	N	Restroom	Staff Restroom	assist principle
Other	4000								N	N	N	Auditorium & Theater	Auditorium - Dedicated	1st Floor
Other	4212								N	N	N	Gymnasia	Standard Dedicated Gymnasium	1st Floor
Other	2220								N	N	N	Lunch & Multipurpose Room	Lunchroom	1st Floor
Other	564								N	N	N	Kitchen	Cooking Kitchen	1st Floor
Other	100								N	N	N	Kitchen	Warming Kitchen	dish cleaning room off of lunch room
Other	55								N	N	N	Restroom	Staff Restroom	Kitchen locker
Other	190								N	N	N	Restroom	Children's Standard Student Restroom	Girls -East - 1st floor

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	64			6					N	N	N	Administrative Suites/Offices		Engineers Office
Other	286								N	N	N	Corridors		stair 2
Other	40								N	N	N	Restroom	Staff Restroom	Engineers toilet
Other	130								N	N	N	Restroom	Children's Standard Student Restroom	Boys at Gym
Other	130								N	N	N	Restroom	Children's Standard Student Restroom	Girls at Gym
Other	234								N	N	N	Restroom	Children's Standard Student Restroom	West - Boys 1st floor
Other	234								N	N	N	Restroom	Children's Standard Student Restroom	West -Girls 1st floor
Other	234								N	N	N	Restroom	Children's Standard Student Restroom	West - Boys 2ed floor
Other	234								N	N	N	Restroom	Children's Standard Student Restroom	West -Girls 2ed floor
Other	234								N	N	N	Restroom	Children's Standard Student Restroom	West -Girls 3ed floor
Other	90			2					N	N	Y	Administrative Suites/Offices		Gym Office