

Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx.

Condition Rankings and Descriptions

Rank 7: The item/system is new or in good condition and no work is required.

Rank 6: The item/system requires general cleaning and/or routine maintenance.

Rank 5: The item/system requires repairs and has not reached the end of its serviceable life.

Rank 4: The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.

Rank 3: The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.

Rank 2: The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.

Rank 1: The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.¹

Definitions

Quantity means, for each item, the total number (or amount) of that item that exists and was evaluated.

Unit means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").

Cost means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.

For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.

Total Campus Need also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

Building: Main Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Canopy		Metal Canopy	bridge	7	1,500	SF	\$0	
Canopy		Metal Canopy	North Façade	7	310	SF	\$0	
Chimney		Metal Flue	east roof	7	24	LF	\$0	
Cornice		Cornice - Metal Projecting	North Façade	7	858	LF	\$0	
Doors		Exterior Steel Door	Entire Building	7	17	EA	\$0	
Doors		Store Front Door	West Entrances	7	2	EA	\$0	
Doors		Transom Lite	W & S entrances	7	2	EA	\$0	
Entrance		Entrance Controls - Audio	N & S	7	2	EA	\$0	
Foundation		Concrete Foundation	Entire Building	7	1,050	LF	\$0	
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	14	EA	\$3,003	
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	31	EA	\$6,650	
Lighting		Exterior Lights - Wall Mounted	Entire Site	6	24	EA	\$5,148	
Lintels		Lintels - Steel	Entire Building	7	998	LF	\$0	
Parapet		Coping - Metal	Entire Building	7	484	LF	\$0	

Building: Main
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Parapet		Coping - Stone	Entire Building	7	1,500	LF	\$0	
Parapet		Parapet < 16" Height	Entire Building	7	300	LF	\$0	
Parapet		Parapet > 30" Height	Entire Building	7	346	LF	\$0	
Parapet		Parapet 16" to 30" Height	Entire Building	7	532	LF	\$0	
Roof System		Interior Downspouts	Entire Building	6	1,737	LF	\$0	
Roof System		Modified Bitumen Roof	Entire Building	6	35,100	SF	\$248,455	
Roof System		Roof Structure: Steel/Metal Deck/Concrete Topping	Entire Building	7	35,100	SF	\$0	
Superstructure		Metal Deck/Concrete Topping	Entire Building	7	115,000	SF	\$0	
Walls		Brick	Entire Building	7	37,502	SF	\$0	
Walls		Prefabricated Metal Panel Wall	roof and bridge	7	1,365	SF	\$0	
Walls		Stone - Cut	base and bands	7	11,180	SF	\$0	
Windows		Clerestory - Glass Double-Pane	S at roof	7	110	SF	\$0	
Windows		Curtain wall - Glazed Double Pane	Entire Building	7	11,940	SF	\$0	
Windows		Curtain wall - Insulated panel	Entire Building	7	7,514	SF	\$0	
Windows		Curtain wall - Louver	masonry walls	7	1,926	SF	\$0	
Windows		Curtain wall - Windows	Entire Building	7	1,160	SF	\$0	
Windows		Storefront Windows	West Façade	7	143	SF	\$0	
Windows		Window - Guards perforated	Entire Building	7	3,365	SF	\$0	
Windows		Windows - Decorative	E & W elevations	7	180	SF	\$0	
Windows		Windows - Sash Aluminum Double-pane	Entire Building	7	4,660	SF	\$0	
EXTERIOR Sub Total							\$263,256	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	1st Floor	5	1	EA	\$4,433	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	5	21,643	SF	\$27,236	
Emergency System		Emergency A/C power - Gym and Lunch rooms	1st Floor	5	4,537	SF	\$5,190	
Emergency System		Emergency A/C power - Students Toilets	Entire Building	5	2,720	SF	\$3,890	
Emergency System		Emergency Battery Packs - Corridors and Stairs	Penthouse	6	1	EA	\$107	Preventive Maintenance Needed
Emergency System		Emergency Battery Packs - Corridors and Stairs	Entire Building	6	59	EA	\$6,328	Preventive Maintenance Needed
Emergency System		Emergency Battery Packs - Lunchroom and Gym	1st Floor	6	5	EA	\$536	Preventive Maintenance Needed
Emergency System		Emergency Battery Packs - Lunchroom and Gym	1st Floor	6	3	EA	\$322	Preventive Maintenance Needed
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	6	55	EA	\$12,820	Preventive Maintenance Needed

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Exit Signs - Corridors and Stairs	Penthouse	6	2	EA	\$466	Preventive Maintenance Needed.
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st Floor	6	2	EA	\$466	Preventive Maintenance Needed
Emergency System		Independent Electrical Service for emergency power	1st Floor	5	1	EA	\$5,005	
Emergency System		Public Announcement System	Entire Building	6	156,400	SF	\$93,934	Preventive Maintenance Needed
Emergency System		Security System - CCTV	Entire Building	6	156,400	SF	\$223,652	Preventive Maintenance Needed
Main Service		Main Electrical service 2000 to 3000 A 277/480/3PH	1st Floor	6	1	EA	\$30,388	Preventive Maintenance Needed
Power Distribution		Lighting and power panels	2nd Floor	6	1	EA	\$715	Preventive Maintenance Needed
Power Distribution		Lighting and power panels	4th Floor	6	1	EA	\$715	Preventive Maintenance Needed
Power Distribution		Lighting and power panels	1st Floor	6	1	EA	\$715	Preventive Maintenance Needed
Power Distribution		Lighting and power panels	2nd Floor	6	2	EA	\$1,430	Preventive Maintenance Needed
Power Distribution		Lighting and power panels	1st Floor	6	1	EA	\$715	Preventive Maintenance Needed
Power Distribution		Lighting and power panels	4th Floor	6	1	EA	\$715	Preventive Maintenance Needed
Power Distribution		Lighting and power panels	3rd Floor	6	2	EA	\$1,430	Preventive Maintenance Needed
Power Distribution		Lighting and power panels	3rd Floor	6	1	EA	\$715	Preventive Maintenance Needed
Power Distribution		Lighting and power panels	3rd Floor	6	1	EA	\$715	Preventive Maintenance Needed
Power Distribution		Lighting and power panels	Electrical Room	6	1	EA	\$715	Preventive Maintenance Needed
Power Distribution		Lighting and power panels	2nd Floor	6	1	EA	\$715	Preventive Maintenance Needed
Power Distribution		Lighting and power panels	4th Floor	6	1	EA	\$715	Preventive Maintenance Needed
Power Distribution		Lighting and power panels	4th Floor	6	1	EA	\$715	Preventive Maintenance Needed
Power Distribution		Lighting and power panels	Penthouse	6	1	EA	\$715	Preventive Maintenance Needed
Power Distribution		Lighting and power panels	1st Floor	6	1	EA	\$715	Preventive Maintenance Needed
Power Distribution		Lighting and power panels	2nd Floor	6	1	EA	\$715	Preventive Maintenance Needed

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Power Distribution		Lighting and power panels	1st Floor	6	1	EA	\$715	Preventive Maintenance Needed
Power Distribution		Lighting and power panels	2nd Floor	6	1	EA	\$715	Preventive Maintenance Needed
Power Distribution		Lighting and power panels	2nd Floor	6	1	EA	\$715	Preventive Maintenance Needed
Power Distribution		Lighting and power panels	3rd Floor	6	1	EA	\$715	Preventive Maintenance Needed
Power Distribution		Lighting and power panels	4th Floor	6	1	EA	\$715	Preventive Maintenance Needed
Power Distribution		Lighting and power panels	2nd Floor	6	1	EA	\$715	Preventive Maintenance Needed
Power Distribution		Main distribution panels 400-600 amp	1st Floor	6	1	EA	\$1,430	Preventive Maintenance Needed
Power Distribution		Main distribution panels 400-600 amp	1st Floor	6	2	EA	\$2,860	Preventive Maintenance Needed
Power Distribution		Main distribution panels 400-600 amp	4th Floor	6	1	EA	\$1,430	Preventive Maintenance Needed
Power Distribution		Main distribution panels 400-600 amp	Penthouse	6	1	EA	\$1,430	Preventive Maintenance Needed
Power Distribution		Main distribution panels 400-600 amp	2nd Floor	6	1	EA	\$1,430	Preventive Maintenance Needed
Power Distribution		Main distribution panels above 600 amp	1st Floor	6	1	EA	\$2,145	Preventive Maintenance Needed
Power Distribution		Main distribution panels above 600 amp	3rd Floor	6	1	EA	\$2,145	Preventive Maintenance Needed
Power Distribution		Main distribution panels above 600 amp	1st Floor	6	1	EA	\$2,145	Preventive Maintenance Needed
Power Distribution		Main distribution panels less than 400 amp	Penthouse	6	1	EA	\$1,216	Preventive Maintenance Needed
Power Distribution		Main distribution panels less than 400 amp	1st Floor	6	1	EA	\$1,216	Preventive Maintenance Needed
Power Distribution		Transformers 277/480-120/208	1st Floor	6	1	EA	\$1,144	Preventive Maintenance Needed
Power Distribution		Transformers 277/480-120/208	2nd Floor	6	1	EA	\$1,144	Preventive Maintenance Needed
Power Distribution		Transformers 277/480-120/208	1st Floor	6	1	EA	\$1,144	Preventive Maintenance Needed
Power Distribution		Transformers 277/480-120/208	1st Floor	6	1	EA	\$1,144	Preventive Maintenance Needed
Power Distribution		Transformers 277/480-120/208	4th Floor	6	1	EA	\$1,144	Preventive Maintenance Needed
ELECTRICAL Sub Total							\$455,098	

Building: Main
Category: FIRE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
-------	-----------	------	----------	------	----------	------	------	--------

Building: Main
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Entire Building	6	92,500	SF	\$33,069	Preventive Maintenance Needed
Sprinkler System		Sprinkler Heads	Entire Building	6	92,500	SF	\$5,291	Preventive Maintenance Needed
Sprinkler System		Wet Sprinkler System	Entire Building	6	92,500	SF	\$52,910	Preventive Maintenance Needed

FIRE PROTECTION Sub Total **\$91,270**

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Chillers - Air Cooled - Rotary/Screw type - Roof Mounted 201 to 300 tons	Main Roof	6	2	EA	\$120,120	Preventive Maintenance Needed.
Air Conditioning		Condensing Unit - Roof Mounted less than 5 tons	Main Roof	6	1	EA	\$858	Preventive Maintenance Needed.
Air Handling Systems		Air Handling Unit Package - Multi Zone - Hot Water 10,001 to 15,000 cfm	Mechanical Room	6	1	EA	\$7,436	Preventive Maintenance Needed.
Air Handling Systems		Air Handling Unit Package - Multi Zone - Hot Water above 30,000 cfm	Mechanical Room	6	1	EA	\$21,450	preventive maintenance needed
Air Handling Systems		Air Handling Unit Package - Multi Zone - Hot Water above 30,000 cfm	Mechanical Room	6	1	EA	\$21,450	Preventive Maintenance Needed.
Air Handling Systems		Air intake for all Air Handling Units except built up AHU	Mechanical Room	6	3	EA	\$4,290	Preventive Maintenance Needed.
Air Handling Systems		Fan Coil Unit - Hot Water and Chilled Water	Entire Building	6	5	EA	\$7,150	Preventive Maintenance Needed.
Air Handling Systems		Fan Power Box With Hot Water Coil	1st Floor	6	18	EA	\$6,950	Preventive Maintenance Needed.
Air Handling Systems		Fan Power Box With Hot Water Coil	2nd Floor	6	21	EA	\$8,108	Preventive Maintenance Needed.
Air Handling Systems		Fan Power Box With Hot Water Coil	4th Floor	6	20	EA	\$7,722	Preventive Maintenance Needed.
Air Handling Systems		Fan Power Box With Hot Water Coil	3rd Floor	6	15	EA	\$5,792	Preventive Maintenance Needed.
Air Handling Systems		Return Fans - Indoor greater than 20,000 CFM	Mechanical Room	6	2	EA	\$6,578	Preventive Maintenance Needed.
Air Handling Systems		Return Fans - Indoor less than 5,000 CFM	Mechanical Room	6	1	EA	\$715	Preventive Maintenance Needed.
Air Handling Systems		Variable Air Volume (VAV) Box With Hot Water Coil	4th Floor	6	1	EA	\$329	Preventive Maintenance Needed

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Handling Systems		Variable Air Volume (VAV) Box With Hot Water Coil	3rd Floor	6	6	EA	\$1,973	Preventive Maintenance Needed
Air Handling Systems		Variable Air Volume (VAV) Box With Hot Water Coil	2nd Floor	6	6	EA	\$1,973	Preventive Maintenance Needed
Air Handling Systems		Variable Air Volume (VAV) Box With Hot Water Coil	1st Floor	6	10	EA	\$3,289	Preventive Maintenance Needed
Boiler Systems		Boiler Assembly - Non-Condensing Flexible Tube Hot Water Boiler greater than 4,000 MBH	Mechanical Room	6	2	EA	\$33,462	Preventive Maintenance Needed.
Boiler Systems		Boiler Auxiliary Non-Condensing Hot Water Boiler greater than 4,000MBH	Mechanical Room	6	2	EA	\$13,156	Preventive Maintenance Needed.
Boiler Systems		Chemical Pot Feeder - Hot Water	Mechanical Room	6	1	EA	\$300	Preventive Maintenance Needed.
Boiler Systems		Combustion Dampers	Mechanical Room	6	2	EA	\$572	Preventive Maintenance Needed.
Boiler Systems		Glycol Feed System	Mechanical Room	6	1	EA	\$1,087	Preventive Maintenance Needed.
Heating Devices		Cabinet Heaters With Hot Water Coils	1st Floor	6	5	EA	\$2,503	Preventive Maintenance Needed.
Heating Devices		Fin Tube Hot Water	1st Floor	6	40	LF	\$686	Preventive Maintenance Needed.
Heating Devices		Fin Tube Hot Water	4th Floor	6	80	LF	\$1,373	Preventive Maintenance Needed.
Heating Devices		Fin Tube Hot Water	4th Floor	6	22	LF	\$378	Preventive Maintenance Needed.
Heating Devices		Fin Tube Hot Water	3rd Floor	6	22	LF	\$378	Preventive Maintenance Needed.
Heating Devices		Fin Tube Hot Water	1st Floor	6	37	LF	\$635	Preventive Maintenance Needed.
Heating Devices		Fin Tube Hot Water	2nd Floor	6	22	LF	\$378	Preventive Maintenance Needed.
Heating Devices		Unit Heater - Electric	1st Floor	6	1	EA	\$1,430	Preventive Maintenance Needed
Heating Devices		Unit Heater - Hot Water	Penthouse	6	1	EA	\$1,430	Preventive Maintenance Needed
Mechanical Plumbing		Piping - Hydronic Supply and Return - Copper	Entire Building	6	2,000	LF	\$33,748	Preventive Maintenance Needed.
Mechanical Plumbing		Pumps - Chilled Water 10 to 20 HP	Mechanical Room	6	2	EA	\$5,148	Preventive Maintenance Needed.
Mechanical Plumbing		Pumps - Chilled Water 10 to 20 HP	Mechanical Room	6	2	EA	\$5,148	Preventive Maintenance Needed.
Mechanical Plumbing		Pumps - Hot Water 11 to 20 HP	Mechanical Room	6	2	EA	\$5,148	Preventive Maintenance Needed.
Mechanical Plumbing		Pumps - Hot Water 11 to 20 HP	Mechanical Room	6	2	EA	\$5,148	Preventive Maintenance Needed.

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Mechanical Plumbing		Pumps - Hot Water 5 to 10 HP	Mechanical Room	7	3	EA	\$0	
Temperature Control		Direct Digital Control (DDC) System	1st Floor	5	156,400	SF	\$782,782	system in Community center does not function, building operated manually
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	6	103	EA	\$14,729	Preventive Maintenance Needed.
Ventilation		Exhaust Fan - Indoor	Mechanical Room	6	1	EA	\$501	Preventive Maintenance Needed.
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	6	1	EA	\$429	Preventive Maintenance Needed
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Main Roof	6	1	EA	\$429	Preventive Maintenance Needed.
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Main Roof	6	1	EA	\$229	Preventive Maintenance Needed.
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Main Roof	6	1	EA	\$229	Preventive Maintenance Needed.
Ventilation		Exhaust Fans - Roof mounted less than 500 CFM	Main Roof	6	1	EA	\$157	Preventive Maintenance Needed.
Ventilation		Exhaust Fans - Roof mounted less than 500 CFM	Mechanical Room	6	1	EA	\$157	Preventive Maintenance Needed.
Ventilation		Exhaust Fans - Roof mounted less than 500 CFM	Main Roof	6	1	EA	\$157	Preventive Maintenance Needed.
Ventilation		Type I Exhaust Hood - Kitchen or Culinary Arts	1st Floor	6	1	EA	\$1,716	Preventive Maintenance Needed
MECHANICAL Sub Total							\$1,139,804	

Building: Main
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas more than 300,000 BTU/HR	Mezzanine	6	3	EA	\$20,163	
Hot Water		Storage Tank more than 500 gallons	Mechanical Room	6	3	EA	\$22,308	Preventive Maintenance Needed
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	6	92,500	SF	\$10,582	Preventive Maintenance Needed
Piping		Domestic Piping - Cold Water Risers	Entire Building	6	92,500	SF	\$14,550	Preventive Maintenance Needed
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	6	92,500	SF	\$14,550	Preventive Maintenance Needed
Piping		Domestic Piping - Hot Water Risers	Entire Building	6	92,500	SF	\$14,550	Preventive Maintenance Needed
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	6	92,500	SF	\$21,164	Preventive Maintenance Needed

Building: Main
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	6	92,500	SF	\$18,519	Preventive Maintenance Needed
Piping		Sanitary Piping	Entire Building	6	92,500	SF	\$37,037	Preventive Maintenance Needed
Piping		Storm Piping	Entire Building	6	92,500	SF	\$19,841	Preventive Maintenance Needed
Piping		Vent Piping	Entire Building	6	92,500	SF	\$14,550	Preventive Maintenance Needed
PLUMBING Sub Total							\$207,815	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	3rd floor observation 3	7	455	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	109A engineers office	7	170	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	psychologists office across from 406	7	290	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	4th floor observation 4	7	455	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	303/ 300 shared prep room	7	390	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	307 office/ storage	7	290	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Media Room, 2nd Flr	7	1,102	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	2nd floor observation 2	6	455	SF	\$976	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	205 small office	7	290	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Main office on 1st floor	7	649	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	in Main Office	7	170	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Library Workroom in Library	7	218	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Asst. Principals office in Main Office	7	216	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Student Services office	7	140	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Principals office in Main Office	7	247	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Kitchen staff breakroom and lunchroom storage	7	396	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	309A office/ storage	6	170	SF	\$365	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	1st floor parent room (observation 1)	7	455	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	office located in Kitchen	7	105	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Conference Room in Main Office	7	202	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Faculty Lounge in Main Office	7	533	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Main office on 1st floor	7	184	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Conference Room in Main Office	7	202	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Main office on 1st floor	7	702	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Asst. Principals office in Main Office	7	216	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Principals office in Main Office	7	247	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Terrazzo	Main office on 1st floor	7	131	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Media Room, 2nd Flr	6	1,102	SF	\$1,576	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	303/ 300 shared prep room	7	390	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	psychologists office across from 406	7	290	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	1st floor parent room (observation 1)	7	455	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	307 office/ storage	7	290	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	3rd floor observation 3	7	455	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	309A office/ storage	7	170	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Library Workroom in Library	7	218	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	205 small office	7	290	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	4th floor observation 4	7	455	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Student Services office	7	140	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Faculty Lounge in Main Office	7	533	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	in Main Office	7	170	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Kitchen staff breakroom and lunchroom storage	7	396	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	2nd floor observation 2	7	455	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	109A engineers office	7	170	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	office located in Kitchen	7	105	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Library Workroom in Library	6	4	SF	\$3	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Kitchen staff breakroom and lunchroom storage	6	4	SF	\$3	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Main office on 1st floor	7	12	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Main office on 1st floor	7	8	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	in Main Office	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Faculty Lounge in Main Office	7	8	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Student Services office	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	307 office/ storage	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Asst. Principals office in Main Office	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	office located in Kitchen	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	1st floor parent room (observation 1)	7	6	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	309A office/ storage	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Media Room, 2nd Flr	7	16	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	3rd floor observation 3	7	6	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	109A engineers office	7	2	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	303/ 300 shared prep room	7	3	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	205 small office	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	2nd floor observation 2	7	6	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Conference Room in Main Office	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	psychologists office across from 406	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Principals office in Main Office	7	3	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	3rd floor observation 3	7	305	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	2nd floor observation 2	7	305	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	205 small office	7	240	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	307 office/ storage	7	240	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	303/ 300 shared prep room	7	100	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	4th floor observation 4	7	305	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	109A engineers office	7	120	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Media Room, 2nd Flr	7	1,455	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	309A office/ storage	7	120	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	1st floor parent room (observation 1)	6	305	SF	\$872	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	office located in Kitchen	6	390	SF	\$1,115	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Conference Room in Main Office	7	256	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	psychologists office across from 406	7	240	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Kitchen staff breakroom and lunchroom storage	7	990	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Library Workroom in Library	7	30	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Student Services office	7	480	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Faculty Lounge in Main Office	7	330	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Principals office in Main Office	7	114	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Asst. Principals office in Main Office	7	102	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	in Main Office	7	540	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Main office on 1st floor	7	1,380	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	3rd floor observation 3	7	520	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	205 small office	7	430	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	psychologists office across from 406	7	430	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	4th floor observation 4	7	520	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	303/ 300 shared prep room	7	670	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	1st floor parent room (observation 1)	6	520	SF	\$1,227	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	109A engineers office	7	420	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Asst. Principals office in Main Office	7	546	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Faculty Lounge in Main Office	7	588	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Conference Room in Main Office	6	342	SF	\$807	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	307 office/ storage	7	430	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	2nd floor observation 2	7	520	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	309A office/ storage	7	420	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Main office on 1st floor	7	912	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Library Workroom in Library	7	470	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Principals office in Main Office	7	582	SF	\$0	
Band Room	Classroom	Instrument Storage Casework		7	13	LF	\$0	
Clinic		Health Clinic	1st Floor	7	1,130	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Doors		Interior Steel Doors incl hw	Entire Building	7	57	EA	\$0	
Doors		Interior Steel Doors incl hw	Entire Building	6	16	EA	\$4,530	
Doors		Interior Steel Doors incl hw	Entire Building	7	105	EA	\$0	
Doors		Interior Steel Doors incl hw	Entire Building	6	14	EA	\$3,964	
Doors		Side-lite	Entire Building	7	6	SF	\$0	
Doors		Side-lite	Entire Building	7	628	SF	\$0	
Kitchen	Cooking Kitchen	Ceiling - Lay-In	Dishwashing located in Lunchroom	7	162	SF	\$0	
Kitchen	Cooking Kitchen	Ceiling - Lay-In	in Lunchroom	6	1,163	SF	\$3,326	
Kitchen	Cooking Kitchen	Flooring - Tile/Sheet	Dishwashing located in Lunchroom	6	162	SF	\$232	
Kitchen	Cooking Kitchen	Flooring - Tile/Sheet	in Lunchroom	6	1,163	SF	\$1,663	
Kitchen	Cooking Kitchen	Lighting - Lay-In	Dishwashing located in Lunchroom	7	2	SF	\$0	
Kitchen	Cooking Kitchen	Lighting - Lay-In	in Lunchroom	7	18	SF	\$0	
Kitchen	Cooking Kitchen	Wall - Concrete Block	in Lunchroom	6	1,420	SF	\$4,061	
Kitchen	Cooking Kitchen	Wall - Concrete Block	Dishwashing located in Lunchroom	7	540	SF	\$0	
Library	Library	Casework	2nd Floor	7	65	LF	\$0	
Library	Library	Flooring Carpet	2nd Floor	7	2,492	SF	\$0	
Library	Library	Flooring Carpet	Professional Library 2nd Flr	6	1,073	SF	\$1,534	
Library	Library	Lighting - Lay-In	Professional Library 2nd Flr	7	15	SF	\$0	
Library	Library	Lighting - Lay-In	2nd Floor	6	30	SF	\$21	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd floor boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd floor girls			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd floor unisex 1			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd floor girls			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st floor girls			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st floor boys			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd floor unisex 2			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	4th floor girls			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd floor boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	4th floor boys			LF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Staff Restroom	Benches	4th floor unisex 1			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	4th floor unisex 2			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	3rd floor unisex 2			LF	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Benches	112			LF	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Benches	113			LF	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Benches	111			LF	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Benches	110			LF	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Benches	108			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st floor unisex 1			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st floor unisex 2			LF	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Benches	106			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	3rd floor unisex 1			LF	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Lockers	108			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Lockers	106			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Lockers	113			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st floor unisex 2			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st floor unisex 1			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Kitchen Staff toilet in Kitchen	7	24	EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Lockers	110			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	4th floor unisex 2			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	4th floor boys			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Lockers	111			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd floor girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	3rd floor unisex 2			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	4th floor unisex 1			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd floor boys			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd floor boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st floor girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	3rd floor unisex 1			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st floor boys			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Lockers	112			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd floor unisex 1			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd floor unisex 2			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	4th floor girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd floor girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd floor unisex 1			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	3rd floor unisex 1			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st floor unisex 1			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Showers	111			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st floor unisex 2			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Showers	106			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Showers	108			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	4th floor unisex 1			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st floor girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	3rd floor unisex 2			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	4th floor unisex 2			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	4th floor boys			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Showers	112			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Showers	113			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd floor boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	4th floor girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd floor girls			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd floor boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st floor boys			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Showers	110			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd floor girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd floor unisex 2			EA	\$0	
Lunchroom	Lunchroom	Ceiling - Lay-In	Serving Room in Lunchroom	7	650	SF	\$0	
Lunchroom	Lunchroom	Ceiling - Lay-In	1st Floor	7	2,600	SF	\$0	
Lunchroom	Lunchroom	Ceiling - Plaster/Drywall	1st Floor	6	1,287	SF	\$3,644	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	1st Floor	6	3,887	SF	\$5,558	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	Serving Room in Lunchroom	7	650	SF	\$0	
Lunchroom	Lunchroom	Lighting - Lay-In	1st Floor	6	19	SF	\$14	
Lunchroom	Lunchroom	Lighting - Lay-In	Serving Room in Lunchroom	7	6	SF	\$0	
Lunchroom	Lunchroom	Lighting - Pendant/Surface	1st Floor	6	37	SF	\$26	
Lunchroom	Lunchroom	Serving Line	Serving Room in Lunchroom	7	18	LF	\$0	
Lunchroom	Lunchroom	Serving Line	1st Floor			LF	\$0	
Lunchroom	Lunchroom	Wall - Concrete Block	Serving Room in Lunchroom	6	1,030	SF	\$2,946	
Lunchroom	Lunchroom	Wall - Structural Glazed Tile	1st Floor	7	7,099	SF	\$0	
MDF/IDF		Finishes	2nd Floor	7	377	SF	\$0	
MDF/IDF		Ventilation and Cooling	2nd Floor	6	377	EA	\$528,328	
Mechanical/Service Rooms		Boiler Room	2nd floor fan room	7	2,500	SF	\$0	
Mechanical/Service Rooms		Janitor's Closet	Entire Building	6	4	SF	\$19	
Mechanical/Service Rooms		Mechanical/Service Rooms	1st Floor	6	1,238	SF	\$5,842	
Mechanical/Service Rooms		Mechanical/Service Rooms	4th floor electric room next to elevator	6	215	SF	\$1,015	
Mechanical/Service Rooms		Mechanical/Service Rooms	1st floor kitchen cooler	6	63	SF	\$297	
Mechanical/Service Rooms		Mechanical/Service Rooms	1st floor kitchen freezer	6	88	SF	\$415	
Mechanical/Service Rooms		Mechanical/Service Rooms	3rd floor electric room next to elevator	6	215	SF	\$1,015	
Mechanical/Service Rooms		Mechanical/Service Rooms	2nd floor electric room next to elevator	6	215	SF	\$1,015	
Mechanical/Service Rooms		Storage Room	2nd floor library storage	6	98	SF	\$462	
Mechanical/Service Rooms		Storage Room	1st floor classroom storage	6	950	SF	\$4,483	
Mechanical/Service Rooms		Storage Room	207A	7	170	SF	\$0	
Mechanical/Service Rooms		Storage Room	1st floor kitchen storage	7	259	SF	\$0	
Mechanical/Service Rooms		Storage Room	112 closet and storage	7	160	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Mechanical/Service Rooms		Storage Room	111 closet and storage	7	160	SF	\$0	
Mechanical/Service Rooms		Storage Room	106 storage and closet	7	160	SF	\$0	
Mechanical/Service Rooms		Storage Room	113 closet and storage	7	160	SF	\$0	
Mechanical/Service Rooms		Storage Room	110 closet and storage	7	160	SF	\$0	
Mechanical/Service Rooms		Storage Room	406	7	165	SF	\$0	
Mechanical/Service Rooms		Storage Room	109	7	160	SF	\$0	
Mechanical/Service Rooms		Storage Room	108 storage and closet	7	160	SF	\$0	
Mechanical/Service Rooms		Storage Room	4th floor art room storage/ kiln	6	120	SF	\$566	
Mechanical/Service Rooms		Storage Room	4th floor music room storage	6	125	SF	\$590	
Mechanical/Service Rooms		Storage Room	3rd floor hall storage	6	170	SF	\$802	
Mechanical/Service Rooms		Storage Room	2nd floor elevator storage	6	170	SF	\$802	
Staff Restroom	Children's Standard Student Restroom	Accessories	4th floor boys	7	310	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	113	7	40	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	112	7	40	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	110	7	40	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	Faculty toilet in Main Office	7	42	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	Kitchen Staff toilet in Kitchen	7	41	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor girls	7	310	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	4th floor unisex 2	7	57	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	4th floor unisex 1	7	57	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	111	7	40	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	106	7	40	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st floor unisex 1	7	57	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd floor boys	7	310	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	108	7	40	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd floor unisex 1	7	57	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	3rd floor unisex 2	7	57	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd floor girls	7	310	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd floor boys	7	310	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd floor girls	7	310	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st floor unisex 2	7	57	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor boys	7	310	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd floor unisex 2	7	57	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	4th floor girls	7	310	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	3rd floor unisex 1	7	57	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	108	7	40	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	3rd floor unisex 2	7	57	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	3rd floor unisex 1	7	57	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	4th floor unisex 1	7	57	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	4th floor unisex 2	7	57	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	Kitchen Staff toilet in Kitchen	7	41	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	106	7	40	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	1st floor unisex 1	7	57	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	110	7	40	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	112	7	40	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	2nd floor unisex 2	7	57	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	111	7	40	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	1st floor unisex 2	7	57	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	113	7	40	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	Faculty toilet in Main Office	7	42	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	2nd floor unisex 1	7	57	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd floor girls	7	310	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor boys	7	310	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	4th floor girls	7	310	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor boys	7	310	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor girls	7	310	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd floor boys	7	310	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	4th floor boys	7	310	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor girls	7	310	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	111	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	106	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st floor unisex 2	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	108	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	3rd floor unisex 1	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	110	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st floor unisex 1	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	Faculty toilet in Main Office	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	113	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd floor boys	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	Kitchen Staff toilet in Kitchen	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor girls	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	2nd floor unisex 1	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	2nd floor unisex 2	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	112	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	4th floor girls	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	4th floor boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd floor girls	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd floor boys	7	2	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd floor girls	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	3rd floor unisex 2	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	4th floor unisex 1	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	4th floor unisex 2	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	3rd floor unisex 2	7	57	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	3rd floor unisex 1	7	57	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	3rd floor girls	7	310	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Terrazzo	108	7	40	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Terrazzo	106	7	40	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	1st floor unisex 1	7	57	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	3rd floor boys	7	310	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	1st floor unisex 2	7	57	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	2nd floor girls	7	310	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	1st floor girls	7	310	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	1st floor boys	7	310	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	2nd floor unisex 1	7	57	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	2nd floor unisex 2	7	57	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	4th floor girls	7	310	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	2nd floor boys	7	310	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	4th floor boys	7	310	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	4th floor unisex 2	7	57	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Terrazzo	110	7	40	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Terrazzo	112	7	40	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Terrazzo	111	7	40	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	4th floor unisex 1	7	57	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Terrazzo	113	7	40	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	Faculty toilet in Main Office	7	42	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	Kitchen Staff toilet in Kitchen	6	41	SF	\$59	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor girls	7	2	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Hand Dryer	108			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	4th floor unisex 1			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	4th floor boys			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd floor boys			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	4th floor girls			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd floor unisex 1			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Hand Dryer	110			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd floor girls			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd floor boys			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd floor girls			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	3rd floor unisex 2			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Hand Dryer	106			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	3rd floor unisex 1			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd floor unisex 2			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Hand Dryer	111			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	1st floor unisex 1			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	1st floor unisex 2			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Hand Dryer	113			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Hand Dryer	112			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	4th floor unisex 2			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd floor girls	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st floor unisex 1	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st floor unisex 2	7	1	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Early Childhood Student Restroom	Lavatory	106	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	108	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	111	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	113	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	112	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	3rd floor unisex 2	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor girls	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	4th floor girls	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd floor unisex 2	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd floor unisex 1	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor boys	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor girls	6	1	EA	\$372	
Staff Restroom	Staff Restroom	Lavatory	3rd floor unisex 1	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	110	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	4th floor unisex 1	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor boys	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	4th floor unisex 2	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Kitchen Staff toilet in Kitchen	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Faculty toilet in Main Office	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor girls	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd floor boys	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	4th floor boys	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st floor unisex 1	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	4th floor girls	7	6	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st floor unisex 2	7	1	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	106	7	1	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	108	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	3rd floor unisex 1	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	3rd floor unisex 2	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	3rd floor girls	7	6	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	3rd floor boys	7	6	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	2nd floor girls	7	6	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st floor girls	7	6	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st floor boys	7	6	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	2nd floor unisex 1	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	Faculty toilet in Main Office	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	2nd floor unisex 2	7	1	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	111	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	4th floor unisex 2	7	1	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	113	7	1	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	112	7	1	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	110	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	Kitchen Staff toilet in Kitchen	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	4th floor unisex 1	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	4th floor boys	7	6	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	2nd floor boys	7	6	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Partitions	111			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Partitions	110			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Partitions	113			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	4th floor unisex 2			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd floor boys	7	3	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Partitions	112			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	4th floor unisex 1			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	4th floor boys	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd floor girls	7	7	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	3rd floor unisex 2			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	1st floor unisex 1			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	1st floor unisex 2			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Partitions	106			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	4th floor girls	7	7	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	3rd floor unisex 1			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd floor boys	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd floor girls	7	7	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor girls	7	7	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor boys	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	2nd floor unisex 1			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	2nd floor unisex 2			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Partitions	108			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd floor unisex 2			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Urinals	108			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	3rd floor unisex 2			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd floor girls			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd floor boys			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd floor girls			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st floor girls			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Urinals	1st floor boys			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd floor unisex 1			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Urinals	111			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Urinals	112			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	4th floor unisex 2			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	4th floor girls			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Urinals	110			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Urinals	106			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd floor boys			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	4th floor boys			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	4th floor unisex 1			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Urinals	113			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	3rd floor unisex 1			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st floor unisex 2			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st floor unisex 1			EA	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	Kitchen Staff toilet in Kitchen	6	247	SF	\$706	
Staff Restroom	Early Childhood Student Restroom	Wall - Concrete Block	110	7	200	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Wall - Concrete Block	108	7	200	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Wall - Concrete Block	112	7	200	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Wall - Concrete Block	113	7	200	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Wall - Concrete Block	111	7	200	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Wall - Concrete Block	106	7	200	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd floor boys	7	910	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	Faculty toilet in Main Office	7	234	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	4th floor unisex 2	7	250	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	4th floor boys	7	910	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	4th floor girls	7	1,120	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st floor girls	7	1,120	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	4th floor unisex 1	7	250	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd floor girls	7	1,120	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	2nd floor unisex 2	7	250	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd floor girls	7	1,120	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	3rd floor unisex 2	7	250	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	3rd floor unisex 1	7	250	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	1st floor unisex 2	7	250	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	1st floor unisex 1	7	250	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st floor boys	7	910	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	2nd floor unisex 1	7	250	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd floor boys	7	910	SF	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st floor unisex 2	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor girls	7	7	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st floor unisex 1	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	106	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	108	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	3rd floor unisex 1	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	3rd floor unisex 2	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd floor girls	7	7	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd floor boys	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor girls	7	7	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	4th floor unisex 1	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	Kitchen Staff toilet in Kitchen	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	110	7	1	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Early Childhood Student Restroom	Water Closet	112	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	113	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	111	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	Faculty toilet in Main Office	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	4th floor unisex 2	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor boys	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd floor unisex 1	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd floor unisex 2	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	4th floor girls	7	7	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	4th floor boys	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor boys	7	3	EA	\$0	
Vertical Conveyance		Elevator - Roped Holeless Hydraulic	Entire Building	7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	5	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	4	EA	\$0	
Vocational Shop	Classroom	Work Sink		5	1	EA	\$1,931	
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0	

INTERIOR Sub Total

\$587,183

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
ADMIN_LIGHT	Administrative Suites/Offices	Administrative Office Lighting	4th floor observation 4	6	6	EA	\$172	bulb out
Casework	Classroom	Casework		6	68	LF	\$2,431	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		7	68	LF	\$0	
Casework	Classroom	Casework		7	66	LF	\$0	
Casework	Classroom	Casework		7	137	LF	\$0	
Casework	Classroom	Casework		7	68	LF	\$0	
Casework	Classroom	Casework		7	84	LF	\$0	
Casework	Classroom	Casework		7	68	LF	\$0	
Casework	Classroom	Casework		7	68	LF	\$0	
Casework	Classroom	Casework		7	64	LF	\$0	
Casework	Classroom	Casework		7	68	LF	\$0	
Casework	Classroom	Casework		7	64	LF	\$0	
Casework	Classroom	Casework		7	68	LF	\$0	
Casework	Classroom	Casework		7	84	LF	\$0	
Casework	Classroom	Casework		7	154	LF	\$0	
Casework	Classroom	Casework		7	68	LF	\$0	
Casework	Classroom	Casework		7	66	LF	\$0	
Casework	Classroom	Casework		7	68	LF	\$0	
Casework	Classroom	Casework		7	68	LF	\$0	
Casework	Classroom	Casework		7	64	LF	\$0	
Casework	Classroom	Casework		7	64	LF	\$0	
Casework	Classroom	Casework		7	64	LF	\$0	
Casework	Classroom	Casework		7	64	LF	\$0	
Casework	Classroom	Casework		7	64	LF	\$0	
Casework	Classroom	Casework		6	68	LF	\$2,431	ceiling leaking onto casework; warped
Casework	Classroom	Casework		7	64	LF	\$0	
Casework	Classroom	Casework		7	68	LF	\$0	
Casework	Classroom	Casework		7	84	LF	\$0	
Casework	Classroom	Casework		7	68	LF	\$0	
Casework	Classroom	Casework		7	84	LF	\$0	
Casework	Classroom	Casework		7	68	LF	\$0	
Casework	Classroom	Casework		7	68	LF	\$0	
Casework	Classroom	Casework		7	68	LF	\$0	
Casework	Classroom	Casework		7	68	LF	\$0	
Casework	Classroom	Casework		7	68	LF	\$0	
Casework	Classroom	Casework		7	44	LF	\$0	
Casework	Classroom	Casework		7	68	LF	\$0	
Casework	Classroom	Casework		7	68	LF	\$0	
Casework	Classroom	Casework		7	68	LF	\$0	
Casework	Classroom	Casework		7	68	LF	\$0	
Casework	Classroom	Casework		7	68	LF	\$0	
Casework	Classroom	Casework		7	68	LF	\$0	
Casework	Classroom	Casework		7	68	LF	\$0	
Casework	Classroom	Casework		7	68	LF	\$0	
Casework	Classroom	Casework		6	68	LF	\$2,431	broken drawer

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		7	68	LF	\$0	
Casework	Classroom	Casework		7	73	LF	\$0	
Casework	Classroom	Casework		7	68	LF	\$0	
Casework	Classroom	Casework		7	68	LF	\$0	
Casework	Classroom	Casework		7	68	LF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,215	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,445	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	870	SF	\$1,866	
Ceiling	Classroom	Lay-In/Drop		6	870	SF	\$1,866	
Ceiling	Classroom	Lay-In/Drop		6	830	SF	\$1,780	
Ceiling	Classroom	Lay-In/Drop		6	830	SF	\$1,780	
Ceiling	Classroom	Lay-In/Drop		6	830	SF	\$1,780	
Ceiling	Classroom	Lay-In/Drop		6	1,270	SF	\$2,724	
Ceiling	Classroom	Lay-In/Drop		6	1,020	SF	\$2,188	loose/ missing panels
Ceiling	Classroom	Lay-In/Drop		7	870	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	870	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	870	SF	\$1,866	
Ceiling	Classroom	Lay-In/Drop		7	1,215	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	830	SF	\$1,780	
Ceiling	Classroom	Lay-In/Drop		7	1,215	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	870	SF	\$1,866	
Ceiling	Classroom	Lay-In/Drop		7	1,020	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,215	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	1,215	SF	\$2,606	
Ceiling	Classroom	Lay-In/Drop		7	870	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,050	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	870	SF	\$1,866	
Ceiling	Classroom	Lay-In/Drop		6	870	SF	\$1,866	
Ceiling	Classroom	Lay-In/Drop		6	1,270	SF	\$2,724	
Ceiling	Classroom	Lay-In/Drop		7	1,345	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	870	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	870	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	870	SF	\$1,866	
Ceiling	Classroom	Lay-In/Drop		7	870	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,215	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	870	SF	\$1,866	
Ceiling	Classroom	Lay-In/Drop		7	870	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Corridors	Corridors	Concrete Block	Boiler Room Exit Stair	7	1,880	SF	\$0	
Corridors	Corridors	Concrete Block	Vestibules at 1st Flr exits	7	1,090	SF	\$0	
Corridors	Corridors	Concrete Epoxy/Painted	Vestibules at 1st Flr exits	6	260	SF	\$1,227	
Corridors	Corridors	Concrete Epoxy/Painted	Boiler Room Exit Stair	7	145	SF	\$0	
Corridors	Corridors	Drinking Fountains	3rd Floor	7	2	EA	\$0	
Corridors	Corridors	Drinking Fountains	1st Floor	7	3	EA	\$0	
Corridors	Corridors	Drinking Fountains	4th Floor	7	2	EA	\$0	
Corridors	Corridors	Drinking Fountains	1st Floor	7	6	EA	\$0	
Corridors	Corridors	Drinking Fountains	2nd Floor	7	2	EA	\$0	
Corridors	Corridors	Drop/Lay-In	4th Floor	7	3,234	SF	\$0	
Corridors	Corridors	Drop/Lay-In	2nd Floor	7	4,151	SF	\$0	
Corridors	Corridors	Drop/Lay-In	3rd Floor	7	3,316	SF	\$0	
Corridors	Corridors	Drop/Lay-In	Vestibules at 1st Flr exits	6	328	SF	\$704	
Corridors	Corridors	Drop/Lay-In	1st Floor	7	4,762	SF	\$0	
Corridors	Corridors	Exposed	Boiler Room Exit Stair	7	145	SF	\$0	
Corridors	Corridors	Lay-In	3rd Floor	7	238	EA	\$0	
Corridors	Corridors	Lay-In	Stair 'A'	7	664	EA	\$0	
Corridors	Corridors	Lay-In	4th Floor	7	3,234	EA	\$0	
Corridors	Corridors	Lay-In	3rd Floor	7	3,316	EA	\$0	
Corridors	Corridors	Lay-In	2nd Floor	7	476	EA	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Lay-In	Stair 'B'	7	713	EA	\$0	
Corridors	Corridors	Lay-In	Vestibules at 1st Flr exits	7	328	EA	\$0	
Corridors	Corridors	Lay-In	Stair 'C'	7	812	EA	\$0	
Corridors	Corridors	Lay-In	2nd Floor	7	4,151	EA	\$0	
Corridors	Corridors	Lay-In	Vestibules at 1st Flr exits	7	668	EA	\$0	
Corridors	Corridors	Lay-In	1st Floor	7	4,762	EA	\$0	
Corridors	Corridors	Lay-In	1st Floor	7	639	EA	\$0	
Corridors	Corridors	Lighting	4th Floor	7	238	EA	\$0	
Corridors	Corridors	Pendant/Surface	Stair 'A'	7	332	EA	\$0	
Corridors	Corridors	Pendant/Surface	Stair 'B'	7	357	EA	\$0	
Corridors	Corridors	Plaster/Drywall	Stair 'B'	7	345	SF	\$0	
Corridors	Corridors	Stair Handrails	Stair 'A'	6	96	LF	\$0	
Corridors	Corridors	Stair Handrails	Stair 'B'	7	144	LF	\$0	
Corridors	Corridors	Stair Handrails	Boiler Room Exit Stair	7	40	LF	\$0	
Corridors	Corridors	Stair Handrails	Stair 'C'	7	130	LF	\$0	
Corridors	Corridors	Structural Glazed Tile	2nd Floor	7	5,010	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	1st Floor	7	8,573	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	4th Floor	7	3,530	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	3rd Floor	7	4,030	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	Stair 'B'	7	5,400	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	Vestibules at 1st Flr exits	7	1,308	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	Stair 'C'	7	6,844	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	Stair 'A'	7	5,298	SF	\$0	
Corridors	Corridors	Student Lockers	4th Floor	7	280	EA	\$0	
Corridors	Corridors	Student Lockers	3rd Floor	7	196	EA	\$0	
Corridors	Corridors	Student Lockers	2nd Floor	7	280	EA	\$0	
Corridors	Corridors	Terrazzo	Stair 'B'	7	623	SF	\$0	
Corridors	Corridors	Terrazzo	Stair 'A'	7	708	SF	\$0	
Corridors	Corridors	Terrazzo	Vestibules at 1st Flr exits	7	668	SF	\$0	
Corridors	Corridors	Terrazzo	2nd Floor	7	4,663	SF	\$0	
Corridors	Corridors	Terrazzo	4th Floor	7	3,508	SF	\$0	
Corridors	Corridors	Terrazzo	1st Floor	7	5,457	SF	\$0	
Corridors	Corridors	Terrazzo	3rd Floor	7	3,590	SF	\$0	
Corridors	Corridors	Terrazzo	Stair 'C'	7	1,086	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	Vestibules at 1st Flr exits	6	68	SF	\$97	
Corridors	Corridors	Wall Mounted	Stair 'C'	7	406	EA	\$0	
Corridors	Corridors	Wall Mounted	Boiler Room Exit Stair	7	145	EA	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Floor	Classroom	Tile/Sheet		7	870	SF	\$0	
Floor	Classroom	Tile/Sheet		7	870	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,345	SF	\$0	
Floor	Classroom	Tile/Sheet		7	830	SF	\$0	
Floor	Classroom	Tile/Sheet		7	870	SF	\$0	
Floor	Classroom	Tile/Sheet		7	870	SF	\$0	
Floor	Classroom	Tile/Sheet		7	870	SF	\$0	
Floor	Classroom	Tile/Sheet		7	870	SF	\$0	
Floor	Classroom	Tile/Sheet		6	870	SF	\$1,244	
Floor	Classroom	Tile/Sheet		7	830	SF	\$0	
Floor	Classroom	Tile/Sheet		6	830	SF	\$1,187	
Floor	Classroom	Tile/Sheet		7	1,610	SF	\$0	
Floor	Classroom	Tile/Sheet		7	830	SF	\$0	
Floor	Classroom	Tile/Sheet		6	1,270	SF	\$1,816	
Floor	Classroom	Tile/Sheet		7	1,215	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,215	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,215	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,215	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,215	SF	\$0	
Floor	Classroom	Tile/Sheet		7	870	SF	\$0	
LIBRARY_CEILING	Library	Drop/Lay-In	Professional Library 2nd Flr	7	1,073	SF	\$0	
LIBRARY_CEILING	Library	Drop/Lay-In	2nd Floor	7	2,492	SF	\$0	
LIBRARY_WALL	Library	Concrete Block	2nd Floor	7	1,480	SF	\$0	
LIBRARY_WALL	Library	Concrete Block	Professional Library 2nd Flr	7	898	SF	\$0	
LIBRARY_WALL	Library	Plaster/Drywall	Professional Library 2nd Flr	7	275		\$0	
LIBRARY_WALL	Library	Plaster/Drywall	2nd Floor	7	300		\$0	
Lighting	Classroom	Lay-In		7	13	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	10	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	19	EA	\$0	
Lighting	Classroom	Lay-In		7	15	EA	\$0	
Lighting	Classroom	Lay-In		7	10	EA	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	13	EA	\$0	
Lighting	Classroom	Lay-In		7	13	EA	\$0	
Lighting	Classroom	Lay-In		7	13	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	14	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	15	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	10	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	13	EA	\$0	
Lighting	Classroom	Lay-In		7	13	EA	\$0	
Lighting	Classroom	Lay-In		7	10	EA	\$0	
Lighting	Classroom	Lay-In		7	15	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	22	EA	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	18	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	18	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	18	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	18	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	18	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	18	LF	\$0	
Wall	Classroom	Concrete Block		7	765	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Concrete Block		7	480	SF	\$0	
Wall	Classroom	Concrete Block		7	580	SF	\$0	
Wall	Classroom	Concrete Block		7	620	SF	\$0	
Wall	Classroom	Concrete Block		7	875	SF	\$0	
Wall	Classroom	Concrete Block		7	875	SF	\$0	
Wall	Classroom	Concrete Block		7	695	SF	\$0	
Wall	Classroom	Concrete Block		7	480	SF	\$0	
Wall	Classroom	Concrete Block		7	580	SF	\$0	
Wall	Classroom	Concrete Block		7	875	SF	\$0	
Wall	Classroom	Concrete Block		7	580	SF	\$0	
Wall	Classroom	Concrete Block		7	725	SF	\$0	
Wall	Classroom	Concrete Block		7	825	SF	\$0	
Wall	Classroom	Concrete Block		7	580	SF	\$0	
Wall	Classroom	Concrete Block		7	1,150	SF	\$0	
Wall	Classroom	Concrete Block		7	480	SF	\$0	
Wall	Classroom	Concrete Block		6	560	SF	\$1,602	
Wall	Classroom	Concrete Block		7	725	SF	\$0	
Wall	Classroom	Concrete Block		7	520	SF	\$0	
Wall	Classroom	Concrete Block		7	480	SF	\$0	
Wall	Classroom	Concrete Block		7	825	SF	\$0	
Wall	Classroom	Concrete Block		7	580	SF	\$0	
Wall	Classroom	Concrete Block		7	580	SF	\$0	
Wall	Classroom	Concrete Block		7	1,760	SF	\$0	
Wall	Classroom	Concrete Block		7	1,415	SF	\$0	
Wall	Classroom	Concrete Block		7	1,050	SF	\$0	
Wall	Classroom	Concrete Block		7	940	SF	\$0	
Wall	Classroom	Concrete Block		7	825	SF	\$0	
Wall	Classroom	Concrete Block		7	825	SF	\$0	
Wall	Classroom	Concrete Block		7	825	SF	\$0	
Wall	Classroom	Concrete Block		7	565	SF	\$0	
Wall	Classroom	Concrete Block		7	725	SF	\$0	
Wall	Classroom	Concrete Block		7	1,235	SF	\$0	
Wall	Classroom	Concrete Block		7	1,340	SF	\$0	
Wall	Classroom	Concrete Block		7	480	SF	\$0	
Wall	Classroom	Concrete Block		7	1,020	SF	\$0	
Wall	Classroom	Concrete Block		7	1,020	SF	\$0	
Wall	Classroom	Concrete Block		7	875	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Concrete Block		7	480	SF	\$0	
Wall	Classroom	Concrete Block		7	580	SF	\$0	
Wall	Classroom	Concrete Block		7	825	SF	\$0	
Wall	Classroom	Concrete Block		7	620	SF	\$0	
Wall	Classroom	Concrete Block		7	725	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	430	SF	\$1,015	
Wall	Classroom	Plaster/Drywall		7	245	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	245	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	245	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	225	SF	\$531	
Wall	Classroom	Plaster/Drywall		7	490	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	520	SF	\$1,227	
Wall	Classroom	Plaster/Drywall		6	490	SF	\$1,156	
Wall	Classroom	Plaster/Drywall		6	470	SF	\$1,109	
Wall	Classroom	Plaster/Drywall		7	445	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	590	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	410	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	270	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	245	SF	\$578	
Wall	Classroom	Plaster/Drywall		6	245	SF	\$578	
Wall	Classroom	Plaster/Drywall		7	195	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	490	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	560	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	245	SF	\$578	
Wall	Classroom	Plaster/Drywall		7	345	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	180	SF	\$425	
Wall	Classroom	Plaster/Drywall		6	490	SF	\$1,156	
Wall	Classroom	Plaster/Drywall		6	430	SF	\$1,015	
Wall	Classroom	Plaster/Drywall		7	345	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	345	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	470	SF	\$1,109	
Wall	Classroom	Plaster/Drywall		7	560	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	450	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	245	SF	\$578	
Wall	Classroom	Plaster/Drywall		7	180	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	515	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	410	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Plaster/Drywall		6	490	SF	\$1,156	
Wall	Classroom	Plaster/Drywall		7	220	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	345	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	410	SF	\$967	
Wall	Classroom	Plaster/Drywall		7	450	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	245	SF	\$578	
Wall	Classroom	Plaster/Drywall		6	245	SF	\$578	
Wall	Classroom	Plaster/Drywall		6	430	SF	\$1,015	
Wall	Classroom	Plaster/Drywall		6	430	SF	\$1,015	
Wall	Classroom	Plaster/Drywall		6	490	SF	\$1,156	
Wall	Classroom	Plaster/Drywall		6	245	SF	\$578	
ROOM Sub Total							\$81,111	
Building Main Sub Total							\$2,825,537	

Building: Athletic
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chimney		Metal Flue	Roof- North	7	6	LF	\$0	
Doors		Exterior Steel Door	Roof Access in 2nd fl Mechanical	5	1	EA	\$1,090	
Doors		Exterior Steel Door	Entire Building	7	8	EA	\$0	
Doors		Store Front Door	East Entrances	7	4	EA	\$0	
Entrance		Entrance Controls - Audio and Video	East Entrance	7	1	EA	\$0	
Foundation		Concrete Foundation	Basement	7	888	LF	\$0	
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	24	EA	\$5,148	
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	6	EA	\$1,287	
Lintels		Lintels - Steel	Entire Building	7	413	LF	\$0	
Parapet		Coping - Metal	Main Roof	7	346	LF	\$0	
Parapet		Coping - Stone	Main Roof	7	892	LF	\$0	
Parapet		Parapet > 30" Height	Main Roof	7	524	LF	\$0	
Parapet		Parapet 16" to 30" Height	Main Roof	7	619	LF	\$0	
Roof System		Interior Downspouts	Entire Building	6	582	LF	\$0	
Roof System		Modified Bitumen Roof	Main Roof	6	30,400	SF	\$215,186	
Roof System		Roof Structure: Steel/Metal Deck/Concrete Topping	Main Roof	7	30,400	SF	\$0	
Superstructure		Metal Deck/Concrete Topping	Entire Building	7	49,400	SF	\$0	
Walls		Brick	Entire Building	7	22,668	SF	\$0	

Building: Athletic
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Walls		Prefabricated Metal Panel Wall	Chiller Well	7	1,060	SF	\$0	
Walls		Stone - Cut	Entire Building	7	3,572	SF	\$0	
Windows		Clerestory - Glass Single-Pane	Pool	4	4,160	SF	\$588,931	
Windows		Curtain wall - Glazed Double Pane	Entire Building	7	5,152	SF	\$0	
Windows		Curtain wall - Glazed Double Pane	South Façade	4	35	SF	\$5,946	
Windows		Curtain wall - Insulated panel	Entire Building	7	626	SF	\$0	
Windows		Curtain wall - Louver	Masonry Walls	7	796	SF	\$0	
Windows		Curtain wall - Windows	Entire Building	7	220	SF	\$0	
Windows		Storefront Windows	East Façade	7	286	SF	\$0	
Windows		Window - Guards perforated	Entire Building	7	2,010	SF	\$0	
Windows		Windows - Sash Aluminum Double-pane	Entire Building	7	941	SF	\$0	
EXTERIOR Sub Total							\$817,589	

Building: Athletic
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	1st Floor	6	1	EA	\$1,430	Preventive Maintenance Needed
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	6	9,655	SF	\$4,142	Preventive Maintenance Needed.
Emergency System		Emergency A/C power - Gym and Lunch rooms	1st Floor	6	7,045	SF	\$3,728	Preventive Maintenance Needed.
Emergency System		Emergency A/C power - Students Toilets	Entire Building	6	1,877	SF	\$805	Preventive Maintenance Needed.
Emergency System		Emergency Battery Packs - Corridors and Stairs	Entire Building	6	37	EA	\$3,968	Preventive Maintenance Needed.
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	6	42	EA	\$9,790	Preventive Maintenance Needed.
Emergency System		Independent Electrical Service for emergency power	1st Floor	6	1	EA	\$1,430	Preventive Maintenance Needed.
Main Service		Main Electrical service 1200 A 277/480/3PH	1st Floor	6	1	EA	\$8,938	Preventive Maintenance Needed.
Power Distribution		Lighting and power panels	2nd Floor	6	1	EA	\$715	Preventive Maintenance Needed.
Power Distribution		Lighting and power panels	1st Floor	6	1	EA	\$715	Preventive Maintenance Needed.
Power Distribution		Lighting and power panels	1st Floor	6	1	EA	\$715	Preventive Maintenance Needed.
Power Distribution		Lighting and power panels	1st Floor	6	1	EA	\$715	Preventive Maintenance Needed.

Building: Athletic
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Power Distribution		Lighting and power panels	1st Floor	6	1	EA	\$715	Preventive Maintenance Needed.
Power Distribution		Lighting and power panels	1st Floor	6	1	EA	\$715	Preventive Maintenance Needed.
Power Distribution		Lighting and power panels	2nd Floor	6	1	EA	\$715	Preventive Maintenance Needed.
Power Distribution		Lighting and power panels	1st Floor	6	1	EA	\$715	Preventive Maintenance Needed.
Power Distribution		Lighting and power panels	2nd Floor	6	1	EA	\$715	Preventive Maintenance Needed.
Power Distribution		Lighting and power panels	1st Floor	6	1	EA	\$715	Preventive Maintenance Needed.
Power Distribution		Lighting and power panels	1st Floor	6	1	EA	\$715	Preventive Maintenance Needed.
Power Distribution		Lighting and power panels	2nd Floor	6	1	EA	\$715	Preventive Maintenance Needed.
Power Distribution		Lighting and power panels	2nd Floor	6	1	EA	\$715	Preventive Maintenance Needed.
Power Distribution		Lighting and power panels	2nd Floor	6	1	EA	\$715	Preventive Maintenance Needed.
Power Distribution		Lighting and power panels	2nd Floor	6	1	EA	\$715	Preventive Maintenance Needed.
Power Distribution		Lighting and power panels	1st Floor	6	1	EA	\$715	Preventive Maintenance Needed.
Power Distribution		Main distribution panels 400-600 amp	2nd Floor	6	1	EA	\$1,430	Preventive Maintenance Needed.
Power Distribution		Main distribution panels 400-600 amp	1st Floor	6	1	EA	\$1,430	Preventive Maintenance Needed.
Power Distribution		Main distribution panels less than 400 amp	2nd Floor	6	1	EA	\$1,216	Preventive Maintenance Needed.
Power Distribution		Transformers 277/480-120/208	Electrical Room	6	1	EA	\$1,144	Preventive Maintenance Needed.
Power Distribution		Transformers 277/480-120/208	2nd Floor	6	1	EA	\$1,144	Preventive Maintenance Needed.
ELECTRICAL Sub Total							\$51,319	

Building: Athletic
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Entire Building	6	63,900	SF	\$22,844	Preventive Maintenance Needed
Fire Alarm		Fire Alarm System	1st Floor	6	63,900	SF	\$77,670	Preventive Maintenance Needed
Fire Alarm		Fire Pump Controller	1st Floor	6	1	EA	\$2,145	Preventive Maintenance Needed

Building: Athletic
Category: FIRE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Pump Room Assembly		Fire Pump 50-75hp	1st Floor	6	1	EA	\$4,648	Preventive Maintenance Needed
Pump Room Assembly		Jockey Pump	1st Floor	6	1	EA	\$744	Preventive Maintenance Needed
Sprinkler System		Sprinkler Heads	Entire Building	6	63,900	SF	\$3,655	Preventive Maintenance Needed
Sprinkler System		Wet Sprinkler System	Entire Building	6	63,900	SF	\$36,551	Preventive Maintenance Needed
FIRE PROTECTION Sub Total							\$148,257	

Building: Athletic
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Chillers - Air Cooled - Screw Type - Roof Mounted less than 50 tons	Main Roof	6	1	EA	\$15,873	Preventive Maintenance Needed
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water 20,001 to 30,000 cfm	Mechanical Room	6	1	EA	\$12,155	Preventive Maintenance Needed
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water 20,001 to 30,000 cfm	Mechanical Room	6	1	EA	\$12,155	Preventive Maintenance Needed
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water 8,001 to 12,000 cfm	Mechanical Room	6	1	EA	\$6,292	Preventive Maintenance Needed
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water less than 4,000 cfm	Mechanical Room	6	1	EA	\$3,575	Preventive Maintenance Needed
Air Handling Systems		Air intake for all Air Handling Units except built up AHU	Mechanical Room	6	4	EA	\$5,720	Preventive Maintenance Needed
Air Handling Systems		Fan Power Box With Hot Water Coil	1st Floor	6	11	EA	\$4,247	Preventive Maintenance Needed
Air Handling Systems		Fan Power Box With Hot Water Coil	2nd Floor	6	13	EA	\$5,019	Preventive Maintenance Needed
Air Handling Systems		Return Fans - Indoor 10,001 to 20,000 CFM	2nd Floor	6	1	EA	\$2,431	Preventive Maintenance Needed
Air Handling Systems		Variable Air Volume (VAV) Box With Hot Water Coil	1st Floor	6	5	EA	\$1,645	Preventive Maintenance Needed
Boiler Systems		Glycol Feed System	2nd Floor	6	1	EA	\$1,087	Preventive Maintenance Needed
Heating Devices		Cabinet Heaters With Hot Water Coils	1st Floor	6	7	EA	\$3,504	Preventive Maintenance Needed
Heating Devices		Fin Tube Hot Water	1st Floor	6	85	LF	\$1,459	Preventive Maintenance Needed
Heating Devices		Radiators - Hot Water	1st Floor	6	3	EA	\$378	Preventive Maintenance Needed
Heating Devices		Unit Heater - Electric	1st Floor	6	2	EA	\$2,860	Preventive Maintenance Needed

Building: Athletic
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Heating Devices		Unit Heater - Hot Water	1st Floor	6	1	EA	\$1,430	Preventive Maintenance Needed
Heating Devices		Unit Heater - Hot Water	2nd Floor	6	2	EA	\$2,860	Preventive Maintenance Needed
Mechanical Plumbing		Piping - Hydronic Supply and Return - Copper	Entire Building	6	1,000	LF	\$16,874	Preventive Maintenance Needed
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	7	28	EA	\$0	
Ventilation		Exhaust Fan - Indoor	1st Floor	5	1	EA	\$1,859	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Main Roof	6	1	EA	\$429	Preventive Maintenance Needed
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Main Roof	6	1	EA	\$429	Preventive Maintenance Needed
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Main Roof	6	1	EA	\$429	Preventive Maintenance Needed
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Main Roof	6	1	EA	\$229	Preventive Maintenance Needed
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Main Roof	6	1	EA	\$229	Preventive Maintenance Needed
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Main Roof	6	1	EA	\$229	Preventive Maintenance Needed
Ventilation		Exhaust Fans - Roof mounted less than 500 CFM	Main Roof	6	1	EA	\$157	Preventive Maintenance Needed
Ventilation		Exhaust Fans - Roof mounted less than 500 CFM	Main Roof	6	2	EA	\$315	Preventive Maintenance Needed
Ventilation		Exhaust Fans - Roof mounted less than 500 CFM	Main Roof	6	1	EA	\$157	Preventive Maintenance Needed
Ventilation		Exhaust Fans - Roof mounted less than 500 CFM	Main Roof	6	1	EA	\$157	Preventive Maintenance Needed
MECHANICAL Sub Total							\$104,181	

Building: Athletic
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	6	63,900	SF	\$7,310	Preventive Maintenance Needed
Piping		Domestic Piping - Cold Water Risers	Entire Building	6	63,900	SF	\$10,051	Preventive Maintenance Needed
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	6	63,900	SF	\$10,051	Preventive Maintenance Needed
Piping		Domestic Piping - Hot Water Risers	Entire Building	6	63,900	SF	\$10,051	Preventive Maintenance Needed

Building: Athletic
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	6	63,900	SF	\$14,620	Preventive Maintenance Needed
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	6	63,900	SF	\$12,793	Preventive Maintenance Needed
Piping		Sanitary Piping	Entire Building	6	49,400	SF	\$19,780	Preventive Maintenance Needed
Piping		Storm Piping	Entire Building	6	49,400	SF	\$10,596	Preventive Maintenance Needed
Piping		Vent Piping	Entire Building	6	49,400	SF	\$7,771	Preventive Maintenance Needed
Pool Systems		Pool Drain Piping	1st Floor	6	250	LF	\$4,290	Preventive Maintenance Needed
Pool Systems		Pool Filtration System	1st Floor	6	1	EA	\$27,885	Preventive Maintenance Needed
Pool Systems		Pool Hot Water Heater - Gas Fired	1st Floor	5	1	EA	\$18,590	Preventive Maintenance Needed
Pool Systems		Pool Supply and Return Piping	1st Floor	6	500	LF	\$7,865	Preventive Maintenance Needed
Pumps		Domestic Booster Pump duplex	1st Floor	6	1	EA	\$3,146	Preventive Maintenance Needed
Pumps		Ejector Pump	1st Floor	6	1	EA	\$3,003	Preventive Maintenance Needed
Pumps		Ejector Pump	1st Floor	6	1	EA	\$3,003	Preventive Maintenance Needed
PLUMBING Sub Total							\$170,806	

Building: Athletic
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Office B in Main office 1st fl	7	94	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Main Office FP#C139	7	517	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Office A- in main office 1st fl	7	128	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	office 1st fl FP#C130	7	257	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Office C in Main Office 1st fl	7	14	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Gym Office FP#103	6	180	SF	\$386	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Teacher workroom in rm 7	6	222	SF	\$476	

Building: Athletic
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	pool office C11	6	158	SF	\$447	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Main Office FP#C139	7	517	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Office B in Main office 1st fl	7	94	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Office C in Main Office 1st fl	7	14	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Terrazzo	pool office C11	7	158	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Office A- in main office 1st fl	7	128	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	office 1st fl FP#C130	7	257	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Gym Office FP#103	7	180	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Teacher workroom in rm 7	7	222	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	office 1st fl FP#C130	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	pool office C11	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Teacher workroom in rm 7	6	4	SF	\$3	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Gym Office FP#103	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Office C in Main Office 1st fl	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Office A- in main office 1st fl	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Office B in Main office 1st fl	7	1	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Main Office FP#C139	7	7	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Main Office FP#C139	7	557	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Office C in Main Office 1st fl	7	207	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	pool office C11	6	391	SF	\$1,118	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Office B in Main office 1st fl	7	110	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Teacher workroom in rm 7	7	459	SF	\$0	

Building: Athletic
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	office 1st fl FP#C130	7	580	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Office A- in main office 1st fl	7	135	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Gym Office FP#103	7	451	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Office C in Main Office 1st fl	6	267	SF	\$630	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Office B in Main office 1st fl	6	218	SF	\$514	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Main Office FP#C139	6	419	SF	\$989	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Office A- in main office 1st fl	6	290	SF	\$684	
Doors		Interior Steel Doors incl hw	Entire Building	6	15	EA	\$4,247	
Doors		Interior Steel Doors incl hw	Entire Building	7	61	EA	\$0	
Doors		Interior Wood Doors incl hw	Daycare Wing	6	12	EA	\$3,398	
Doors		Side-lite	Entire Building	7	240	SF	\$0	
Doors		Store Front Door	Entire Building	7	8	EA	\$0	
Doors		Transom Window	Entire Building	7	54	SF	\$0	
Drinking Fountains		Single Water Cooler	Natatorium- 1st fl	5	3	EA	\$9,224	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Bleacher Seating	1st Floor	7	96	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Ceiling - Exposed	1st Floor	7	5,395	SF	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Ceiling - Lay-In	1st Floor	7	110	SF	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Flooring - Wood	1st Floor	6	5,395	SF	\$40,734	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Lighting - Metal Halide/Sodium Vapor	1st Floor	6	30	EA	\$5,363	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Scoreboards	1st Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Sound System	1st Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Stage Curtain	1st Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Concrete Block	1st Floor	7	9,261	SF	\$0	
Kitchen	Warming Kitchen	Ceiling - Lay-In	2nd fl across from rm7	7	216	SF	\$0	
Kitchen	Warming Kitchen	Flooring - Tile/Sheet	2nd fl across from rm7	7	216	SF	\$0	
Kitchen	Warming Kitchen	Lighting - Lay-In	2nd fl across from rm7	7	3	SF	\$0	

Building: Athletic
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Kitchen	Warming Kitchen	Wall - Concrete Block	2nd fl across from rm7	7	479	SF	\$0	
Kitchen	Warming Kitchen	Wall - Plaster/Drywall	2nd fl across from rm7	7	85	SF	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Benches	in rm 3- partial height wall			LF	\$0	
Locker/Shower Room	Locker/Shower Room	Benches	pool staff locker room in C114			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	in rm 4			LF	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Benches	in rm 2- partial height wall			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd fl next to prep kitchen			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st fl across from locker rm FP#C147- mens			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	in rm 1			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st fl next to office FP#c130			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	pool staff toilet C115			LF	\$0	
Locker/Shower Room	Locker/Shower Room	Benches	Girl's Locker Rm 1st flr.	6	42	LF	\$240	
Locker/Shower Room	Staff Restroom	Benches	2nd fl across from elevator 2			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st fl across from locker rm FP#C148-womens			LF	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Benches	in rm 7- partial height wall			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	in rm 6			LF	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Benches	in rm 5- partial height wall			LF	\$0	
Locker/Shower Room	Locker/Shower Room	Benches	Girl's Locker Rm 1st flr.	5	42	LF	\$2,102	
Locker/Shower Room	Staff Restroom	Benches	2nd fl across from elevator 2			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	in rm 1			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st fl next to office FP#c130			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd fl next to prep kitchen			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Lockers	in rm 2- partial height wall			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st fl across from locker rm FP#C148-womens			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	in rm 4			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Lockers	in rm 7- partial height wall			EA	\$0	

Building: Athletic
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Lockers	in rm 6			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Lockers	in rm 5- partial height wall			EA	\$0	
Locker/Shower Room	Locker/Shower Room	Lockers	Girl's Locker Rm 1st flr.	7	100	EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd fl across from elevator 2			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd fl across from elevator 2			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	pool staff toilet C115			EA	\$0	
Locker/Shower Room	Locker/Shower Room	Lockers	pool staff locker room in C114	7	12	EA	\$0	
Locker/Shower Room	Locker/Shower Room	Lockers	Girl's Locker Rm 1st flr.	7	100	EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st fl across from locker rm FP#C147- mens			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Lockers	in rm 3- partial height wall			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Showers	in rm 5- partial height wall			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	in rm 4			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd fl across from elevator 2			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Showers	in rm 3- partial height wall			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Showers	in rm 2- partial height wall			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	in rm 1			EA	\$0	
Locker/Shower Room	Locker/Shower Room	Showers	pool staff locker room in C114			EA	\$0	
Locker/Shower Room	Locker/Shower Room	Showers	Girl's Locker Rm 1st flr.	7	6	EA	\$0	
Locker/Shower Room	Locker/Shower Room	Showers	Girl's Locker Rm 1st flr.	7	6	EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	in rm 6			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Showers	in rm 7- partial height wall			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st fl across from locker rm FP#C148-womens			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st fl across from locker rm FP#C147- mens			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd fl next to prep kitchen			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd fl across from elevator 2			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st fl next to office FP#c130			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	pool staff toilet C115	7	1	EA	\$0	

Building: Athletic
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lunchroom	Multipurpose Room	Ceiling - Lay-In	2nd fl 8B FP#C205	6	770	SF	\$1,652	
Lunchroom	Multipurpose Room	Ceiling - Lay-In	2nd fl 8A FP#C205	6	770	SF	\$1,652	
Lunchroom	Multipurpose Room	Flooring - Tile/Sheet	2nd fl 8B FP#C205	7	770	SF	\$0	
Lunchroom	Multipurpose Room	Flooring - Tile/Sheet	2nd fl 8A FP#C205	7	770	SF	\$0	
Lunchroom	Multipurpose Room	Lighting - Lay-In	2nd fl 8A FP#C205	7	9	SF	\$0	
Lunchroom	Multipurpose Room	Lighting - Lay-In	2nd fl 8B FP#C205	7	9	SF	\$0	
Lunchroom	Warming Kitchen	Serving Line	2nd fl across from rm7			LF	\$0	
Lunchroom	Multipurpose Room	Serving Line	2nd fl 8B FP#C205			LF	\$0	
Lunchroom	Multipurpose Room	Serving Line	2nd fl 8A FP#C205			LF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	1st floor pool filter room	6	610	SF	\$2,879	
Mechanical/Service Rooms		Mechanical/Service Rooms	2nd fl Electric	7	50	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	in 2nd fl prep rm	7	43	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	1st floor plumbing room	6	130	SF	\$613	
Mechanical/Service Rooms		Mechanical/Service Rooms	1st floor pool meter room	6	60	SF	\$283	
Mechanical/Service Rooms		Mechanical/Service Rooms	2nd fl elevator machine rm	7	55	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	2nd floor fan room between gym and pool	6	4,417	SF	\$20,844	
Mechanical/Service Rooms		Mechanical/Service Rooms	1st floor elevator machine room	6	55	SF	\$260	
Mechanical/Service Rooms		Mechanical/Service Rooms	1st floor laundry room	6	74	SF	\$349	
Mechanical/Service Rooms		Storage Room	1st floor hall storage	6	26	SF	\$123	
Mechanical/Service Rooms		Storage Room	in rm 8	7	300	SF	\$0	
Mechanical/Service Rooms		Storage Room	1st floor gym storage	6	355	SF	\$1,675	
Mechanical/Service Rooms		Storage Room	1st floor pool storage room	6	650	SF	\$3,067	
Mechanical/Service Rooms		Storage Room	in pool staffs office	7	30	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	in rm 4	7	35	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	in rm 1	7	35	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	in rm 2- partial height wall	7	43	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st fl next to office FP#c130	7	45	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	in rm 3- partial height wall	7	43	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd fl across from elevator 2	7	45	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd fl next to prep kitchen	7	45	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st fl across from locker rm FP#C147- mens	7	45	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st fl across from locker rm FP#C148-womens	7	45	SF	\$0	

Building: Athletic
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Early Childhood Student Restroom	Accessories	in rm 7- partial height wall	7	43	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	in rm 6	7	35	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	in rm 5- partial height wall	7	43	SF	\$0	
Staff Restroom	Locker/Shower Room	Accessories	Girl's Locker Rm 1st flr.	7	808	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd fl across from elevator 2	7	45	SF	\$0	
Staff Restroom	Locker/Shower Room	Accessories	pool staff locker room in C114			SF	\$0	
Staff Restroom	Locker/Shower Room	Accessories	Girl's Locker Rm 1st flr.	6	808	SF	\$6,239	
Staff Restroom	Staff Restroom	Accessories	pool staff toilet C115	6	53	SF	\$409	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	in rm 6	7	35	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	in rm 4	7	35	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	in rm 2- partial height wall	7	35	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	in rm 1	7	35	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	2nd fl across from elevator 2	7	45	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	in rm 5- partial height wall	7	43	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	in rm 3- partial height wall	7	35	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	1st fl next to office FP#c130	7	45	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	2nd fl next to prep kitchen	7	45	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	1st fl across from locker rm FP#C147- mens	7	45	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	in rm 7- partial height wall	7	43	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	1st fl across from locker rm FP#C148-womens	7	45	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	2nd fl across from elevator 2	7	45	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	pool staff toilet C115	7	53	SF	\$0	
Staff Restroom	Locker/Shower Room	Ceiling - Plaster/Drywall	Girl's Locker Rm 1st flr.	6	808	SF	\$2,288	
Staff Restroom	Locker/Shower Room	Ceiling - Plaster/Drywall	Girl's Locker Rm 1st flr.	6	808	SF	\$2,288	
Staff Restroom	Locker/Shower Room	Ceiling - Plaster/Drywall	pool staff locker room in C114	7	46	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	in rm 1	6	1	EA	\$300	

Building: Athletic
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Early Childhood Student Restroom	Floor Drain	in rm 3- partial height wall	6	1	EA	\$300	
Staff Restroom	Staff Restroom	Floor Drain	1st fl next to office FP#c130	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	in rm 4	6	1	EA	\$300	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	in rm 2- partial height wall	6	1	EA	\$300	
Staff Restroom	Staff Restroom	Floor Drain	1st fl across from locker rm FP#C147- mens	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st fl across from locker rm FP#C148-womens	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	in rm 7- partial height wall	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	in rm 6	6	1	EA	\$300	
Staff Restroom	Locker/Shower Room	Floor Drain	pool staff locker room in C114	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	in rm 5- partial height wall	6	1	EA	\$300	
Staff Restroom	Staff Restroom	Floor Drain	pool staff toilet C115	6	2	EA	\$601	
Staff Restroom	Locker/Shower Room	Floor Drain	Girl's Locker Rm 1st flr.	6	9	EA	\$2,703	
Staff Restroom	Staff Restroom	Floor Drain	2nd fl across from elevator 2	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	2nd fl next to prep kitchen	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	2nd fl across from elevator 2	7	1	EA	\$0	
Staff Restroom	Locker/Shower Room	Floor Drain	Girl's Locker Rm 1st flr.	6	10	EA	\$3,003	
Staff Restroom	Locker/Shower Room	Flooring - Terrazzo	Girl's Locker Rm 1st flr.	7	668	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	2nd fl next to prep kitchen	7	45	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	1st fl next to office FP#c130	7	45	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	1st fl across from locker rm FP#C148-womens	7	45	SF	\$0	
Staff Restroom	Locker/Shower Room	Flooring - Terrazzo	pool staff locker room in C114	7	46	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	2nd fl across from elevator 2	7	45	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	1st fl across from locker rm FP#C147- mens	7	45	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	2nd fl across from elevator 2	7	45	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	pool staff toilet C115	7	53	SF	\$0	
Staff Restroom	Locker/Shower Room	Flooring - Terrazzo	Girl's Locker Rm 1st flr.	7	718	SF	\$0	
Staff Restroom	Locker/Shower Room	Flooring - Tile Ceramic/Porcelain	Girl's Locker Rm 1st flr.	7	90	SF	\$0	
Staff Restroom	Locker/Shower Room	Flooring - Tile Ceramic/Porcelain	Girl's Locker Rm 1st flr.	7	140	SF	\$0	

Building: Athletic
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile/Sheet	in rm 3- partial height wall	7	35	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile/Sheet	in rm 7- partial height wall	7	43	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile/Sheet	in rm 2- partial height wall	7	35	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile/Sheet	in rm 6	7	35	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile/Sheet	in rm 5- partial height wall	7	43	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile/Sheet	in rm 4	7	35	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile/Sheet	in rm 1	7	35	SF	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd fl across from elevator 2			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	pool staff toilet C115			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	in rm 1			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	in rm 4			EA	\$0	
Staff Restroom	Locker/Shower Room	Hand Dryer	pool staff locker room in C114			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd fl next to prep kitchen			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Hand Dryer	in rm 5- partial height wall			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	in rm 6			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Hand Dryer	in rm 7- partial height wall			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd fl across from elevator 2			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Hand Dryer	in rm 3- partial height wall			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	1st fl across from locker rm FP#C148-womens			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Hand Dryer	in rm 2- partial height wall			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	1st fl across from locker rm FP#C147- mens			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	1st fl next to office FP#c130			EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st fl across from locker rm FP#C147- mens	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	in rm 7- partial height wall	7	1	EA	\$0	

Building: Athletic
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Lavatory	2nd fl across from elevator 2	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	in rm 4	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd fl across from elevator 2	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	pool staff toilet C115	7	1	EA	\$0	
Staff Restroom	Locker/Shower Room	Lavatory	pool staff locker room in C114			EA	\$0	
Staff Restroom	Locker/Shower Room	Lavatory	Girl's Locker Rm 1st flr.	7	3	EA	\$0	
Staff Restroom	Locker/Shower Room	Lavatory	Girl's Locker Rm 1st flr.	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	in rm 6	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st fl across from locker rm FP#C148-womens	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd fl next to prep kitchen	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	in rm 5- partial height wall	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st fl next to office FP#c130	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	in rm 1	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	in rm 2- partial height wall	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	in rm 3- partial height wall	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	in rm 1	7	1	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	in rm 3- partial height wall	7	1	SF	\$0	
Staff Restroom	Locker/Shower Room	Lighting - Lay-In	Girl's Locker Rm 1st flr.	7	13	SF	\$0	
Staff Restroom	Locker/Shower Room	Lighting - Lay-In	pool staff locker room in C114	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	in rm 4	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	pool staff toilet C115	7	1	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	in rm 2- partial height wall	7	1	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	in rm 5- partial height wall	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st fl across from locker rm FP#C148-womens	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	in rm 6	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st fl next to office FP#c130	7	1	SF	\$0	

Building: Athletic
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Lighting - Lay-In	2nd fl across from elevator 2	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	2nd fl across from elevator 2	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	2nd fl next to prep kitchen	7	2	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st fl across from locker rm FP#C147- mens	7	1	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	in rm 7- partial height wall	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Partitions	pool staff toilet C115			EA	\$0	
Staff Restroom	Locker/Shower Room	Partitions	pool staff locker room in C114			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	2nd fl across from elevator 2			EA	\$0	
Staff Restroom	Locker/Shower Room	Partitions	Girl's Locker Rm 1st flr.	7	2	EA	\$0	
Staff Restroom	Locker/Shower Room	Partitions	Girl's Locker Rm 1st flr.	7	4	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Partitions	in rm 2- partial height wall			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	1st fl next to office FP#c130			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	2nd fl across from elevator 2			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Partitions	in rm 3- partial height wall			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	in rm 1			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	2nd fl next to prep kitchen			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Partitions	in rm 5- partial height wall			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	in rm 6			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Partitions	in rm 7- partial height wall			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	1st fl across from locker rm FP#C148-womens			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	1st fl across from locker rm FP#C147- mens			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	in rm 4			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	in rm 6			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd fl next to prep kitchen			EA	\$0	
Staff Restroom	Locker/Shower Room	Urinals	pool staff locker room in C114			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st fl across from locker rm FP#C147- mens			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	pool staff toilet C115			EA	\$0	

Building: Athletic
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Urinals	2nd fl across from elevator 2			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Urinals	in rm 7- partial height wall			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd fl across from elevator 2			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st fl across from locker rm FP#C148-womens			EA	\$0	
Staff Restroom	Locker/Shower Room	Urinals	Girl's Locker Rm 1st flr.	7	2	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Urinals	in rm 5- partial height wall			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Urinals	in rm 2- partial height wall			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	in rm 4			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Urinals	in rm 3- partial height wall			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	in rm 1			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st fl next to office FP#c130			EA	\$0	
Staff Restroom	Locker/Shower Room	Wall - Concrete Block	pool staff locker room in C114	7	168	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	in rm 4	6	209	SF	\$598	
Staff Restroom	Early Childhood Student Restroom	Wall - Concrete Block	in rm 7- partial height wall	7	107	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	in rm 1	6	209	SF	\$598	
Staff Restroom	Early Childhood Student Restroom	Wall - Concrete Block	in rm 5- partial height wall	7	107	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	in rm 6	6	209	SF	\$598	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	1st fl across from locker rm FP#C148-womens	7	222	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	2nd fl across from elevator 2	7	222	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	pool staff toilet C115	7	312	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	1st fl next to office FP#c130	7	222	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	1st fl across from locker rm FP#C147- mens	7	222	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	2nd fl next to prep kitchen	7	222	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	2nd fl across from elevator 2	7	222	SF	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st fl across from locker rm FP#C147- mens	7	1	EA	\$0	
Staff Restroom	Locker/Shower Room	Water Closet	Girl's Locker Rm 1st flr.	7	4	EA	\$0	

Building: Athletic
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Water Closet	pool staff toilet C115	7	1	EA	\$0	
Staff Restroom	Locker/Shower Room	Water Closet	Girl's Locker Rm 1st flr.	7	2	EA	\$0	
Staff Restroom	Locker/Shower Room	Water Closet	pool staff locker room in C114			EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd fl next to prep kitchen	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd fl across from elevator 2	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	in rm 7- partial height wall	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st fl next to office FP#c130	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	in rm 5- partial height wall	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	in rm 4	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	in rm 1	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd fl across from elevator 2	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st fl across from locker rm FP#C148-womens	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	in rm 6	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	in rm 3- partial height wall	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	in rm 2- partial height wall	7	1	EA	\$0	
Swimming Pool		Accessories	Natatorium- 1st fl	7	6,391	SF	\$0	
Swimming Pool		Bleacher Seating/Plank seating	Natatorium- 1st fl	7	25	EA	\$0	
Swimming Pool		Lighting - Pendant/ Surface	Natatorium- 1st fl (balcony)	7	618	SF	\$0	
Swimming Pool		Lighting - Pendant/ Surface	Natatorium- 1st fl	7	36	SF	\$0	
Swimming Pool		Pool Basin	Natatorium- 1st fl	7	3,207	SF	\$0	
Swimming Pool		Pool Deck	Natatorium- 1st fl	7	3,184	SF	\$0	
Swimming Pool		Pool deck drains	Natatorium- 1st fl	7	7	EA	\$0	
Swimming Pool		Splined Ceiling including access	Natatorium- 1st fl (balcony)	6	618	SF	\$6,628	
Swimming Pool		Splined Ceiling including access	Natatorium	7	6,391	SF	\$0	
Swimming Pool		Wall Tile	Natatorium- 1st fl	7	10,350	SF	\$0	
Vertical Conveyance		Elevator - Roped Holeless Hydraulic	Entire Building	7	2	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	3	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	3	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	3	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0	

Building: Athletic
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	3	EA	\$0	
INTERIOR Sub Total							\$132,006	

Building: Athletic
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		7	9	LF	\$0	
Casework	Classroom	Casework		7	9	LF	\$0	
Casework	Classroom	Casework		7	9	LF	\$0	
Casework	Classroom	Casework		7	9	LF	\$0	
Casework	Classroom	Casework		7	9	LF	\$0	
Casework	Classroom	Casework		7	9	LF	\$0	
Casework	Classroom	Casework		7	9	LF	\$0	
Casework	Classroom	Casework		7	9	LF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	730	SF	\$1,566	
Ceiling	Classroom	Lay-In/Drop		6	730	SF	\$1,566	
Ceiling	Classroom	Lay-In/Drop		6	730	SF	\$1,566	
Ceiling	Classroom	Lay-In/Drop		6	730	SF	\$1,566	
Ceiling	Classroom	Lay-In/Drop		6	730	SF	\$1,566	
Ceiling	Classroom	Lay-In/Drop		6	730	SF	\$1,566	
Ceiling	Classroom	Lay-In/Drop		6	730	SF	\$1,566	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Multipurpose Room	Chalk Board	2nd fl 8A FP#C205	4		LF		
Chalk Board	Multipurpose Room	Chalk Board	2nd fl 8B FP#C205	4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Corridors	Corridors	Concrete Block	pool staff corridor	7	377	SF	\$0	
Corridors	Corridors	Concrete Block	Stair CA6	7	2,270	SF	\$0	
Corridors	Corridors	Drinking Fountains	stairs to connecting corridor			EA	\$0	
Corridors	Corridors	Drinking Fountains	vestibule under connecting corridor			EA	\$0	
Corridors	Corridors	Drinking Fountains	2nd fl- connecting corridor to main building			EA	\$0	
Corridors	Corridors	Drinking Fountains	Stair CA5			EA	\$0	

Building: Athletic
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Drinking Fountains	Day Care Entrance			EA	\$0	
Corridors	Corridors	Drinking Fountains	pool staff corridor			EA	\$0	
Corridors	Corridors	Drinking Fountains	Stair CA6			EA	\$0	
Corridors	Corridors	Drinking Fountains	2nd Floor			EA	\$0	
Corridors	Corridors	Drop/Lay-In	Stair CA5	7	510	SF	\$0	
Corridors	Corridors	Drop/Lay-In	2nd Floor	6	2,834	SF	\$6,079	
Corridors	Corridors	Drop/Lay-In	1st Floor	6	2,918	SF	\$6,259	
Corridors	Corridors	Drop/Lay-In	2nd fl- connecting corridor to main building	7	1,194	SF	\$0	
Corridors	Corridors	Exposed	Stair CA6	7	444	SF	\$0	
Corridors	Corridors	Floors	Stair CA6	7	500	SF	\$0	
Corridors	Corridors	Lay-In	1st Floor	7	3,460	EA	\$0	
Corridors	Corridors	Lay-In	2nd Floor	7	2,834	EA	\$0	
Corridors	Corridors	Lay-In	Stair CA5	7	510	EA	\$0	
Corridors	Corridors	Lay-In	Day Care Entrance	7	232	EA	\$0	
Corridors	Corridors	Lay-In	vestibule under connecting corridor	7	227	EA	\$0	
Corridors	Corridors	Lay-In	pool staff corridor	7	2	EA	\$0	
Corridors	Corridors	Lay-In	stairs to connecting corridor	7	403	EA	\$0	
Corridors	Corridors	Lay-In	2nd fl- connecting corridor to main building	7	1,194	EA	\$0	
Corridors	Corridors	Single Water Cooler	1st Floor	6	4	EA	\$2,460	
Corridors	Corridors	Single Water Cooler	1st Floor	5	2	EA	\$6,149	
Corridors	Corridors	Stair Handrails	stairs to connecting corridor	7	70	LF	\$0	
Corridors	Corridors	Stair Handrails	pool staff corridor			LF	\$0	
Corridors	Corridors	Stair Handrails	vestibule under connecting corridor			LF	\$0	
Corridors	Corridors	Stair Handrails	Day Care Entrance			LF	\$0	
Corridors	Corridors	Stair Handrails	Stair CA5	7	81	LF	\$0	
Corridors	Corridors	Stair Handrails	1st Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	2nd Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	2nd fl- connecting corridor to main building			LF	\$0	
Corridors	Corridors	Stair Handrails	Stair CA6	6	86	LF	\$0	
Corridors	Corridors	Stairs	Stair CA6	6	57	EA	\$408	
Corridors	Corridors	Stairs	2nd Floor			EA	\$0	
Corridors	Corridors	Stairs	1st Floor			EA	\$0	
Corridors	Corridors	Stairs	Day Care Entrance			EA	\$0	

Building: Athletic
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Stairs	vestibule under connecting corridor			EA	\$0	
Corridors	Corridors	Stairs	pool staff corridor			EA	\$0	
Corridors	Corridors	Stairs	2nd fl- connecting corridor to main building			EA	\$0	
Corridors	Corridors	Structural Glazed Tile	2nd fl- connecting corridor to main building	7	396	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	stairs to connecting corridor	7	2,156	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	vestibule under connecting corridor	7	600	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	Day Care Entrance	7	536	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	Stair CA5	7	1,831	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	1st Floor	7	7,407	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	2nd Floor	7	3,803	SF	\$0	
Corridors	Corridors	Student Lockers	stairs to connecting corridor			EA	\$0	
Corridors	Corridors	Student Lockers	pool staff corridor			EA	\$0	
Corridors	Corridors	Student Lockers	vestibule under connecting corridor			EA	\$0	
Corridors	Corridors	Student Lockers	Stair CA5			EA	\$0	
Corridors	Corridors	Student Lockers	1st Floor			EA	\$0	
Corridors	Corridors	Student Lockers	Stair CA6			EA	\$0	
Corridors	Corridors	Student Lockers	2nd fl- connecting corridor to main building			EA	\$0	
Corridors	Corridors	Student Lockers	Day Care Entrance			EA	\$0	
Corridors	Corridors	Student Lockers	2nd Floor			EA	\$0	
Corridors	Corridors	Terrazzo	Stair CA5	7	597	SF	\$0	
Corridors	Corridors	Terrazzo	stairs to connecting corridor	7	291	SF	\$0	
Corridors	Corridors	Terrazzo	pool staff corridor	7	97	SF	\$0	
Corridors	Corridors	Terrazzo	2nd Floor	7	2,834	SF	\$0	
Corridors	Corridors	Terrazzo	Day Care Entrance	7	232	SF	\$0	
Corridors	Corridors	Terrazzo	1st Floor	7	3,460	SF	\$0	
Corridors	Corridors	Terrazzo	2nd fl- connecting corridor to main building	7	1,428	SF	\$0	
Corridors	Corridors	Terrazzo	vestibule under connecting corridor	7	227	SF	\$0	
Corridors	Corridors	Wall Mounted	Stair CA6	7	10	EA	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	2nd fl- connecting corridor to main building	7	234	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	2nd Floor	7	20	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	1st Floor	7	542	SF	\$0	

Building: Athletic
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors Ceiling	Corridors	Plaster/Drywall	vestibule under connecting corridor	7	227	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	pool staff corridor	6	97	SF	\$275	
Corridors Ceiling	Corridors	Plaster/Drywall	stairs to connecting corridor	7	403	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	Day Care Entrance	7	232	SF	\$0	
Stairs	Corridors	Terrazzo	stairs to connecting corridor	7	40	SF	\$0	
Stairs	Corridors	Terrazzo	Stair CA5	7	48	SF	\$0	
Floor	Classroom	Tile/Sheet		7	730	SF	\$0	
Floor	Classroom	Tile/Sheet		7	730	SF	\$0	
Floor	Classroom	Tile/Sheet		7	730	SF	\$0	
Floor	Classroom	Tile/Sheet		7	730	SF	\$0	
Floor	Classroom	Tile/Sheet		7	730	SF	\$0	
Floor	Classroom	Tile/Sheet		7	730	SF	\$0	
Floor	Classroom	Tile/Sheet		7	730	SF	\$0	
Floor	Classroom	Tile/Sheet		7	730	SF	\$0	
GYM_FLOOR	Standard Dedicated Gymnasium	Gymnasia Floor	1st Floor	7	110	SF	\$0	
Lighting	Classroom	Lay-In		6	12	EA	\$858	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		6	12	EA	\$858	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
LUNCH_WALL	Multipurpose Room	Lunchroom Walls	2nd fl 8A FP#C205	7	290	SF	\$0	
LUNCH_WALL	Multipurpose Room	Lunchroom Walls	2nd fl 8B FP#C205	7	290	SF	\$0	
LUNCH_WALL	Multipurpose Room	Lunchroom Walls	2nd fl 8B FP#C205	6	642	SF	\$1,836	
LUNCH_WALL	Multipurpose Room	Lunchroom Walls	2nd fl 8A FP#C205	6	642	SF	\$1,836	
Marker Board	Multipurpose Room	Marker Board	2nd fl 8A FP#C205	7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Multipurpose Room	Marker Board	2nd fl 8B FP#C205	7	12	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
RESTROOM_LIGHT	Locker/Shower Room	Restroom Lighting	Girl's Locker Rm 1st flr.	7	12	EA	\$0	
RESTROOM_WALL	Locker/Shower Room	Restroom Walls	Girl's Locker Rm 1st flr.	7	2,205	SF	\$0	

Building: Athletic
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
RESTROOM_WALL	Locker/Shower Room	Restroom Walls	Girl's Locker Rm 1st flr.	7	2,205	SF	\$0	
RESTROOM_WALL	Early Childhood Student Restroom	Restroom Walls	in rm 2- partial height wall	7	92	SF	\$0	
RESTROOM_WALL	Early Childhood Student Restroom	Restroom Walls	in rm 3- partial height wall	7	92	SF	\$0	
Wall	Classroom	Concrete Block		7	828	SF	\$0	
Wall	Classroom	Concrete Block		6	828	SF	\$2,368	
Wall	Classroom	Concrete Block		6	828	SF	\$2,368	
Wall	Classroom	Concrete Block		6	828	SF	\$2,368	
Wall	Classroom	Concrete Block		6	828	SF	\$2,368	
Wall	Classroom	Concrete Block		7	631	SF	\$0	
Wall	Classroom	Concrete Block		7	731	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	147	SF	\$347	
Wall	Classroom	Plaster/Drywall		6	147	SF	\$347	
Wall	Classroom	Plaster/Drywall		6	147	SF	\$347	
Wall	Classroom	Plaster/Drywall		6	147	SF	\$347	
Wall	Classroom	Plaster/Drywall		6	147	SF	\$347	
Wall	Classroom	Plaster/Drywall		6	147	SF	\$347	
Wall	Classroom	Plaster/Drywall		6	294	SF	\$694	
ROOM Sub Total							\$50,225	
Building Athletic Sub Total							\$1,474,383	

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Civil/Drainage		Catch Basin	Entire Site	7	10	EA	\$0	
Civil/Drainage		Site Manhole	Entire Site	7	18	EA	\$0	
Fencing		Chain Link	Site z South	6	40	LF	\$574	
Fencing		Ornamental Iron	Entire Site	6	2,046	LF	\$38,620	
Fencing		Ornamental Iron	W side of SW lot	4	16	LF	\$3,020	Missing sections
Landscape		Benches	Site z North	7	5	EA	\$0	
Landscape		Grass	Entire Building	7	44,306	SF	\$0	
Landscape		Hardscape - Concrete	Entire Site	7	6,640	SF	\$0	
Landscape		Hardscape - Pavers	Site z North	7	12,712	SF	\$0	
Landscape		Parkway trees	Entire Site	7	31	EA	\$0	
Landscape		Planting Beds/ Areas	Entire Site	7	5,532	SF	\$0	

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Landscape		Retaining Wall - Masonry	Site ζ West	7	21,245	SF	\$0	
Landscape		Trash Receptacles	Site ζ North	6	4	EA	\$831	
Parking Lot		Asphalt	Parking Lot	6	40,000	SF	\$34,320	
Parking Lot		Concrete	Trash Enclosure in Parking Lot	7	2,358	SF	\$0	
Parking Lot		Concrete Curbs	Parking Lot	7	1,014	LF	\$0	
Parking Lot		Parking lot interior plantings	Parking Lot	7	10	LF	\$0	
Parking Lot		Trash Compactor	Parking Lot	7	2	EA	\$0	
Parking Lot		Trash Enclosure	Parking Lot	7	2,358	SF	\$0	
Parking Lot		Vehicular Screening	Parking Lot	7	360	LF	\$0	
Playground		Playground Equipment - Pre-K 3-5	site- NW	7	1	EA	\$0	
Playground		Playground Equipment - School Age 5-12	site- NE	6	1	EA	\$0	
Playground		Playground Surfacing - Poured Surface	site- NW	7	1,450	SF	\$0	
Playground		Playground Surfacing - Poured Surface	site- NE	6	5,220	SF	\$13,810	holes
Sidewalks		Internal Walks	Entire Site	7	1,176	LF	\$0	
Sidewalks		Perimeter Sidewalks	Entire Site	7	24,547	SF	\$0	
Signage		Flag Pole	Site ζ North	7	2	EA	\$0	
Signage		Monument Sign	Site ζ North	7	1	EA	\$0	
SITE Sub Total							\$91,174	
SITE Sub Total							\$91,174	

Total Campus Need ^{2 3} \$4,391,094

¹ It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

² As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

³ The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Building: Main														
106	1215	1	8	24	40	198	18		Y	N	Y	Classroom		
108	1215	1	8	24	40	198	18		Y	N	Y	Classroom		
109	1050	1	12	38	40	198	18		Y	N	N	Classroom		
110	1215	1	8	24	40	198	18		Y	N	Y	Classroom		
111	1215	1	8	24	40	198	18		Y	Y	Y	Classroom		
112	1215	1	8	24	40	198	18		Y	Y	Y	Classroom		
113	1215	1	8	24	40	198	18		Y	Y	Y	Classroom		
203	870	1	12	32	40	108	4		Y	N	N	Classroom		
204	870	1	12	32	40	108	4		Y	N	N	Classroom		
206	870	1	12	32	40	108	4		Y	N	N	Classroom		
207	1050	3	12	38	40	162	6		Y	N	N	Classroom		
208	870	1	12	32	40	108	4		Y	N	Y	Classroom		
209	870	1	12	32	40	108	4		Y	N	Y	Classroom		
210	870	1	12	32	40	108	4		Y	N	Y	Classroom		
211	870	1	12	32	40	108	4		Y	N	N	Classroom		
212	870	1	12	32	40	108	4		Y	N	Y	Classroom		
213	870	1	12	32	40	108	4		Y	N	N	Classroom		
214	870	1	12	32	40	108	4		Y	N	N	Classroom		
301	1445	1	15	50	40	168	4		Y	N	Y	Classroom		
303	1345	1	15	50	40	168	4		Y	N	N	Classroom		
305	870	1	12	34	40	108	4		Y	N	N	Classroom		
306	1270	1	59	80	40	162	6		Y	N	Y	Classroom		
308	1270	1	12	44	40	162	6		Y	Y	Y	Classroom		
309	1020	5	14	46	40	162	6		Y	Y	Y	Classroom		
310	870	1	12	24	40	78	4		Y	N	Y	Classroom		
311	870	1	12	32	40	108	4		Y	N	Y	Classroom		
312	870	1	12	32	40	108	4		Y	Y	Y	Classroom		
313	870	1	12	32	40	108	4		Y	Y	Y	Classroom		
314	870	1	12	34	40	108	4		Y	N	N	Classroom		
315	870	1	12	32	40	108	4		Y	N	N	Classroom		
400	1250	1	8	30	40	543	4		Y	N	Y	Classroom		
401	1610	2	4	30	40	678	6		Y	N	Y	Classroom		
401B	830	1	12	34	40	108	4		Y	N	Y	Classroom		
404	830	1	12	32	40	108	4		Y	N	Y	Classroom		
405	1020	5	14	46	40	162	6		Y	N	N	Classroom		
406	830	1	12	32	40	108	4		Y	N	Y	Classroom		

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
408	830	1	12	32	40	108	4		Y	N	N	Classroom		
409	830	1	12	34	40	108	4		Y	N	N	Classroom		
410	830	1	12	32	40	108	4		Y	N	N	Classroom		
411	830	1	13	24	40	108	4		Y	N	Y	Classroom		
412	830	1	12	24	40	108	4		Y	N	Y	Classroom		
413	830	1	12	24	40	108	4		Y	N	Y	Classroom		
420	830	1	12	24	40	108	4		Y	N	Y	Classroom		
Other	40								N	N	N	Restroom	Early Childhood Student Restroom	113
Other	57								N	N	N	Restroom	Staff Restroom	2nd floor unisex 1
Other	57								N	N	N	Restroom	Staff Restroom	2nd floor unisex 2
Other	170			8					N	N	N	Administrative Suites/Offices		309A office/ storage
Other	40								N	N	N	Restroom	Early Childhood Student Restroom	112
Other	40								N	N	N	Restroom	Early Childhood Student Restroom	110
Other	290			20					N	N	N	Administrative Suites/Offices		205 small office
Other	455			20					N	N	N	Administrative Suites/Offices		2nd floor observation 2
Other	310								N	N	N	Restroom	Children's Standard Student Restroom	3rd floor girls
Other	455			20					N	N	N	Administrative Suites/Offices		4th floor observation 4
Other	57								N	N	N	Restroom	Staff Restroom	4th floor unisex 1
Other	57								N	N	N	Restroom	Staff Restroom	4th floor unisex 2
Other	290			20					N	N	N	Administrative Suites/Offices		psychologists office across from 406
Other	310								N	N	N	Restroom	Children's Standard Student Restroom	4th floor girls
Other	310								N	N	N	Restroom	Children's Standard Student Restroom	2nd floor boys
Other	310								N	N	N	Restroom	Children's Standard Student Restroom	4th floor boys
Other	455			20					N	N	N	Administrative Suites/Offices		3rd floor observation 3
Other	57								N	N	N	Restroom	Staff Restroom	3rd floor unisex 1
Other	57								N	N	N	Restroom	Staff Restroom	1st floor unisex 2
Other	290			20					N	N	N	Administrative Suites/Offices		307 office/ storage
Other	170			8					N	N	N	Administrative Suites/Offices		109A engineers office
Other	310								N	N	N	Restroom	Children's Standard Student Restroom	3rd floor boys
Other	390			8					N	N	N	Administrative Suites/Offices		303/ 300 shared prep room
Other	310								N	N	N	Restroom	Children's Standard Student Restroom	2nd floor girls
Other	310								N	N	N	Restroom	Children's Standard Student Restroom	1st floor girls
Other	310								N	N	N	Restroom	Children's Standard Student Restroom	1st floor boys
Other	57								N	N	N	Restroom	Staff Restroom	1st floor unisex 1
Other	455			20					N	N	N	Administrative Suites/Offices		1st floor parent room (observation 1)
Other	40								N	N	N	Restroom	Early Childhood Student Restroom	106

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	40								N	N	N	Restroom	Early Childhood Student Restroom	108
Other	57								N	N	N	Restroom	Staff Restroom	3rd floor unisex 2
Other	140			12					N	N	Y	Administrative Suites/Offices		Student Services office
Other	40								N	N	N	Restroom	Early Childhood Student Restroom	111
Other	2492								N	N	N	Library		2nd Floor
Other	202			12					N	N	N	Administrative Suites/Offices		Conference Room in Main Office
Other	533			20					N	N	N	Administrative Suites/Offices		Faculty Lounge in Main Office
Other	247			12					N	N	Y	Administrative Suites/Offices		Principals office in Main Office
Other	216			10					N	N	Y	Administrative Suites/Offices		Asst. Principals office in Main Office
Other	170			12					N	N	Y	Administrative Suites/Offices		in Main Office
Other	833			18					N	N	Y	Administrative Suites/Offices		Main office on 1st floor
Other	396			4					N	N	Y	Administrative Suites/Offices		Kitchen staff breakroom and lunchroom storage
Other	162								N	N	N	Kitchen	Cooking Kitchen	Dishwashing located in Lunchroom
Other	105			6					N	N	N	Administrative Suites/Offices		office located in Kitchen
Other	1163								N	N	N	Kitchen	Cooking Kitchen	in Lunchroom
Other	650								N	N	N	Lunch & Multipurpose Room	Lunchroom	Serving Room in Lunchroom
Other	996								N	N	N	Corridors		Vestibules at 1st Flr exits
Other	218			6					N	N	N	Administrative Suites/Offices		Library Workroom in Library
Other	3887								N	N	N	Lunch & Multipurpose Room	Lunchroom	1st Floor
Other	1073								N	N	N	Library		Professional Library 2nd Flr
Other	1102			34					N	N	Y	Administrative Suites/Offices		Media Room, 2nd Flr
Other	5457								N	N	N	Corridors		1st Floor
Other	4663								N	N	N	Corridors		2nd Floor
Other	3590								N	N	N	Corridors		3rd Floor
Other									N	N	N	Corridors		Boiler Room Exit Stair
Other									N	N	N	Corridors		Stair 'A'
Other									N	N	N	Corridors		Stair 'B'
Other									N	N	N	Corridors		Stair 'C'
Other	42								N	N	N	Restroom	Staff Restroom	Faculty toilet in Main Office
Other	3508								N	N	N	Corridors		4th Floor
Other	41								N	N	N	Restroom	Staff Restroom	Kitchen Staff toilet in Kitchen

Building: Athletic

1	730	1	2	12	40	140			Y	N	N	Classroom		
2	730	1	2	12	40	140			Y	N	N	Classroom		

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
3	730	1	2	12	40	140			Y	N	N	Classroom		
4	730	1	2	12	40	140			Y	N	N	Classroom		
5	730	1	2	8	40	100	4		Y	N	N	Classroom		
6	730	1	2	8	40	100	4		Y	N	N	Classroom		
7	730	1	2	8	40	100	4		Y	N	N	Classroom		
Other									N	N	N	Corridors		Stair CA6
Other	46								N	N	N	Restroom	Locker/Shower Room	pool staff locker room in C114
Other	5395								N	N	N	Gymnasia	Standard Dedicated Gymnasium	1st Floor
Other	53								N	N	N	Restroom	Staff Restroom	pool staff toilet C115
Other	3460								N	N	N	Corridors		1st Floor
Other	180			6					N	N	Y	Administrative Suites/Offices		Gym Office FP#103
Other	45								N	N	N	Restroom	Staff Restroom	1st fl across from locker rm FP#C148-womens
Other	2834								N	N	N	Corridors		2nd Floor
Other	158			6					N	N	N	Administrative Suites/Offices		pool office C11
Other	45								N	N	N	Restroom	Staff Restroom	2nd fl across from elevator 2
Other	45								N	N	N	Restroom	Staff Restroom	2nd fl across from elevator 2
Other	97								N	N	N	Corridors		pool staff corridor
Other									N	N	N	Corridors		Stair CA5
Other	227								N	N	N	Corridors		vestibule under connecting corridor
Other	403								N	N	N	Corridors		stairs to connecting corridor
Other	808								N	N	N	Restroom	Locker/Shower Room	Girl's Locker Rm 1st flr.
Other	45								N	N	N	Restroom	Staff Restroom	1st fl across from locker rm FP#C147- mens
Other	770								N	N	N	Lunch & Multipurpose Room	Multipurpose Room	2nd fl 8A FP#C205
Other	232								N	N	N	Corridors		Day Care Entrance Vestibule
Other	35								N	N	N	Restroom	Early Childhood Student Restroom	in rm 3- partial height wall
Other	43								N	N	N	Restroom	Early Childhood Student Restroom	in rm 7- partial height wall
Other	222			4					N	N	Y	Administrative Suites/Offices		Teacher workroom in rm 7
Other	35								N	N	N	Restroom	Children's Standard Student Restroom	in rm 6
Other	43								N	N	N	Restroom	Early Childhood Student Restroom	in rm 5- partial height wall
Other	808								N	N	N	Restroom	Locker/Shower Room	Girl's Locker Rm 1st flr.
Other	770								N	N	N	Lunch & Multipurpose Room	Multipurpose Room	2nd fl 8B FP#C205
Other	45								N	N	N	Restroom	Staff Restroom	2nd fl next to prep kitchen
Other	216								N	N	N	Kitchen	Warming Kitchen	2nd fl across from rm7
Other	35								N	N	N	Restroom	Children's Standard Student Restroom	in rm 4
Other	14			4					N	N	Y	Administrative Suites/Offices		Office C in Main Office 1st fl

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	35								N	N	N	Restroom	Early Childhood Student Restroom	in rm 2- partial height wall
Other	35								N	N	N	Restroom	Children's Standard Student Restroom	in rm 1
Other	517			8					N	N	Y	Administrative Suites/Offices		Main Office FP#C139
Other	128			4					N	N	N	Administrative Suites/Offices		Office A- in main office 1st fl
Other	45								N	N	N	Restroom	Staff Restroom	1st fl next to office FP#c130
Other	257			8					N	N	N	Administrative Suites/Offices		office 1st fl FP#C130
Other	94			4					N	N	N	Administrative Suites/Offices		Office B in Main office 1st fl
Other	1428								N	N	N	Corridors		2nd fl- connecting corridor to main building