

Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx.

Condition Rankings and Descriptions

- Rank 7:** The item/system is new or in good condition and no work is required.
- Rank 6:** The item/system requires general cleaning and/or routine maintenance.
- Rank 5:** The item/system requires repairs and has not reached the end of its serviceable life.
- Rank 4:** The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.
- Rank 3:** The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.
- Rank 2:** The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.
- Rank 1:** The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.¹

Definitions

- Quantity** means, for each item, the total number (or amount) of that item that exists and was evaluated.
- Unit** means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").
- Cost** means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.
- For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.**
- Total Campus Need** also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

Building: Main Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chimney		Brick Chimney - Concrete/ Mortar Liner	Above Roof Level	5	10	LF	\$17,875	
Chimney		Brick Chimney - Concrete/ Mortar Liner	Below Re-Built Top Section	4	10	LF	\$55,055	
Chimney		Brick Chimney - Concrete/ Mortar Liner	NW Corner	6	55	LF	\$27,528	
Cornice		Cornice - Cast Stone	Door 3, SE and SW Corners	5	80	LF	\$14,203	chipping/deteriorating
Doors		Exterior Steel Door	Door 7	5	2	EA	\$2,180	damage to exterior
Doors		Exterior Steel Door	Doors 5, 6, and Roof Access	7	4	EA	\$0	
Doors		Exterior Wood Door	Door 4 at South	4	1	EA	\$3,209	
Doors		Exterior Wood Door	Door 3- East Facade	5	2	EA	\$2,118	
Doors		Transom Lite	Door 5	7	2	EA	\$0	
Doors		Transom Lite	Door 3	5	1	EA	\$934	
Entrance		Concrete Exterior Stairs	Doors 3, 4, 6, 7	6	300	LF	\$32,175	
Entrance		Stair Handrails	Doors 4, 6, 7	5	40	LF	\$321	loose, deteriorated
Foundation		Concrete Foundation	Entire Building	7	392	LF	\$0	
Foundation		Concrete Foundation	West Wall of Boiler Rm	6	40	LF	\$6,229	water seepage

Building: Main
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting		Exterior Lights - Parapet or Roof Mounted	Roof	4	11	EA	\$40,898	
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	2	EA	\$429	
Lintels		Lintels - Steel	Entire Building	6	546	LF	\$20,613	
Lintels		Lintels - Steel	1st fl at SE and SW Corners	4	22	LF	\$9,595	
Parapet		Coping - Clay Tile	Auditorium Roof	6	265	LF	\$0	
Parapet		Coping - Stone	West Side of Auditorium	5	42	LF	\$3,662	open joints- deteriorated concrete
Parapet		Coping - Stone	Main Roof	7	266	LF	\$0	
Parapet		Parapet < 16" Height	Main Roofs	6	282	LF	\$43,915	
Parapet		Parapet > 30" Height	Main Roof- South and East Parapet	4	80	LF	\$79,508	
Parapet		Parapet > 30" Height	Main Roofs	6	186	LF	\$48,275	
Parapet		Parapet 16" to 30" Height	Main Roofs	6	25	LF	\$5,191	
Roof System		Asphalt Gravel Ballast Roof	Main Roofs	6	11,090	SF	\$70,730	
Roof System		Exterior Downspouts	Main Roof at Access Area	7	8	LF	\$0	
Roof System		Interior Downspouts	Main Roof	7	120	LF	\$0	
Roof System		Interior Downspouts	Auditorium Roof	6	96	LF	\$0	
Roof System		Roof Structure: Concrete	Main Roofs	7	11,090	SF	\$0	
Superstructure		Concrete	Entire Building	7	32,730	SF	\$0	
Walls		Brick	Perimeter of Auditorium at Roof Level	5	350	SF	\$7,928	
Walls		Brick	Entire Building	6	13,400	SF	\$88,528	
Walls		Brick	Perimeter of Auditorium at Roof Level	4	350	SF	\$26,426	
Walls		Stone - Cast	Base and Pier Caps	6	1,060	SF	\$15,158	open joints
Windows		Window - Guards perforated	Entire Building	7	910	SF	\$0	
Windows		Windows - Sash Aluminum Double-pane	Entire Building	6	4,616	SF	\$39,605	
EXTERIOR Sub Total							\$662,289	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	Electrical Room	7	3	EA	\$0	
Emergency System		Emergency A/C power - Auditorium and aisle lighting	3rd Floor	7	3,127	SF	\$0	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	7	3,710	SF	\$0	
Emergency System		Emergency A/C power - Gym and Lunch rooms	1st Floor	7	2,120	SF	\$0	
Emergency System		Emergency A/C power - Gym and Lunch rooms	1st Floor	7	3,498	SF	\$0	
Emergency System		Emergency A/C power - Gym and Lunch rooms	1st Floor	7	1,173	SF	\$0	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Emergency A/C power - Students Toilets	Entire Building	7	465	SF	\$0	
Emergency System		Emergency generator 100 to 150 KW natural gas - Outdoor	OUTSIDE BY PARKING LOT	7	1	EA	\$0	
Emergency System		Exit Signs - Auditorium	2nd Floor	7	3	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	7	14	EA	\$0	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st Floor	7	2	EA	\$0	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st Floor	7	5	EA	\$0	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st Floor	7	1	EA	\$0	
Emergency System		Independent Electrical Service for emergency power	Electrical Room	7	1	EA	\$0	
Emergency System		Public Announcement System	1st Floor	6	71,980	SF	\$43,231	
Emergency System		Security System - CCTV	1st Floor	6	71,980	SF	\$102,931	
Emergency System		Security System - Intrusion detection	1st Floor	5	71,980	SF	\$118,371	
Main Service		Main Electrical service 2000 to 3000 A 120/208/3PH	Electrical Room	7	1	EA	\$0	
Power Distribution		Lighting and power panels	Entire Building	4	2	EA	\$10,868	
Power Distribution		Lighting and power panels	Entire Building	6	5	EA	\$3,575	
Power Distribution		Lighting and power panels	Entire Building	7	7	EA	\$0	
Power Distribution		Main distribution panels 400-600 amp	Boiler Room	4	1	EA	\$12,155	
Power Distribution		Main distribution panels above 600 amp	Electrical Room	7	1	EA	\$0	
Power Distribution		Main distribution panels less than 400 amp	Boiler Room	4	1	EA	\$6,578	
ELECTRICAL Sub Total							\$297,710	

Building: Main
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Entire Building	6	32,730	SF	\$11,701	
FIRE PROTECTION Sub Total							\$11,701	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Condensing Unit - Ground Mounted 5 to 10 tons	OUTSIDE BY PARKING LOT	6	2	EA	\$3,718	
Air Conditioning		Condensing Unit - Roof Mounted less than 5 tons	Roof	6	2	EA	\$1,716	
Air Conditioning		Window A/C Unit	1st Floor	4	1	EA	\$2,145	
Air Conditioning		Window A/C Unit	1st Floor	6	1	EA	\$215	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Handling Systems		Air Handling Unit Package - Single Zone - Steam 4,000 to 8,000 cfm	1st Floor	6	1	EA	\$5,005	
Air Handling Systems		Air intake for all Air Handling Units except built up AHU	GROUND LEVEL, WEST WALL EXPOSURE	6	1	EA	\$1,430	
Air Handling Systems		Fan Coil Unit - Electric	2nd Floor	4	1	EA	\$11,869	
Air Handling Systems		Fan Coil Unit - Electric	Entire Building	6	1	EA	\$1,187	
Air Handling Systems		Make Up Air Unit - Roof Mounted - Gas-Heating 10,001 cfm - 15,000 cfm	Roof	6	1	EA	\$5,577	
Air Handling Systems		Make Up Air Unit - Roof Mounted - Gas-Heating less than 6,000 cfm	Roof	6	1	EA	\$2,860	
Boiler Systems		Boiler Assembly - Steam - Low Pressure Scotch Marine Boiler 76-100 HP	Boiler Room	6	2	EA	\$23,738	
Boiler Systems		Boiler Auxiliary - Steam Boiler 76-100 HP	Boiler Room	7	2	EA	\$0	
Boiler Systems		Chemical Feed System (Steam Boilers)	Boiler Room	6	1	EA	\$2,145	
Boiler Systems		Combustion Dampers	Boiler Room	6	2	EA	\$572	
Boiler Systems		Feed Water Pumps and Tank - Steam Boilers	Boiler Room	6	1	EA	\$8,437	
Boiler Systems		Gas Boosters	Boiler Room	3	1	EA	\$13,013	NOT FUNCTIONAL
Boiler Systems		Gas Boosters	Boiler Room	7	1	EA	\$0	
Heating Devices		Fin Tube Hot Water	Entire Building	7	45	LF	\$0	
Heating Devices		Fin Tube Hot Water	Entire Building	6	62	LF	\$1,064	
Heating Devices		Radiators - Steam	Entire Building	6	17	EA	\$2,382	
Heating Devices		Unit Heater - Electric	Electrical Room	7	1	EA	\$0	
Heating Devices		Unit Heater - Gas	Boiler Room	7	1	EA	\$0	
Mechanical Plumbing		Condensate Assembly - Pumps and Tank	Boiler Room	6	1	EA	\$715	
Mechanical Plumbing		Piping - Condensate - Steel or Galvanized	Entire Building	7	60	LF	\$0	
Mechanical Plumbing		Piping - Steam - Steel or Galvanized	Entire Building	7	200	LF	\$0	
Temperature Control		Direct Digital Control (DDC) System	1st Floor	6	71,980	SF	\$72,052	
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	6	16	EA	\$2,288	
Unit Ventilation		Unit Ventilators - Steam	Entire Building	6	12	EA	\$18,876	
Ventilation		Exhaust Fan - Indoor	Entire Building	6	3	EA	\$1,502	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	5	2	EA	\$3,003	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	6	1	EA	\$429	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	6	1	EA	\$229	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	5	1	EA	\$1,287	
Ventilation		Type I Exhaust Hood - Kitchen or Culinary Arts	1st Floor	3	1	EA	\$26,884	NO FIRE SUPPRESSION
Ventilation		Type II Exhaust Hood - Warming Kitchen	1st Floor	7	1	EA	\$0	
MECHANICAL Sub Total							\$214,337	

Building: Main
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Building: Main								
Category: PLUMBING								
Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas more than 300,000 BTU/HR	Boiler Room	6	1	EA	\$6,721	
Hot Water		Storage Tank less than 500 gallons	Boiler Room	6	1	EA	\$1,859	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	7	32,730	SF	\$0	
Piping		Domestic Piping - Cold Water Risers	Entire Building	5	32,730	SF	\$10,765	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	7	32,730	SF	\$0	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	5	32,730	SF	\$7,021	
Piping		Domestic Piping - Hot Water Risers	Entire Building	5	32,730	SF	\$8,425	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	7	32,730	SF	\$0	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	7	32,730	SF	\$0	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	5	32,730	SF	\$17,785	
Piping		Sanitary Piping	Entire Building	5	32,730	SF	\$20,126	
Piping		Storm Piping	Entire Building	5	32,730	SF	\$15,445	
Piping		Vent Piping	Entire Building	5	32,730	SF	\$11,701	
Pumps		Domestic Booster Pump duplex	Boiler Room	7	1	EA	\$0	
Pumps		Sump Pump	Boiler Room	7	1	EA	\$0	
PLUMBING Sub Total							\$99,848	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Gym office/storage in Basement	7	209	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Library workroom in library	7	184	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	101C	6	616	SF	\$1,321	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	in 101C	5	193	SF	\$1,093	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	101C	6	507	SF	\$725	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	101C	7	109	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Gym office/storage in Basement	6	209	SF	\$299	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Library workroom in library	7	184	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	in 101C	7	193	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	in 101C	7	3	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	101C	7	7	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Gym office/storage in Basement	7	3	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Library workroom in library	7	3	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Gym office/storage in Basement	6	450	SF	\$1,062	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	in 101C	6	527	SF	\$1,243	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Library workroom in library	6	763	SF	\$1,800	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	101C	5	1,150	SF	\$5,427	
Auditorium - Dedicated	Auditorium - Dedicated	Balcony Seating	205			EA	\$0	
Auditorium - Dedicated	Auditorium - Dedicated	Main Floor Seating	205			EA	\$0	
Auditorium - Dedicated	Auditorium - Dedicated	Sound System	205	5	1	EA	\$92,950	
Auditorium - Dedicated	Auditorium - Dedicated	Stage Curtains	205	7	6	EA	\$0	
Auditorium - Dedicated	Auditorium - Dedicated	Stage Lighting System	205	5	1	EA	\$214,500	
Doors		Interior Steel Doors incl hw	Entire Building	7	6	EA	\$0	
Doors		Interior Steel Doors incl hw	Entire Building	6	19	EA	\$5,380	
Doors		Interior Wood Doors incl hw	Entire Building	7	4	EA	\$0	
Doors		Interior Wood Doors incl hw	Entire Building	6	45	EA	\$12,741	
Doors		Interior Wood Doors incl hw	Entire Building	5	9	EA	\$4,247	
Doors		Interior Wood Doors incl hw	Entire Building	4	1	EA	\$3,209	
Doors		Transom Window	Entire Building	6	310	SF	\$5,763	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Bleacher Seating	rm 005 in Basement			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Flooring - Wood	rm 005 in Basement	6	2,706	SF	\$20,431	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Lighting - Metal Halide/Sodium Vapor	rm 005 in Basement	7	12	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Lighting - Pendant/Surface	rm 005 in Basement	7	4	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Scoreboards	rm 005 in Basement	6	1	EA	\$2,076	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Sound System	rm 005 in Basement			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Stage Curtain	rm 005 in Basement			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Plaster/Drywall	rm 005 in Basement	6	3,398	SF	\$29,155	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Structural Glazed Tile	rm 005 in Basement	7	1,498	SF	\$0	
Kitchen	Cooking Kitchen	Ceiling - Plaster/Drywall	in rms 003 & 006	6	834	SF	\$3,149	
Kitchen	Cooking Kitchen	Flooring - Tile/Sheet	in rms 003 & 006	6	834	SF	\$1,193	
Kitchen	Cooking Kitchen	Lighting - Pendant/Surface	in rms 003 & 006	7	6	SF	\$0	
Kitchen	Cooking Kitchen	Wall - Plaster/Drywall	in rms 003 & 006	6	977	SF	\$2,305	
Library	Library	Casework	rm 204	7	100	LF	\$0	
Library	Library	Flooring Tile/ Sheet	rm 204	7	1,277	SF	\$0	
Library	Library	Lighting - Lay-In	rm 204	7	24	SF	\$0	
Locker/Shower Room	Staff Restroom	Benches	basement- kitchen locker rm			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl girls			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st fl boys			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	Mens 2nd fl			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd fl- unisex			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	in office 101C			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st fl boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	in office 101C			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd fl- unisex			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Mens 2nd fl			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	basement- kitchen locker rm	6	8	EA	\$393	
Locker/Shower Room	Staff Restroom	Showers	basement- kitchen locker rm			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd fl girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	Mens 2nd fl			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd fl- unisex			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st fl boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	in office 101C			EA	\$0	
Lunchroom	Lunchroom	Ceiling - Lay-In	rm 003 in Basement	7	1,173	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lunchroom	Lunchroom	Ceiling - Lay-In	rm 006 in Basement	7	2,120	SF	\$0	
Lunchroom	Multipurpose Room	Ceiling - Lay-In	2nd Floor	7	295	SF	\$0	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	rm 006 in Basement	7	2,120	SF	\$0	
Lunchroom	Multipurpose Room	Flooring - Tile/Sheet	2nd Floor	6	295	SF	\$422	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	rm 003 in Basement	7	1,173	SF	\$0	
Lunchroom	Lunchroom	Lighting - Lay-In	rm 006 in Basement	7	24	SF	\$0	
Lunchroom	Lunchroom	Lighting - Lay-In	rm 003 in Basement	7	13	SF	\$0	
Lunchroom	Multipurpose Room	Lighting - Lay-In	2nd Floor	7	7	SF	\$0	
Lunchroom	Cooking Kitchen	Serving Line	in rms 003 & 006			LF	\$0	
Lunchroom	Lunchroom	Serving Line	rm 006 in Basement	7	15	LF	\$0	
Lunchroom	Lunchroom	Serving Line	rm 003 in Basement	7	18	LF	\$0	
Lunchroom	Multipurpose Room	Serving Line	2nd Floor			LF	\$0	
Lunchroom	Lunchroom	Wall - Plaster/Drywall	rm 003 in Basement	7	155	SF	\$0	
Lunchroom	Multipurpose Room	Wall - Plaster/Drywall	2nd Floor	7	714	SF	\$0	
Lunchroom	Lunchroom	Wall - Plaster/Drywall	rm 006 in Basement	6	704	SF	\$1,661	
Lunchroom	Lunchroom	Wall - Structural Glazed Tile	rm 006 in Basement	7	1,292	SF	\$0	
Lunchroom	Lunchroom	Wall - Structural Glazed Tile	rm 003 in Basement	7	839	SF	\$0	
MDF/IDF		Finishes	in rm 103	6	130	SF	\$442	
MDF/IDF		Ventilation and Cooling	in rm 130	6	1	EA	\$1,401	
Mechanical/Service Rooms		Boiler Room	Boiler Room	5	2,250	SF	\$25,483	
Mechanical/Service Rooms		Janitor's Closet	Entire Building	6	2	SF	\$9	
Mechanical/Service Rooms		Mechanical/Service Rooms	kitchen storage-basement	7	384	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	Basement	6	1,180	SF	\$5,568	
Mechanical/Service Rooms		Storage Room	1st Floor	6	200	SF	\$944	
Mechanical/Service Rooms		Storage Room	2nd Floor	6	170	SF	\$802	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st fl boys	7	285	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd fl- unisex	7	88	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl girls	7	180	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	Mens 2nd fl	7	88	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	basement- kitchen locker rm			SF	\$0	
Staff Restroom	Staff Restroom	Accessories	in office 101C	6	20	SF	\$154	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd fl girls	7	180	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	basement- kitchen locker rm	6	133	SF	\$377	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	in office 101C	7	20	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st fl boys	7	285	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd fl- unisex	7	88	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	Mens 2nd fl	7	88	SF	\$0	
Staff Restroom	Staff Restroom	Floor Drain	basement- kitchen locker rm	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	2nd fl- unisex	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st fl boys	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	Mens 2nd fl	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl girls	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	in office 101C			EA	\$0	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	in office 101C	7	20	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl girls	7	180	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	Mens 2nd fl	7	88	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl- unisex	7	88	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st fl boys	7	285	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	basement- kitchen locker rm	6	133	SF	\$190	
Staff Restroom	Staff Restroom	Hand Dryer	basement- kitchen locker rm			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st fl boys	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl girls	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	Mens 2nd fl	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd fl- unisex	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	in office 101C			EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	in office 101C	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	basement- kitchen locker rm	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl boys	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd fl- unisex	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Mens 2nd fl	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl girls	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	Mens 2nd fl	7	2	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	2nd fl- unisex	7	2	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st fl boys	7	4	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	in office 101C	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd fl girls	7	3	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl girls	7	5	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	in office 101C			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st fl boys	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	basement- kitchen locker rm	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	Mens 2nd fl			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	2nd fl- unisex			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	basement- kitchen locker rm			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd fl girls			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	Mens 2nd fl	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Urinals	in office 101C			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st fl boys	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st fl boys	7	506	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	Mens 2nd fl	7	209	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd fl girls	7	335	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	2nd fl- unisex	7	209	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	basement- kitchen locker rm	7	160	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	in office 101C	7	190	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	basement- kitchen locker rm	7	375	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	2nd fl- unisex	7	209	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	Mens 2nd fl	7	209	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	2nd fl girls	7	335	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	1st fl boys	7	506	SF	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd fl- unisex	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	basement- kitchen locker rm	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	Mens 2nd fl	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl girls	7	5	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	in office 101C	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl boys	7	2	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Theater	Auditorium - Dedicated	Ceiling - Plaster/Drywall	205	7	1,025	SF	\$0	
Theater	Auditorium - Dedicated	Ceiling - Plaster/Drywall	205	4	24	SF	\$680	
Theater	Auditorium - Dedicated	Ceiling - Splined	205	7	2,078	SF	\$0	
Theater	Auditorium - Dedicated	Flooring - Tile/Sheet	205	7	3,127	SF	\$0	
Theater	Auditorium - Dedicated	Lighting - Pendant/ Surface	205	7	15	SF	\$0	
Theater	Auditorium - Dedicated	Lighting - Pendant/ Surface	205	4	3	SF	\$23	
Theater	Auditorium - Dedicated	Lighting - Wall Mounted	205	7	9	EA	\$0	
Theater	Auditorium - Dedicated	Stage	205	7	365	SF	\$0	
Theater	Auditorium - Dedicated	Wall - Plaster/Drywall	205	7	4,978	SF	\$0	
Theater	Auditorium - Dedicated	Wall - Plaster/Drywall	205	4	184	SF	\$3,947	
Vertical Conveyance		Stage Lift	Auditorium	7	1	EA	\$0	
INTERIOR Sub Total							\$452,937	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework		5	4	LF	\$715	
Ceiling	Classroom	Lay-In/Drop		7	690	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	600	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	690	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	725	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	690	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	600	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	470	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	564	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	483	SF	\$0	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chalk Board	Lunchroom	Chalk Board	rm 006 in Basement	4		LF		
Chalk Board	Classroom	Chalk Board		4	22	LF	\$2,674	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Lunchroom	Chalk Board	rm 003 in Basement	4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Multipurpose Room	Chalk Board	2nd Floor	4		LF		
Corridors	Corridors	Drinking Fountains	1st Floor	7	3	EA	\$0	
Corridors	Corridors	Drinking Fountains	Stair #4- West End			EA	\$0	
Corridors	Corridors	Drinking Fountains	Stair 3- East End			EA	\$0	
Corridors	Corridors	Drop/Lay-In	Basement	7	768	SF	\$0	
Corridors	Corridors	Drop/Lay-In	2nd Floor	6	1,507	SF	\$3,233	
Corridors	Corridors	Drop/Lay-In	1st Floor	7	1,435	SF	\$0	
Corridors	Corridors	Lay-In	Basement	7	768	EA	\$0	
Corridors	Corridors	Lay-In	1st Floor	7	1,435	EA	\$0	
Corridors	Corridors	Lay-In	2nd Floor	7	1,507	EA	\$0	
Corridors	Corridors	Pendant/Surface	Stair #4- West End	7	481	EA	\$0	
Corridors	Corridors	Pendant/Surface	Stair 3- East End	7	502	EA	\$0	
Corridors	Corridors	Plaster/Drywall	Stair 3- East End	6	2,048	SF	\$4,832	
Corridors	Corridors	Plaster/Drywall	Stair #4- West End	6	2,480	SF	\$5,852	
Corridors	Corridors	Plaster/Drywall	Basement	6	1,415	SF	\$3,339	
Corridors	Corridors	Plaster/Drywall	1st Floor	6	2,121	SF	\$5,004	
Corridors	Corridors	Plaster/Drywall	2nd Floor	6	2,373	SF	\$5,599	
Corridors	Corridors	Single Water Cooler	2nd Floor	7	2	EA	\$0	
Corridors	Corridors	Stair Handrails	2nd Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	1st Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	Basement			LF	\$0	
Corridors	Corridors	Stair Handrails	Stair 3- East End	6	29	LF	\$0	
Corridors	Corridors	Stair Handrails	Stair #4- West End	6	66	LF	\$0	
Corridors	Corridors	Stairs	2nd Floor			EA	\$0	
Corridors	Corridors	Stairs	1st Floor			EA	\$0	
Corridors	Corridors	Stairs	Basement			EA	\$0	
Corridors	Corridors	Student Lockers	Stair 3- East End			EA	\$0	
Corridors	Corridors	Student Lockers	1st Floor	7	126	EA	\$0	
Corridors	Corridors	Student Lockers	Stair #4- West End			EA	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Student Lockers	2nd Floor	7	163	EA	\$0	
Corridors	Corridors	Terrazzo	Stair #4- West End	7	181	SF	\$0	
Corridors	Corridors	Terrazzo	Stair 3- East End	7	272	SF	\$0	
Corridors	Corridors	Terrazzo	Basement	7	210	SF	\$0	
Corridors	Corridors	Terrazzo	1st Floor	7	287	SF	\$0	
Corridors	Corridors	Terrazzo	2nd Floor	7	359	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	1st Floor	7	1,148	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	Stair 3- East End	6	78	SF	\$112	
Corridors	Corridors	Tile/Sheet Flooring	2nd Floor	7	1,148	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	Basement	7	558	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	Stair #4- West End	6	137	SF	\$196	
Corridors	Corridors	Walls	Stair 3- East End	7	144	SF	\$0	
Corridors	Corridors	Walls	2nd Floor	7	25	SF	\$0	
Corridors	Corridors	Walls	1st Floor	7	40	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	Stair 3- East End	7	502	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	Stair #4- West End	7	481	SF	\$0	
Stairs	Corridors	Tile	Stair 3- East End	7	38	SF	\$0	
Stairs	Corridors	Tile	Stair #4- West End	7	58	SF	\$0	
Floor	Classroom	Tile/Sheet		6	690	SF	\$987	
Floor	Classroom	Tile/Sheet		7	690	SF	\$0	
Floor	Classroom	Tile/Sheet		7	470	SF	\$0	
Floor	Classroom	Tile/Sheet		7	564	SF	\$0	
Floor	Classroom	Tile/Sheet		7	600	SF	\$0	
Floor	Classroom	Tile/Sheet		7	483	SF	\$0	
Floor	Classroom	Tile/Sheet		6	725	SF	\$1,037	
Floor	Classroom	Tile/Sheet		7	690	SF	\$0	
Floor	Classroom	Tile/Sheet		6	600	SF	\$858	
GYM_CEILING	Standard Dedicated Gymnasium	Gymnasia Ceiling	rm 005 in Basement	5	3,498	SF	\$35,015	
GYM_FLOOR	Standard Dedicated Gymnasium	Gymnasia Floor	rm 005 in Basement	6	792	SF	\$5,980	
LIBRARY_CEILING	Library	Drop/Lay-In	rm 204	7	1,277	SF	\$0	
LIBRARY_WALL	Library	Plaster/Drywall	rm 204	7	1,330		\$0	
Lighting	Classroom	Lay-In		7	10	EA	\$0	
Lighting	Classroom	Lay-In		7	10	EA	\$0	
Lighting	Classroom	Lay-In		7	10	EA	\$0	
Lighting	Classroom	Lay-In		7	10	EA	\$0	
Lighting	Classroom	Lay-In		7	14	EA	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	10	EA	\$0	
Lighting	Classroom	Lay-In		7	14	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Marker Board	Lunchroom	Marker Board	rm 006 in Basement			LF	\$0	
Marker Board	Lunchroom	Marker Board	rm 003 in Basement			LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		6	15	LF	\$429	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Multipurpose Room	Marker Board	2nd Floor			LF	\$0	
Marker Board	Classroom	Marker Board		7	10	LF	\$0	
Marker Board	Classroom	Marker Board		7	10	LF	\$0	
Marker Board	Classroom	Marker Board		7	15	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
RESTROOM_LIGHT	Staff Restroom	Restroom Lighting	basement- kitchen locker rm			EA	\$0	
THEATER_FLOOR	Auditorium - Dedicated	Auditorium Floor	205	7	1,200	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	818	SF	\$1,930	
Wall	Classroom	Plaster/Drywall		7	898	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	898	SF	\$2,119	
Wall	Classroom	Plaster/Drywall		6	974	SF	\$2,298	
Wall	Classroom	Plaster/Drywall		7	1,043	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	935	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	895	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	980	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	898	SF	\$0	

ROOM Sub Total \$82,208

Building Main Sub Total \$1,821,029

Building: Addition
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Canopy		Concrete/ Stucco Canopy	1 Story Building	6	850	SF	\$24,067	(overhang) peeling paint
Canopy		Metal Canopy	East and West Entrances	6	1,132	SF	\$27,244	

Building: Addition
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Canopy		Metal Canopy	North Façade	7	20	SF	\$0	
Doors		Exterior Steel Door	Doors 2, 10, 11, 13, 14	6	10	EA	\$3,303	
Doors		Side Lite	Doors 10, 13	6	4	EA	\$906	
Doors		Store Front Door	Doors 1, 8, 9	6	6	EA	\$3,115	
Doors		Transom Lite	Doors 1, 2, 8, 10, 11, 14	6	12	EA	\$3,398	
Entrance		Concrete Exterior Stairs	Door 1, 3	7	100	LF	\$0	
Entrance		Concrete Ramp	Main Entrance	7	50	LF	\$0	
Entrance		Entrance Controls - Audio and Video	Doors 1, 8	7	2	EA	\$0	
Entrance		Power Door Operator and Controls	Doors 1, 8	7	2	EA	\$0	
Foundation		Concrete Foundation	Entire Building	7	859	LF	\$0	
Lighting		Exterior Lights - Parapet or Roof Mounted	Entire Building	4	9	EA	\$33,462	
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	1	EA	\$215	
Lighting		Exterior Lights - Wall Mounted	Entire Building	5	5	EA	\$2,503	
Lighting		Exterior Lights - Wall Mounted	Entire Building	7	2	EA	\$0	
Lintels		Lintels - Steel	Doors 10, 11, 13, 14	7	24	LF	\$0	
Parapet		Coping - Metal	Entire Building	6	1,082	LF	\$0	
Roof System		Asphalt Gravel Ballast Roof	Lower Roofs	6	11,180	SF	\$71,304	
Roof System		Interior Downspouts	Lower Roofs	6	60	LF	\$0	
Roof System		Interior Downspouts	2 Story Bldg	5	92	LF	\$9,867	clean/replace drains-ponding
Roof System		Modified Bitumen Roof	High Roof- 2 Story	6	14,870	SF	\$105,257	
Roof System		Roof Structure: Concrete	Roofs	7	26,050	SF	\$0	
Superstructure		Concrete	Entire Building	7	71,396	SF	\$0	
Walls		Brick	West Entrances	7	233	SF	\$0	glazed brick
Walls		Brick	Entire Building	7	5,742	SF	\$0	
Windows		Curtain wall - Glazed Double Pane	Entire Building	7	6,000	SF	\$0	
Windows		Curtain wall - Insulated panel	East Facade of 1 Story	4	185	SF	\$19,206	
Windows		Curtain wall - Insulated panel	1-Story	7	1,202	SF	\$0	
Windows		Curtain wall - Insulated panel	East and West Facade of 2 Story Bldg	5	1,994	SF	\$75,277	dented/damaged
Windows		Curtain wall - Louver	Entire Building	7	290	SF	\$0	
Windows		Curtain wall - Windows	Entire Building	6	1,936	SF	\$18,272	loose hardware on casements
Windows		Window - Guards perforated	Entire Building	7	6,320	SF	\$0	
EXTERIOR Sub Total							\$397,395	

Building: Addition
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	7	8,311	SF	\$0	
Emergency System		Emergency A/C power - Students Toilets	Entire Building	7	1,155	SF	\$0	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	7	11	EA	\$0	
Power Distribution		Lighting and power panels	Entire Building	6	4	EA	\$2,860	
Power Distribution		Lighting and power panels	Entire Building	7	3	EA	\$0	
Power Distribution		Main distribution panels 400-600 amp	1st Floor	6	1	EA	\$1,430	
Power Distribution		Main distribution panels above 600 amp	Electrical Room	6	1	EA	\$2,145	
Power Distribution		Main distribution panels less than 400 amp	Electrical Room	7	1	EA	\$0	
ELECTRICAL Sub Total							\$6,435	

Building: Addition
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Entire Building	6	39,250	SF	\$14,032	
Fire Alarm		Fire Alarm System	1st Floor	6	71,396	SF	\$86,782	
FIRE PROTECTION Sub Total							\$100,814	

Building: Addition
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Condensing Unit - Roof Mounted less than 5 tons	Roof	5	2	EA	\$8,580	
Heating Devices		Cabinet Heaters With Steam Coils	1st Floor	6	1	EA	\$501	
Heating Devices		Fin Tube Hot Water	Entire Building	7	104	LF	\$0	
Heating Devices		Fin Tube Hot Water	Entire Building	4	35	LF	\$6,006	
Heating Devices		Fin Tube Hot Water	Entire Building	6	51	LF	\$875	
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	6	31	EA	\$4,433	
Unit Ventilation		Unit Ventilators - Steam	Entire Building	6	29	EA	\$45,617	
Unit Ventilation		Unit Ventilators - Steam and Self Contained	Entire Building	6	2	EA	\$3,146	
		Electric Cooling						
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	6	1	EA	\$429	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	5	2	EA	\$3,003	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	6	1	EA	\$229	
MECHANICAL Sub Total							\$72,818	

Building: Addition
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	5	39,250	SF	\$6,735	
Piping		Domestic Piping - Cold Water Risers	Entire Building	5	39,250	SF	\$12,909	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	5	39,250	SF	\$44,902	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	5	39,250	SF	\$8,419	
Piping		Domestic Piping - Hot Water Risers	Entire Building	5	39,250	SF	\$10,103	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	5	39,250	SF	\$34,799	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	5	39,250	SF	\$20,767	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	5	39,250	SF	\$21,328	
Piping		Sanitary Piping	Entire Building	6	39,250	SF	\$15,716	
Piping		Storm Piping	Entire Building	6	39,250	SF	\$8,419	
Piping		Vent Piping	Entire Building	6	39,250	SF	\$6,174	

PLUMBING Sub Total \$190,272

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Splined	1st floor teachers lounge	6	245	SF	\$526	
Administrative Suites	Administrative Suites/Offices	Ceiling - Splined	principals office	6	230	SF	\$493	
Administrative Suites	Administrative Suites/Offices	Ceiling - Splined	in 121	6	45	SF	\$97	
Administrative Suites	Administrative Suites/Offices	Ceiling - Splined	145 main office	6	765	SF	\$1,641	
Administrative Suites	Administrative Suites/Offices	Ceiling - Splined	124A	6	185	SF	\$397	
Administrative Suites	Administrative Suites/Offices	Ceiling - Splined	124B counselors suite	6	595	SF	\$1,276	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	in 121	6	45	SF	\$64	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	124A	6	185	SF	\$265	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	124B counselors suite	6	595	SF	\$851	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	principals office	7	230	SF	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	145 main office	6	765	SF	\$1,094	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	1st floor teachers lounge	6	245	SF	\$350	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	124B counselors suite	7	8	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	124A	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	145 main office	6	19	SF	\$14	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	in 121	7	1	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	1st floor teachers lounge	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	1st floor teachers lounge	6	1	SF	\$1	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	principals office	6	3	SF	\$2	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	1st floor teachers lounge	6	640	SF	\$1,830	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	145 main office	7	845	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	124B counselors suite	7	965	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	124A	7	470	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	principals office	7	622	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	in 121	7	168	SF	\$0	
Doors		Interior Steel Doors incl hw	Entire Building	6	1	EA	\$283	
Doors		Interior Wood Doors incl hw	Entire Building	7	38	EA	\$0	
Doors		Interior Wood Doors incl hw	Entire Building	6	18	EA	\$5,097	
Doors		Interior Wood Doors incl hw	Entire Building	5	2	EA	\$944	
Doors		Store Front Door	Entire Building	7	1	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	2nd Floor	7	4	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	2nd Floor	7	5	EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd floor girls			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd floor mens			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	principals			LF	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd floor boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st floor boys			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd floor womens			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st floor girls			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st floor womens			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	in 124A			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st floor unisex west			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st floor mens			LF	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st floor mens			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	principals			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	in 124A			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st floor womens			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st floor boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd floor boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st floor girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd floor girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd floor womens			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd floor mens			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st floor unisex west			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st floor unisex west			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd floor womens			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd floor mens			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd floor girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st floor girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd floor boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st floor boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	principals			EA	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Staff Restroom	Showers	1st floor womens			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	in 124A			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st floor mens			EA	\$0	
Mechanical/Service Rooms		Janitor's Closet	Entire Building	6	3	SF	\$14	
Mechanical/Service Rooms		Mechanical/Service Rooms	Entire Building	6	100	SF	\$472	
Mechanical/Service Rooms		Storage Room	Entire Building	6	1,565	SF	\$7,385	
Mechanical/Service Rooms		Vaults	145 main office	6	75	SF	\$354	
Staff Restroom	Staff Restroom	Accessories	2nd floor mens	7	90	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor boys	7	245	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st floor mens	7	115	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd floor boys	7	245	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd floor girls	6	275	SF	\$2,124	
Staff Restroom	Staff Restroom	Accessories	2nd floor womens	7	175	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	in 124A	7	21	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor unisex west	7	115	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st floor womens	7	115	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	principals	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor girls	7	275	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor girls	7	275	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	principals	7	23	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st floor womens	7	115	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd floor mens	7	90	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd floor womens	7	175	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor boys	6	245	SF	\$694	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	in 124A	7	21	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor unisex west	7	115	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st floor mens	7	115	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor boys	6	245	SF	\$694	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor girls	7	275	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd floor boys	7	1	EA	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor girls	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd floor girls	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	2nd floor mens	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st floor mens	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st floor womens	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor unisex west	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	in 124A			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	2nd floor womens	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor boys	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	principals			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor boys	7	245	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor girls	7	275	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor girls	7	275	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor boys	7	245	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	in 124A	6	21	SF	\$30	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	2nd floor mens	6	90	SF	\$129	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	1st floor mens	6	115	SF	\$164	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile/Sheet	1st floor unisex west	6	115	SF	\$164	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	principals	7	23	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	1st floor womens	6	115	SF	\$164	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	2nd floor womens	6	175	SF	\$250	
Staff Restroom	Staff Restroom	Hand Dryer	2nd floor womens			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd floor girls			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor girls			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	principals			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	in 124A			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor unisex west			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	1st floor womens			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	1st floor mens			EA	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor boys			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd floor mens			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd floor boys			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor girls	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	principals	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd floor mens	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd floor womens	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor girls	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor boys	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor boys	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st floor mens	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st floor womens	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor unisex west	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	in 124A	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor girls	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	1st floor womens	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	in 124A	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st floor unisex west	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	2nd floor mens	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st floor boys	7	2	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd floor boys	7	2	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st floor girls	7	2	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd floor girls	7	2	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	2nd floor womens	7	2	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	principals	4	1	SF	\$4	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	1st floor mens	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Wall Mounted	1st floor unisex west	6	1	EA	\$29	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor boys	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd floor boys	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd floor girls	7	9	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	1st floor mens	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	principals			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor girls	7	9	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	2nd floor mens	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor unisex west	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	in 124A			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	2nd floor womens	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	1st floor womens	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st floor unisex west			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	principals			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd floor mens	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd floor womens			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd floor boys	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st floor boys	7	4	EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st floor womens			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	in 124A			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st floor mens	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	1st floor unisex west	7	295	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	in 124A	7	50	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	principals	7	57	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	2nd floor mens	7	110	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	2nd floor womens	7	190	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd floor girls	6	195	SF	\$460	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st floor girls	6	195	SF	\$460	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd floor boys	6	195	SF	\$460	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st floor boys	6	195	SF	\$460	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	1st floor mens	7	130	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	1st floor womens	7	130	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	2nd floor girls	6	330	SF	\$840	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	1st floor womens	6	215	SF	\$547	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	1st floor mens	6	215	SF	\$547	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	1st floor boys	6	330	SF	\$840	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	1st floor girls	6	330	SF	\$840	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	2nd floor womens	7	330	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	2nd floor mens	7	190	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	principals	7	85	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	2nd floor boys	6	330	SF	\$840	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	in 124A	7	75	SF	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st floor mens	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd floor mens	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd floor womens	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor girls	7	8	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor girls	7	8	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor boys	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st floor womens	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor unisex west	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	in 124A	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	principals	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor boys	7	3	EA	\$0	
Vocational Shop	Classroom	Work Sink		5	2	EA	\$3,861	
Vocational Shop	Classroom	Work Sink		6	2	EA	\$772	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		6	6	EA	\$2,317	
Vocational Shop	Classroom	Work Sink		6	2	EA	\$772	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Vocational Shop	Classroom	Work Sink		5	1	EA	\$1,931	
INTERIOR Sub Total							\$44,987	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	145 main office	6	30	SF	\$71	
Casework	Classroom	Casework		6	3	LF	\$107	
Casework	Classroom	Casework		6	3	LF	\$107	
Casework	Classroom	Casework		6	3	LF	\$107	
Casework	Classroom	Casework		6	6	LF	\$215	
Casework	Classroom	Casework		6	115	LF	\$4,111	
Casework	Classroom	Casework		6	3	LF	\$107	
Casework	Classroom	Casework		6	3	LF	\$107	
Casework	Classroom	Casework		6	6	LF	\$215	
Casework	Classroom	Casework		6	15	LF	\$536	
Casework	Classroom	Casework		7	41	LF	\$0	
Casework	Classroom	Casework		6	101	LF	\$3,611	
Casework	Classroom	Casework		6	68	LF	\$2,431	
Casework	Classroom	Casework		5	68	LF	\$12,155	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		6	75	LF	\$2,681	
Casework	Classroom	Casework		6	6	LF	\$215	
Casework	Classroom	Casework		6	6	LF	\$215	
Casework	Classroom	Casework		6	6	LF	\$215	
Casework	Classroom	Casework		6	6	LF	\$215	
Casework	Classroom	Casework		5	115	LF	\$20,556	
Casework	Classroom	Casework		6	16	LF	\$572	
Casework	Classroom	Casework		6	6	LF	\$215	
Ceiling	Classroom	Lay-In/Drop		7	865	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	865	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	835	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	965	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	790	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,115	SF	\$0	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Ceiling	Classroom	Lay-In/Drop		7	790	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	790	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	790	SF	\$1,695	
Ceiling	Classroom	Lay-In/Drop		7	790	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	790	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,115	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	415	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	790	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	790	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	790	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	865	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	790	SF	\$1,695	
Ceiling	Classroom	Lay-In/Drop		6	790	SF	\$1,695	
Ceiling	Classroom	Lay-In/Drop		6	790	SF	\$1,695	
Ceiling	Classroom	Lay-In/Drop		7	865	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	790	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	790	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	225	SF	\$0	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Corridors	Corridors	Concrete Block	Entry Lobby	7	154	SF	\$0	
Corridors	Corridors	Concrete Block	2nd Floor	7	880	SF	\$0	
Corridors	Corridors	Concrete Block	2nd Floor	7	2,310	SF	\$0	
Corridors	Corridors	Drinking Fountains	North Stairs			EA	\$0	
Corridors	Corridors	Drinking Fountains	South Stairs			EA	\$0	
Corridors	Corridors	Drinking Fountains	Entry Lobby			EA	\$0	
Corridors	Corridors	Drop/Lay-In	North Stairs	7	263	SF	\$0	
Corridors	Corridors	Drop/Lay-In	2nd Floor	7	1,955	SF	\$0	
Corridors	Corridors	Drop/Lay-In	South Stairs	7	205	SF	\$0	
Corridors	Corridors	Drop/Lay-In	2nd Floor	7	4,010	SF	\$0	
Corridors	Corridors	Exposed	Entry Lobby	7	2,346	SF	\$0	
Corridors	Corridors	Lay-In	2nd Floor	7	1,955	EA	\$0	
Corridors	Corridors	Lay-In	2nd Floor	7	4,010	EA	\$0	
Corridors	Corridors	Lay-In	South Stairs	7	205	EA	\$0	
Corridors	Corridors	Lay-In	North Stairs	7	263	EA	\$0	
Corridors	Corridors	Metal Panel	Entry Lobby	7	544	SF	\$0	
Corridors	Corridors	Pendant/Surface	Entry Lobby	7	2,346	EA	\$0	
Corridors	Corridors	Single Water Cooler	2nd Floor	7	1	EA	\$0	
Corridors	Corridors	Stair Handrails	2nd Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	Entry Lobby	6	81	LF	\$0	
Corridors	Corridors	Stair Handrails	South Stairs	6	38	LF	\$0	
Corridors	Corridors	Stair Handrails	2nd Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	North Stairs	6	47	LF	\$0	
Corridors	Corridors	Stairs	2nd Floor			EA	\$0	
Corridors	Corridors	Stairs	2nd Floor			EA	\$0	
Corridors	Corridors	Structural Glazed Tile	Entry Lobby	7	335	SF	\$0	
Corridors	Corridors	Student Lockers	2nd Floor	7	185	EA	\$0	
Corridors	Corridors	Student Lockers	North Stairs			EA	\$0	
Corridors	Corridors	Student Lockers	2nd Floor	7	234	EA	\$0	
Corridors	Corridors	Student Lockers	South Stairs			EA	\$0	
Corridors	Corridors	Student Lockers	Entry Lobby			EA	\$0	
Corridors	Corridors	Tile/Sheet Flooring	South Stairs	6	106	SF	\$152	
Corridors	Corridors	Tile/Sheet Flooring	North Stairs	6	205	SF	\$293	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Tile/Sheet Flooring	Entry Lobby	7	2,346	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	2nd Floor	6	4,010	SF	\$5,734	
Corridors	Corridors	Tile/Sheet Flooring	2nd Floor	6	1,955	SF	\$2,796	
Corridors	Corridors	Walls	2nd Floor	7	4,070	SF	\$0	
Corridors	Corridors	Walls	South Stairs	6	995	SF	\$2,348	
Corridors	Corridors	Walls	Entry Lobby	6	98	SF	\$231	
Corridors	Corridors	Walls	Entry Lobby	6	828	SF	\$1,954	
Corridors	Corridors	Walls	2nd Floor	7	2,845	SF	\$0	
Corridors	Corridors	Walls	North Stairs	6	1,010	SF	\$2,383	
Corridors Ceiling	Corridors	Plaster/Drywall	North Stairs	7	56	SF	\$0	
Stairs	Corridors	Tile	Entry Lobby	7	19	SF	\$0	
Stairs	Corridors	Tile	South Stairs	6	18	SF	\$136	
Floor	Classroom	Tile/Sheet		7	1,190	SF	\$0	
Floor	Classroom	Tile/Sheet		6	790	SF	\$1,130	
Floor	Classroom	Tile/Sheet		7	1,115	SF	\$0	
Floor	Classroom	Tile/Sheet		6	865	SF	\$1,237	
Floor	Classroom	Tile/Sheet		6	865	SF	\$1,237	
Floor	Classroom	Tile/Sheet		6	790	SF	\$1,130	
Floor	Classroom	Tile/Sheet		6	790	SF	\$1,130	
Floor	Classroom	Tile/Sheet		6	790	SF	\$1,130	
Floor	Classroom	Tile/Sheet		6	790	SF	\$1,130	
Floor	Classroom	Tile/Sheet		6	790	SF	\$1,130	
Floor	Classroom	Tile/Sheet		6	790	SF	\$1,130	
Floor	Classroom	Tile/Sheet		6	790	SF	\$1,130	
Floor	Classroom	Tile/Sheet		6	790	SF	\$1,130	
Floor	Classroom	Tile/Sheet		6	415	SF	\$593	
Floor	Classroom	Tile/Sheet		6	790	SF	\$1,130	
Floor	Classroom	Tile/Sheet		5	1,115	SF	\$6,314	
Floor	Classroom	Tile/Sheet		6	865	SF	\$1,237	
Floor	Classroom	Tile/Sheet		6	865	SF	\$1,237	
Floor	Classroom	Tile/Sheet		6	835	SF	\$1,194	
Floor	Classroom	Tile/Sheet		7	790	SF	\$0	
Floor	Classroom	Tile/Sheet		6	790	SF	\$1,130	
Floor	Classroom	Tile/Sheet		6	790	SF	\$1,130	
Floor	Classroom	Tile/Sheet		6	790	SF	\$1,130	
Floor	Classroom	Tile/Sheet		6	790	SF	\$1,130	
Floor	Classroom	Tile/Sheet		6	790	SF	\$1,130	
Floor	Classroom	Tile/Sheet		6	790	SF	\$1,130	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	15	EA	\$0	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting	Classroom	Lay-In		6	15	EA	\$1,073	
Lighting	Classroom	Lay-In		7	15	EA	\$0	
Lighting	Classroom	Lay-In		6	13	EA	\$930	
Lighting	Classroom	Lay-In		7	15	EA	\$0	
Lighting	Classroom	Lay-In		6	13	EA	\$930	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	20	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	20	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	20	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	20	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	20	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	20	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	20	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	20	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	20	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	20	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	20	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	20	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	20	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	20	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	20	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	20	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	24	EA	\$0	
Marker Board	Classroom	Marker Board		7	48	LF	\$0	
Marker Board	Classroom	Marker Board		7	48	LF	\$0	
Marker Board	Classroom	Marker Board		7	48	LF	\$0	
Marker Board	Classroom	Marker Board		7	48	LF	\$0	
Marker Board	Classroom	Marker Board		7	48	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	32	LF	\$0	
Marker Board	Classroom	Marker Board		7	48	LF	\$0	
Marker Board	Classroom	Marker Board		7	48	LF	\$0	
Marker Board	Classroom	Marker Board		7	48	LF	\$0	
Marker Board	Classroom	Marker Board		7	48	LF	\$0	
Marker Board	Classroom	Marker Board		7	48	LF	\$0	
Marker Board	Classroom	Marker Board		7	48	LF	\$0	
Marker Board	Classroom	Marker Board		7	48	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	32	LF	\$0	
Marker Board	Classroom	Marker Board		7	48	LF	\$0	
Marker Board	Classroom	Marker Board		7	48	LF	\$0	
Marker Board	Classroom	Marker Board		7	48	LF	\$0	
Marker Board	Classroom	Marker Board		7	48	LF	\$0	
Wall	Classroom	Concrete Block		7	925	SF	\$0	
Wall	Classroom	Concrete Block		7	780	SF	\$0	
Wall	Classroom	Concrete Block		7	725	SF	\$0	
Wall	Classroom	Concrete Block		7	725	SF	\$0	
Wall	Classroom	Concrete Block		6	780	SF	\$2,231	
Wall	Classroom	Concrete Block		7	780	SF	\$0	
Wall	Classroom	Concrete Block		7	780	SF	\$0	
Wall	Classroom	Concrete Block		7	780	SF	\$0	
Wall	Classroom	Concrete Block		7	780	SF	\$0	
Wall	Classroom	Concrete Block		7	780	SF	\$0	
Wall	Classroom	Concrete Block		7	780	SF	\$0	
Wall	Classroom	Concrete Block		7	880	SF	\$0	
Wall	Classroom	Concrete Block		7	780	SF	\$0	
Wall	Classroom	Concrete Block		7	780	SF	\$0	
Wall	Classroom	Concrete Block		7	875	SF	\$0	
Wall	Classroom	Concrete Block		7	875	SF	\$0	
Wall	Classroom	Concrete Block		7	675	SF	\$0	
Wall	Classroom	Concrete Block		6	780	SF	\$2,231	
Wall	Classroom	Concrete Block		7	780	SF	\$0	
Wall	Classroom	Concrete Block		7	780	SF	\$0	
Wall	Classroom	Concrete Block		7	780	SF	\$0	
Wall	Classroom	Concrete Block		7	780	SF	\$0	
Wall	Classroom	Concrete Block		7	780	SF	\$0	
Wall	Classroom	Concrete Block		7	780	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	920	SF	\$0	
ROOM Sub Total							\$107,375	
Building Addition Sub Total							\$920,096	

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
-------	-----------	------	----------	------	----------	------	------	--------

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Civil/Drainage		Catch Basin	Entire Site	7	6	EA	\$0	
Civil/Drainage		Site Drain	Doors 4, 6, 7	5	3	EA	\$3,003	drains clogged, ponding water
Civil/Drainage		Site Manhole	Entire Site	7	4	EA	\$0	
Fencing		Chain Link	North Parking Lot, SW Site, and generator enclosure	7	720	LF	\$0	
Fencing		Chain Link	Site South/East/North/South Parking Lot	5	935	LF	\$33,426	
Fencing		Ornamental Iron	Site ζ West	7	282	LF	\$0	
Fencing		Wood Fencing w/ Steel Frame	Site ζ North	7	75	LF	\$0	
Landscape		Asphalt Play Area/Hardscape	Site ζ North	7	19,600	SF	\$0	
Landscape		Grass	Entire Site	7	17,800	SF	\$0	
Landscape		Hardscape - Concrete	Entire Site	7	2,353	SF	\$0	
Landscape		Parkway trees	Entire Site	7	21	EA	\$0	
Landscape		Retaining Wall - Concrete	Doors 4, 6, 7	7	417	SF	\$0	
Parking Lot		Asphalt	Site West- South Lot	7	13,020	SF	\$0	
Parking Lot		Asphalt	Site West: North Lot, Repair in Progress	5	7,200	SF	\$20,386	
Parking Lot		Trash Enclosure	Site ζ West	6	1,488	SF	\$15,959	privacy slats missing
Playground		Playground Equipment - Combo 3-12	Site ζ West	7	1	EA	\$0	
Playground		Playground Surfacing - Poured Surface	Site ζ West	5	2,400	SF	\$20,935	deteriorated/pitted
Sidewalks		Perimeter Sidewalks	Entire Site	7	11,992	SF	\$0	
Signage		Flag Pole	Site - East	6	1	EA	\$0	
Signage		Marquee - Free Standing Back Lighted	Site ζ South	6	1	EA	\$0	
SITE Sub Total							\$93,709	
SITE Sub Total							\$93,709	

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Total Campus Need ^{2 3}							\$2,834,834	

¹ It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

² As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

³ The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Building: Main														
100	564		14	28	40	79	35		N	N	N	Classroom		
101	725	1	3	9	40	135	69		N	N	N	Classroom		
102	600		1	3	40	90	46		N	N	N	Classroom		
103	470	1	1	3	40	112	58		N	N	N	Classroom		
104	690			8	40	74	39		N	N	N	Classroom		
200	483	1	3	9	40	60	46		N	N	N	Classroom		
201	690	1	27	64	40	112	58		N	N	N	Classroom		
202	690	1	41	74	40	147	78		N	N	N	Classroom		
203	600			8	40	112	58		N	N	N	Classroom		
Other									N	N	N	Corridors		Stair 3- East End
Other	1277								N	N	N	Library		rm 204
Other	184			4					N	N	N	Administrative Suites/Offices		Library workroom in library
Other	295								N	N	N	Lunch & Multipurpose Room	Multipurpose Room	2nd Floor
Other	3127								N	N	N	Auditorium & Theater	Auditorium - Dedicated	205
Other	1507								N	N	N	Corridors		2nd Floor
Other	133								N	N	N	Restroom	Staff Restroom	basement- kitchen locker rm
Other	20								N	N	N	Restroom	Staff Restroom	in office 101C
Other	768								N	N	N	Corridors		Basement
Other	285								N	N	N	Restroom	Children's Standard Student Restroom	1st fl boys
Other	88								N	N	N	Restroom	Staff Restroom	2nd fl- unisex
Other	180								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl girls
Other	1435								N	N	N	Corridors		1st Floor
Other	834								N	N	N	Kitchen	Cooking Kitchen	in rms 003 & 006
Other	1173								N	N	N	Lunch & Multipurpose Room	Lunchroom	rm 003 in Basement
Other	2120								N	N	N	Lunch & Multipurpose Room	Lunchroom	rm 006 in Basement
Other									N	N	N	Corridors		Stair #4- West End
Other	209			3					N	N	N	Administrative Suites/Offices		Gym office/storage in Basement
Other	616			8					N	N	Y	Administrative Suites/Offices		101C
Other	193			4					N	N	Y	Administrative Suites/Offices		in 101C
Other	3498								N	N	N	Gymnasia	Standard Dedicated Gymnasium	rm 005 in Basement
Other	88								N	N	N	Restroom	Staff Restroom	Mens 2nd fl

Building: Addition

120	1115			8	40	189	45		N	N	Y	Classroom		
121	1190			8	40	168	40		N	N	Y	Classroom		
122	1115	1	5	50	40	189	45		N	N	N	Classroom		

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
123	835	2	3	20	40	147	35		N	N	Y	Classroom		
125	790			8	40	168	40		N	N	Y	Classroom		
126	865	2	3	10	40	189	45		N	N	Y	Classroom		
127	865		1	12	40	210	50		N	N	Y	Classroom		
128	865	2	3	10	40	189	45		N	N	Y	Classroom		
129	865		1	12	40	210	50		N	N	Y	Classroom		
130	790			8	40	168	40		N	N	Y	Classroom		
131	790			8	40	168	40		N	N	Y	Classroom		
220	790	1	2	12	40	168	40		N	N	Y	Classroom		
221	415	1	1	8	40	126	30		N	N	Y	Classroom		
222	790			8	40	168	40		N	N	Y	Classroom		
223	790			8	40	168	40		N	N	Y	Classroom		
224	790			8	40	168	40		N	N	Y	Classroom		
225	790			8	40	168	40		N	N	Y	Classroom		
226	790			8	40	168	40		N	N	Y	Classroom		
227	790			8	40	168	40		N	N	Y	Classroom		
228	790	1	4	12	40	168	40		N	N	Y	Classroom		
229	790			8	40	168	40		N	N	Y	Classroom		
230	790			8	40	168	40		N	N	Y	Classroom		
231	790			8	40	168	40		N	N	Y	Classroom		
Other	245			6					N	N	N	Administrative Suites/Offices		1st floor teachers lounge
Other	230			4					N	N	Y	Administrative Suites/Offices		principals office
Other	2346								N	N	N	Corridors		Entry Lobby
Other	23								N	N	N	Restroom	Staff Restroom	principals
Other	115								N	N	N	Restroom	Children's Standard Student Restroom	1st floor unisex west
Other	90								N	N	N	Restroom	Staff Restroom	2nd floor mens
Other	175								N	N	N	Restroom	Staff Restroom	2nd floor womens
Other	275								N	N	N	Restroom	Children's Standard Student Restroom	2nd floor girls
Other	275								N	N	N	Restroom	Children's Standard Student Restroom	1st floor girls
Other	245								N	N	N	Restroom	Children's Standard Student Restroom	2nd floor boys
Other	245								N	N	N	Restroom	Children's Standard Student Restroom	1st floor boys
Other	4010								N	N	N	Corridors		2nd Floor
Other	115								N	N	N	Restroom	Staff Restroom	1st floor womens
Other									N	N	N	Corridors		South Stairs
Other	21								N	N	N	Restroom	Staff Restroom	in 124A
Other	45			4					N	N	Y	Administrative Suites/Offices		in 121
Other	765			16					N	N	Y	Administrative Suites/Offices		145 main office

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	185			8					N	N	N	Administrative Suites/Offices		124A
Other	595			16					N	N	Y	Administrative Suites/Offices		124B counselors suite
Other	1955								N	N	N	Corridors		2nd Floor
Other									N	N	N	Corridors		North Stairs
Other	115								N	N	N	Restroom	Staff Restroom	1st floor mens