

Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx.

Condition Rankings and Descriptions

- Rank 7:** The item/system is new or in good condition and no work is required.
- Rank 6:** The item/system requires general cleaning and/or routine maintenance.
- Rank 5:** The item/system requires repairs and has not reached the end of its serviceable life.
- Rank 4:** The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.
- Rank 3:** The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.
- Rank 2:** The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.
- Rank 1:** The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.¹

Definitions

- Quantity** means, for each item, the total number (or amount) of that item that exists and was evaluated.
- Unit** means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").
- Cost** means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.
- For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.**
- Total Campus Need** also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

Building: Main Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Canopy		Concrete/ Stucco Canopy	Entire Building	7	220	SF	\$0	
Chimney		Brick Chimney - Concrete/ Mortar Liner	East Façade	7	35	LF	\$0	
Chimney		Brick Chimney - Concrete/ Mortar Liner	East Façade	5	5	LF	\$8,938	Repoint
Chimney		Metal Flue	Main Roof	7	12	LF	\$0	
Doors		Exterior FRP Door	Entire Building	7	15	EA	\$0	
Doors		Exterior Steel Door	East Entrances	7	3	EA	\$0	
Doors		Side Lite	Entire Building	7	20	EA	\$0	
Doors		Store Front Door	West and Courtyard	7	5	EA	\$0	
Doors		Transom Lite	Entire Building	7	78	EA	\$0	
Entrance		Concrete Exterior Stairs	North Entrances	7	46	LF	\$0	
Entrance		Concrete Ramp	Courtyard	7	20	LF	\$0	
Entrance		Entrance Controls - Audio and Video	East and West	7	2	EA	\$0	
Entrance		Power Door Operator and Controls	West Entrances	7	1	EA	\$0	
Foundation		Concrete Foundation	Entire Building	7	1,280	LF	\$0	

Building: Main
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting		Exterior Lights - Parapet or Roof Mounted	Entire Building	6	15	EA	\$7,508	
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	8	EA	\$1,716	
Lintels		Lintels - Steel	East Façade	6	24	LF	\$906	
Parapet		Coping - Metal	Roof	5	1,280	LF	\$35,876	Open Joints
Parapet		Coping - Metal	Elevator Roof	7	54	LF	\$0	
Roof System		Asphalt Gravel Ballast Roof	Roof	5	29,470	SF	\$375,486	Ponding/Moss/Repaired Leaks Locations
Roof System		Exterior Downspouts	Main Roof	7	224	LF	\$0	
Roof System		Exterior Downspouts	@ elevator	7	5	LF	\$0	
Roof System		Modified Bitumen Roof	Elevator Roof	7	150	SF	\$0	
Roof System		Roof Structure: Steel/Metal Deck/Concrete Topping	Main Roof	7	29,620	SF	\$0	
Superstructure		Metal Deck/Concrete Topping	Entire Building	7	43,400	SF	\$0	
Walls		Brick	Entire Building	7	6,573	SF	\$0	
Walls		Brick	South and East Facade	5	2,878	SF	\$65,190	Graffiti, repaint, spalls
Walls		Brick	NE of 2 story portion of building	4	100	SF	\$7,550	
Walls		Prefabricated Metal Panel Wall	Fascia	6	1,920	SF	\$16,309	
Windows		Curtain wall - Insulated panel	Entire Building	6	2,332	SF	\$22,009	
Windows		Curtain wall - Windows	Entire Building	6	6,494	SF	\$61,290	Broken Latches
Windows		Storefront Windows	E&W Entrances at North Building	7	250	SF	\$0	
Windows		Window - Guards perforated	East Façade	6	615	SF	\$0	
Windows		Window - Guards wire guard	Entire Building	4	1,104	SF	\$84,398	Insect Screen Material
EXTERIOR Sub Total							\$687,177	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Emergency Battery Packs - Corridors and Stairs	Entire Building	7	19	EA	\$0	
Emergency System		Emergency Battery Packs - Lunchroom and Gym	1st Floor	7	6	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	1st Floor	7	15	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	1st Floor	4	3	EA	\$2,789	
Emergency System		Exit Signs - Corridors and Stairs	2nd Floor	7	3	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	2nd Floor	4	3	EA	\$2,789	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st Floor	4	1	EA	\$930	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st Floor	7	8	EA	\$0	
Emergency System		Public Announcement System	Entire Building	6	43,400	SF	\$26,066	
Emergency System		Security System - Intrusion detection	Entire Building	4	43,400	SF	\$173,774	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Main Service		Main Electrical service 1600 A 120/208/3PH	Electrical Room	4	1	EA	\$130,416	
Power Distribution		Lighting and power panels	Boiler Room	7	2	EA	\$0	
Power Distribution		Lighting and power panels	2nd Floor	4	2	EA	\$10,868	
Power Distribution		Lighting and power panels	Boiler Room	4	2	EA	\$10,868	
Power Distribution		Lighting and power panels	1st Floor	7	1	EA	\$0	
Power Distribution		Lighting and power panels	1st Floor	4	5	EA	\$27,170	
Power Distribution		Lighting and power panels	Electrical Room	7	1	EA	\$0	
Power Distribution		Main distribution panels 400-600 amp	2nd Floor	4	1	EA	\$12,155	
Power Distribution		Main distribution panels 400-600 amp	Boiler Room	5	1	EA	\$4,576	
Power Distribution		Main distribution panels above 600 amp	Electrical Room	4	1	EA	\$18,590	
Power Distribution		Main distribution panels above 600 amp	Boiler Room	7	1	EA	\$0	
ELECTRICAL Sub Total							\$420,989	

Building: Main
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Entire Building	7	43,400	SF	\$0	
Fire Alarm		Fire Alarm System	1st Floor	7	43,300	SF	\$0	
FIRE PROTECTION Sub Total							\$0	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Heat Pump - Self Contained	1st Floor	5	1	EA	\$4,219	
Air Conditioning		Window A/C Unit	1st Floor	5	1	EA	\$1,073	
Air Conditioning		Window A/C Unit	1st Floor	3	1	EA	\$2,145	
Air Conditioning		Window A/C Unit	1st Floor	4	2	EA	\$4,290	
Air Conditioning		Window A/C Unit	2nd Floor	5	1	EA	\$1,073	
Air Conditioning		Window A/C Unit	1st Floor	6	1	EA	\$215	
Air Conditioning		Window A/C Unit	2nd Floor	3	1	EA	\$2,145	
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water 4,000 to 8,000 cfm	2nd Floor	4	1	EA	\$50,050	
Air Handling Systems		Air intake for all Air Handling Units except built up AHU	Roof	7	2	EA	\$0	
Air Handling Systems		Fan Coil Unit - Hot Water-Heating	2nd Floor	5	2	EA	\$13,442	
Air Handling Systems		Fan Coil Unit - Hot Water-Heating	2nd Floor	6	10	EA	\$13,442	
Air Handling Systems		Fan Coil Unit - Hot Water-Heating	1st Floor	6	11	EA	\$14,786	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Handling Systems		Make Up Air Unit - Indoor Mounted - Gas-Heating less than 6,000 cfm	1st Floor	6	1	EA	\$2,002	
Air Handling Systems		Make Up Air Unit - Roof Mounted - Gas-Heating greater than 30,000 cfm	Roof	7	1	EA	\$0	
Boiler Systems		Boiler Assembly - Condensing Hot Water Boiler 1,001MBH-2,000 MBH	Boiler Room	7	2	EA	\$0	
Boiler Systems		Boiler Auxiliary - Condensing Hot Water Boiler 1,001MBH-2,000 MBH	Boiler Room	6	2	EA	\$10,010	
Boiler Systems		Chemical Pot Feeder - Hot Water	Boiler Room	6	1	EA	\$300	
Boiler Systems		Glycol Feed System	Boiler Room	6	1	EA	\$1,087	
Heating Devices		Cabinet Heaters With Hot Water Coils	Entire Building	5	23	EA	\$42,757	
Heating Devices		Fin Tube Hot Water	Entire Building	4	250	LF	\$42,900	
Heating Devices		Radiators - Hot Water	1st Floor	4	2	EA	\$2,517	
Heating Devices		Unit Heater - Gas	1st Floor	5	2	EA	\$8,580	
Heating Devices		Unit Heater - Gas	Boiler Room	7	1	EA	\$0	
Heating Devices		Wall Heater - Electric	1st Floor	5	2	EA	\$1,030	
Mechanical Plumbing		Piping - Hydronic Supply and Return - Steel or Galvanized	Entire Building	5	500	LF	\$24,739	
Mechanical Plumbing		Pumps - Hot Water 11 to 20 HP	Boiler Room	5	2	EA	\$21,450	
Temperature Control		Direct Digital Control (DDC) System	Entire Building	7	43,400	SF	\$0	
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	7	46	EA	\$0	
Temperature Control		Thermostats - Direct Digital Control (DDC)	1st Floor	6	2	EA	\$286	
Unit Ventilation		Unit Ventilators - Hot Water-Heating	1st Floor	6	8	EA	\$11,440	
Ventilation		Exhaust Fan - Indoor	2nd Floor	4	1	EA	\$5,577	
Ventilation		Exhaust Fan - Indoor	1st Floor	6	1	EA	\$501	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	6	1	EA	\$429	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	7	5	EA	\$0	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	7	13	EA	\$0	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	6	1	EA	\$229	
Ventilation		Type I Exhaust Hood - Kitchen or Culinary Arts	1st Floor	6	1	EA	\$1,716	

MECHANICAL Sub Total \$284,427

Building: Main
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas 150,000 -300,000 BTU/HR	Boiler Room	7	2	EA	\$0	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	7	43,400	SF	\$0	
Piping		Domestic Piping - Cold Water Risers	Entire Building	5	43,400	SF	\$14,274	

Building: Main
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	7	43,400	SF	\$0	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	5	43,400	SF	\$9,309	
Piping		Domestic Piping - Hot Water Risers	Entire Building	5	43,400	SF	\$11,171	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	5	43,400	SF	\$38,478	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	5	43,400	SF	\$23,584	
Piping		Sanitary Piping	Entire Building	5	43,400	SF	\$26,687	
Piping		Storm Piping	Entire Building	5	43,400	SF	\$20,480	
Piping		Vent Piping	Entire Building	5	43,400	SF	\$15,516	
Pumps		Domestic Booster Pump simplex	Boiler Room	2	1	EA	\$17,160	Pump failed. Not connected. Not full pressure to most remote fixtures.
Pumps		Sump Pump	Boiler Room	7	1	EA	\$0	
PLUMBING Sub Total							\$176,659	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	principals (aka- counseling class room)	7	456	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	public/office	7	140	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Splined	Teachers lounge	7	676	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Splined	Lunch office (AKA office library)	6	90	SF	\$193	
Administrative Suites	Administrative Suites/Offices	Ceiling - Splined	public/office	7	140	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Splined	principals (aka- counseling class room)	7	456	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Splined	Engineers office (AKA Instr. matl center)	7	288	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Splined	Health Office	7	90	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Splined	Assist principal (aka- principal office)	7	135	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Health Office	7	90	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Engineers office (AKA Instr. matl center)	7	288	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	principals (aka- counseling class room)	7	456	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	public/office	7	280	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Lunch office (AKA office library)	7	90	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Teachers lounge	7	676	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	custodian office (aka eng. office)	6	90	SF	\$129	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Assist principal (aka-principal office)	7	135	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	public/office	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Health Office	7	2	SF	\$0	T8
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Lunch office (AKA office library)	7	2	SF	\$0	T8
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	public/office	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	principals (aka- counseling class room)	7	9	SF	\$0	T8
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Engineers office (AKA Instr. matl center)	7	6	SF	\$0	T8
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	custodian office (aka eng. office)	6	1	SF	\$1	missing cover
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Assist principal (aka-principal office)	7	2	SF	\$0	T8
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Teachers lounge	4	9	SF	\$59	recessed incandescent
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Teachers lounge	7	850	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Health Office	7	300	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Assist principal (aka-principal office)	7	316	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	public/office	7	415	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	custodian office (aka eng. office)	6	320	SF	\$915	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Engineers office (AKA Instr. matl center)	7	575	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	principals (aka- counseling class room)	7	760	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Lunch office (AKA office library)	7	285	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Structural Glazed Tile	public/office	7	112	SF	\$0	
Doors		Interior Steel Doors incl hw	Entire Building	7	184	EA	\$0	
Doors		Interior Steel Doors incl hw	Entire Building	6	5	EA	\$1,416	
Doors		Interior Steel Doors incl hw	Entire Building	7	1	EA	\$0	
Drinking Fountains		Single Water Cooler	Entire Building	7	8	EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Bleacher Seating	1st Floor			EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Bleacher Seating	stage			EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Ceiling - Lay-In	1st Floor	7	3,300	SF	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Ceiling - Plaster/Drywall	stage	7	375	SF	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Flooring - Tile/Sheet	1st Floor	7	3,300	SF	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Flooring - Tile/Sheet	stage	7	375	SF	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Lighting - Metal Halide/Sodium Vapor	1st Floor	7	12	EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Lighting - Pendant/Surface	stage	4	375	EA	\$343,200	stage lighting not working
Gymnasium / Auditorium	Gymnasium.Auditorium	Scoreboards	stage			EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Scoreboards	1st Floor			EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Sound System	1st Floor			EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Sound System	stage			EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Stage Curtain	1st Floor			EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Stage Curtain	stage	7	2	EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Walls - Concrete Block	stage	7	550	SF	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Walls - Structural Glazed Tile	1st Floor	6	3,720	SF	\$26,598	efforescents evident 33% of the walls - contractor required
Kitchen	Cooking Kitchen	Ceiling - Plaster/Drywall	1st Floor	7	500	SF	\$0	
Kitchen	Cooking Kitchen	Flooring - Tile Quarry	1st Floor	7	500	SF	\$0	
Kitchen	Cooking Kitchen	Lighting - Pendant/Surface	1st Floor	7	16	SF	\$0	
Kitchen	Cooking Kitchen	Wall - Structural Glazed Tile	1st Floor	7	900	SF	\$0	
Locker/Shower Room	Staff Restroom	Benches	Womens 1st floor North			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st floor Boys north			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st floor girls north			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st floor Boys south			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st floor girls south			LF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Benches	2ed floor boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2ed floor girls north			LF	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Benches	Kindergarten 1 toilet			LF	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Benches	Kindergarten 2 toilet			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	Kitchen toilet / lockers			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	Assist principal (aka principal) toilet			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	Mens 1st floor North			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	Unisex 1st floor			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	Womens- 2ed floor			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	Mens- 2ed floor			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	Engineers Toilet / Locker			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	Health office toilet			LF	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Health office toilet			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Kitchen toilet / lockers	7	6	EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st floor Boys north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st floor girls north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st floor Boys south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st floor girls south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2ed floor boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2ed floor girls north			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Womens 1st floor North			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Lockers	Kindergarten 2 toilet			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Engineers Toilet / Locker			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Assist principal (aka principal) toilet			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Mens 1st floor North			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Unisex 1st floor			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Womens- 2ed floor			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Mens- 2ed floor			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Early Childhood Student Restroom	Lockers	Kindergarten 1 toilet			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st floor girls south			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	Mens 1st floor North			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st floor Boys north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st floor girls north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st floor Boys south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2ed floor boys			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Showers	Kindergarten 1 toilet			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Showers	Kindergarten 2 toilet			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	Kitchen toilet / lockers			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	Health office toilet			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2ed floor girls north			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	Womens 1st floor North			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	Unisex 1st floor			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	Womens- 2ed floor			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	Mens- 2ed floor			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	Engineers Toilet / Locker	6	1	EA	\$243	
Locker/Shower Room	Staff Restroom	Showers	Assist principal (aka principal) toilet			EA	\$0	
Lunchroom	Lunchroom	Ceiling - Splined	lunch not library	7	1,152	SF	\$0	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	lunch not library	7	1,152	SF	\$0	
Lunchroom	Lunchroom	Lighting - Pendant/Surface	lunch not library	7	30	SF	\$0	
Lunchroom	Lunchroom	Serving Line	lunch not library	7	0	LF	\$0	
Lunchroom	Cooking Kitchen	Serving Line	1st Floor	7	17	LF	\$0	
Lunchroom	Lunchroom	Wall - Concrete Block	lunch not library	7	1,080	SF	\$0	
MDF/IDF		Finishes	1st Floor	7	80	SF	\$0	
Mechanical/Service Rooms		Boiler Room	1st Floor	7	765	SF	\$0	
Mechanical/Service Rooms		Janitor's Closet	Entire Building	6	3	SF	\$14	
Mechanical/Service Rooms		Storage Room	Entire Building	7	785	SF	\$0	
Mechanical/Service Rooms		Vaults	1st Floor	7	96	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	Womens- 2ed floor	6	25	SF	\$193	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Accessories	Kitchen toilet / lockers	6	60	SF	\$463	
Staff Restroom	Staff Restroom	Accessories	Health office toilet	6	20	SF	\$154	
Staff Restroom	Staff Restroom	Accessories	Assist principal (aka principal) toilet	6	25	SF	\$193	
Staff Restroom	Staff Restroom	Accessories	Womens 1st floor North	6	30	SF	\$232	
Staff Restroom	Staff Restroom	Accessories	Engineers Toilet / Locker	6	50	SF	\$386	
Staff Restroom	Staff Restroom	Accessories	Unisex 1st floor	6	30	SF	\$232	
Staff Restroom	Staff Restroom	Accessories	Mens- 2ed floor	6	25	SF	\$193	
Staff Restroom	Early Childhood Student Restroom	Accessories	Kindergarten 2 toilet	7	25	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	Kindergarten 1 toilet	7	25	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2ed floor boys	6	230	SF	\$1,776	
Staff Restroom	Children's Standard Student Restroom	Accessories	2ed floor girls north	6	230	SF	\$1,776	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor girls south	6	170	SF	\$1,313	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor Boys south	6	212	SF	\$1,637	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor girls north	6	230	SF	\$1,776	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor Boys north	6	230	SF	\$1,776	
Staff Restroom	Staff Restroom	Accessories	Mens 1st floor North	6	30	SF	\$232	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2ed floor boys	7	230	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor Boys north	7	230	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor girls north	7	230	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Plaster/Drywall	Kindergarten 2 toilet	7	25	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	Engineers Toilet / Locker	7	50	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2ed floor girls north	7	230	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	Mens- 2ed floor	6	25	SF	\$71	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	Womens- 2ed floor	6	25	SF	\$71	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	Unisex 1st floor	6	30	SF	\$85	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	Mens 1st floor North	6	30	SF	\$85	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Plaster/Drywall	Kindergarten 1 toilet	7	25	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	Womens 1st floor North	6	30	SF	\$85	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	Assist principal (aka principal) toilet	6	25	SF	\$71	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor girls south	7	170	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	Health office toilet	6	20	SF	\$57	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor Boys south	7	170	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	Kitchen toilet / lockers	7	60	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor Boys south	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor girls south	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2ed floor boys	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2ed floor girls north	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	Kindergarten 1 toilet			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	Kindergarten 2 toilet			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	Kitchen toilet / lockers			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	Womens- 2ed floor			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor girls north	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor Boys north	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	Health office toilet			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	Assist principal (aka principal) toilet			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	Womens 1st floor North			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	Unisex 1st floor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	Mens- 2ed floor			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	Engineers Toilet / Locker			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	Mens 1st floor North			EA	\$0	
Staff Restroom	Staff Restroom	Flooring - Concrete	Engineers Toilet / Locker	6	50	SF	\$236	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	Kitchen toilet / lockers	7	60	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor Boys north	7	230	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor girls north	7	230	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor Boys south	7	170	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor girls south	7	170	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	Health office toilet	7	20	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	Assist principal (aka principal) toilet	7	25	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	Womens- 2ed floor	7	25	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	Mens- 2ed floor	7	25	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2ed floor girls north	7	230	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2ed floor boys	7	230	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	Mens 1st floor North	7	30	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	Unisex 1st floor	7	30	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile/Sheet	Kindergarten 1 toilet	7	25	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile/Sheet	Kindergarten 2 toilet	7	25	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	Womens 1st floor North	7	30	SF	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	Unisex 1st floor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	Mens 1st floor North			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	Womens 1st floor North			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	Health office toilet			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor girls north	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor Boys north	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	Assist principal (aka principal) toilet			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	Womens- 2ed floor			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	Engineers Toilet / Locker			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor Boys south	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor girls south	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2ed floor boys	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2ed floor girls north	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Hand Dryer	Kindergarten 1 toilet			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Early Childhood Student Restroom	Hand Dryer	Kindergarten 2 toilet			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	Kitchen toilet / lockers			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	Mens- 2ed floor			EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Womens- 2ed floor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Health office toilet	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Kitchen toilet / lockers			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	Kindergarten 2 toilet	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Mens- 2ed floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2ed floor boys	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2ed floor girls north	7	3	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	Kindergarten 1 toilet	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor girls south	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor Boys south	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor girls north	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor Boys north	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Assist principal (aka principal) toilet	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Womens 1st floor North	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Mens 1st floor North	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Engineers Toilet / Locker	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Unisex 1st floor	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Pendant/ Surface	Kindergarten 2 toilet	4	1	SF	\$4	incandescent
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st floor girls north	7	4	SF	\$0	T8
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st floor Boys south	7	2	SF	\$0	T8
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st floor girls south	7	2	SF	\$0	T8
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	Engineers Toilet / Locker	4	1	SF	\$4	incandescent
Staff Restroom	Early Childhood Student Restroom	Lighting - Pendant/ Surface	Kindergarten 1 toilet	4	1	SF	\$4	incandescent

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st floor Boys north	7	4	SF	\$0	T8
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	Kitchen toilet / lockers	7	1	SF	\$0	T8
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	Kitchen toilet / lockers	4	1	SF	\$4	incandescent
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	Health office toilet	4	1	SF	\$4	incandescent
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	Assist principal (aka principal) toilet	4	1	SF	\$4	incandescent
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	Womens 1st floor North	4	1	SF	\$4	incandescent
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	Mens 1st floor North	4	1	SF	\$4	incandescent
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2ed floor boys	7	4	SF	\$0	T8
Staff Restroom	Staff Restroom	Partitions	Mens 1st floor North			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	Engineers Toilet / Locker			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor Boys south	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	Womens- 2ed floor			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor girls north	7	5	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	Mens- 2ed floor			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor girls south	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2ed floor boys	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2ed floor girls north	7	5	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Partitions	Kindergarten 1 toilet			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Partitions	Kindergarten 2 toilet			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	Kitchen toilet / lockers			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	Health office toilet			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	Assist principal (aka principal) toilet			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	Womens 1st floor North			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	Unisex 1st floor			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor Boys north	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Urinals	Kindergarten 2 toilet			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	Womens 1st floor North			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	Mens 1st floor North			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Urinals	1st floor Boys north	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st floor girls north			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st floor Boys south	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2ed floor boys	7	4	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Urinals	Kindergarten 1 toilet			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	Kitchen toilet / lockers			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	Health office toilet			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	Assist principal (aka principal) toilet			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	Engineers Toilet / Locker			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	Mens- 2ed floor			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	Womens- 2ed floor			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	Unisex 1st floor			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2ed floor girls north			EA	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	Engineers Toilet / Locker	7	90	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Wall - Structural Glazed Tile	Kindergarten 1 toilet	7	160	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st floor girls north	7	540	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st floor girls south	7	425	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2ed floor girls north	7	540	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st floor Boys north	7	540	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Wall - Structural Glazed Tile	Kindergarten 2 toilet	7	160	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	Kitchen toilet / lockers	7	310	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	Health office toilet	7	144	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	Assist principal (aka principal) toilet	7	160	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	Womens 1st floor North	7	175	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	Mens 1st floor North	7	175	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	Unisex 1st floor	7	175	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	Womens- 2ed floor	7	160	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	Mens- 2ed floor	7	160	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	Engineers Toilet / Locker	6	150	SF	\$1,073	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2ed floor boys	7	540	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st floor Boys south	7	425	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor Boys north	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	Kitchen toilet / lockers	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	Health office toilet	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	Assist principal (aka principal) toilet	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	Womens 1st floor North	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	Mens 1st floor North	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	Unisex 1st floor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	Womens- 2ed floor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	Mens- 2ed floor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	Engineers Toilet / Locker	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	Kindergarten 2 toilet	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor Boys south	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor girls north	7	5	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	Kindergarten 1 toilet	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2ed floor girls north	7	6	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2ed floor boys	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor girls south	7	2	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	

INTERIOR Sub Total \$386,966

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
ADMIN_CEILING	Administrative Suites/Offices	Administrative Office Ceiling	custodian office (aka eng. office)	6	90	SF	\$255	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Ceiling	Classroom	Splined Ceiling		7	778	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	588	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	792	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	792	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	792	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	792	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	792	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	792	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	792	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	792	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	792	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	792	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	792	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	792	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	792	SF	\$0	
Chalk Board	Classroom	Chalk Board		4	32	LF	\$3,890	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	32	LF	\$3,890	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	6	LF	\$729	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chalk Board	Lunchroom	Chalk Board	lunch not library	4		LF		
Corridors	Corridors	Drinking Fountains	1st floor North cooridor-A			EA	\$0	
Corridors	Corridors	Drinking Fountains	1st floor south cooridor			EA	\$0	
Corridors	Corridors	Drinking Fountains	1st floor West cooridor			EA	\$0	
Corridors	Corridors	Drinking Fountains	stair 1			EA	\$0	
Corridors	Corridors	Drinking Fountains	2ed floor crossover corridor			EA	\$0	
Corridors	Corridors	Drinking Fountains	2ed floor South corridor A			EA	\$0	
Corridors	Corridors	Drinking Fountains	1st floor boiler room cooridor			EA	\$0	
Corridors	Corridors	Drinking Fountains	1st floor East cooridor			EA	\$0	
Corridors	Corridors	Drinking Fountains	1st floor North cooridor			EA	\$0	
Corridors	Corridors	Drinking Fountains	2ed floor crossover corridor B			EA	\$0	
Corridors	Corridors	Drinking Fountains	2ed floor North corridor			EA	\$0	
Corridors	Corridors	Drinking Fountains	stair 2			EA	\$0	
Corridors	Corridors	Floors	1st floor North cooridor	7	100	SF	\$0	
Corridors	Corridors	Floors	1st floor North cooridor	7	850	SF	\$0	
Corridors	Corridors	Metal Panel	2ed floor crossover corridor B	7	50	SF	\$0	
Corridors	Corridors	Metal Panel	2ed floor North corridor	7	300	SF	\$0	
Corridors	Corridors	Metal Panel	2ed floor crossover corridor	7	50	SF	\$0	
Corridors	Corridors	Metal Panel	1st floor North cooridor	7	300	SF	\$0	
Corridors	Corridors	Pendant/Surface	2ed floor crossover corridor	6	104	EA	\$74	T8 howeverall fixtures aremissing diffusers
Corridors	Corridors	Pendant/Surface	stair 2	6	360	EA	\$257	missing diffusser
Corridors	Corridors	Pendant/Surface	2ed floor South corridor A	6	840	EA	\$601	T8 howeverall fixtures aremissing diffusers
Corridors	Corridors	Pendant/Surface	stair 1	6	360	EA	\$257	missing diffusser
Corridors	Corridors	Pendant/Surface	2ed floor crossover corridor B	6	104	EA	\$74	T8 howeverall fixtures aremissing diffusers
Corridors	Corridors	Pendant/Surface	1st floor North cooridor	7	950	EA	\$0	
Corridors	Corridors	Pendant/Surface	1st floor North cooridor-A	7	340	EA	\$0	
Corridors	Corridors	Pendant/Surface	1st floor south cooridor	7	500	EA	\$0	
Corridors	Corridors	Pendant/Surface	1st floor West cooridor	6	1,775	EA	\$1,269	T8 however about 50% of diffusers are missing
Corridors	Corridors	Pendant/Surface	1st floor East cooridor	6	1,680	EA	\$1,201	T8 however about 50% of diffusers are missing
Corridors	Corridors	Pendant/Surface	1st floor boiler room cooridor	6	170	EA	\$122	T8 however about 50% of diffusers are missing

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Pendant/Surface	2ed floor North corridor	6	840	EA	\$601	T8 howeverall fixtures aremissing diffussers
Corridors	Corridors	Plaster/Drywall	1st floor south cooridor	7	400	SF	\$0	
Corridors	Corridors	Plaster/Drywall	1st floor West cooridor	7	200	SF	\$0	
Corridors	Corridors	Stair Handrails	1st floor North cooridor			LF	\$0	
Corridors	Corridors	Stair Handrails	stair 2	7	87	LF	\$0	
Corridors	Corridors	Stair Handrails	2ed floor crossover corridor			LF	\$0	
Corridors	Corridors	Stair Handrails	2ed floor crossover corridor B			LF	\$0	
Corridors	Corridors	Stair Handrails	stair 1	7	87	LF	\$0	
Corridors	Corridors	Stair Handrails	1st floor North cooridor-A			LF	\$0	
Corridors	Corridors	Stair Handrails	1st floor south cooridor			LF	\$0	
Corridors	Corridors	Stair Handrails	1st floor West cooridor			LF	\$0	
Corridors	Corridors	Stair Handrails	2ed floor South corridor A			LF	\$0	
Corridors	Corridors	Stair Handrails	1st floor boiler room cooridor			LF	\$0	
Corridors	Corridors	Stair Handrails	2ed floor North corridor			LF	\$0	
Corridors	Corridors	Stair Handrails	1st floor East cooridor			LF	\$0	
Corridors	Corridors	Stairs	1st floor boiler room cooridor			EA	\$0	
Corridors	Corridors	Stairs	1st floor East cooridor			EA	\$0	
Corridors	Corridors	Stairs	2ed floor North corridor			EA	\$0	
Corridors	Corridors	Stairs	2ed floor South corridor A			EA	\$0	
Corridors	Corridors	Stairs	2ed floor crossover corridor			EA	\$0	
Corridors	Corridors	Stairs	2ed floor crossover corridor B			EA	\$0	
Corridors	Corridors	Stairs	1st floor West cooridor			EA	\$0	
Corridors	Corridors	Stairs	1st floor south cooridor			EA	\$0	
Corridors	Corridors	Stairs	1st floor North cooridor			EA	\$0	
Corridors	Corridors	Stairs	1st floor North cooridor-A			EA	\$0	
Corridors	Corridors	Structural Glazed Tile	2ed floor South corridor A	7	1,600	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	stair 1	7	420	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	stair 2	7	420	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	2ed floor crossover corridor	7	144	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	1st floor boiler room cooridor	7	170	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	2ed floor North corridor	7	1,300	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	2ed floor North corridor	7	64	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	1st floor East cooridor	7	1,720	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Structural Glazed Tile	1st floor West cooridor	7	640	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	1st floor West cooridor	7	200	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	1st floor south cooridor	7	96	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	1st floor south cooridor	7	300	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	1st floor North cooridor	7	64	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	1st floor North cooridor-A	7	600	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	1st floor North cooridor	7	1,300	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	2ed floor crossover cooridor B	7	144	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	1st floor East cooridor	7	650	SF	\$0	
Corridors	Corridors	Student Lockers	1st floor West cooridor			EA	\$0	
Corridors	Corridors	Student Lockers	stair 1			EA	\$0	
Corridors	Corridors	Student Lockers	1st floor North cooridor			EA	\$0	
Corridors	Corridors	Student Lockers	1st floor south cooridor			EA	\$0	
Corridors	Corridors	Student Lockers	1st floor East cooridor			EA	\$0	
Corridors	Corridors	Student Lockers	1st floor boiler room cooridor			EA	\$0	
Corridors	Corridors	Student Lockers	2ed floor North cooridor			EA	\$0	
Corridors	Corridors	Student Lockers	stair 2			EA	\$0	
Corridors	Corridors	Student Lockers	2ed floor crossover cooridor			EA	\$0	
Corridors	Corridors	Student Lockers	2ed floor crossover cooridor B			EA	\$0	
Corridors	Corridors	Student Lockers	1st floor North cooridor-A			EA	\$0	
Corridors	Corridors	Student Lockers	2ed floor South cooridor A			EA	\$0	
Corridors	Corridors	Terrazzo	stair 2	7	480	SF	\$0	
Corridors	Corridors	Terrazzo	stair 1	7	480	SF	\$0	
Corridors	Corridors	Terrazzo	1st floor West cooridor	7	450	SF	\$0	
Corridors	Corridors	Terrazzo	1st floor North cooridor-A	7	100	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	2ed floor crossover cooridor B	7	104	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	2ed floor crossover cooridor	7	104	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	1st floor boiler room cooridor	7	170	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	1st floor East cooridor	7	1,680	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	1st floor West cooridor	7	1,325	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	2ed floor North cooridor	7	840	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	1st floor south cooridor	7	500	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	1st floor North cooridor-A	7	240	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	2ed floor South cooridor A	7	840	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Walls	1st floor boiler room cooridor	7	170	SF	\$0	
Corridors	Corridors	Walls	2ed floor South corridor A	7	64	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	1st floor North cooridor	7	950	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	1st floor south cooridor	7	500	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	1st floor East cooridor	7	1,680	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	stair 1	7	360	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	stair 2	7	360	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	2ed floor crossover corridor	7	104	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	2ed floor crossover corridor B	7	104	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	2ed floor South corridor A	7	840	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	2ed floor North corridor	7	840	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	1st floor West cooridor	7	1,775	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	1st floor North cooridor-A	7	340	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	1st floor boiler room cooridor	7	170	SF	\$0	
Stairs	Corridors	Tile	stair 1	6	19	SF	\$143	minor trip hazard developing at noising multiple locations (see photos)
Stairs	Corridors	Tile	stair 2	6	19	SF	\$143	minor trip hazard developing at noising multiple locations (see photos)
Floor	Classroom	Tile/Sheet		7	792	SF	\$0	
Floor	Classroom	Tile/Sheet		7	792	SF	\$0	
Floor	Classroom	Tile/Sheet		7	792	SF	\$0	
Floor	Classroom	Tile/Sheet		7	792	SF	\$0	
Floor	Classroom	Tile/Sheet		7	792	SF	\$0	
Floor	Classroom	Tile/Sheet		7	792	SF	\$0	
Floor	Classroom	Tile/Sheet		7	792	SF	\$0	
Floor	Classroom	Tile/Sheet		7	588	SF	\$0	
Floor	Classroom	Tile/Sheet		7	792	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,074	SF	\$0	
Floor	Classroom	Tile/Sheet		7	792	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,074	SF	\$0	
Floor	Classroom	Tile/Sheet		7	792	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,816	SF	\$0	
Floor	Classroom	Tile/Sheet		7	792	SF	\$0	
Floor	Classroom	Tile/Sheet		7	792	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Floor	Classroom	Tile/Sheet		7	792	SF	\$0	
Floor	Classroom	Tile/Sheet		7	792	SF	\$0	
Floor	Classroom	Tile/Sheet		7	792	SF	\$0	
Floor	Classroom	Tile/Sheet		7	792	SF	\$0	
Floor	Classroom	Tile/Sheet		7	792	SF	\$0	
Floor	Classroom	Tile/Sheet		7	792	SF	\$0	
Floor	Classroom	Tile/Sheet		7	792	SF	\$0	
Floor	Classroom	Tile/Sheet		7	752	SF	\$0	
Floor	Classroom	Tile/Sheet		7	792	SF	\$0	
Floor	Classroom	Tile/Sheet		7	792	SF	\$0	
Lighting	Classroom	Pendant/Surface		7	21	EA	\$0	T8
Lighting	Classroom	Pendant/Surface		7	24	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	24	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	24	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	24	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	24	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	24	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	24	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	38	EA	\$0	T8
Lighting	Classroom	Pendant/Surface		7	24	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	21	EA	\$0	T8
Lighting	Classroom	Pendant/Surface		7	24	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	24	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	24	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	12	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	24	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	24	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	24	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	24	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	24	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	24	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	24	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	24	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	24	EA	\$0	
Lighting	Classroom	Pendant/Surface		6	24	EA	\$1,716	Missing a few covers
Lighting	Classroom	Pendant/Surface		7	24	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	24	EA	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	0	LF	\$0	
Marker Board	Classroom	Marker Board		7	0	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Lunchroom	Marker Board	lunch not library			LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
RESTROOM_LIGHT	Staff Restroom	Restroom Lighting	Womens- 2ed floor	4	1	EA	\$322	incandescent
RESTROOM_LIGHT	Staff Restroom	Restroom Lighting	Unisex 1st floor	7	1	EA	\$0	T8
RESTROOM_LIGHT	Children's Standard Student Restroom	Restroom Lighting	2ed floor girls north	7	4	EA	\$0	incandescent
RESTROOM_LIGHT	Staff Restroom	Restroom Lighting	Mens- 2ed floor	4	1	EA	\$322	incandescent
Wall	Classroom	Concrete Block		7	904	SF	\$0	
Wall	Classroom	Concrete Block		7	904	SF	\$0	
Wall	Classroom	Concrete Block		7	904	SF	\$0	
Wall	Classroom	Concrete Block		7	904	SF	\$0	
Wall	Classroom	Concrete Block		7	904	SF	\$0	
Wall	Classroom	Concrete Block		7	904	SF	\$0	
Wall	Classroom	Concrete Block		7	904	SF	\$0	
Wall	Classroom	Concrete Block		7	904	SF	\$0	
Wall	Classroom	Concrete Block		7	904	SF	\$0	
Wall	Classroom	Concrete Block		7	904	SF	\$0	
Wall	Classroom	Concrete Block		7	904	SF	\$0	
Wall	Classroom	Concrete Block		7	904	SF	\$0	
Wall	Classroom	Concrete Block		7	904	SF	\$0	
Wall	Classroom	Concrete Block		7	904	SF	\$0	
Wall	Classroom	Concrete Block		7	904	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Concrete Block		7	904	SF	\$0	
Wall	Classroom	Concrete Block		7	904	SF	\$0	
Wall	Classroom	Concrete Block		7	904	SF	\$0	
Wall	Classroom	Concrete Block		7	904	SF	\$0	
Wall	Classroom	Concrete Block		7	904	SF	\$0	
Wall	Classroom	Concrete Block		7	904	SF	\$0	
Wall	Classroom	Concrete Block		7	904	SF	\$0	
Wall	Classroom	Concrete Block		7	904	SF	\$0	
Wall	Classroom	Concrete Block		7	1,500	SF	\$0	
Wall	Classroom	Concrete Block		7	930	SF	\$0	
Wall	Classroom	Concrete Block		7	973	SF	\$0	
Wall	Classroom	Concrete Block		7	973	SF	\$0	
Wall	Classroom	Concrete Block		7	904	SF	\$0	

ROOM Sub Total \$44,552

Building Main Sub Total \$2,000,771

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Civil/Drainage		Catch Basin	Entire Building	7	7	EA	\$0	
Civil/Drainage		Site Drain	East	7	1	EA	\$0	
Civil/Drainage		Site Manhole	Entire Building	7	3	EA	\$0	
Fencing		Chain Link	East Playlot and North	4	943	LF	\$101,137	
Fencing		Chain Link	Parking Lot and Trash	7	262	LF	\$0	
Fencing		Ornamental Iron	NW Corner	4	12	LF	\$2,265	
Fencing		Ornamental Iron	West	7	478	LF	\$0	
Fencing		Wood Fencing w/ Steel Frame	Entire Building	7	78	LF	\$0	
Landscape		Asphalt Play Area/Hardscape	East and South	7	29,586	SF	\$0	
Landscape		Benches	Courtyard	7	5	EA	\$0	
Landscape		Grass	West and North	7	8,404	SF	\$0	
Landscape		Hardscape - Concrete	East site	4	1,215	SF	\$22,934	
Landscape		Hardscape - Concrete	Entire Building	7	1,527	SF	\$0	
Landscape		Hardscape - Pavers	Courtyard	7	810	SF	\$0	
Landscape		Parkway trees	West Site	7	7	EA	\$0	
Landscape		Planting Beds/ Areas	Courtyard	7	2,363	SF	\$0	
Landscape		Retaining Wall - Concrete	South	7	377	SF	\$0	

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Parking Lot		Asphalt	East Site	7	7,200	SF	\$0	
Parking Lot		Trash Enclosure	East Site	7	640	SF	\$0	
Playground		Playground Equipment - Combo 3-12	east	7	1	EA	\$0	
Playground		Playground Surfacing - Poured Surface	east site	7	2,500	SF	\$0	
Sidewalks		Perimeter Sidewalks	West and North	7	5,716	SF	\$0	
Signage		Flag Pole	West Site	7	1	EA	\$0	
Signage		Marquee - Free Standing Back Lighted	West Site	7	1	EA	\$0	
SITE Sub Total							\$126,336	
SITE Sub Total							\$126,336	

Total Campus Need ^{2 3} \$2,127,107

¹ It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

² As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

³ The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Building: Main														
101	792	1	8	28	40	140	24		N	N	Y	Classroom		
102	792	1	8	28	40	140	24		N	N	Y	Classroom		
103	792	1	8	28	40	140	24		N	N	Y	Classroom		
104	792	1	8	28	40	140	24		N	N	Y	Classroom		
105	1816	1	24		40	210	24	1	N	N	N	Classroom		
106	792	1	8	28	40	140	24		N	N	Y	Classroom		
107	588				40	70	8		N	N	N	Classroom		
108	792	1	8	28	40	140	24		N	N	Y	Classroom		
110	792	1	8	28	40	140	24		N	N	Y	Classroom		
112	752	1	8	28	40	140	24		N	N	Y	Classroom		
201	792	1	8	28	40	140	24		N	N	Y	Classroom		
202	792	1	8	28	40	140	24		N	N	Y	Classroom		
203	792	1	8	28	40	140	24		N	N	Y	Classroom		
204	792	1	8	28	40	140	24		N	N	Y	Classroom		
205	792	1	8	28	40	140	24		N	N	Y	Classroom		
206	792	1	8	28	40	140	24		N	N	Y	Classroom		
207	792	1	46	46	40	140	24	1	N	N	Y	Classroom		
208	792	1	8	28	40	140	24		N	N	Y	Classroom		
209	792	1	8	28	40	140	24		N	N	Y	Classroom		
210	792	1	8	28	40	140	24		N	N	Y	Classroom		
211	792	1	8	28	40	140	24	1	N	N	Y	Classroom		
212	792	1	8	28	40	140	24		N	N	Y	Classroom		
Kindergarden 2	1074	1	7	18	40	233	80		N	N	Y	Classroom		
Kindergarten 1	1074	1	7	18	40	233	80		N	N	Y	Classroom		
Other	375								N	N	N	Gymnasia	Gymnasium.Auditorium	stage
Other	280			8					N	N	Y	Administrative Suites/Offices		public/office
Other	456			10					N	N	Y	Administrative Suites/Offices		principals (aka- counseling class room)
Other	135			4					N	N	Y	Administrative Suites/Offices		Assist principal (aka- principal office)
Other	90			4					N	N	Y	Administrative Suites/Offices		Health Office
Other	676			10					N	N	Y	Administrative Suites/Offices		Teachers lounge
Other	1152								N	N	N	Lunch & Multipurpose Room	Lunchroom	lunch not library
Other	500								N	N	N	Kitchen	Cooking Kitchen	1st Floor
Other	1680								N	N	N	Corridors		1st floor East cooridor
Other	50								N	N	N	Restroom	Staff Restroom	Engineers Toilet / Locker

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	288			20					N	N	Y	Administrative Suites/Offices		Engineers office (AKA Instr. matl center)
Other	90			8					N	N	Y	Administrative Suites/Offices		custodian office (aka eng. office)
Other	950								N	N	N	Corridors		1st floor North cooridor
Other	340								N	N	N	Corridors		1st floor North cooridor-A
Other	90			2					N	N	Y	Administrative Suites/Offices		Lunch office (AKA office library)
Other	1775								N	N	N	Corridors		1st floor West cooridor
Other	30								N	N	N	Restroom	Staff Restroom	Unisex 1st floor
Other	170								N	N	N	Corridors		1st floor boiler room cooridor
Other	840								N	N	N	Corridors		2ed floor North corridor
Other	840								N	N	N	Corridors		2ed floor South corridor A
Other	104								N	N	N	Corridors		2ed floor crossover cooridor
Other	104								N	N	N	Corridors		2ed floor crossover cooridor B
Other	360								N	N	N	Corridors		stair 1
Other	500								N	N	N	Corridors		1st floor south cooridor
Other	25								N	N	N	Restroom	Early Childhood Student Restroom	Kindergarten 2 toilet
Other	360								N	N	N	Corridors		stair 2
Other	230								N	N	N	Restroom	Children's Standard Student Restroom	1st floor Boys north
Other	230								N	N	N	Restroom	Children's Standard Student Restroom	1st floor girls north
Other	170								N	N	N	Restroom	Children's Standard Student Restroom	1st floor Boys south
Other	170								N	N	N	Restroom	Children's Standard Student Restroom	1st floor girls south
Other	230								N	N	N	Restroom	Children's Standard Student Restroom	2ed floor boys
Other	25								N	N	N	Restroom	Staff Restroom	Mens- 2ed floor
Other	25								N	N	N	Restroom	Early Childhood Student Restroom	Kindergarten 1 toilet
Other	25								N	N	N	Restroom	Staff Restroom	Womens- 2ed floor
Other	60								N	N	N	Restroom	Staff Restroom	Kitchen toilet / lockers
Other	20								N	N	N	Restroom	Staff Restroom	Health office toilet
Other	25								N	N	N	Restroom	Staff Restroom	Assist principal (aka principal) toilet
Other	30								N	N	N	Restroom	Staff Restroom	Womens 1st floor North
Other	30								N	N	N	Restroom	Staff Restroom	Mens 1st floor North
Other	3300								N	N	N	Gymnasias	Gymnasium.Auditorium	1st Floor
Other	230								N	N	N	Restroom	Children's Standard Student Restroom	2ed floor girls north