

Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx.

Condition Rankings and Descriptions

- Rank 7:** The item/system is new or in good condition and no work is required.
- Rank 6:** The item/system requires general cleaning and/or routine maintenance.
- Rank 5:** The item/system requires repairs and has not reached the end of its serviceable life.
- Rank 4:** The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.
- Rank 3:** The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.
- Rank 2:** The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.
- Rank 1:** The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.¹

Definitions

- Quantity** means, for each item, the total number (or amount) of that item that exists and was evaluated.
- Unit** means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").
- Cost** means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.
- For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.**
- Total Campus Need** also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

Building: Main Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Canopy		Concrete/ Stucco Canopy	West Façade	7	952	SF	\$0	
Canopy		Metal Canopy	Main Entrance	7	882	SF	\$0	
Chimney		Metal Flue	Main roof- North end	7	16	LF	\$0	
Doors		Exterior Steel Door	West and South facade and chiller well	7	11	EA	\$0	
Doors		Exterior Wood Door	west facade- north end	7	1	EA	\$0	
Doors		Store Front Door	doors 1 - 4, green roof access	7	11	EA	\$0	
Entrance		Entrance Controls - Audio	doors 2, 4, kitchen entry	7	3	EA	\$0	
Entrance		Entrance Controls - Audio and Video	doors 1, 3, NW corridor entry	7	3	EA	\$0	
Entrance		Power Door Operator and Controls	doors 1,3, 4	7	3	EA	\$0	
Foundation		Concrete Foundation	Entire Building	7	1,040	LF	\$0	
Lighting		Exterior Lights - Parapet or Roof Mounted	Entire Site	7	15	EA	\$0	
Lighting		Exterior Lights - Wall Mounted	Entire Building	7	25	EA	\$0	
Lintels		Lintels - Steel	Entire Building	7	647	LF	\$0	

Building: Main
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Parapet		Coping - Metal	Entire Building	7	1,504	LF	\$0	
Parapet		Parapet < 16" Height	Low roof- South end	7	171	LF	\$0	
Roof System		Interior Downspouts	Entire Building	6	906	LF	\$0	
Roof System		Modified Bitumen Roof	main roof and chiller well	7	38,032	SF	\$0	
Roof System		Modified Bitumen Roof	low roof at South end	7	4,390	SF	\$0	
Roof System		Roof Structure: Steel/Metal Deck/Concrete Topping	Roof	7	42,422	SF	\$0	
Superstructure		Metal Deck/Concrete Topping	Entire Building	7	104,200	SF	\$0	
Walls		Brick	Entire Building	7	33,970	SF	\$0	
Walls		Concrete Block	chiller well	7	3,465	SF	\$0	
Walls		Stone - Cast	West Façade	7	4,990	SF	\$0	
Windows		Curtain wall - Glazed Double Pane	entrances, library, gym, green roof	7	5,870	SF	\$0	
Windows		Curtain wall - Louver	N and W facade	7	1,120	SF	\$0	
Windows		Window - Guards perforated	Entire Building	7	1,208	SF	\$0	
Windows		Windows - Sash Aluminum Double-pane	Entire Building	7	3,877	SF	\$0	
EXTERIOR Sub Total							\$0	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	elevator mech room	7	1	EA	\$0	
Emergency System		Automatic Transfer switch	Electrical Room	7	2	EA	\$0	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	7	19,178	SF	\$0	
Emergency System		Emergency A/C power - Gym and Lunch rooms	1st Floor	7	3,990	SF	\$0	
Emergency System		Emergency A/C power - Gym and Lunch rooms	1st Floor	7	5,014	SF	\$0	
Emergency System		Emergency A/C power - Students Toilets	Entire Building	7	3,600	SF	\$0	
Emergency System		Emergency generator 200 -250 KW natural gas - Indoor	2ND FLR ROOF	7	1	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	7	49	EA	\$0	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st Floor	7	9	EA	\$0	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st Floor	7	3	EA	\$0	
Emergency System		Independent Electrical Service for emergency power	Electrical Room	7	1	EA	\$0	
Emergency System		Public Announcement System	1st Floor	7	104,200	SF	\$0	
Emergency System		Security System - CCTV	1st Floor	7	104,200	SF	\$0	
Emergency System		Security System - Intrusion detection	Entire Building	7	104,200	SF	\$0	
Main Service		Main Electrical service 2000 to 3000 A 277/480/3PH	Electrical Room	7	1	EA	\$0	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Power Distribution		Lighting and power panels	Entire Building	7	15	EA	\$0	
Power Distribution		Main distribution panels 400-600 amp	Electrical Room	7	1	EA	\$0	
Power Distribution		Main distribution panels above 600 amp	Electrical Room	7	4	EA	\$0	
Power Distribution		Main distribution panels above 600 amp	Electrical Room	7	2	EA	\$0	
Power Distribution		Transformers 277/480-120/208	Electrical Room	7	1	EA	\$0	
Power Distribution		Transformers 277/480-120/208	Electrical Room	7	2	EA	\$0	
Power Distribution		Transformers 277/480-120/208	Electrical Room	7	4	EA	\$0	
Power Distribution		Transformers 277/480-120/208	Electrical Room	7	1	EA	\$0	
ELECTRICAL Sub Total							\$0	

Building: Main
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Entire Building	7	104,200	SF	\$0	
Fire Alarm		Fire Alarm System	Electrical Room	7	104,200	SF	\$0	
Fire Alarm		Fire Pump Controller	pump room	7	1	EA	\$0	
Pump Room Assembly		Fire Pump 25-50hp	pump room	7	1	EA	\$0	
Pump Room Assembly		Jockey Pump	pump room	7	1	EA	\$0	
Sprinkler System		Sprinkler Heads	Entire Building	7	104,200	SF	\$0	
Sprinkler System		Wet Sprinkler System	Entire Building	7	104,200	SF	\$0	
FIRE PROTECTION Sub Total							\$0	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Chillers - Air Cooled - Rotary/Screw type - Roof Mounted greater than 300 tons	2ND FLR ROOF	7	1	EA	\$0	
Air Conditioning		Condensing Unit - Roof Mounted less than 5 tons	Roof	7	1	EA	\$0	
Air Handling Systems		Air Handling Unit Package - Multi Zone - Hot Water 10,001 to 15,000 cfm	2ND FLOOR MECH ROOM	7	1	EA	\$0	
Air Handling Systems		Air Handling Unit Package - Multi Zone - Hot Water above 20,001 to 30,000 cfm	2ND FLOOR MECH ROOM	7	1	EA	\$0	
Air Handling Systems		Air Handling Unit Package - Multi Zone - Hot Water above 20,001 to 30,000 cfm	3RD FLOOR MECH ROOM	7	1	EA	\$0	
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water 8,001 to 12,000 cfm	2ND FLR MECH ROOM	7	1	EA	\$0	
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water 8,001 to 12,000 cfm	3RD FLR MECH ROOM	7	1	EA	\$0	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Handling Systems		Air intake for all Air Handling Units except built up AHU	2ND FLOOR SOUTH WALL EXTERIOR	7	1	EA	\$0	
Air Handling Systems		Air intake for all Air Handling Units except built up AHU	2ND FLOOR SOUTH WALL EXTERIOR	7	1	EA	\$0	
Air Handling Systems		Air intake for all Air Handling Units except built up AHU	2ND FLOOR SOUTH WALL EXTERIOR	7	1	EA	\$0	
Air Handling Systems		Air intake for all Air Handling Units except built up AHU	3RD FLOOR SOUTH WALL EXTERIOR	7	1	EA	\$0	
Air Handling Systems		Air intake for all Air Handling Units except built up AHU	3RD FLOOR SOUTH WALL EXTERIOR	7	1	EA	\$0	
Air Handling Systems		Fan Coil Unit - Electric	MDF ROOM	7	1	EA	\$0	
Air Handling Systems		Fan Power Box With Hot Water Coil	Entire Building	7	47	EA	\$0	
Air Handling Systems		Return Fans - Indoor 10,001 to 20,000 CFM	2ND FLR MECH ROOM	7	1	EA	\$0	
Air Handling Systems		Return Fans - Indoor 10,001 to 20,000 CFM	2ND FLR MECH ROOM	7	1	EA	\$0	
Air Handling Systems		Return Fans - Indoor 10,001 to 20,000 CFM	3RD FLOOR MECH ROOM	7	1	EA	\$0	
Air Handling Systems		Return Fans - Indoor 5,000 to 10,000 CFM	2ND FLR MECH ROOM	7	1	EA	\$0	
Air Handling Systems		Variable Air Volume (VAV) Box With Hot Water Coil	Entire Building	7	15	EA	\$0	
Boiler Systems		Boiler Assembly - Condensing Hot Water Boiler 1,001MBH-2,000 MBH	3RD FLR MECH ROOM	7	3	EA	\$0	
Boiler Systems		Boiler Auxiliary - Condensing Hot Water Boiler 1,001MBH-2,000 MBH	3RD FLR MECH ROOM	7	3	EA	\$0	
Boiler Systems		Chemical Pot Feeder - Hot Water	3RD FLR MECH ROOM	7	2	EA	\$0	
Boiler Systems		Combustion Dampers	3RD FLR MECH ROOM	7	1	EA	\$0	
Boiler Systems		Glycol Feed System	3RD FLR MECH ROOM	7	2	EA	\$0	
Heating Devices		Cabinet Heaters With Hot Water Coils	Entire Building	7	13	EA	\$0	
Heating Devices		Fin Tube Hot Water	Entire Building	7	187	LF	\$0	
Heating Devices		Fin Tube Hot Water	Entire Building	7	76	LF	\$0	
Heating Devices		Unit Heater - Electric	Entire Building	7	2	EA	\$0	
Heating Devices		Unit Heater - Hot Water	Entire Building	7	5	EA	\$0	
Mechanical Plumbing		Piping - Hydronic Supply and Return - Steel or Galvanized	Entire Building	7	600	LF	\$0	
Mechanical Plumbing		Piping - Hydronic Supply and Return - Steel or Galvanized	Entire Building	7	500	LF	\$0	
Mechanical Plumbing		Pumps - Chilled Water 21-50 HP	3RD FLR MECH ROOM	7	1	EA	\$0	
Mechanical Plumbing		Pumps - Chilled Water 21-50 HP	3RD FLR MECH ROOM	3	1	EA	\$48,263	IMPELLER NON FUNCTIONAL. NO REDUNDANCY IN SYSTEM. ONLY ONE PUMP WORKING FULL TIME.
Mechanical Plumbing		Pumps - Hot Water 11 to 20 HP	3RD FLR MECH ROOM	7	2	EA	\$0	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Mechanical Plumbing		Pumps - Hot Water less than 5 HP	Mechanical Room	7	5	EA	\$0	
Temperature Control		Direct Digital Control (DDC) System	Mechanical Room	7	104,200	SF	\$0	
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	7	73	EA	\$0	
Ventilation		Exhaust Fan - Indoor	Entire Building	7	6	EA	\$0	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	7	3	EA	\$0	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	7	6	EA	\$0	
Ventilation		Exhaust Fans - Roof mounted less than 500 CFM	Roof	7	3	EA	\$0	
Ventilation		Type I Exhaust Hood - Kitchen or Culinary Arts	1st Floor	7	1	EA	\$0	
Ventilation		Type II Exhaust Hood - Warming Kitchen	1st Floor	7	2	EA	\$0	
MECHANICAL Sub Total							\$48,263	

Building: Main
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas more than 300,000 BTU/HR	3RD FLR MECH ROOM	7	2	EA	\$0	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	7	104,200	SF	\$0	
Piping		Domestic Piping - Cold Water Risers	Entire Building	7	104,200	SF	\$0	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	7	104,200	SF	\$0	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	7	104,200	SF	\$0	
Piping		Domestic Piping - Hot Water Risers	Entire Building	7	104,200	SF	\$0	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	7	104,200	SF	\$0	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	7	104,200	SF	\$0	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	7	104,200	SF	\$0	
Piping		Sanitary Piping	Entire Building	7	104,200	SF	\$0	
Piping		Storm Piping	Entire Building	7	104,200	SF	\$0	
Piping		Vent Piping	Entire Building	7	104,200	SF	\$0	
Pumps		Domestic Booster Pump duplex	pump room	7	1	EA	\$0	
PLUMBING Sub Total							\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	111E	7	125	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	111D	7	190	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	1111	7	123	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	111 business office	7	1,340	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	211A library work room	7	275	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	111B	7	248	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	111C	7	410	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	111A	7	150	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	112 student services	7	643	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	112 nurse	7	475	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	rm 122A - Kitchen office	7	80	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	rm 126 - Engineer's office	7	228	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Rm 101A - Gym office	7	150	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	309 staff lounge	7	605	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	111K	7	150	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	112 student services	7	643	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	111 business office	7	1,080	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	111D	7	190	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	111B	7	248	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	111C	7	410	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	111A	7	150	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	111E	7	125	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Terrazzo	111 business office	7	260	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Rm 101A - Gym office	7	150	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	211A library work room	7	275	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	309 staff lounge	7	605	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	rm 126 - Engineer's office	7	228	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	112 nurse	7	475	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	111K	7	150	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	111I	7	123	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	111C	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	111B	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	112 nurse	7	8	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	111C	7	3	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	112 student services	7	10	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	111I	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	111 business office	7	20	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	111 business office	7	6	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	211A library work room	7	3	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	111K	7	3	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	111A	7	6	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	111D	7	3	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	rm 126 - Engineer's office	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Rm 101A - Gym office	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	309 staff lounge	7	8	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	rm 122A - Kitchen office	7	2	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	111E	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	309 staff lounge	7	760	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	111 business office	7	980	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	111I	7	230	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	111D	7	122	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	111B	7	244	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	111C	7	150	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	111A	7	108	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	111E	7	68	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	111K	7	189	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	112 student services	7	613	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	211A library work room	7	610	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Rm 101A - Gym office	7	440	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	rm 126 - Engineer's office	7	550	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	rm 122A - Kitchen office	7	291	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	112 nurse	7	778	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	111I	6	194	SF	\$458	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	111E	6	297	SF	\$701	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	111 business office	6	1,880	SF	\$4,436	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	111B	6	324	SF	\$764	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	111A	6	313	SF	\$739	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	111K	6	324	SF	\$764	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	112 student services	6	1,323	SF	\$3,122	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	112 nurse	6	477	SF	\$1,125	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	309 staff lounge	7	230	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	111D	6	350	SF	\$826	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	111C	6	378	SF	\$892	
Doors		Interior Steel Doors incl hw	Entire Building	6	64	EA	\$18,121	
Doors		Interior Steel Doors incl hw	Entire Building	7	54	EA	\$0	
Doors		Interior Wood Doors incl hw	Entire Building	7	62	EA	\$0	
Doors		Side-lite	Entire Building	7	51	SF	\$0	
Doors		Store Front Door	Entire Building	7	7	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Bleacher Seating	rm 101	7	68	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Ceiling - Exposed	rm 101	7	3,990	SF	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Flooring - Wood	rm 101	7	3,990	SF	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Lighting - Metal Halide/Sodium Vapor	rm 101	7	20	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Scoreboards	rm 101	5	1	EA	\$6,852	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Sound System	rm 101			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Stage Curtain	rm 101			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Concrete Block	rm 101	7	7,200	SF	\$0	
Kitchen	Cooking Kitchen	Ceiling - Lay-In	rm 122 Kitchen and 118A Dishwashing	7	1,520	SF	\$0	
Kitchen	Cooking Kitchen	Lighting - Lay-In	rm 122 Kitchen and 118A Dishwashing	7	21	SF	\$0	
Kitchen	Cooking Kitchen	Wall - Concrete Block	rm 122 Kitchen and 118A Dishwashing	7	2,529	SF	\$0	
Library	Library	Casework	211	7	343	LF	\$0	
Library	Library	Flooring Carpet	211	7	3,815	SF	\$0	
Library	Library	Lighting - Lay-In	211	7	33	SF	\$0	
Library	Library	Lighting - Lay-In	211	7	52	SF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st floor unisex south			LF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st floor girls south			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	112A2 and A3 toilet/ shower			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st floor boys north			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st floor unisex north			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st floor girls north			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd floor girls north			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd floor boys north			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd floor boys south			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	in 121			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd floor girls north			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st floor boys south			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	3rd floor unisex north			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd floor boys north			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	in 125			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd floor unisex north			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	in 108			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	mens rm in 122			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	womens rm in 122			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	in 104			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	in 115			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	in 111			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	3rd floor unisex south			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd floor unisex south			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd floor boys south			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd floor girls south			LF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd floor girls south			LF	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd floor unisex north			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd floor unisex south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd floor girls south			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	mens rm in 122			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st floor boys south			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st floor unisex south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st floor girls south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st floor boys north			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st floor unisex north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd floor boys south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd floor boys north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd floor girls north			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	womens rm in 122			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	in 115			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	in 104			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	in 108			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st floor girls north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd floor girls north			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	in 111			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd floor boys south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd floor boys north			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	3rd floor unisex south			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	3rd floor unisex north			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	112A2 and A3 toilet/ shower			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd floor girls south			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Lockers	in 121			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	in 125			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st floor girls north			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	mens rm in 122			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd floor boys south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	in 108			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	in 104			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	in 115			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	in 111			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	womens rm in 122			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd floor girls north			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st floor unisex north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd floor boys north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st floor girls south			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd floor unisex south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	in 125			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd floor girls south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st floor boys south			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st floor unisex south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st floor boys north			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd floor unisex north			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	112A2 and A3 toilet/ shower			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	3rd floor unisex north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd floor girls south			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	3rd floor unisex south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd floor boys south			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd floor boys north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd floor girls north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	in 121			EA	\$0	
Lunchroom	Lunchroom	Ceiling - Lay-In	rm 118	7	5,014	SF	\$0	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	rm 118	7	5,014	SF	\$0	
Lunchroom	Lunchroom	Lighting - Lay-In	rm 118	6	65	SF	\$46	
Lunchroom	Lunchroom	Serving Line	rm 118	7	46	LF	\$0	
Lunchroom	Cooking Kitchen	Serving Line	rm 122 Kitchen and 118A Dishwashing			LF	\$0	
Lunchroom	Lunchroom	Wall - Concrete Block	rm 118	7	3,840	SF	\$0	
Lunchroom	Lunchroom	Wall - Plaster/Drywall	rm 118	6	1,510	SF	\$3,563	
MDF/IDF		Finishes	220	7	145	SF	\$0	
MDF/IDF		Ventilation and Cooling	220	7	1	EA	\$0	
Mechanical/Service Rooms		Janitor's Closet	Entire Building	7	7	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	Entire Building	7	125	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	122F, 320, 320A, 226, 110A, 110B, 107B, 101C, 120	7	5,863	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	303	7	1,120	SF	\$0	
Mechanical/Service Rooms		Storage Room	326A	7	480	SF	\$0	
Mechanical/Service Rooms		Storage Room	adjacent to music room 326	7	350	SF	\$0	
Mechanical/Service Rooms		Storage Room	325A	7	225	SF	\$0	
Mechanical/Service Rooms		Storage Room	323	6	250	SF	\$1,180	
Mechanical/Service Rooms		Storage Room	318	6	365	SF	\$1,722	
Mechanical/Service Rooms		Storage Room	rm 101B - Gym Storage	7	228	SF	\$0	
Mechanical/Service Rooms		Storage Room	Rms 115B, 117 & 118B	7	580	SF	\$0	
Mechanical/Service Rooms		Storage Room	rm 128 - Yard Storage	7	270	SF	\$0	
Mechanical/Service Rooms		Storage Room	1st Floor	7	680	SF	\$0	
Mechanical/Service Rooms		Storage Room	218	7	255	SF	\$0	
Mechanical/Service Rooms		Storage Room	211A1	7	160	SF	\$0	
Mechanical/Service Rooms		Storage Room	203	7	155	SF	\$0	
Mechanical/Service Rooms		Storage Room	225A	7	225	SF	\$0	
Mechanical/Service Rooms		Storage Room	223	7	250	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st floor unisex north	7	61	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	in 115	7	68	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd floor girls south	7	300	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	3rd floor unisex south	7	61	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd floor boys south	7	300	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd floor boys north	7	300	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd floor girls north	7	300	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	3rd floor unisex north	7	61	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	112A2 and A3 toilet/ shower			SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	in 121	7	68	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	in 125	7	68	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	in 108	7	68	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	mens rm in 122	7	48	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor girls south	7	300	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	in 104	7	68	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd floor boys south	7	300	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	in 111	7	68	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd floor girls north	7	300	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd floor unisex north	7	61	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd floor boys north	7	300	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor girls north	7	300	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor boys north	7	300	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st floor unisex south	7	61	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor boys south	7	300	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd floor girls south	7	300	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd floor unisex south	7	61	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	womens rm in 122	7	48	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	2nd floor unisex south	7	61	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	in 104	7	68	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	3rd floor unisex south	7	61	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	in 121	7	68	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	in 125	7	68	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	3rd floor unisex north	7	61	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	in 108	7	68	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	in 115	7	68	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	in 111	7	68	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	womens rm in 122	7	48	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	112A2 and A3 toilet/ shower	7	42	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	2nd floor unisex north	7	61	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	1st floor unisex south	7	61	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	mens rm in 122	7	48	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	1st floor unisex north	7	61	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor boys south	7	300	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd floor girls north	7	300	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor boys south	7	300	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor girls south	7	300	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor girls south	7	300	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor boys north	7	300	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd floor girls south	6	300	SF	\$849	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd floor boys north	6	300	SF	\$849	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd floor boys south	7	300	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor girls north	7	300	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	112A2 and A3 toilet/ shower	7	43	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor girls north	7	300	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor boys north	7	300	SF	\$0	
Staff Restroom	Staff Restroom	Floor Drain	2nd floor unisex north	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd floor boys south	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	in 125	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	in 108	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	womens rm in 122	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	in 115	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	2nd floor unisex south	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd floor girls north	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	mens rm in 122	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd floor boys north	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor girls north	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st floor unisex north	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor boys north	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor girls south	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st floor unisex south	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd floor girls south	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	in 121	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	in 104	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor boys south	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	3rd floor unisex north	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd floor girls north	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	in 111	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd floor girls south	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	112A2 and A3 toilet/ shower			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd floor boys north	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd floor boys south	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	3rd floor unisex south	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Flooring - Concrete	mens rm in 122	7	48	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Concrete	womens rm in 122	7	48	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	1st floor boys south	7	100	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	2nd floor girls south	7	100	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	1st floor girls south	7	100	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	1st floor girls north	7	100	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	3rd floor girls south	7	100	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	2nd floor boys north	7	100	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	2nd floor girls north	7	100	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	3rd floor girls north	7	100	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	3rd floor boys north	7	100	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	3rd floor boys south	7	100	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	1st floor boys north	7	100	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	2nd floor boys south	7	100	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor unisex south	7	61	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor girls north	7	200	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	1st floor unisex north	7	61	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor boys north	7	200	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor girls south	7	200	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	1st floor unisex south	7	61	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor girls south	7	200	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor boys south	7	200	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor boys north	7	200	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	in 115	7	68	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor boys south	7	200	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd floor boys north	7	200	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor girls north	7	200	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor unisex north	7	61	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd floor boys south	7	200	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd floor girls south	7	200	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd floor girls north	7	200	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	3rd floor unisex north	7	61	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	112A2 and A3 toilet/ shower	7	85	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	in 121	7	68	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	in 125	7	68	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	in 108	7	68	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	in 104	7	68	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	in 111	7	68	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	3rd floor unisex south	7	61	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd floor girls north	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	1st floor unisex north			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd floor girls south	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	3rd floor unisex south			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd floor boys south	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd floor boys north	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	3rd floor unisex north			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Hand Dryer	112A2 and A3 toilet/ shower			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	in 121			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	in 125			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	mens rm in 122			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	in 108			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	in 104			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	womens rm in 122			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor boys south	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor girls south	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd floor boys south	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd floor girls south	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	1st floor unisex south			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor boys north	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor girls north	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd floor boys north	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd floor unisex north			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd floor girls north	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	in 111			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	in 115			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd floor unisex south			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	in 121	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	112A2 and A3 toilet/ shower			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd floor girls south	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	3rd floor unisex south	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd floor boys south	7	3	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd floor boys north	5	3	EA	\$5,577	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd floor girls north	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd floor unisex north	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd floor unisex south	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor girls south	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor boys south	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st floor unisex south	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor girls south	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor boys north	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st floor unisex north	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	3rd floor unisex north	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor boys north	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor boys south	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor girls north	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	in 111	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	in 115	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	in 104	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	in 108	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	womens rm in 122	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	mens rm in 122	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	in 125	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor girls north	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	mens rm in 122	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	in 111	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	2nd floor unisex south	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	2nd floor girls south	7	8	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st floor boys south	7	8	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st floor unisex south	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st floor girls south	7	8	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st floor boys north	7	8	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st floor unisex north	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st floor girls north	7	8	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	2nd floor boys north	7	8	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	2nd floor unisex north	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	2nd floor boys south	7	8	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	womens rm in 122	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	in 121	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	in 115	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	in 108	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	in 125	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	112A2 and A3 toilet/ shower	4	2	SF	\$7	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	in 104	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	3rd floor unisex north	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	3rd floor girls north	7	8	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	3rd floor boys north	7	8	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	3rd floor boys south	7	8	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	3rd floor unisex south	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	3rd floor girls south	7	8	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	2nd floor girls north	7	8	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	112A2 and A3 toilet/ shower	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor boys north	7	2	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Partitions	2nd floor unisex south			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd floor girls south	7	5	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	in 111			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	womens rm in 122			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd floor girls north	7	5	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	2nd floor unisex north			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd floor boys north	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	1st floor unisex north			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	in 115			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor girls south	7	5	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	1st floor unisex south			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor boys south	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	in 121			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd floor boys south	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd floor boys south	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor girls north	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd floor girls south	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd floor girls north	7	5	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	3rd floor unisex south			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	112A2 and A3 toilet/ shower			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd floor boys north	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	in 125			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	mens rm in 122			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	in 108			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	in 104			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	3rd floor unisex north			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Urinals	1st floor boys north	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st floor unisex north			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st floor girls south			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st floor girls north			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st floor unisex south			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st floor boys south	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd floor girls south			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd floor unisex south			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	mens rm in 122			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd floor boys north	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd floor girls south			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	in 125			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	in 108			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd floor unisex north			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd floor girls north			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	womens rm in 122			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	in 111			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	in 115			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	in 104			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	112A2 and A3 toilet/ shower			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	3rd floor unisex north			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd floor girls north			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd floor boys north	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	in 121			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	3rd floor unisex south			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd floor boys south	7	3	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd floor boys south	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	in 108	7	270	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	112A2 and A3 toilet/ shower	7	234	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	in 121	7	270	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	mens rm in 122	7	252	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	in 104	7	270	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	in 115	7	270	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	in 111	7	270	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	womens rm in 122	7	252	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	in 125	7	270	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd floor boys north	7	290	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st floor boys south	7	290	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd floor boys south	7	290	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd floor girls north	7	290	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd floor girls north	7	290	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd floor boys north	7	290	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st floor girls north	7	290	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd floor girls south	7	290	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st floor girls south	7	290	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd floor girls south	7	290	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd floor boys south	7	290	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st floor boys north	7	290	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	3rd floor boys south	7	605	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	1st floor unisex south	7	230	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	1st floor boys south	7	605	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	2nd floor girls south	7	605	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	2nd floor unisex south	7	230	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	2nd floor boys south	7	605	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	3rd floor unisex south	7	230	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	2nd floor boys north	7	605	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	3rd floor boys north	7	605	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	1st floor boys north	7	605	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	3rd floor girls south	7	605	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	1st floor unisex north	7	230	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	3rd floor girls north	7	605	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	1st floor girls south	7	605	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	2nd floor unisex north	7	230	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	2nd floor girls north	7	605	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	112A2 and A3 toilet/ shower	7	342	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	3rd floor unisex north	7	230	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	1st floor girls north	7	605	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	in 121	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd floor girls south	7	5	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	3rd floor unisex south	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd floor boys south	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd floor boys north	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd floor girls north	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor girls south	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor boys south	7	2	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Water Closet	2nd floor unisex south	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor girls south	7	5	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	3rd floor unisex north	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st floor unisex south	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	112A2 and A3 toilet/ shower	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor boys north	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st floor unisex north	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor girls north	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor boys north	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	in 108	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor boys south	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd floor unisex north	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	mens rm in 122	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	in 104	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	in 115	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	in 111	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	womens rm in 122	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor girls north	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	in 125	7	1	EA	\$0	
Vertical Conveyance		Elevator - Roped Holeless Hydraulic	Entire Building	7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	3	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0	
INTERIOR Sub Total							\$52,894	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
ADMIN_FLOOR	Administrative Suites/Offices	Administrative Office Floor	rm 122A - Kitchen office	7	80	SF	\$0	
Casework	Classroom	Casework		7	48	LF	\$0	
Casework	Classroom	Casework		7	48	LF	\$0	
Casework	Classroom	Casework		7	21	LF	\$0	
Casework	Classroom	Casework		7	10	LF	\$0	
Casework	Classroom	Casework		7	10	LF	\$0	
Casework	Classroom	Casework		7	10	LF	\$0	
Casework	Classroom	Casework		7	10	LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework		7	95	LF	\$0	
Casework	Classroom	Casework		7	38	LF	\$0	
Casework	Classroom	Casework		7	48	LF	\$0	
Casework	Classroom	Casework		7	48	LF	\$0	
Casework	Classroom	Casework		7	48	LF	\$0	
Casework	Classroom	Casework		7	48	LF	\$0	
Casework	Classroom	Casework		7	108	LF	\$0	
Casework	Classroom	Casework		6	25	LF	\$894	
Casework	Classroom	Casework		7	10	LF	\$0	
Casework	Classroom	Casework		7	38	LF	\$0	
Casework	Classroom	Casework		7	48	LF	\$0	
Casework	Classroom	Casework		7	48	LF	\$0	
Casework	Classroom	Casework		7	48	LF	\$0	
Casework	Classroom	Casework		7	48	LF	\$0	
Casework	Classroom	Casework		7	48	LF	\$0	
Casework	Classroom	Casework		7	18	LF	\$0	
Casework	Classroom	Casework		7	53	LF	\$0	
Casework	Classroom	Casework		7	48	LF	\$0	
Casework	Classroom	Casework		7	48	LF	\$0	
Casework	Classroom	Casework		7	48	LF	\$0	
Casework	Classroom	Casework		7	48	LF	\$0	
Casework	Classroom	Casework		7	48	LF	\$0	
Casework	Classroom	Casework		7	48	LF	\$0	
Casework	Classroom	Casework		7	48	LF	\$0	
Casework	Classroom	Casework		7	38	LF	\$0	
Ceiling	Classroom	Exposed Ceiling		7	1,980	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Ceiling	Classroom	Lay-In/Drop		7	800	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,215	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	585	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,580	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	830	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	830	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	830	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	640	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,005	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,215	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,215	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,215	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	830	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,215	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,640	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	270	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	830	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	830	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	585	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	585	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	830	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	830	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	830	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	830	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	830	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,640	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	830	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,005	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	830	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	830	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	195	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	30	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	195	SF	\$0	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Lunchroom	Chalk Board	rm 118	4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
CLASSROOM	Classroom	Eye Wash Station		7	2	EA	\$0	
Corridors	Corridors	Concrete Block	Center Stairs	7	3,485	SF	\$0	
Corridors	Corridors	Concrete Block	C stairs (North)	7	2,810	SF	\$0	
Corridors	Corridors	Concrete Block	1st Floor	7	1,206	SF	\$0	
Corridors	Corridors	Concrete Block	B stairs (South)	7	2,870	SF	\$0	
Corridors	Corridors	Drinking Fountains	2nd Floor	7	6	EA	\$0	
Corridors	Corridors	Drinking Fountains	C stairs (North)			EA	\$0	
Corridors	Corridors	Drinking Fountains	B stairs (South)			EA	\$0	
Corridors	Corridors	Drinking Fountains	Center Stairs			EA	\$0	
Corridors	Corridors	Drop/Lay-In	C stairs (North)	7	591	SF	\$0	
Corridors	Corridors	Drop/Lay-In	3rd Floor	7	5,738	SF	\$0	
Corridors	Corridors	Drop/Lay-In	Center Stairs	7	1,481	SF	\$0	
Corridors	Corridors	Drop/Lay-In	2nd Floor	7	7,200	SF	\$0	
Corridors	Corridors	Drop/Lay-In	1st Floor	7	4,958	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Drop/Lay-In	B stairs (South)	7	591	SF	\$0	
Corridors	Corridors	Lay-In	B stairs (South)	7	591	EA	\$0	
Corridors	Corridors	Lay-In	1st Floor	7	5,698	EA	\$0	
Corridors	Corridors	Lay-In	2nd Floor	7	7,470	EA	\$0	
Corridors	Corridors	Lay-In	3rd Floor	7	6,008	EA	\$0	
Corridors	Corridors	Lay-In	C stairs (North)	7	591	EA	\$0	
Corridors	Corridors	Lay-In	Center Stairs	7	1,481	EA	\$0	
Corridors	Corridors	Plaster/Drywall	B stairs (South)	6	130	SF	\$307	
Corridors	Corridors	Plaster/Drywall	C stairs (North)	6	130	SF	\$307	
Corridors	Corridors	Single Water Cooler	3rd Floor	5	2	EA	\$6,149	
Corridors	Corridors	Single Water Cooler	3rd Floor	7	4	EA	\$0	
Corridors	Corridors	Single Water Cooler	1st Floor	7	5	EA	\$0	
Corridors	Corridors	Single Water Cooler	1st Floor	7	6	EA	\$0	
Corridors	Corridors	Stair Handrails	2nd Floor	7	102	LF	\$0	
Corridors	Corridors	Stair Handrails	1st Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	3rd Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	Center Stairs	7	168	LF	\$0	
Corridors	Corridors	Stair Handrails	C stairs (North)	7	119	LF	\$0	
Corridors	Corridors	Stair Handrails	B stairs (South)	7	119	LF	\$0	
Corridors	Corridors	Stairs	2nd Floor			EA	\$0	
Corridors	Corridors	Stairs	1st Floor			EA	\$0	
Corridors	Corridors	Stairs	3rd Floor			EA	\$0	
Corridors	Corridors	Student Lockers	3rd Floor	7	309	EA	\$0	
Corridors	Corridors	Student Lockers	C stairs (North)			EA	\$0	
Corridors	Corridors	Student Lockers	B stairs (South)			EA	\$0	
Corridors	Corridors	Student Lockers	1st Floor			EA	\$0	
Corridors	Corridors	Student Lockers	2nd Floor			EA	\$0	
Corridors	Corridors	Student Lockers	Center Stairs			EA	\$0	
Corridors	Corridors	Terrazzo	1st Floor	7	7,300	SF	\$0	
Corridors	Corridors	Terrazzo	3rd Floor	7	6,008	SF	\$0	
Corridors	Corridors	Terrazzo	C stairs (North)	7	577	SF	\$0	
Corridors	Corridors	Terrazzo	B stairs (South)	7	577	SF	\$0	
Corridors	Corridors	Terrazzo	Center Stairs	7	1,243	SF	\$0	
Corridors	Corridors	Terrazzo	2nd Floor	7	5,870	SF	\$0	
Corridors	Corridors	Wall Mounted	C stairs (North)	7	349	EA	\$0	
Corridors	Corridors	Wall Mounted	B stairs (South)	7	349	EA	\$0	
Corridors	Corridors	Walls	1st Floor	7	7,578	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Walls	1st Floor	7	450	SF	\$0	
Corridors	Corridors	Walls	2nd Floor	7	6,990	SF	\$0	
Corridors	Corridors	Walls	2nd Floor	7	663	SF	\$0	
Corridors	Corridors	Walls	2nd Floor	7	248	SF	\$0	
Corridors	Corridors	Walls	3rd Floor	7	7,353	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	1st Floor	7	740	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	2nd Floor	7	270	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	3rd Floor	7	270	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	C stairs (North)	7	349	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	B stairs (South)	7	349	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	Center Stairs	7	361	SF	\$0	
Stairs	Corridors	Terrazzo	C stairs (North)	7	52	SF	\$0	
Stairs	Corridors	Terrazzo	Center Stairs	7	52	SF	\$0	
Stairs	Corridors	Terrazzo	B stairs (South)	7	52	SF	\$0	
Floor	Classroom	Tile/Sheet		7	830	SF	\$0	
Floor	Classroom	Tile/Sheet		7	830	SF	\$0	
Floor	Classroom	Tile/Sheet		7	830	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,005	SF	\$0	
Floor	Classroom	Tile/Sheet		7	830	SF	\$0	
Floor	Classroom	Tile/Sheet		7	585	SF	\$0	
Floor	Classroom	Tile/Sheet		7	830	SF	\$0	
Floor	Classroom	Tile/Sheet		7	830	SF	\$0	
Floor	Classroom	Tile/Sheet		7	830	SF	\$0	
Floor	Classroom	Tile/Sheet		7	830	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,580	SF	\$0	
Floor	Classroom	Tile/Sheet		7	830	SF	\$0	
Floor	Classroom	Tile/Sheet		7	585	SF	\$0	
Floor	Classroom	Tile/Sheet		7	830	SF	\$0	
Floor	Classroom	Tile/Sheet		7	830	SF	\$0	
Floor	Classroom	Tile/Sheet		7	830	SF	\$0	
Floor	Classroom	Tile/Sheet		7	585	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,215	SF	\$0	
Floor	Classroom	Tile/Sheet		7	2,250	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,835	SF	\$0	
Floor	Classroom	Tile/Sheet		6	1,005	SF	\$1,437	
Floor	Classroom	Tile/Sheet		7	830	SF	\$0	
Floor	Classroom	Tile/Sheet		7	830	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,835	SF	\$0	
Floor	Classroom	Tile/Sheet		7	640	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Floor	Classroom	Tile/Sheet		7	1,215	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,215	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,215	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,215	SF	\$0	
Floor	Classroom	Tile/Sheet		7	830	SF	\$0	
KITCHEN_FLOOR	Cooking Kitchen	Kitchen Floor	rm 122 Kitchen and 118A Dishwashing	7	1,520	SF	\$0	
LIBRARY_CEILING	Library	Drop/Lay-In	211	7	2,695	SF	\$0	
LIBRARY_CEILING	Library	Plaster/Drywall	211	7	1,120	SF	\$0	
LIBRARY_WALL	Library	Mansory	211	7	3,100	SF	\$0	
LIBRARY_WALL	Library	Plaster/Drywall	211	7	1,200		\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	18	EA	\$0	
Lighting	Classroom	Lay-In		7	9	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		6	24	EA	\$1,716	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	6	EA	\$0	
Lighting	Classroom	Lay-In		7	14	EA	\$0	
Lighting	Classroom	Lay-In		7	14	EA	\$0	
Lighting	Classroom	Lay-In		7	14	EA	\$0	
Lighting	Classroom	Lay-In		7	14	EA	\$0	
Lighting	Classroom	Lay-In		7	14	EA	\$0	
Lighting	Classroom	Lay-In		7	14	EA	\$0	
Lighting	Classroom	Lay-In		7	18	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		6	12	EA	\$858	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		6	12	EA	\$858	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	6	EA	\$0	
Lighting	Classroom	Lay-In		7	9	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	6	EA	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	45	EA	\$0	
LUNCH_WALL	Lunchroom	Lunchroom Walls	rm 118	7	1,200	SF	\$0	
Marker Board	Lunchroom	Marker Board	rm 118			LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Wall	Classroom	Concrete Block		7	1,270	SF	\$0	
Wall	Classroom	Concrete Block		7	1,270	SF	\$0	
Wall	Classroom	Concrete Block		7	260	SF	\$0	
Wall	Classroom	Concrete Block		7	550	SF	\$0	
Wall	Classroom	Concrete Block		7	550	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Concrete Block		7	550	SF	\$0	
Wall	Classroom	Concrete Block		7	550	SF	\$0	
Wall	Classroom	Concrete Block		7	930	SF	\$0	
Wall	Classroom	Concrete Block		7	380	SF	\$0	
Wall	Classroom	Concrete Block		7	560	SF	\$0	
Wall	Classroom	Concrete Block		7	550	SF	\$0	
Wall	Classroom	Concrete Block		7	810	SF	\$0	
Wall	Classroom	Concrete Block		7	810	SF	\$0	
Wall	Classroom	Concrete Block		7	340	SF	\$0	
Wall	Classroom	Concrete Block		7	1,385	SF	\$0	
Wall	Classroom	Concrete Block		7	1,385	SF	\$0	
Wall	Classroom	Concrete Block		7	1,375	SF	\$0	
Wall	Classroom	Concrete Block		7	1,037	SF	\$0	
Wall	Classroom	Concrete Block		7	1,270	SF	\$0	
Wall	Classroom	Concrete Block		7	810	SF	\$0	
Wall	Classroom	Concrete Block		7	1,680	SF	\$0	
Wall	Classroom	Concrete Block		7	520	SF	\$0	
Wall	Classroom	Concrete Block		7	550	SF	\$0	
Wall	Classroom	Concrete Block		7	550	SF	\$0	
Wall	Classroom	Concrete Block		7	550	SF	\$0	
Wall	Classroom	Concrete Block		7	550	SF	\$0	
Wall	Classroom	Concrete Block		7	930	SF	\$0	
Wall	Classroom	Concrete Block		7	3,310	SF	\$0	
Wall	Classroom	Metal/Folding Panel		7	270	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	105	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	760	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	105	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	60	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	520	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	520	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	520	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	520	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	260	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	520	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	260	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	520	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	260	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Plaster/Drywall		7	260	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	260	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	60	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	338	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	105	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	580	SF	\$1,369	
Wall	Classroom	Plaster/Drywall		7	260	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	510	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	520	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	520	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	520	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	520	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	960	SF	\$0	
ROOM Sub Total							\$13,894	
Building Main Sub Total							\$115,051	

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Civil/Drainage		Catch Basin	Entire Site	7	9	EA	\$0	
Civil/Drainage		Site Drain	Site - East	7	1	EA	\$0	
Civil/Drainage		Site Manhole	Entire Site	7	3	EA	\$0	
Fencing		Ornamental Iron	Entire Site	7	1,440	LF	\$0	
Landscape		Benches	Entire Site	7	13	EA	\$0	
Landscape		Grass	Site ζ West	7	83,270	SF	\$0	
Landscape		Hardscape - Concrete	Entire Site	7	8,488	SF	\$0	
Landscape		Parkway trees	Entire Site	7	56	EA	\$0	
Landscape		Planting Beds/ Areas	site east and west	7	7,740	SF	\$0	
Landscape		Trash Receptacles	Entire Site	7	3	EA	\$0	
Landscape		Trash Receptacles	site NW	4	1	EA	\$1,645	damaged with no liner
Landscape		Walking Path - Crushed Stone	Site ζ North	7	430	SF	\$0	
Parking Lot		Asphalt	Site ζ North	7	20,064	SF	\$0	
Parking Lot		Concrete Curbs	north lot	7	700	LF	\$0	
Parking Lot		Parking lot interior plantings	north lot	7	7	LF	\$0	
Parking Lot		Trash Compactor	Site ζ North	7	1	EA	\$0	

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Parking Lot		Trash Enclosure	Site ζ North	7	1,056	SF	\$0	
Parking Lot		Vehicular Screening	north lot	7	230	LF	\$0	
Playground		Playground Equipment - Combo 3-12	Site ζ South	7	1	EA	\$0	
Playground		Playground Surfacing - Poured Surface	Site ζ South	7	2,690	SF	\$0	
Sidewalks		Internal Walks	N parking lot, S playlot	7	840	LF	\$0	
Sidewalks		Perimeter Sidewalks	Entire Site	7	14,650	SF	\$0	
Signage		Flag Pole	Site - East	7	2	EA	\$0	
Signage		Marquee - Free Standing Back Lighted w/ LED	Site - East	7	1	EA	\$0	
Signage		Monument Sign - Lighted	site NE	7	1	EA	\$0	
SITE Sub Total							\$1,645	
SITE Sub Total							\$1,645	

Total Campus Need ^{2 3} \$116,695

¹ It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

² As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

³ The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Building: Main														
102	640	1	1	4	40	41	8		N	N	N	Classroom		
104	1215	1	8	34	40	81	17		N	N	Y	Classroom		
108	1215	1	4	24	40	81	17		N	Y	Y	Classroom		
115	1215	1	6	26	40	81	17		N	Y	N	Classroom		
121	1215		2	16	40	81	17		N	Y	Y	Classroom		
125	1215	1	6	28	40	81	17		N	Y	Y	Classroom		
202	585	1	6	24	40	42	12		N	Y	Y	Classroom		
204	830	1	6	24	40	56	16		N	Y	Y	Classroom		
206	830	1	6	24	40	56	16		N	Y	Y	Classroom		
208	830	1	8	24	40	56	16		N	Y	Y	Classroom		
210	830	1	8	24	40	56	16		N	Y	Y	Classroom		
212	1005	4	49	198	40	56	16		N	Y	Y	Classroom		
215/217	1580	2	16	66	40	112	32		N	N	Y	Classroom		
223	830	1	6	24	40	56	16		N	Y	Y	Classroom		
225	1835	1	6	26	40	270	8		N	Y	Y	Classroom		
302	585	1	6	24	40	42	12		N	Y	Y	Classroom		
304	830	1	6	24	40	56	16		N	Y	Y	Classroom		
306	830	1	6	24	40	56	16		N	Y	Y	Classroom		
308	830	1	8	24	40	56	16		N	Y	Y	Classroom		
310	830	1	8	24	40	56	16		N	N	Y	Classroom		
311	830	1	8	24	40	232			N	Y	Y	Classroom		
312	1005	1	8	36	40	56	16		N	N	Y	Classroom		
313	585	1	6	24	40	220			N	N	Y	Classroom		
315	830	1	8	24	40	56	16		N	Y	Y	Classroom		
317	830	1	8	24	40	56	16		N	Y	Y	Classroom		
321	830	1	8	24	40	56	16		N	Y	Y	Classroom		
325	1835	1	6	26	40	270	8		N	Y	Y	Classroom		
326	2250	2	10	36	40	475			N	N	N	Classroom		
Other	275			10					N	N	N	Administrative Suites/Offices		211A library work room
Other	61								N	N	N	Restroom	Staff Restroom	3rd floor unisex north
Other	3815								N	N	N	Library		211
Other	300								N	N	N	Restroom	Children's Standard Student Restroom	2nd floor boys north
Other	61								N	N	N	Restroom	Staff Restroom	2nd floor unisex north
Other	300								N	N	N	Restroom	Children's Standard Student Restroom	2nd floor girls north
Other									N	N	N	Corridors		C stairs (North)
Other	300								N	N	N	Restroom	Children's Standard Student Restroom	1st floor girls south

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	300								N	N	N	Restroom	Children's Standard Student Restroom	3rd floor girls north
Other	300								N	N	N	Restroom	Children's Standard Student Restroom	3rd floor boys north
Other	605			18					N	N	N	Administrative Suites/Offices		309 staff lounge
Other	300								N	N	N	Restroom	Children's Standard Student Restroom	3rd floor boys south
Other	61								N	N	N	Restroom	Staff Restroom	3rd floor unisex south
Other	300								N	N	N	Restroom	Children's Standard Student Restroom	3rd floor girls south
Other									N	N	N	Corridors		B stairs (South)
Other	5014								N	N	N	Lunch & Multipurpose Room	Lunchroom	rm 118
Other	68								N	N	N	Restroom	Children's Standard Student Restroom	in 121
Other	68								N	N	N	Restroom	Children's Standard Student Restroom	in 125
Other	68								N	N	N	Restroom	Children's Standard Student Restroom	in 108
Other	68								N	N	N	Restroom	Children's Standard Student Restroom	in 104
Other	68								N	N	N	Restroom	Children's Standard Student Restroom	in 115
Other	68								N	N	N	Restroom	Staff Restroom	in 111
Other	61								N	N	N	Restroom	Staff Restroom	1st floor unisex north
Other	150			10					N	N	N	Administrative Suites/Offices		Rm 101A - Gym office
Other	190			10					N	N	Y	Administrative Suites/Offices		111D
Other	1520								N	N	N	Kitchen	Cooking Kitchen	rm 122 Kitchen and 118A Dishwashing
Other	228			16					N	N	Y	Administrative Suites/Offices		rm 126 - Engineer's office
Other	7300								N	N	N	Corridors		1st Floor
Other	80			10					N	N	N	Administrative Suites/Offices		rm 122A - Kitchen office
Other	5870								N	N	N	Corridors		2nd Floor
Other	48								N	N	N	Restroom	Staff Restroom	mens rm in 122
Other	48								N	N	N	Restroom	Staff Restroom	womens rm in 122
Other	3990								N	N	N	Gymnasia	Standard Dedicated Gymnasium	rm 101
Other	643			26					N	N	Y	Administrative Suites/Offices		112 student services
Other	300								N	N	N	Restroom	Children's Standard Student Restroom	1st floor girls north
Other	300								N	N	N	Restroom	Children's Standard Student Restroom	1st floor boys north
Other	6008								N	N	N	Corridors		3rd Floor
Other	61								N	N	N	Restroom	Staff Restroom	1st floor unisex south
Other	300								N	N	N	Restroom	Children's Standard Student Restroom	1st floor boys south
Other	300								N	N	N	Restroom	Children's Standard Student Restroom	2nd floor girls south
Other	61								N	N	N	Restroom	Staff Restroom	2nd floor unisex south
Other	1340			28					N	N	Y	Administrative Suites/Offices		111 business office
Other	475			18					N	N	N	Administrative Suites/Offices		112 nurse
Other	123			4					N	N	N	Administrative Suites/Offices		1111
Other	85								N	N	N	Restroom	Staff Restroom	112A2 and A3 toilet/ shower

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	150			14					N	N	Y	Administrative Suites/Offices		111K
Other	125			8					N	N	N	Administrative Suites/Offices		111E
Other	150			10					N	N	Y	Administrative Suites/Offices		111A
Other	410			12					N	N	Y	Administrative Suites/Offices		111C
Other	248			14					N	N	Y	Administrative Suites/Offices		111B
Other									N	N	N	Corridors		Center Stairs
Other	300								N	N	N	Restroom	Children's Standard Student Restroom	2nd floor boys south