

Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx.

Condition Rankings and Descriptions

- Rank 7:** The item/system is new or in good condition and no work is required.
- Rank 6:** The item/system requires general cleaning and/or routine maintenance.
- Rank 5:** The item/system requires repairs and has not reached the end of its serviceable life.
- Rank 4:** The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.
- Rank 3:** The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.
- Rank 2:** The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.
- Rank 1:** The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.¹

Definitions

- Quantity** means, for each item, the total number (or amount) of that item that exists and was evaluated.
- Unit** means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").
- Cost** means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.
- For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.**
- Total Campus Need** also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

Building: Main Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Canopy		Concrete/ Stucco Canopy	East and North Entrances	6	240	SF	\$6,795	
Canopy		Concrete/ Stucco Canopy	West Entry, Bris Soleil	5	4,400	SF	\$411,119	
Chimney		Brick Chimney - Stainless Steel Liner	North Wing	6	42	LF	\$21,021	
Chimney		Metal Flue	North Wing	6	5	LF	\$322	
Doors		Exterior FRP Door	East kindergarten and West Cafeteria	6	3	EA	\$1,671	
Doors		Exterior Steel Door	West Boiler Room and Kitchen	6	3	EA	\$991	
Doors		Exterior Wood Door	Gym at West	5	2	EA	\$2,118	
Doors		Side Lite	North, West, and main east	6	70	EA	\$15,856	
Doors		Store Front Door	North, West, and Main East	6	10	EA	\$5,191	
Doors		Transom Lite	Entire Building	6	136	EA	\$38,507	
Entrance		Concrete Exterior Stairs	Entire Building	6	186	LF	\$19,949	
Entrance		Concrete Exterior Stairs	Main Entrance	7	36	LF	\$0	
Entrance		Concrete Ramp	Exterior Storage	6	9	LF	\$1,255	

Building: Main
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Entrance		Concrete Ramp	Main Entrance	7	37	LF	\$0	
Entrance		Entrance Controls - Audio	Main Entrance	6	1	EA	\$429	
Entrance		Ramp Handrails	Main Entrance	7	75	LF	\$0	
Entrance		Ramp Handrails	Exterior Storage	6	18	LF	\$0	
Entrance		Stair Handrails	Entire Building	6	75	LF	\$0	
Entrance		Stair Handrails	Main Entrance	7	25	LF	\$0	
Entrance		Stone Stairs	Entrance 4	6	10	LF	\$1,788	
Foundation		Concrete Foundation	Basement	7	920	LF	\$0	
Lighting		Exterior Lights - Parapet or Roof Mounted	Roof	5	1	EA	\$1,430	
Lighting		Exterior Lights - Parapet or Roof Mounted	Roof	6	7	EA	\$3,504	
Lintels		Lintels - Steel	Entire Building	6	115	LF	\$4,341	
Parapet		Coping - Metal	Roofs	7	1,250	LF	\$0	
Roof System		Exterior Downspouts	Over boiler Room Roof	7	12	LF	\$0	
Roof System		Interior Downspouts	Entire Building	6	260	LF	\$0	
Roof System		Modified Bitumen Roof	Roofs	6	27,500	SF	\$194,659	
Roof System		Roof Structure: Concrete	Roofs	7	27,500	SF	\$0	
Superstructure		Concrete	Entire Building	7	61,055	SF	\$0	
Walls		Brick	Entire Building	7	15,475	SF	\$0	
Walls		Brick	West Facade by playlot	6	270	SF	\$1,784	
Walls		Prefabricated Metal Panel Wall	Above and Below windows 2nd and 2rd fl	6	6,625	SF	\$56,274	
Walls		Stone - Cut	at main entries 1 and 2	7	200	SF	\$0	
Windows		Curtain wall - Glazed Double Pane	Stair Wells at North, East, West	6	860	SF	\$8,117	
Windows		Curtain wall - Insulated panel	Stair Wells at North, East, West	6	660	SF	\$6,229	
Windows		Window - Guards perforated	Entire Building	6	4,785	SF	\$0	
Windows		Window - Guards wire guard	West Elevation Gym	6	315	SF	\$0	
Windows		Windows - Sash Aluminum Double-pane	Entire Building	6	9,000	SF	\$77,220	
EXTERIOR Sub Total							\$880,568	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	1st Floor Next to Stage Area	4	1	EA	\$8,866	
Emergency System		Automatic Transfer switch	Electrical Room	4	1	EA	\$8,866	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	6	12,028	SF	\$5,160	
Emergency System		Emergency A/C power - Gym and Lunch rooms	1st Floor	6	5,364	SF	\$2,838	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Emergency A/C power - Students Toilets	Entire Building	6	2,087	SF	\$895	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	2	17	EA	\$15,802	No Battery backup
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st Floor	2	8	EA	\$7,436	No Battery backup
Emergency System		Independent Electrical Service for emergency power	Electrical Room	4	1	EA	\$17,160	
Emergency System		Public Announcement System	Main Office	6	61,055	SF	\$36,670	
Emergency System		Security System - Intrusion detection	Boiler Room	6	61,055	SF	\$56,751	
Main Service		Main Electrical service 1600 A 120/240/3PH	Electrical Room	4	1	EA	\$130,416	
Power Distribution		Lighting and power panels	Boiler Room	5	3	EA	\$6,435	
Power Distribution		Lighting and power panels	Entire Building	6	15	EA	\$10,725	
Power Distribution		Main distribution panels 400-600 amp	Boiler Room	6	1	EA	\$1,430	
ELECTRICAL Sub Total							\$309,449	

Building: Main
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Entire Building	6	61,055	SF	\$21,827	
Fire Alarm		Fire Alarm System	Electrical Room	5	64,100	SF	\$139,328	
FIRE PROTECTION Sub Total							\$161,155	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Window A/C Unit	Entire Building	6	10	EA	\$2,145	
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water 8,001 to 12,000 cfm	2nd Floor Mechanical room	5	1	EA	\$21,450	
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water less than 4,000 cfm	Boiler Room	5	1	EA	\$10,010	
Air Handling Systems		Air intake for all Air Handling Units except built up AHU	Roof	4	1	EA	\$7,436	
Air Handling Systems		Air intake for all Air Handling Units except built up AHU	Boiler room Wall	4	1	EA	\$7,436	
Boiler Systems		Boiler Assembly - Steam - Low Pressure Scotch Marine Boiler 101-150 HP	Boiler Room	4	2	EA	\$294,580	
Boiler Systems		Boiler Auxiliary - Steam Boiler 101-150 HP	Boiler Room	4	2	EA	\$45,760	
Boiler Systems		Combustion Dampers	Boiler Room	4	2	EA	\$11,154	
Boiler Systems		Feed Water Pumps and Tank - Steam Boilers	Boiler Room	4	1	EA	\$31,460	
Boiler Systems		Gas Boosters	Boiler Room	6	2	EA	\$2,603	
Heat Exchangers		Heat Exchanger - Steam to Hot Water Shell Type	Boiler Room	4	1	EA	\$21,164	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Heating Devices		Cabinet Heaters With Hot Water Coils	Gym Vestibule	4	1	EA	\$5,148	
Heating Devices		Cabinet Heaters With Hot Water Coils	Entire Building	5	16	EA	\$29,744	
Heating Devices		Fin Tube Hot Water	Nurse' Office	6	8	LF	\$137	
Heating Devices		Wall Heater - Electric	Entire Building	6	3	EA	\$309	
Heating Devices		Wall Heater - Electric	1st Floor Storage Room; Women's Toilet	4	2	EA	\$2,059	
Mechanical Plumbing		Condensate Assembly - Pumps and Tank	Boiler Room	4	1	EA	\$28,600	
Mechanical Plumbing		Piping - Condensate - Steel or Galvanized	Boiler Room	4	300	LF	\$29,387	
Mechanical Plumbing		Piping - Hydronic Supply and Return - Steel or Galvanized	Entire Building	4	300	LF	\$35,929	
Mechanical Plumbing		Piping - Steam - Steel or Galvanized	Boiler Room	4	300	LF	\$35,929	
Mechanical Plumbing		Pumps - Hot Water 11 to 20 HP	Boiler Room	4	2	EA	\$53,625	
Temperature Control		Pneumatic System	Entire Building	5	61,055	SF	\$261,926	
Temperature Control		Thermostats - Pneumatic	Entire Building	4	49	EA	\$32,232	
Unit Ventilation		Unit Ventilators - Hot Water-Heating	Entire Building	5	47	EA	\$336,050	
Ventilation		Exhaust Fan - Indoor	Electrical Room	4	1	EA	\$5,577	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Main Roof	6	1	EA	\$429	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Main Roof	5	1	EA	\$1,502	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Main Roof	6	1	EA	\$229	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Main Roof	5	3	EA	\$3,861	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Lower Roof	5	2	EA	\$2,574	
Ventilation		Exhaust Fans - Roof mounted less than 500 CFM	Lower Roof	5	2	EA	\$2,059	
Ventilation		Type I Exhaust Hood - Kitchen or Culinary Arts	Kitchen	2	1	EA	\$26,884	Hood does not cover entire stove area
Ventilation		Type I Exhaust Hood - Kitchen or Culinary Arts	Kitchen	6	1	EA	\$1,716	
MECHANICAL Sub Total							\$1,351,103	

Building: Main
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas 150,000 -300,000 BTU/HR	Boiler Room	6	1	EA	\$4,147	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	6	61,055	SF	\$6,985	
Piping		Domestic Piping - Cold Water Risers	Entire Building	4	61,055	SF	\$39,289	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	6	61,055	SF	\$9,604	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	4	61,055	SF	\$27,939	
Piping		Domestic Piping - Hot Water Risers	Entire Building	4	61,055	SF	\$33,177	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	4	61,055	SF	\$145,805	

Building: Main
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	4	61,055	SF	\$120,486	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	4	61,055	SF	\$69,847	
Piping		Sanitary Piping	Entire Building	5	61,055	SF	\$37,543	
Piping		Storm Piping	Entire Building	5	61,055	SF	\$28,812	
Piping		Vent Piping	Entire Building	5	61,055	SF	\$21,827	
Pumps		Sump Pump	Boiler Room	4	1	EA	\$11,869	
PLUMBING Sub Total							\$557,330	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Principals Office in main office	7	160	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	1st fl office FP nurses office	6	126	SF	\$357	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Engineers Office in Boiler Room	6	84	SF	\$238	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Main Office 1st fl	6	353	SF	\$999	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Gym Office in gym	7	103	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Splined	3rd floor teachers lounge	6	230	SF	\$493	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Main Office 1st fl	6	353	SF	\$505	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Principals Office in main office	7	160	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Gym Office in gym	7	103	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	1st fl office FP nurses office	5	126	SF	\$714	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	3rd floor teachers lounge	6	230	SF	\$329	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Engineers Office in Boiler Room	6	84	SF	\$120	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Gym Office in gym	4	2	SF	\$9	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Engineers Office in Boiler Room	4	2	SF	\$9	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	3rd floor teachers lounge	6	1	SF	\$1	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Main Office 1st fl	4	1	SF	\$7	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Main Office 1st fl	7	6	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	1st fl office FP nurses office	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	3rd floor teachers lounge	7	3	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Principals Office in main office	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Principals Office in main office	7	370	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Main Office 1st fl	7	467	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Engineers Office in Boiler Room	6	296	SF	\$847	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Gym Office in gym	7	303	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	1st fl office FP nurses office	6	339	SF	\$970	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	3rd floor teachers lounge	6	570	SF	\$1,630	
Drinking Fountains	Corridors	Double Fountain	3rd floor SW	7	1	EA	\$0	
Drinking Fountains	Corridors	Double Fountain	2nd Floor	7	2	EA	\$0	
Drinking Fountains	Corridors	Double Fountain	1st Floor	5	2	EA	\$6,578	
Drinking Fountains	Corridors	Single Fountain	1st Floor	7	3	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	3rd floor NE	6	1	EA	\$386	
Gymnasium / Auditorium	Gymnasium.Auditorium	Bleacher Seating	1st Floor			EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Ceiling - Plaster/Drywall	1st Floor	6	4,196	SF	\$35,882	
Gymnasium / Auditorium	Gymnasium.Auditorium	Flooring - Tile/Sheet	1st Floor	6	3,449	SF	\$4,932	
Gymnasium / Auditorium	Gymnasium.Auditorium	Flooring - Tile/Sheet	1st Floor	7	53	SF	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Flooring - Wood	1st Floor	5	694	SF	\$11,135	
Gymnasium / Auditorium	Gymnasium.Auditorium	Lighting - Lay-In	1st Floor	4	4	SF	\$19	
Gymnasium / Auditorium	Gymnasium.Auditorium	Lighting - Metal Halide/Sodium Vapor	1st Floor	6	15	EA	\$2,681	
Gymnasium / Auditorium	Gymnasium.Auditorium	Lighting - Pendant/Surface	1st Floor	7	1	EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Lighting - Pendant/Surface	1st Floor	4	2	EA	\$1,830	
Gymnasium / Auditorium	Gymnasium.Auditorium	Scoreboards	1st Floor	7	1	EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Sound System	1st Floor			EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Stage Curtain	1st Floor	7	8	EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Walls - Concrete Block	1st Floor	6	5,235	SF	\$44,916	
Kitchen	Cooking Kitchen	Ceiling - Plaster/Drywall	1st Floor	6	540	SF	\$2,039	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Kitchen	Cooking Kitchen	Flooring - Tile Ceramic/Porcelain	1st Floor	7	43	SF	\$0	
Kitchen	Cooking Kitchen	Flooring - Tile Quarry	1st Floor	6	497	SF	\$1,713	
Kitchen	Cooking Kitchen	Lighting - Pendant/Surface	1st Floor	6	15	SF	\$11	
Kitchen	Cooking Kitchen	Wall - Structural Glazed Tile	1st Floor	7	927	SF	\$0	
Library		Casework	2nd floor library	6	162	LF	\$4,969	
Library	Library	Ceiling - Splined	200, 201,202	6	2,240	SF	\$4,805	
Library	Library	Flooring Carpet	200, 201,202	6	2,240	SF	\$3,203	
Library	Library	Lighting - Pendant/ Surface	200, 201,202	6	48	SF	\$34	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st floor boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd floor boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd floor boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd floor girls			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	in 3rd floor teachers lounge			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	in 102			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd floor mens			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st floor unisex next to boys restroom			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	in 2nd floor teachers lounge			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	in 101			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st custodial staff			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st fl in FP nurses suite			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	Engineers toilet in Engineers Storage			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	in Main Office			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st floor girls			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st floor unisex next to girls restroom			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd floor girls			LF	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Engineers toilet in Engineers Storage			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	in Main Office			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st floor girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st floor unisex next to girls restroom			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st floor unisex next to boys restroom			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	in 2nd floor teachers lounge			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st fl in FP nurses suite			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd floor boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	in 3rd floor teachers lounge			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd floor girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd floor mens			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st floor boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd floor girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	in 102			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	in 101			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st custodial staff	7	8	EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd floor boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st custodial staff			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	in 101			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	in 102			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st floor unisex next to girls restroom			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st fl in FP nurses suite			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd floor boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd floor girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	Engineers toilet in Engineers Storage			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	in 3rd floor teachers lounge			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	in Main Office			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st floor girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd floor mens			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	in 2nd floor teachers lounge			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd floor boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd floor girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st floor boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st floor unisex next to boys restroom			EA	\$0	
Lunchroom	Lunchroom	Ceiling - Splined	1st Floor	7	1,168	SF	\$0	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	1st Floor	6	1,168	SF	\$1,670	
Lunchroom	Lunchroom	Lighting - Pendant/Surface	1st Floor	7	22	SF	\$0	
Lunchroom	Lunchroom	Serving Line	1st Floor			LF	\$0	
Lunchroom	Lunchroom	Wall - Concrete Block	1st Floor	6	1,059	SF	\$3,029	
MDF/IDF		Finishes	2nd Floor	6	195	SF	\$664	
MDF/IDF		Ventilation and Cooling	2nd Floor	6	1	EA	\$1,401	
Mechanical/Service Rooms		Janitor's Closet	Entire Building	6	6	SF	\$28	
Mechanical/Service Rooms		Mechanical/Service Rooms	Basement	6	1,956	SF	\$9,230	
Mechanical/Service Rooms		Mechanical/Service Rooms	2nd Floor	6	200	SF	\$944	
Mechanical/Service Rooms		Mechanical/Service Rooms	Boiler Room	7	1,247	SF	\$0	
Mechanical/Service Rooms		Storage Room	2nd Floor	6	350	SF	\$1,652	
Mechanical/Service Rooms		Storage Room	In Kitchen	7	75	SF	\$0	
Mechanical/Service Rooms		Storage Room	In Gymnasium	7	150	SF	\$0	
Mechanical/Service Rooms		Storage Room	in Gym Office	7	22	SF	\$0	
Mechanical/Service Rooms		Storage Room	Kitchen Storage 1st fl	7	75	SF	\$0	
Mechanical/Service Rooms		Storage Room	1st Floor	7	270	SF	\$0	
Mechanical/Service Rooms		Storage Room	in CR 102	7	50	SF	\$0	
Mechanical/Service Rooms		Storage Room	in lunchroom	7	55	SF	\$0	
Mechanical/Service Rooms		Storage Room	in CR 101	7	50	SF	\$0	
Mechanical/Service Rooms		Vaults	in Main Office	7	70	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	Engineers toilet in Engineers Storage	6	22	SF	\$170	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd floor boys	7	245	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd floor girls	7	245	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	in 3rd floor teachers lounge	7	95	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd floor girls	7	245	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd floor mens	7	90	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd floor boys	7	245	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor boys	7	245	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	in 2nd floor teachers lounge	7	95	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	in 102	6	30	SF	\$232	
Staff Restroom	Children's Standard Student Restroom	Accessories	in 101	6	30	SF	\$232	
Staff Restroom	Staff Restroom	Accessories	1st floor unisex next to boys restroom	7	45	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st fl in FP nurses suite	6	25	SF	\$193	
Staff Restroom	Staff Restroom	Accessories	in Main Office			SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st floor unisex next to girls restroom	7	45	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor girls	7	245	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st custodial staff	7	96	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd floor girls	7	245	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st custodial staff	6	96	SF	\$272	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st floor unisex next to boys restroom	6	45	SF	\$127	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor girls	6	245	SF	\$694	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	in 101	7	30	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	in 102	7	30	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	in 2nd floor teachers lounge	6	95	SF	\$269	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor boys	6	245	SF	\$694	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor boys	6	245	SF	\$694	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st floor unisex next to girls restroom	6	45	SF	\$127	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	in Main Office	6	44	SF	\$125	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	Engineers toilet in Engineers Storage	5	22	SF	\$125	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	in 3rd floor teachers lounge	6	95	SF	\$269	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor girls	6	245	SF	\$694	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd floor boys	6	245	SF	\$694	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st fl in FP nurses suite	7	25	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd floor mens	6	90	SF	\$255	
Staff Restroom	Staff Restroom	Floor Drain	1st custodial staff			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st fl in FP nurses suite			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd floor boys	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd floor girls	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	in 3rd floor teachers lounge			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd floor girls	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	2nd floor mens			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd floor boys	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor boys	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	in 2nd floor teachers lounge			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	in 102			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	Engineers toilet in Engineers Storage			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	in 101			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	in Main Office			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor girls	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st floor unisex next to girls restroom			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st floor unisex next to boys restroom			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor girls	7	245	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd floor boys	7	245	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor girls	6	245	SF	\$624	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor boys	7	245	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	in 101	6	30	SF	\$76	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st fl in FP nurses suite	6	25	SF	\$64	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor boys	7	245	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd floor girls	7	245	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	1st floor unisex next to girls restroom	6	45	SF	\$64	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	in Main Office	6	44	SF	\$63	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	Engineers toilet in Engineers Storage	6	22	SF	\$31	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	1st custodial staff	6	71	SF	\$102	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile/Sheet	in 102	6	30	SF	\$43	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	in 2nd floor teachers lounge	6	95	SF	\$136	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	2nd floor mens	6	90	SF	\$129	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	in 3rd floor teachers lounge	6	95	SF	\$136	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	1st floor unisex next to boys restroom	6	45	SF	\$64	
Staff Restroom	Staff Restroom	Hand Dryer	1st custodial staff			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd floor boys			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd floor girls			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	in 3rd floor teachers lounge			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd floor girls			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd floor boys			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	in 2nd floor teachers lounge			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st fl in FP nurses suite			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	in 101			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd floor mens			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	in 102			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Hand Dryer	1st floor unisex next to boys restroom			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	Engineers toilet in Engineers Storage			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	in Main Office			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor girls			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	1st floor unisex next to girls restroom			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor boys			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl in FP nurses suite	6	1	EA	\$372	
Staff Restroom	Staff Restroom	Lavatory	1st custodial staff	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd floor girls	5	1	EA	\$1,859	
Staff Restroom	Staff Restroom	Lavatory	Engineers toilet in Engineers Storage	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor boys	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	in 3rd floor teachers lounge	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor boys	6	3	EA	\$1,115	
Staff Restroom	Staff Restroom	Lavatory	2nd floor mens	5	1	EA	\$1,859	
Staff Restroom	Staff Restroom	Lavatory	in 2nd floor teachers lounge	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Lavatory	in 101	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	in 102	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd floor girls	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor girls	5	1	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor girls	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor girls	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd floor boys	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor girls	6	1	EA	\$372	
Staff Restroom	Staff Restroom	Lavatory	1st floor unisex next to girls restroom	7	1	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Lavatory	1st floor unisex next to boys restroom	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	in Main Office	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	in 101	4	1	SF	\$4	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	3rd floor girls	6	1	SF	\$1	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	2nd floor boys	6	1	SF	\$1	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	in 102	4	1	SF	\$4	
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st custodial staff	4	1	SF	\$4	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st fl in FP nurses suite	4	1	SF	\$4	
Staff Restroom	Staff Restroom	Lighting - Lay-In	Engineers toilet in Engineers Storage	4	1	SF	\$4	
Staff Restroom	Staff Restroom	Lighting - Lay-In	in 3rd floor teachers lounge	4	1	SF	\$4	
Staff Restroom	Staff Restroom	Lighting - Lay-In	2nd floor mens	4	2	SF	\$7	
Staff Restroom	Staff Restroom	Lighting - Lay-In	in Main Office	4	1	SF	\$4	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st floor girls	6	1	SF	\$1	
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st floor unisex next to boys restroom	4	1	SF	\$4	
Staff Restroom	Staff Restroom	Lighting - Lay-In	in 2nd floor teachers lounge	4	1	SF	\$4	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	3rd floor boys	6	1	SF	\$1	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	2nd floor girls	6	1	SF	\$1	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st floor boys	6	1	SF	\$1	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	3rd floor boys	7	2	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	1st floor unisex next to girls restroom	5	1	SF	\$1	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st floor girls	7	2	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st floor boys	7	2	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd floor boys	7	2	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	3rd floor girls	7	2	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd floor girls	7	2	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	Engineers toilet in Engineers Storage	4	1	EA	\$322	
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	1st floor unisex next to girls restroom	5	1	EA	\$157	
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	in Main Office	4	1	EA	\$322	
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	2nd floor mens	5	1	EA	\$157	
Staff Restroom	Children's Standard Student Restroom	Lighting - Wall Mounted	1st fl in FP nurses suite	4	1	EA	\$322	
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	1st custodial staff	4	1	EA	\$322	
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	in 2nd floor teachers lounge	6	1	EA	\$29	
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	1st floor unisex next to boys restroom	6	1	EA	\$29	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor boys	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	1st custodial staff			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor girls	5	7	EA	\$4,004	
Staff Restroom	Staff Restroom	Partitions	in Main Office			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	1st floor unisex next to girls restroom	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st fl in FP nurses suite			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	1st floor unisex next to boys restroom	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	in 101			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	in 102			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	in 2nd floor teachers lounge	6	2	EA	\$359	
Staff Restroom	Staff Restroom	Partitions	2nd floor mens	6	2	EA	\$359	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd floor girls	5	7	EA	\$4,004	
Staff Restroom	Staff Restroom	Partitions	in 3rd floor teachers lounge	6	2	EA	\$359	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd floor girls	5	1	EA	\$572	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd floor girls	6	6	EA	\$1,076	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd floor boys	7	2	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd floor boys	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	Engineers toilet in Engineers Storage			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st floor unisex next to boys restroom	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	in 102			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st custodial staff			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	Engineers toilet in Engineers Storage			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	in 2nd floor teachers lounge			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st floor unisex next to girls restroom			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	in 101			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	in Main Office			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd floor boys	7	5	EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd floor mens	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Urinals	in 3rd floor teachers lounge			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd floor boys	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st floor boys	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st fl in FP nurses suite			EA	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	in 3rd floor teachers lounge	6	320	SF	\$915	
Staff Restroom	Staff Restroom	Wall - Concrete Block	1st floor unisex next to boys restroom	6	220	SF	\$629	
Staff Restroom	Staff Restroom	Wall - Concrete Block	1st floor unisex next to girls restroom	6	220	SF	\$629	
Staff Restroom	Staff Restroom	Wall - Concrete Block	in Main Office	6	216	SF	\$618	
Staff Restroom	Staff Restroom	Wall - Concrete Block	Engineers toilet in Engineers Storage	6	152	SF	\$435	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	1st fl in FP nurses suite	6	25	SF	\$72	
Staff Restroom	Staff Restroom	Wall - Concrete Block	1st custodial staff	7	512	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	in 101	6	175	SF	\$501	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	in 102	6	175	SF	\$501	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Wall - Concrete Block	in 2nd floor teachers lounge	6	320	SF	\$915	
Staff Restroom	Staff Restroom	Wall - Concrete Block	2nd floor mens	7	330	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st floor girls	7	540	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st floor boys	6	540	SF	\$3,861	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd floor boys	7	540	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd floor boys	6	540	SF	\$3,861	
Staff Restroom	Staff Restroom	Water Closet	in 3rd floor teachers lounge	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st floor unisex next to boys restroom	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd floor mens	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	Engineers toilet in Engineers Storage	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl in FP nurses suite	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st custodial staff	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	in 101	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	in 102	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	in 2nd floor teachers lounge	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd floor girls	7	7	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor girls	7	7	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd floor boys	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	in Main Office	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor girls	7	7	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st floor unisex next to girls restroom	7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		5	1	EA	\$1,931	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	

INTERIOR Sub Total \$198,473

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		5	41	LF	\$7,329	
Casework	Classroom	Casework		5	46	LF	\$8,223	
Casework	Classroom	Casework		5	46	LF	\$8,223	
Casework	Classroom	Casework		5	41	LF	\$7,329	
Casework	Classroom	Casework		5	46	LF	\$8,223	
Casework	Classroom	Casework		6	41	LF	\$1,466	
Casework	Classroom	Casework		6	43	LF	\$1,537	
Casework	Classroom	Casework		6	41	LF	\$1,466	
Casework	Classroom	Casework		6	46	LF	\$1,645	
Casework	Classroom	Casework		6	46	LF	\$1,645	
Casework	Classroom	Casework		6	43	LF	\$1,537	
Casework	Classroom	Casework		5	41	LF	\$7,329	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		6	31	LF	\$1,108	
Casework	Classroom	Casework		5	41	LF	\$7,329	
Casework	Classroom	Casework		6	41	LF	\$1,466	
Casework	Classroom	Casework		6	5	LF	\$179	
Casework	Classroom	Casework		6	41	LF	\$1,466	
Casework	Classroom	Casework		6	41	LF	\$1,466	
Casework	Classroom	Casework		6	41	LF	\$1,466	
Casework	Classroom	Casework		5	41	LF	\$7,329	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		5	46	LF	\$8,223	
Casework	Classroom	Casework		6	41	LF	\$1,466	
Casework	Classroom	Casework		6	41	LF	\$1,466	
Casework	Classroom	Casework		6	41	LF	\$1,466	
Casework	Classroom	Casework		5	46	LF	\$8,223	
Casework	Classroom	Casework		6	41	LF	\$1,466	
Casework	Classroom	Casework		6	41	LF	\$1,466	
Casework	Classroom	Casework		6	41	LF	\$1,466	
Casework	Classroom	Casework		5	46	LF	\$8,223	
Casework	Classroom	Casework		6	41	LF	\$1,466	
Casework	Classroom	Casework		6	41	LF	\$1,466	
Casework	Classroom	Casework		6	41	LF	\$1,466	
Casework	Classroom	Casework		6	41	LF	\$1,466	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		5	41	LF	\$7,329	
Casework	Classroom	Casework		5	41	LF	\$7,329	
Casework	Classroom	Casework		6	46	LF	\$1,645	
Ceiling	Classroom	Plaster/Drywall		6	730	SF	\$2,067	
Ceiling	Classroom	Plaster/Drywall		6	730	SF	\$2,067	
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	998	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		6	730	SF	\$2,067	
Ceiling	Classroom	Plaster/Drywall		6	730	SF	\$2,067	
Ceiling	Classroom	Plaster/Drywall		6	234	SF	\$663	
Ceiling	Classroom	Plaster/Drywall		7	998	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		6	730	SF	\$2,067	
Ceiling	Classroom	Plaster/Drywall		6	360	SF	\$1,019	
Ceiling	Classroom	Plaster/Drywall		6	717	SF	\$2,030	
Ceiling	Classroom	Plaster/Drywall		6	730	SF	\$2,067	
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		6	360	SF	\$1,019	
Ceiling	Classroom	Plaster/Drywall		6	730	SF	\$2,067	
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		6	730	SF	\$2,067	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Ceiling	Classroom	Plaster/Drywall		6	730	SF	\$2,067	
Ceiling	Classroom	Plaster/Drywall		6	730	SF	\$2,067	
Ceiling	Classroom	Plaster/Drywall		6	730	SF	\$2,067	
Ceiling	Classroom	Plaster/Drywall		6	730	SF	\$2,067	
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		6	730	SF	\$2,067	
Ceiling	Classroom	Plaster/Drywall		6	730	SF	\$2,067	
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	730	SF	\$0	
Ceiling	Classroom	Splined Ceiling		6	730	SF	\$1,566	
Ceiling	Classroom	Splined Ceiling		7	730	SF	\$0	
Ceiling	Classroom	Splined Ceiling		6	730	SF	\$1,566	
Ceiling	Classroom	Splined Ceiling		7	730	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	360	SF	\$0	
Chalk Board	Classroom	Chalk Board		4	41	LF	\$4,984	
Chalk Board	Classroom	Chalk Board		4	37	LF	\$4,497	
Chalk Board	Classroom	Chalk Board		4	37	LF	\$4,497	
Chalk Board	Classroom	Chalk Board		4	37	LF	\$4,497	
Chalk Board	Classroom	Chalk Board		4	37	LF	\$4,497	
Chalk Board	Classroom	Chalk Board		4	41	LF	\$4,984	
Chalk Board	Classroom	Chalk Board		4	17	LF	\$2,066	
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	37	LF	\$4,497	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	17	LF	\$2,066	
Chalk Board	Classroom	Chalk Board		4	37	LF	\$4,497	
Chalk Board	Classroom	Chalk Board		4	28	LF	\$3,403	
Chalk Board	Classroom	Chalk Board		4	41	LF	\$4,984	
Chalk Board	Lunchroom	Chalk Board	1st Floor	4		LF		
Chalk Board	Classroom	Chalk Board		4	36	LF	\$4,376	
Chalk Board	Classroom	Chalk Board		4	41	LF	\$4,984	
Chalk Board	Classroom	Chalk Board		4	41	LF	\$4,984	
Chalk Board	Classroom	Chalk Board		4	41	LF	\$4,984	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Pendant/Surface	3rd floor SW	7	1,255	EA	\$0	
Corridors	Corridors	Stair Handrails	3rd floor SW			LF	\$0	
Corridors	Corridors	Stair Handrails	1st Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	Center Stairs	6	92	LF	\$0	
Corridors	Corridors	Stair Handrails	End Stairs	6	142	LF	\$0	
Corridors	Corridors	Stair Handrails	waiting rm 1st fl			LF	\$0	
Corridors	Corridors	Stair Handrails	3rd floor NE			LF	\$0	
Corridors	Corridors	Stair Handrails	2nd Floor			LF	\$0	
Corridors	Corridors	Stairs	waiting rm 1st fl			EA	\$0	
Corridors	Corridors	Stairs	3rd floor SW			EA	\$0	
Corridors	Corridors	Stairs	2nd Floor			EA	\$0	
Corridors	Corridors	Stairs	1st Floor			EA	\$0	
Corridors	Corridors	Stairs	3rd floor NE			EA	\$0	
Corridors	Corridors	Structural Glazed Tile	End Stairs	7	1,304	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	2nd Floor	6	3,030	SF	\$21,665	
Corridors	Corridors	Structural Glazed Tile	3rd floor NE	6	990	SF	\$7,079	
Corridors	Corridors	Structural Glazed Tile	3rd floor SW	6	990	SF	\$7,079	
Corridors	Corridors	Structural Glazed Tile	Center Stairs	7	2,042	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	1st Floor	6	3,570	SF	\$25,526	
Corridors	Corridors	Student Lockers	1st Floor			EA	\$0	
Corridors	Corridors	Student Lockers	Center Stairs			EA	\$0	
Corridors	Corridors	Student Lockers	End Stairs			EA	\$0	
Corridors	Corridors	Student Lockers	2nd Floor			EA	\$0	
Corridors	Corridors	Student Lockers	waiting rm 1st fl			EA	\$0	
Corridors	Corridors	Student Lockers	3rd floor SW			EA	\$0	
Corridors	Corridors	Student Lockers	3rd floor NE			EA	\$0	
Corridors	Corridors	Terrazzo	End Stairs	7	338	SF	\$0	
Corridors	Corridors	Terrazzo	3rd floor NE	6	95	SF	\$538	
Corridors	Corridors	Terrazzo	2nd Floor	6	175	SF	\$991	
Corridors	Corridors	Terrazzo	Center Stairs	7	352	SF	\$0	
Corridors	Corridors	Terrazzo	1st Floor	6	175	SF	\$991	
Corridors	Corridors	Terrazzo	3rd floor SW	6	95	SF	\$538	
Corridors	Corridors	Tile Ceramic/Porcelain	1st Floor	7	550	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	3rd floor NE	6	1,160	SF	\$1,659	
Corridors	Corridors	Tile/Sheet Flooring	3rd floor SW	6	1,160	SF	\$1,659	
Corridors	Corridors	Tile/Sheet Flooring	waiting rm 1st fl	6	126	SF	\$180	
Corridors	Corridors	Tile/Sheet Flooring	2nd Floor	6	3,535	SF	\$5,055	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0	
Lighting	Classroom	Pendant/Surface		6	8	EA	\$572	bulb out
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0	
Lighting	Classroom	Pendant/Surface		6	8	EA	\$572	
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Lunchroom	Marker Board	1st Floor			LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Concrete Block		7	775	SF	\$0	
Wall	Classroom	Concrete Block		7	775	SF	\$0	
Wall	Classroom	Concrete Block		7	775	SF	\$0	
Wall	Classroom	Concrete Block		6	775	SF	\$2,217	
Wall	Classroom	Concrete Block		7	590	SF	\$0	
Wall	Classroom	Concrete Block		7	590	SF	\$0	
Wall	Classroom	Concrete Block		7	775	SF	\$0	
Wall	Classroom	Concrete Block		7	775	SF	\$0	
Wall	Classroom	Concrete Block		7	775	SF	\$0	
Wall	Classroom	Concrete Block		6	393	SF	\$1,124	
Wall	Classroom	Concrete Block		6	775	SF	\$2,217	
Wall	Classroom	Concrete Block		7	841	SF	\$0	
Wall	Classroom	Concrete Block		6	775	SF	\$2,217	
Wall	Classroom	Concrete Block		7	775	SF	\$0	
Wall	Classroom	Concrete Block		7	775	SF	\$0	
Wall	Classroom	Concrete Block		7	775	SF	\$0	
Wall	Classroom	Concrete Block		7	775	SF	\$0	
Wall	Classroom	Concrete Block		7	775	SF	\$0	
Wall	Classroom	Concrete Block		7	775	SF	\$0	
Wall	Classroom	Concrete Block		6	775	SF	\$2,217	
ROOM Sub Total							\$537,794	
Building Main Sub Total							\$3,995,871	

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Civil/Drainage		Catch Basin	Entire Site	7	3	EA	\$0	
Civil/Drainage		Site Manhole	Entire Site	7	5	EA	\$0	
Fencing		Chain Link	Entire Site	6	1,365	LF	\$19,578	
Landscape		Asphalt Play Area/Hardscape	North Site	5	18,600	SF	\$52,664	
Landscape		Grass	Entire Site	7	5,865	SF	\$0	
Landscape		Hardscape - Concrete	Entire Site	7	1,800	SF	\$0	
Landscape		Trash Receptacles	Entire Site	7	2	EA	\$0	
Parking Lot		Asphalt	North between fence and Alley	4	2,000	SF	\$17,160	
Parking Lot		Asphalt	North Site	5	13,000	SF	\$36,808	
Playground		Playground Equipment - School Age 5-12	North West Site	6	1	EA	\$0	

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Playground		Playground Surfacing - Square Rubber Mats	North West Site	4	2,200	SF	\$48,763	
Sidewalks		Perimeter Sidewalks	South West by flagpole	5	400	SF	\$2,494	
Sidewalks		Perimeter Sidewalks	Entire Site	7	9,700	SF	\$0	
Signage		Flag Pole	South West Corner	6	1	EA	\$0	
Signage		Marquee - Free Standing Back Lighted	South West Corner	7	1	EA	\$0	
SITE Sub Total							\$177,467	
SITE Sub Total							\$177,467	

Total Campus Need ^{2 3} \$4,173,338

¹ It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

² As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

³ The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Building: Main														
101	998			6	40	164	66		N	N	N	Classroom		
102	998	1	8	22	40	164	66		N	N	Y	Classroom		
103	730	1	3	14	40	112	48		N	N	N	Classroom		
104	730	1	3	14	40	112	48		N	N	N	Classroom		
105	730	1	3	14	40	112	48		N	N	N	Classroom		
106	730	1	3	14	40	112	48		N	N	N	Classroom		
107	730	1	3	14	40	112	48		N	N	N	Classroom		
108	730	1	3	14	40	112	48		N	N	N	Classroom		
109	730	1	3	14	40	112	48		N	N	N	Classroom		
203	730	2	8	22	40	112	48		N	N	N	Classroom		
204	730	2	8	22	40	112	48		N	N	N	Classroom		
205	730	2	8	22	40	112	48		N	N	N	Classroom		
206	730	2	8	22	40	112	48		N	N	N	Classroom		
207	730	2	8	22	40	112	48		N	N	N	Classroom		
208	730	2	8	22	40	112	48		N	N	N	Classroom		
209	730	2	8	22	40	112	48		N	N	N	Classroom		
210	730	2	8	22	40	112	48		N	N	N	Classroom		
211	730	2	8	20	40	112	48		N	N	N	Classroom		
212	730	2	8	22	40	112	48		N	N	Y	Classroom		
213	730	2	36	80	40	98	36	2	N	N	Y	Classroom		
214	730	2	36	80	40	98	36	2	N	N	Y	Classroom		
215	360	2	8	18	40	56	24		N	N	Y	Classroom		
303	730	2	11	30	40	112	48		N	N	N	Classroom		
304	730	2	8	22	40	112	48		N	N	N	Classroom		
305	730	2	8	22	40	112	48		N	N	N	Classroom		
306	730	2	8	22	40	112	48		N	N	N	Classroom		
307	730	2	8	22	40	112	48		N	N	N	Classroom		
308	730	2	8	22	40	112	48		N	N	N	Classroom		
309	730	2	8	22	40	112	48		N	N	N	Classroom		
310	730	2	8	22	40	112	48		N	N	N	Classroom		
311	730	2	8	20	40	112	48		N	N	N	Classroom		
312	730	2	8	38	40	112	48		N	N	N	Classroom		
313	730	2	8	20	40	112	48		N	N	N	Classroom		
314	730	2	8	22	40	112	48		N	N	N	Classroom		
315	360	2	8	18	40	56	24		N	N	Y	Classroom		
Adj Room	360	2	8	18	40	56	24		N	N	Y	Classroom		

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Counselor	717	3	5	8	40	116	48		N	N	Y	Classroom		
fl 1 FP exam rm	234			6	40	73	30		N	N	N	Classroom		
Other	230			6					N	N	N	Administrative Suites/Offices		3rd floor teachers lounge
Other	95								N	N	N	Restroom	Staff Restroom	in 3rd floor teachers lounge
Other	1255								N	N	N	Corridors		3rd floor SW
Other	1255								N	N	N	Corridors		3rd floor NE
Other	2240								N	N	N	Library		200, 201,202
Other	245								N	N	N	Restroom	Children's Standard Student Restroom	3rd floor boys
Other	245								N	N	N	Restroom	Children's Standard Student Restroom	1st floor boys
Other	245								N	N	N	Restroom	Children's Standard Student Restroom	2nd floor girls
Other	245								N	N	N	Restroom	Children's Standard Student Restroom	3rd floor girls
Other	126			8					N	N	N	Administrative Suites/Offices		1st fl office FP nurses office
Other	245								N	N	N	Restroom	Children's Standard Student Restroom	1st floor girls
Other	160			10					N	N	Y	Administrative Suites/Offices		Principals Office in main office
Other	4355								N	N	N	Corridors		1st Floor
Other	353			10					N	N	Y	Administrative Suites/Offices		Main Office 1st fl
Other	103			6					N	N	N	Administrative Suites/Offices		Gym Office in gym
Other	84			6					N	N	N	Administrative Suites/Offices		Engineers Office in Boiler Room
Other	1168								N	N	N	Lunch & Multipurpose Room	Lunchroom	1st Floor
Other	540								N	N	N	Kitchen	Cooking Kitchen	1st Floor
Other	3805								N	N	N	Corridors		2nd Floor
Other	95								N	N	N	Restroom	Staff Restroom	in 2nd floor teachers lounge
Other									N	N	N	Corridors		End Stairs
Other	45								N	N	N	Restroom	Staff Restroom	1st floor unisex next to boys restroom
Other	90								N	N	N	Restroom	Staff Restroom	2nd floor mens
Other	30								N	N	N	Restroom	Children's Standard Student Restroom	in 101
Other	126								N	N	N	Corridors		waiting rm 1st fl
Other	96								N	N	N	Restroom	Staff Restroom	1st custodial staff
Other									N	N	N	Corridors		Center Stairs
Other	25								N	N	N	Restroom	Children's Standard Student Restroom	1st fl in FP nurses suite
Other	22								N	N	N	Restroom	Staff Restroom	Engineers toilet in Engineers Storage
Other	45								N	N	N	Restroom	Staff Restroom	1st floor unisex next to girls restroom
Other	44								N	N	N	Restroom	Staff Restroom	in Main Office
Other	4196								N	N	N	Gymnasia	Gymnasium.Auditorium	1st Floor
Other	245								N	N	N	Restroom	Children's Standard Student Restroom	2nd floor boys

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	30								N	N	N	Restroom	Children's Standard Student Restroom	in 102