

## Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at [http://www.cps.edu/About\\_CPS/Policies\\_and\\_guidelines/Pages/facilitystandards.aspx](http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx).

### Condition Rankings and Descriptions

- Rank 7:** The item/system is new or in good condition and no work is required.
- Rank 6:** The item/system requires general cleaning and/or routine maintenance.
- Rank 5:** The item/system requires repairs and has not reached the end of its serviceable life.
- Rank 4:** The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.
- Rank 3:** The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.
- Rank 2:** The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.
- Rank 1:** The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.<sup>1</sup>

### Definitions

- Quantity** means, for each item, the total number (or amount) of that item that exists and was evaluated.
- Unit** means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").
- Cost** means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.
- For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.**
- Total Campus Need** also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

### Building: Main Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Cornice		Cornice - Masonry Projecting/Limestone	Entire Building	6	813	LF	\$24,938	cleaning
Cornice		Cornice - Metal Projecting	Entire Building	6	478	LF	\$42,858	flaking paint/rust
Doors		Exterior FRP Door	Entire Building	7	4	EA	\$0	
Doors		Exterior Steel Door	Entire Building	6	1	EA	\$330	
Doors		Transom Lite	Entire Building	7	8	EA	\$0	
Entrance		Entrance Controls - Audio and Video	Entire Building	7	1	EA	\$0	
Foundation		Masonry Foundation	basement fan room	6	5	SF	\$495	efflorescence
Foundation		Masonry Foundation	Entire Building	7	351	SF	\$0	
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	6	EA	\$1,287	cleaning
Lintels		Lintels - Brick	Entire Building	6	198	LF	\$0	mortar
Lintels		Lintels - Stone	Entire Building	6	432	LF	\$0	mortar
Parapet		Coping - Stone	upper elevator roof	7	25	LF	\$0	
Parapet		Coping - Stone	lower SW roof	7	20	LF	\$0	
Parapet		Coping - Terra Cotta	lower NE roof	6	55	LF	\$0	

**Building: Main**  
**Category: EXTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Parapet		Parapet < 16" Height	upper elevator roof	7	25	LF	\$0	
Parapet		Parapet < 16" Height	lower NE roof	6	55	LF	\$8,565	
Parapet		Parapet < 16" Height	lower SW roof	7	20	LF	\$0	
Roof System		Exterior Downspouts	Roofs	7	280	LF	\$0	
Roof System		Metal Roof	Roof	7	6,360	SF	\$0	
Roof System		Modified Bitumen Roof	Roofs	6	2,502	SF	\$17,710	deteriorated surface
Roof System		Roof Structure: Heavy Timber	Roofs	7	8,471	SF	\$0	
Superstructure		Heavy Timber	Entire Building	7	33,247	SF	\$0	
Superstructure		Heavy Timber	SW corner	5	50	SF	\$1,090	cracks visible inside & outside
Walls		Brick	Entire Building	6	16,180	SF	\$106,895	
Walls		Brick	SW corner	5	150	SF	\$3,398	vertical cracks/mortar
Walls		Brick	NE lower wall	5	300	SF	\$6,795	
Walls		Stone - Cast	Entire Building	6	350	SF	\$5,005	
Walls		Stone - Cut	Entire Building	6	2,088	SF	\$29,858	
Windows		Window - Guards perforated	throughout	7	1,125	SF	\$0	
Windows		Windows - Sash Aluminum Double-pane	Entire Building	7	5,760	SF	\$0	
<b>EXTERIOR Sub Total</b>							<b>\$249,225</b>	

**Building: Main**  
**Category: ELECTRICAL**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Emergency A/C power - Corridors and Stairs	Corridors and Stairs	6	7,471	SF	\$3,205	
Emergency System		Emergency Battery Packs - Corridors and Stairs	Entire Building	6	14	EA	\$1,502	
Emergency System		Emergency Battery Packs - Toilets	Entire Building	6	4	EA	\$429	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	6	8	EA	\$1,865	
Power Distribution		Lighting and power panels	Entire Building	4	4	EA	\$21,736	
Power Distribution		Lighting and power panels	Main Corridor 1st Floor	6	1	EA	\$715	
<b>ELECTRICAL Sub Total</b>							<b>\$29,451</b>	

**Building: Main**  
**Category: FIRE PROTECTION**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Entire Building	3	33,297	SF	\$70,470	Strobe lights are not located in all areas
Fire Alarm		Fire Pump Controller	Fan & Engine Room	4	1	EA	\$18,590	
Pump Room Assembly		Fire Pump less than 25hp	Fan & Engine Room	5	1	EA	\$12,441	

**Building: Main**  
**Category: FIRE**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Sprinkler System		Dry Sprinkler System	Entire Building	3	33,297	SF	\$238,074	Sprinkler heads are moer than 50 Years old and should be replaced.
Sprinkler System		Sprinkler Heads	Entire Building	3	33,297	SF	\$16,665	
<b>FIRE PROTECTION Sub Total</b>							<b>\$356,239</b>	

**Building: Main**  
**Category: MECHANICAL**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Window A/C Unit	Entire Building	3	4	EA	\$8,580	Units are not working
Air Conditioning		Window A/C Unit	Entire Building	6	3	EA	\$644	
Air Handling Systems		Air Intake - Built Up Air Handling Unit	Areawell	6	1	EA	\$1,430	
Air Handling Systems		Multi Zone Built Up Air Handling Unit - Steam 15,001 to 25,000 cfm	Fan & Engine Room	4	1	EA	\$92,950	
Air Handling Systems		Multi Zone Built Up Air Handling Unit Auxiliaries - Steam 15,001 to 25,000 cfm	Fan & Engine Room	4	1	EA	\$32,890	
Air Handling Systems		Return Duct Work - Masonry and Ducts - Existing or Missing Exterior Shaft	Basement	4	100	LF	\$264,550	
Heating Devices		Radiators - Steam	Entire Building	6	8	EA	\$1,121	
Mechanical Plumbing		Condensate Assembly - Pumps and Tank	Basement	5	1	EA	\$9,438	
Mechanical Plumbing		Piping - Condensate - Steel or Galvanized	Basement	5	500	LF	\$16,266	
Mechanical Plumbing		Piping - Steam - Steel or Galvanized	Basement	5	500	LF	\$24,739	
Temperature Control		Thermostats - Pneumatic	Entire Building	4	17	EA	\$11,183	
Temperature Control		Zone Dampers	fan & Engine Room	5	17	EA	\$6,321	
Ventilation		Exhaust Fans - Roof mounted less than 500 CFM	Roof	4	1	EA	\$1,573	
<b>MECHANICAL Sub Total</b>							<b>\$471,684</b>	

**Building: Main**  
**Category: PLUMBING**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Electric less than 50 KW	Fan & Engine Room	4	1	EA	\$11,211	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	7	33,297	SF	\$0	
Piping		Domestic Piping - Cold Water Risers	Entire Building	4	33,297	SF	\$21,427	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	7	33,297	SF	\$0	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	4	33,297	SF	\$15,237	
Piping		Domestic Piping - Hot Water Risers	Entire Building	4	33,297	SF	\$18,094	

**Building: Main**  
**Category: PLUMBING**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	4	33,297	SF	\$79,517	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	4	33,297	SF	\$65,708	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	4	33,297	SF	\$38,092	
Piping		Sanitary Piping	Entire Building	5	33,297	SF	\$20,474	
Piping		Storm Piping	Entire Building	5	33,297	SF	\$15,713	
Piping		Vent Piping	Entire Building	5	33,297	SF	\$11,904	
Pumps		Sump Pump	Elevator Pit	6	1	EA	\$1,359	

**PLUMBING Sub Total \$298,734**

**Building: Main**  
**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Lower Level Office 221-124	7	96	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Room 220, Teacher's Resource	7	692	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Main Office (Floor Plan Room 104)	7	636	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Room 322 (304), Parent's Room	7	654	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Lower Level Office 221-124	6	96	SF	\$137	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Main Office (Floor Plan Room 104)	7	636	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Room 220, Teacher's Resource	7	692	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Room 322 (304), Parent's Room	7	654	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Lower Level Office 221-124	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Room 220, Teacher's Resource	7	12	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Room 322 (304), Parent's Room	7	12	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Main Office (Floor Plan Room 104)	7	12	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Main Office (Floor Plan Room 104)	6	1,290	SF	\$3,044	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Room 322 (304), Parent's Room	7	1,339	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Lower Level Office 221-124	6	235	SF	\$554	

**Building: Main**  
**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Room 220, Teacher's Resource	7	1,453	SF	\$0	
Doors		Interior Steel Doors incl hw	Entire Building	6	6	EA	\$1,699	
Doors		Interior Wood Doors incl hw	Entire Building	6	48	EA	\$13,591	
Doors		Side-lite	Entire Building	7	24	SF	\$0	
Doors		Transom Window	Entire Building	7	47	SF	\$0	
Doors		Transom Window	Entire Building	6	47	SF	\$874	
Drinking Fountains	Corridors	Single Fountain	3rd Floor	7	2	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	Lower Level	7	1	EA	\$0	
Mechanical/Service Rooms		Janitor's Closet	Entire Building	7	4	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	Lower Level	7	146	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	Lower Level Fan Room	7	186	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	Lower Level	7	202	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	Lower Level	7	193	SF	\$0	
Mechanical/Service Rooms		Storage Room	3rd Floor	7	57	SF	\$0	
Mechanical/Service Rooms		Storage Room	Wardrobe Rooms 120, 123 & 124	7	336	SF	\$0	
Mechanical/Service Rooms		Storage Room	Lower Level Room B-2	6	258	SF	\$1,218	
Mechanical/Service Rooms		Storage Room	Lower Level	6	80	SF	\$378	
Mechanical/Service Rooms		Storage Room	Lower Level	7	253	SF	\$0	
Mechanical/Service Rooms		Storage Room	2nd Floor	7	182	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	3rd Floor	7	79	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st Floor Boy's Room	7	405	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd Floor Women's Room	7	54	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	In Main Office	7	29	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st Floor Girl's Room	7	579	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd Floor Men's Room	7	54	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st Floor Boy's Room	7	405	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	In Main Office	7	29	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st Floor Girl's Room	7	579	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd Floor Men's Room	7	54	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	3rd Floor	6	79	SF	\$224	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st Floor Girl's Room	7	2	EA	\$0	

**Building: Main**  
**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	In Main Office	7	29	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	2nd Floor Men's Room	7	54	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	2nd Floor Women's Room	7	60	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st Floor Boy's Room	7	405	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st Floor Girl's Room	7	579	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	3rd Floor	7	79	SF	\$0	
Staff Restroom	Staff Restroom	Lavatory	3rd Floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st Floor Girl's Room	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st Floor Boy's Room	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd Floor Men's Room	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	In Main Office	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd Floor Women's Room	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	2nd Floor Men's Room	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	3rd Floor	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st Floor Boy's Room	7	8	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	In Main Office	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st Floor Girl's Room	7	9	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	2nd Floor Women's Room	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st Floor Boy's Room	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st Floor Girl's Room	7	12	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st Floor Boy's Room	7	12	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	1st Floor Boy's Room	7	405	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	1st Floor Girl's Room	7	445	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st Floor Boy's Room	7	405	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	3rd Floor	7	509	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st Floor Girl's Room	7	445	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	2nd Floor Women's Room	7	214	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	In Main Office	7	280	SF	\$0	

**Building: Main**  
**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	2nd Floor Men's Room	7	214	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	2nd Floor Men's Room	7	214	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	2nd Floor Women's Room	7	214	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	In Main Office	7	38	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st Floor Boy's Room	7	4	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	3rd Floor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd Floor Women's Room	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st Floor Girl's Room	7	13	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	In Main Office	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd Floor Men's Room	7	1	EA	\$0	
<b>INTERIOR Sub Total</b>							<b>\$21,718</b>	

**Building: Main**  
**Category: ROOM**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		7	5	LF	\$0	
Casework	Classroom	Casework		7	5	LF	\$0	
Casework	Classroom	Casework		7	5	LF	\$0	
Casework	Classroom	Casework		7	5	LF	\$0	
Casework	Classroom	Casework		7	5	LF	\$0	
Casework	Classroom	Casework		7	5	LF	\$0	
Casework	Classroom	Casework		7	6	LF	\$0	
Casework	Classroom	Casework		7	5	LF	\$0	
Casework	Classroom	Casework		7	5	LF	\$0	
Casework	Classroom	Casework		7	5	LF	\$0	
Casework	Classroom	Casework		7	5	LF	\$0	
Casework	Classroom	Casework		7	5	LF	\$0	
Casework	Classroom	Casework		7	5	LF	\$0	
Casework	Classroom	Casework		7	5	LF	\$0	
Casework	Classroom	Casework		7	5	LF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	908	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	847	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		5	847	SF	\$4,796	
Ceiling	Classroom	Plaster/Drywall		7	847	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	780	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	847	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	847	SF	\$0	

**Building: Main**  
**Category: ROOM**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Ceiling	Classroom	Plaster/Drywall		7	847	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	847	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	654	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	847	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	847	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		5	847	SF	\$4,796	
Ceiling	Classroom	Plaster/Drywall		5	847	SF	\$4,796	
Chalk Board	Classroom	Chalk Board		4	60	LF	\$7,293	
Chalk Board	Classroom	Chalk Board		4	18	LF	\$2,188	
Chalk Board	Classroom	Chalk Board		4	10	LF	\$1,216	
Chalk Board	Classroom	Chalk Board		4	10	LF	\$1,216	
Chalk Board	Classroom	Chalk Board		4	10	LF	\$1,216	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	60	LF	\$7,293	
Chalk Board	Classroom	Chalk Board		4	18	LF	\$2,188	
Chalk Board	Classroom	Chalk Board		4	60	LF	\$7,293	
Corridors	Corridors	Carpet	1st Floor	7	1,934	SF	\$0	
Corridors	Corridors	Carpet	2nd Floor	7	1,000	SF	\$0	
Corridors	Corridors	Pendant/Surface	3rd Floor	7	48	EA	\$0	
Corridors	Corridors	Pendant/Surface	2nd Floor	7	36	EA	\$0	
Corridors	Corridors	Pendant/Surface	1st Floor	7	42	EA	\$0	
Corridors	Corridors	Pendant/Surface	Lower Level	7	54	EA	\$0	
Corridors	Corridors	Plaster/Drywall	1st Floor	7	3,649	SF	\$0	
Corridors	Corridors	Plaster/Drywall	2nd Floor	7	3,881	SF	\$0	
Corridors	Corridors	Plaster/Drywall	3rd Floor	7	3,988	SF	\$0	
Corridors	Corridors	Plaster/Drywall	Lower Level	7	4,406	SF	\$0	
Corridors	Corridors	Single Water Cooler	2nd Floor	7	2	EA	\$0	
Corridors	Corridors	Single Water Cooler	1st Floor	7	2	EA	\$0	
Corridors	Corridors	Stair Handrails	2nd Floor	7	128	LF	\$0	
Corridors	Corridors	Stair Handrails	3rd Floor	7	112	LF	\$0	
Corridors	Corridors	Stair Handrails	Lower Level	7	64	LF	\$0	
Corridors	Corridors	Stair Handrails	1st Floor	7	128	LF	\$0	
Corridors	Corridors	Student Lockers	1st Floor	7	36	EA	\$0	
Corridors	Corridors	Student Lockers	2nd Floor	7	51	EA	\$0	
Corridors	Corridors	Student Lockers	3rd Floor	7	68	EA	\$0	
Corridors	Corridors	Terrazzo	Lower Level	7	2,186	SF	\$0	
Corridors	Corridors	Terrazzo	1st Floor	7	653	SF	\$0	



**Building: Main**  
**Category: ROOM**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Terrazzo	2nd Floor	7	653	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	Lower Level	7	1,934	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	3rd Floor	7	1,564	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	2nd Floor	7	190	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	Lower Level	7	2,186	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	1st Floor	7	1,878	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	3rd Floor	7	1,564	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	2nd Floor	7	1,843	SF	\$0	
Stairs	Corridors	Terrazzo	Lower Level	7	35	SF	\$0	
Stairs	Corridors	Terrazzo	1st Floor	7	68	SF	\$0	
Stairs	Corridors	Terrazzo	2nd Floor	7	68	SF	\$0	
Stairs	Corridors	Terrazzo	3rd Floor	7	68	SF	\$0	
Floor	Classroom	Floor		6	780	SF	\$3,346	
Floor	Classroom	Tile/Sheet		6	847	SF	\$1,211	
Floor	Classroom	Tile/Sheet		7	847	SF	\$0	
Floor	Classroom	Tile/Sheet		7	847	SF	\$0	
Floor	Classroom	Tile/Sheet		7	847	SF	\$0	
Floor	Classroom	Tile/Sheet		6	847	SF	\$1,211	
Floor	Classroom	Tile/Sheet		7	908	SF	\$0	
Floor	Classroom	Tile/Sheet		6	847	SF	\$1,211	
Floor	Classroom	Tile/Sheet		7	847	SF	\$0	
Floor	Classroom	Tile/Sheet		7	847	SF	\$0	
Floor	Classroom	Tile/Sheet		6	847	SF	\$1,211	
Floor	Classroom	Tile/Sheet		7	654	SF	\$0	
Floor	Classroom	Tile/Sheet		7	847	SF	\$0	
Floor	Classroom	Tile/Sheet		6	847	SF	\$1,211	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	12	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	12	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	12	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	12	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	12	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	12	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	12	EA	\$0	

**Building: Main**  
**Category: ROOM**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting	Classroom	Pendant/Surface		7	12	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		7	18	LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	18	LF	\$0	
Marker Board	Classroom	Marker Board		7	36	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	36	LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	36	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
RESTROOM_CEILING	Staff Restroom	Restroom Ceiling	2nd Floor Women's Room	7	60	SF	\$0	
Wall	Classroom	Concrete Block		6	1,232	SF	\$3,524	
Wall	Classroom	Plaster/Drywall		6	1,368	SF	\$3,228	
Wall	Classroom	Plaster/Drywall		6	1,455	SF	\$3,433	
Wall	Classroom	Plaster/Drywall		7	979	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	1,455	SF	\$3,433	
Wall	Classroom	Plaster/Drywall		6	1,455	SF	\$3,433	
Wall	Classroom	Plaster/Drywall		6	1,368	SF	\$3,228	
Wall	Classroom	Plaster/Drywall		5	1,426	SF	\$6,729	
Wall	Classroom	Plaster/Drywall		6	1,455	SF	\$3,433	
Wall	Classroom	Plaster/Drywall		5	1,426	SF	\$6,729	
Wall	Classroom	Plaster/Drywall		6	1,455	SF	\$3,433	
Wall	Classroom	Plaster/Drywall		6	1,339	SF	\$3,159	
Wall	Classroom	Plaster/Drywall		5	1,426	SF	\$6,729	
Wall	Classroom	Plaster/Drywall		6	1,368	SF	\$3,228	
<b>ROOM Sub Total</b>							<b>\$107,412</b>	
<b>Building Main Sub Total</b>							<b>\$1,534,464</b>	

**Building: Addition #'s 1 & 2 (1961)**

**Category: EXTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
-------	-----------	------	----------	------	----------	------	------	--------

**Building: Addition #'s 1 & 2 (1961)**

**Category: EXTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Canopy		Concrete/ Stucco Canopy	Main Entrance	7	76	SF	\$0	
Canopy		Metal Canopy	entrances	6	100	SF	\$2,407	flaking paint
Chimney		Brick Chimney - Concrete/ Mortar Liner	Roof	5	15	LF	\$26,813	efflorescence, no rain cap, produces water in boiler room
Chimney		Brick Chimney - Concrete/ Mortar Liner	Roof	6	35	LF	\$17,518	
Chimney		Metal Flue	Roof	6	3	LF	\$193	
Doors		Exterior FRP Door	Entire Building	7	15	EA	\$0	
Doors		Exterior Steel Door	Entire Building	7	2	EA	\$0	
Doors		Transom Lite	Entire Building	7	20	EA	\$0	
Entrance		Concrete Exterior Stairs	Entire Building	7	150	LF	\$0	
Entrance		Concrete Ramp	Entire Building	7	95	LF	\$0	
Entrance		Entrance Controls - Audio	Entire Building	7	1	EA	\$0	
Entrance		Entrance Controls - Audio and Video	Entire Building	7	1	EA	\$0	
Entrance		Ramp Handrails	Entire Building	6	50	LF	\$0	
Entrance		Stair Handrails	Entire Building	6	80	LF	\$0	
Entrance		Steel or Aluminum Stairs	Entire Building	6	5	LF	\$35	
Entrance		Stone Stairs	Entire Building	6	100	LF	\$17,875	
Foundation		Concrete Foundation	Entire Building	7	1,028	LF	\$0	
Foundation		Concrete Foundation	S elevation crawl space	6	20	LF	\$3,115	water seepage
Foundation		Concrete Foundation	NW fan room - basement	6	5	LF	\$779	water intrusion
Lighting		Exterior Lights - Parapet or Roof Mounted	Roofs	6	10	EA	\$5,005	clean lenses
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	15	EA	\$3,218	clean lenses
Parapet		Coping - Metal	Roofs	7	616	LF	\$0	
Parapet		Coping - Metal	link roof at door #8	5	4	LF	\$112	producing water inside
Parapet		Coping - Stone	SW roof	6	15	LF	\$0	
Parapet		Coping - Stone	N & S roofs	7	473	LF	\$0	
Parapet		Parapet < 16" Height	Roofs	7	620	LF	\$0	
Parapet		Parapet > 30" Height	E elevation roof	7	15	LF	\$0	
Parapet		Parapet 16" to 30" Height	N & S elevations	7	473	LF	\$0	
Roof System		Asphalt Gravel Ballast Roof	Main Roofs	4	27,057	SF	\$689,483	blisters & water ponding
Roof System		Interior Downspouts	Roofs	6	210	LF	\$0	
Roof System		Modified Bitumen Roof	link roof	6	592	SF	\$4,190	deteriorated surface
Roof System		Roof Structure: Concrete	Roofs	7	27,649	SF	\$0	

**Building: Addition #'s 1 & 2 (1961)**  
**Category: EXTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Superstructure		Concrete	Entire Building	7	61,088	SF	\$0	
Walls		Brick	Entire Building	7	24,168	SF	\$0	
Walls		Brick	N & NW elevations	6	3,451	SF	\$22,799	clean & seal joints
Walls		Stone - Cast	Entire Building	6	252	SF	\$3,604	
Walls		Terra Cotta	Entire Building	6	1,064	SF	\$30,430	chipping & cracks
Windows		Window - Guards wire guard	throughout	6	2,200	SF	\$0	paint
Windows		Windows - Decorative	NW stairwell	4	48	SF	\$14,497	
Windows		Windows - Sash Lexan/ Glass Double-pane	Entire Building	4	7,900	SF	\$1,364,452	balance issues
<b>EXTERIOR Sub Total</b>							<b>\$2,206,523</b>	

**Building: Addition #'s 1 & 2 (1961)**  
**Category: ELECTRICAL**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	Electrical Room	4	1	EA	\$8,866	
Emergency System		Emergency A/C power - Corridors and Stairs	Corridors and Stairs	6	11,749	SF	\$5,040	
Emergency System		Emergency A/C power - Gym and Lunch rooms	Gym and Lunch Room	6	2,087	SF	\$1,104	
Emergency System		Emergency Battery Packs - Corridors and Stairs	Entire Building	7	26	EA	\$0	
Emergency System		Emergency Battery Packs - Lunchroom and Gym	Entire Building	7	4	EA	\$0	
Emergency System		Emergency Battery Packs - Toilets	Entire Building	6	8	EA	\$858	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	6	48	EA	\$11,188	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	Entire Building	6	6	EA	\$1,399	
Emergency System		Independent Electrical Service for emergency power	Basement	4	1	EA	\$17,160	
Emergency System		Public Announcement System	Main Office	4	94,385	SF	\$334,727	
Emergency System		Security System - CCTV	Entire Building	6	94,385	SF	\$134,971	
Emergency System		Security System - Intrusion detection	Boiler Room	6	94,385	SF	\$87,731	
Main Service		Main Electrical service - Live Front - 1500 A 120/208/3PH	Electrical Room	3	1	EA	\$130,416	Switch gear is live front and significantly deteriorated.
Power Distribution		Lighting and power panels	Entire Building	6	14	EA	\$10,010	
Power Distribution		Lighting and power panels	Entire Building	7	3	EA	\$0	
Power Distribution		Lighting and power panels	Entire Building	4	3	EA	\$16,302	
Power Distribution		Main distribution panels 400-600 amp	Electrical Room	6	2	EA	\$2,860	
Power Distribution		Main distribution panels 400-600 amp	Mechanical Room	3	1	EA	\$12,155	Distribution Panel is a Live Front
Power Distribution		Main distribution panels above 600 amp	Mechanical Room	3	2	EA	\$37,180	Distribution Panel is a Live Front
Power Distribution		Main distribution panels less than 400 amp	Mechanical Room	3	2	EA	\$13,156	Distribution Panel is a Live Front

**Building: Addition #'s 1 & 2 (1961)**  
**Category: ELECTRICAL**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
<b>ELECTRICAL Sub Total</b>							<b>\$825,123</b>	

**Building: Addition #'s 1 & 2 (1961)**  
**Category: FIRE PROTECTION**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Entire Building	6	61,088	SF	\$21,839	
Fire Alarm		Fire Alarm System	Fan Room/Trans. Vault	7	61,088	SF	\$0	
<b>FIRE PROTECTION Sub Total</b>							<b>\$21,839</b>	

**Building: Addition #'s 1 & 2 (1961)**  
**Category: MECHANICAL**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Window A/C Unit	Entire Building	6	12	EA	\$2,574	
Air Conditioning		Window A/C Unit	2nd Floor	3	1	EA	\$2,145	Unit is not working
Air Handling Systems		Air Intake - Built Up Air Handling Unit	Roof	6	2	EA	\$2,860	
Air Handling Systems		Multi Zone Built Up Air Handling Unit - Steam above 35,000 cfm	Mechanical Room	4	1	EA	\$164,450	
Air Handling Systems		Multi Zone Built Up Air Handling Unit Auxiliaries - Steam above 35,000 cfm	Fan Room	4	1	EA	\$44,330	
Air Handling Systems		Reheat Boxes With Steam Coils	Air Tunnel	5	9	EA	\$50,193	
Air Handling Systems		Single Zone Built Up Air Handling Unit - Steam 4,000 to 8,000 cfm	Fan Room	4	1	EA	\$25,740	
Air Handling Systems		Single Zone Built Up Air Handling Unit Auxiliaries - Steam 4,000 to 8,000 cfm	Fan Room	5	1	EA	\$7,150	
Boiler Systems		Boiler Assembly - Steam - Low Pressure Scotch Marine Boiler 101-150 HP	Boiler Room	4	2	EA	\$294,580	
Boiler Systems		Boiler Auxiliary - Steam Boiler 101-150 HP	Boiler Room	4	2	EA	\$45,760	
Boiler Systems		Chemical Feed System (Steam Boilers)	Boiler Room	6	1	EA	\$2,145	
Boiler Systems		Combustion Dampers	Boiler Room	6	2	EA	\$572	
Boiler Systems		Feed Water Pumps and Tank - Steam Boilers	Boiler Room	4	1	EA	\$31,460	
Boiler Systems		Gas Boosters	Mechanical Room	3	1	EA	\$13,013	Note: One of the Boosters does not operate - Active gas leak and is valved off.
Boiler Systems		Gas Boosters	Gas Booster room off Boiler Room	4	1	EA	\$13,013	
Heating Devices		Radiators - Steam	Entire Building	6	10	EA	\$1,401	
Heating Devices		Wall Heater - Electric	Entire Building	6	6	EA	\$618	
Mechanical Plumbing		Condensate Assembly - Pumps and Tank	Basement	5	2	EA	\$18,876	

**Building: Addition #'s 1 & 2 (1961)**

**Category: MECHANICAL**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Mechanical Plumbing		Piping - Condensate - Steel or Galvanized	Basement	5	500	LF	\$16,266	
Mechanical Plumbing		Piping - Steam - Steel or Galvanized	Basement	5	500	LF	\$24,739	
Temperature Control		Pneumatic System	Entire Building	4	94,385	SF	\$674,853	
Temperature Control		Thermostats - Pneumatic	Entire Building	4	20	EA	\$13,156	
Temperature Control		Zone Dampers	Air Tunnel	6	19	EA	\$2,717	
Unit Ventilation		Unit Ventilators - Steam	Entire Building	4	15	EA	\$235,950	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	5	2	EA	\$3,003	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	7	2	EA	\$0	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	5	1	EA	\$1,287	
Ventilation		Type I Exhaust Hood - Kitchen or Culinary Arts	Kitchen	2	1	EA	\$26,884	Fire suppression is not working or does not exist. Kitchen equipment are located outside the hood
<b>MECHANICAL Sub Total</b>							<b>\$1,719,735</b>	

**Building: Addition #'s 1 & 2 (1961)**

**Category: PLUMBING**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas 150,000 -300,000 BTU/HR	Boiler Room	6	1	EA	\$4,147	
Hot Water		Hot Water Heater - Gas 150,000 -300,000 BTU/HR	Boiler Room	7	1	EA	\$0	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	7	61,088	SF	\$0	
Piping		Domestic Piping - Cold Water Risers	Entire Building	4	61,088	SF	\$39,310	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	7	61,088	SF	\$0	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	4	61,088	SF	\$27,954	
Piping		Domestic Piping - Hot Water Risers	Entire Building	4	61,088	SF	\$33,195	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	4	61,088	SF	\$145,884	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	4	61,088	SF	\$120,551	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	4	61,088	SF	\$69,885	
Piping		Sanitary Piping	Entire Building	5	61,088	SF	\$37,563	
Piping		Storm Piping	Entire Building	5	61,088	SF	\$28,827	
Piping		Vent Piping	Entire Building	5	61,088	SF	\$21,839	
<b>PLUMBING Sub Total</b>							<b>\$529,156</b>	

**Building: Addition #'s 1 & 2 (1961)**

**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
-------	-----------	------	----------	------	----------	------	------	--------

**Building: Addition #'s 1 & 2 (1961)**  
**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Room 111, Assistant Principal's Office	7	557	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Room 209	7	289	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Principal's Office in Main Office	7	184	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Room 113, Counselor's Office	7	745	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Gym Office	7	65	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Room 114 (Floor Plan Room 112)	7	732	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Main Office	7	363	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Engineer's Office	6	68	SF	\$193	
Administrative Suites	Administrative Suites/Offices	Ceiling - Splined	Kitchen Office	6	66	SF	\$142	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Principal's Office in Main Office	7	184	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Room 209	7	289	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Kitchen Office	7	66	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Engineer's Office	7	68	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Gym Office	7	65	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Room 113, Counselor's Office	7	745	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Room 114 (Floor Plan Room 112)	7	732	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Room 111, Assistant Principal's Office	7	557	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Main Office	7	363	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Room 114 (Floor Plan Room 112)	7	16	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Engineer's Office	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Kitchen Office	7	1	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Gym Office	7	2	SF	\$0	

**Building: Addition #'s 1 & 2 (1961)**

**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Room 111, Assistant Principal's Office	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Room 113, Counselor's Office	7	16	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Principal's Office in Main Office	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Main Office	7	8	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Room 209	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Room 209	7	732	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Engineer's Office	6	245	SF	\$701	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Main Office	7	790	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Room 113, Counselor's Office	7	1,064	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Room 111, Assistant Principal's Office	7	1,030	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Room 114 (Floor Plan Room 112)	7	1,042	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Kitchen Office	6	283	SF	\$668	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Principal's Office in Main Office	7	460	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Structural Glazed Tile	Gym Office	7	220	SF	\$0	
Computer Labs		Charging Station	Room 218 Library	7	2	EA	\$0	
Corridor		Student Lockers	Rooms 112 & 114	7	44	EA	\$0	
Doors		Interior Steel Doors incl hw	Entire Building	7	8	EA	\$0	
Doors		Interior Wood Doors incl hw	Entire Building	7	70	EA	\$0	
Doors		Interior Wood Doors incl hw	Entire Building	6	20	EA	\$5,663	
Drinking Fountains	Corridors	Double Fountain	1st Floor	7	1	EA	\$0	
Drinking Fountains	Corridors	Double Fountain	2nd Floor	7	1	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	1st Floor	7	4	EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Ceiling - Splined	1st Floor	6	2,087	SF	\$19,399	
Gymnasium / Auditorium	Gymnasium.Auditorium	Flooring - Wood	1st Floor	7	2,087	SF	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Lighting - Metal Halide/Sodium Vapor	1st Floor	7	12	EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Sound System	1st Floor	7	1	EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Stage Curtain	1st Floor	7	2	EA	\$0	



**Building: Addition #'s 1 & 2 (1961)**

**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Gymnasium / Auditorium	Gymnasium.Auditorium	Walls - Structural Glazed Tile	1st Floor	7	3,960	SF	\$0	
Kitchen	Cooking Kitchen	Ceiling - Splined	Basement	6	498	SF	\$1,424	
Kitchen	Cooking Kitchen	Flooring - Tile/Sheet	Basement	7	498	SF	\$0	
Kitchen	Cooking Kitchen	Lighting - Pendant/Surface	Basement	7	16	SF	\$0	
Kitchen	Cooking Kitchen	Wall - Structural Glazed Tile	Basement	7	984	SF	\$0	
Library	Library	Ceiling - Splined	Room 218	6	1,226	SF	\$2,630	
Library	Library	Flooring Carpet	Room 218	7	1,226	SF	\$0	
Library	Library	Lighting - Lay-In	Room 218	7	36	SF	\$0	
Locker/Shower Room	Staff Restroom	Lockers	In the Boiler Room Area	6	5	EA	\$245	
Locker/Shower Room	Staff Restroom	Lockers	In Kitchen Area	6	4	EA	\$196	
Lunchroom	Lunchroom	Ceiling - Splined	Basement	7	1,593	SF	\$0	
Lunchroom	Lunchroom	Ceiling - Splined	Teacher's Lunchroom in Basement	7	326	SF	\$0	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	Basement	7	1,593	SF	\$0	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	Teacher's Lunchroom in Basement	7	326	SF	\$0	
Lunchroom	Lunchroom	Lighting - Pendant/Surface	Teacher's Lunchroom in Basement	7	7	SF	\$0	
Lunchroom	Lunchroom	Lighting - Pendant/Surface	Basement	7	38	SF	\$0	
Lunchroom	Lunchroom	Serving Line	Basement	7	30	LF	\$0	
Lunchroom	Lunchroom	Wall - Concrete Block	Teacher's Lunchroom in Basement	7	157	SF	\$0	
Lunchroom	Lunchroom	Wall - Plaster/Drywall	Basement	7	1,698	SF	\$0	
Lunchroom	Lunchroom	Wall - Structural Glazed Tile	Teacher's Lunchroom in Basement	7	472	SF	\$0	
MDF/IDF		Finishes	2nd Floor	7	225	SF	\$0	
MDF/IDF		Ventilation and Cooling	2nd Floor	7	225	EA	\$0	
Mechanical/Service Rooms		Boiler Room	Basement	7	1,513	SF	\$0	
Mechanical/Service Rooms		Crawl Space - Unfinished	Basement	7	17,033	SF	\$0	
Mechanical/Service Rooms		Janitor's Closet	Entire Building	7	4	SF	\$0	
Mechanical/Service Rooms		Janitor's Closet	Basement	6	1	SF	\$5	
Mechanical/Service Rooms		Mechanical/Service Rooms	Basement	6	239	SF	\$1,128	
Mechanical/Service Rooms		Mechanical/Service Rooms	Basement	7	284	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	Basement	7	660	SF	\$0	
Mechanical/Service Rooms		Storage Room	In Kitchen Area	7	90	SF	\$0	
Mechanical/Service Rooms		Storage Room	1st Floor	7	45	SF	\$0	
Mechanical/Service Rooms		Storage Room	1st Floor Lost and Found Room	6	110	SF	\$519	
Mechanical/Service Rooms		Storage Room	Rooms 108 & 110	7	50	SF	\$0	

**Building: Addition #'s 1 & 2 (1961)**

**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Mechanical/Service Rooms		Vaults	In Main Office	7	68	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	In Room 209	7	77	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	In Pre-School Room 104	7	79	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	In Kindergarten Room 108	7	56	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st Floor South Girl's Room	7	294	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st Floor Women's Room	7	35	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd Floor North Boy's Room	7	276	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	In Main Office	7	27	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	In Kindergarten Room 110	7	23	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd Floor South Boy's Room	7	276	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st Floor South Boy's Room	7	276	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st Floor North Boy's Room	7	276	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	In Kitchen Area	6	52	SF	\$402	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd Floor South Girl's Room	7	294	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	In the Boiler Room Area	6	131	SF	\$1,012	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st Floor North Girl's Room	7	294	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd Floor Women's Room	7	35	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd Floor North Girl's Room	7	294	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd Floor North Boy's Room	7	276	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	In Main Office	7	27	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Plaster/Drywall	In Kindergarten Room 110	7	23	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st Floor South Girl's Room	7	294	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st Floor North Girl's Room	7	294	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	In Room 209	7	77	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd Floor Women's Room	7	35	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	In Kitchen Area	7	52	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	In the Boiler Room Area	6	131	SF	\$371	

**Building: Addition #'s 1 & 2 (1961)**

**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd Floor North Girl's Room	7	294	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Plaster/Drywall	In Pre-School Room 104	7	79	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st Floor Women's Room	7	35	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Plaster/Drywall	In Kindergarten Room 108	7	56	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd Floor South Boy's Room	7	276	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st Floor South Boy's Room	7	276	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd Floor South Girl's Room	7	294	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st Floor North Boy's Room	7	276	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st Floor North Girl's Room	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st Floor South Boy's Room	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st Floor South Girl's Room	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd Floor South Girl's Room	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd Floor North Girl's Room	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd Floor North Boy's Room	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd Floor South Boy's Room	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st Floor North Boy's Room	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Flooring - Concrete	In Kitchen Area	7	52	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Concrete	In the Boiler Room Area	6	131	SF	\$618	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st Floor North Boy's Room	7	276	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd Floor North Boy's Room	7	276	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile Ceramic/Porcelain	In Kindergarten Room 108	7	56	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st Floor South Boy's Room	7	276	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st Floor North Girl's Room	7	294	SF	\$0	

**Building: Addition #'s 1 & 2 (1961)**

**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd Floor North Girl's Room	7	294	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd Floor South Girl's Room	7	294	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st Floor South Girl's Room	7	294	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd Floor South Boy's Room	7	276	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	1st Floor Women's Room	7	35	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile/Sheet	In Pre-School Room 104	7	79	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile/Sheet	In Kindergarten Room 110	7	23	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	2nd Floor Women's Room	7	35	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	In Room 209	7	77	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	In Main Office	7	27	SF	\$0	
Staff Restroom	Staff Restroom	Lavatory	In Kitchen Area	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	In the Boiler Room Area	6	1	EA	\$372	
Staff Restroom	Staff Restroom	Lavatory	2nd Floor Women's Room	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	In Room 209	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st Floor North Girl's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st Floor South Girl's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd Floor North Girl's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st Floor South Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd Floor South Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd Floor South Girl's Room	7	2	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	In Kindergarten Room 108	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	In Pre-School Room 104	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	In Kindergarten Room 110	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st Floor Women's Room	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	In Main Office	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd Floor North Boy's Room	7	2	EA	\$0	

**Building: Addition #'s 1 & 2 (1961)**  
**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st Floor North Boy's Room	7	2	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	In Kindergarten Room 108	7	1	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	In Pre-School Room 104	7	1	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	In Kindergarten Room 110	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd Floor North Girl's Room	7	3	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	2nd Floor Women's Room	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd Floor South Girl's Room	7	3	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st Floor South Girl's Room	7	3	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st Floor North Girl's Room	7	3	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st Floor South Boy's Room	7	4	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st Floor North Boy's Room	7	4	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	In Kitchen Area	6	2	SF	\$1	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	In the Boiler Room Area	6	2	SF	\$1	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	1st Floor Women's Room	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd Floor North Boy's Room	7	4	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	In Main Office	4	2	SF	\$9	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd Floor South Boy's Room	7	4	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	In Main Office	4	2	EA	\$644	
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	In Room 209	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd Floor North Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st Floor North Boy's Room	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	In Kitchen Area	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st Floor North Girl's Room	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st Floor South Girl's Room	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd Floor North Girl's Room	7	5	EA	\$0	

**Building: Addition #'s 1 & 2 (1961)**

**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Partitions	1st Floor South Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd Floor South Boy's Room	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	In Main Office	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd Floor South Girl's Room	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd Floor North Boy's Room	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd Floor South Boy's Room	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st Floor South Boy's Room	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st Floor North Boy's Room	7	4	EA	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	In Kitchen Area	6	241	SF	\$689	
Staff Restroom	Staff Restroom	Wall - Concrete Block	In the Boiler Room Area	6	484	SF	\$1,384	
Staff Restroom	Early Childhood Student Restroom	Wall - Concrete Block	In Kindergarten Room 108	7	245	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Wall - Concrete Block	In Pre-School Room 104	7	280	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	In Room 209	7	225	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st Floor South Girl's Room	7	189	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st Floor South Boy's Room	7	186	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	2nd Floor Women's Room	7	125	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st Floor North Girl's Room	7	189	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd Floor North Girl's Room	7	189	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st Floor North Boy's Room	7	186	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd Floor South Boy's Room	7	186	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	1st Floor Women's Room	7	125	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd Floor North Boy's Room	7	186	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	In Main Office	7	210	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Wall - Plaster/Drywall	In Kindergarten Room 110	7	170	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd Floor South Girl's Room	7	189	SF	\$0	

**Building: Addition #'s 1 & 2 (1961)**

**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd Floor North Boy's Room	7	558	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st Floor North Girl's Room	7	567	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st Floor South Girl's Room	7	567	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd Floor South Girl's Room	7	567	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd Floor North Girl's Room	7	567	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st Floor North Boy's Room	7	558	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st Floor South Boy's Room	7	558	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd Floor South Boy's Room	7	558	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	In Kindergarten Room 110	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st Floor North Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st Floor South Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd Floor South Boy's Room	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st Floor Women's Room	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	In Kindergarten Room 108	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd Floor North Girl's Room	7	6	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	In Main Office	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	In Kitchen Area	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd Floor South Girl's Room	7	6	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	In the Boiler Room Area	6	1	EA	\$372	
Staff Restroom	Staff Restroom	Water Closet	2nd Floor Women's Room	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	In Pre-School Room 104	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st Floor North Girl's Room	7	6	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st Floor South Girl's Room	7	6	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd Floor North Boy's Room	7	2	EA	\$0	

**Building: Addition #'s 1 & 2 (1961)**

**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Water Closet	In Room 209	7	1	EA	\$0	
Theater		Stage Platform	1st Floor	7	516	SF	\$0	
Vertical Conveyance		Elevator - Roped Holeless Hydraulic	Entire Building	7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	

INTERIOR Sub Total

\$38,786

**Building: Addition #'s 1 & 2 (1961)**

**Category: ROOM**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		7	18	LF	\$0	
Casework	Classroom	Casework		7	20	LF	\$0	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		7	50	LF	\$0	
Casework	Classroom	Casework		7	10	LF	\$0	
Casework	Classroom	Casework		6	60	LF	\$2,145	
Casework	Classroom	Casework		7	10	LF	\$0	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		7	18	LF	\$0	
Casework	Classroom	Casework		7	18	LF	\$0	
Casework	Classroom	Casework		7	18	LF	\$0	
Casework	Classroom	Casework		7	20	LF	\$0	
Casework	Classroom	Casework		7	18	LF	\$0	
Casework	Classroom	Casework		7	20	LF	\$0	
Casework	Classroom	Casework		7	18	LF	\$0	
Casework	Classroom	Casework		7	18	LF	\$0	
Casework	Classroom	Casework		7	18	LF	\$0	
Casework	Classroom	Casework		7	20	LF	\$0	
Casework	Classroom	Casework		7	8	LF	\$0	
Casework	Classroom	Casework		7	8	LF	\$0	
Casework	Classroom	Casework		7	8	LF	\$0	
Casework	Classroom	Casework		7	8	LF	\$0	
Casework	Classroom	Casework		7	8	LF	\$0	
Casework	Classroom	Casework		7	10	LF	\$0	



**Building: Addition #'s 1 & 2 (1961)**

**Category: ROOM**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		7	8	LF	\$0	
Casework	Classroom	Casework		7	18	LF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	750	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	750	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	750	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	780	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	780	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	780	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	780	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	780	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	780	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	343	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	735	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	780	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	770	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	1,126	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	1,157	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	732	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	711	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	711	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	711	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	770	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	735	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	770	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	770	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	770	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	770	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	1,126	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	735	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	735	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	735	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	735	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	1,136	SF	\$0	
Chalk Board	Classroom	Chalk Board		4	36	LF	\$4,376	
Chalk Board	Classroom	Chalk Board		4	18	LF	\$2,188	
Chalk Board	Classroom	Chalk Board		4	18	LF	\$2,188	
Chalk Board	Classroom	Chalk Board		4	22	LF	\$2,674	
Chalk Board	Classroom	Chalk Board		4	22	LF	\$2,674	
Chalk Board	Classroom	Chalk Board		4	22	LF	\$2,674	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	

**Building: Addition #'s 1 & 2 (1961)**

**Category: ROOM**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	36	LF	\$4,376	
Chalk Board	Classroom	Chalk Board		4	36	LF	\$4,376	
Chalk Board	Classroom	Chalk Board		4	18	LF	\$2,188	
Chalk Board	Classroom	Chalk Board		4	36	LF	\$4,376	
Chalk Board	Classroom	Chalk Board		4	18	LF	\$2,188	
Chalk Board	Classroom	Chalk Board		4	36	LF	\$4,376	
Chalk Board	Classroom	Chalk Board		4	36	LF	\$4,376	
Chalk Board	Classroom	Chalk Board		4	36	LF	\$4,376	
Chalk Board	Classroom	Chalk Board		4	28	LF	\$3,403	
Chalk Board	Classroom	Chalk Board		4	18	LF	\$2,188	
Chalk Board	Classroom	Chalk Board		4	18	LF	\$2,188	
Chalk Board	Classroom	Chalk Board		4	18	LF	\$2,188	
Chalk Board	Classroom	Chalk Board		4	18	LF	\$2,188	
Chalk Board	Classroom	Chalk Board		4	36	LF	\$4,376	
Chalk Board	Classroom	Chalk Board		4	18	LF	\$2,188	
CLASSROOM	Classroom	Eye Wash Station		7	1	EA	\$0	
CLASSROOM	Classroom	Science Lab Elements		7	1,136	SF	\$0	
Corridors	Corridors	Pendant/Surface	2nd Floor	7	54	EA	\$0	
Corridors	Corridors	Pendant/Surface	1st Floor	7	102	EA	\$0	
Corridors	Corridors	Plaster/Drywall	2nd Floor	7	5,345	SF	\$0	
Corridors	Corridors	Plaster/Drywall	1st Floor	7	6,865	SF	\$0	
Corridors	Corridors	Single Water Cooler	2nd Floor	7	2	EA	\$0	
Corridors	Corridors	Splined	2nd Floor	7	5,070	SF	\$0	
Corridors	Corridors	Splined	1st Floor	7	6,679	SF	\$0	
Corridors	Corridors	Stair Handrails	1st Floor	7	198	LF	\$0	
Corridors	Corridors	Stair Handrails	2nd Floor	7	198	LF	\$0	
Corridors	Corridors	Structural Glazed Tile	1st Floor	7	6,865	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	2nd Floor	7	5,345	SF	\$0	
Corridors	Corridors	Student Lockers	2nd Floor	7	209	EA	\$0	
Corridors	Corridors	Student Lockers	1st Floor	7	209	EA	\$0	
Corridors	Corridors	Terrazzo	1st Floor	7	994	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	2nd Floor	7	5,070	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	1st Floor	7	5,685	SF	\$0	

**Building: Addition #'s 1 & 2 (1961)**

**Category: ROOM**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Stairs	Corridors	Terrazzo	1st Floor	7	84	SF	\$0	
Stairs	Corridors	Terrazzo	2nd Floor	7	84	SF	\$0	
Floor	Classroom	Carpet		7	173	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,136	SF	\$0	
Floor	Classroom	Tile/Sheet		7	770	SF	\$0	
Floor	Classroom	Tile/Sheet		6	770	SF	\$1,101	
Floor	Classroom	Tile/Sheet		7	770	SF	\$0	
Floor	Classroom	Tile/Sheet		7	711	SF	\$0	
Floor	Classroom	Tile/Sheet		7	711	SF	\$0	
Floor	Classroom	Tile/Sheet		6	770	SF	\$1,101	
Floor	Classroom	Tile/Sheet		7	750	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,157	SF	\$0	
Floor	Classroom	Tile/Sheet		7	170	SF	\$0	
Floor	Classroom	Tile/Sheet		7	750	SF	\$0	
Floor	Classroom	Tile/Sheet		7	732	SF	\$0	
Floor	Classroom	Tile/Sheet		6	1,126	SF	\$1,610	
Floor	Classroom	Tile/Sheet		7	780	SF	\$0	
Floor	Classroom	Tile/Sheet		7	780	SF	\$0	
Floor	Classroom	Tile/Sheet		7	780	SF	\$0	
Floor	Classroom	Tile/Sheet		7	780	SF	\$0	
Floor	Classroom	Tile/Sheet		6	735	SF	\$1,051	
Floor	Classroom	Tile/Sheet		7	780	SF	\$0	
Floor	Classroom	Tile/Sheet		6	770	SF	\$1,101	
Floor	Classroom	Tile/Sheet		7	750	SF	\$0	
Floor	Classroom	Tile/Sheet		6	735	SF	\$1,051	
Floor	Classroom	Tile/Sheet		6	735	SF	\$1,051	
Floor	Classroom	Tile/Sheet		6	735	SF	\$1,051	
Floor	Classroom	Tile/Sheet		6	735	SF	\$1,051	
Floor	Classroom	Tile/Sheet		7	1,126	SF	\$0	
Floor	Classroom	Tile/Sheet		7	780	SF	\$0	
Floor	Classroom	Tile/Sheet		7	711	SF	\$0	
LIBRARY_WALL	Library	Plaster/Drywall	Room 218	7	1,230		\$0	
Lighting	Classroom	Lay-In		7	16	EA	\$0	
Lighting	Classroom	Lay-In		7	8	EA	\$0	
Lighting	Classroom	Lay-In		7	16	EA	\$0	
Lighting	Classroom	Lay-In		7	16	EA	\$0	
Lighting	Classroom	Lay-In		7	16	EA	\$0	



**Building: Addition #'s 1 & 2 (1961)**

**Category: ROOM**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		7	22	LF	\$0	
Marker Board	Classroom	Marker Board		7	22	LF	\$0	
Marker Board	Classroom	Marker Board		7	22	LF	\$0	
Marker Board	Classroom	Marker Board		7	18	LF	\$0	
Marker Board	Classroom	Marker Board		7	18	LF	\$0	
Marker Board	Classroom	Marker Board		7	18	LF	\$0	
Marker Board	Classroom	Marker Board		7	18	LF	\$0	
Marker Board	Classroom	Marker Board		7	18	LF	\$0	
Marker Board	Classroom	Marker Board		7	18	LF	\$0	
Wall	Classroom	Concrete Block		7	1,046	SF	\$0	
Wall	Classroom	Concrete Block		7	1,232	SF	\$0	
Wall	Classroom	Concrete Block		7	1,232	SF	\$0	
Wall	Classroom	Concrete Block		7	1,232	SF	\$0	
Wall	Classroom	Concrete Block		7	1,280	SF	\$0	
Wall	Classroom	Concrete Block		7	1,046	SF	\$0	
Wall	Classroom	Concrete Block		7	1,046	SF	\$0	
Wall	Classroom	Concrete Block		7	1,046	SF	\$0	
Wall	Classroom	Concrete Block		7	1,280	SF	\$0	
Wall	Classroom	Concrete Block		7	1,046	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	740	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,290	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,022	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,022	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,092	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,092	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,092	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,092	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,182	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,182	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,182	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,232	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,232	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,232	SF	\$0	

**Building: Addition #'s 1 & 2 (1961)**

**Category: ROOM**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Plaster/Drywall		7	1,300	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,042	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	1,022	SF	\$2,411	
Wall	Classroom	Plaster/Drywall		7	1,092	SF	\$0	
<b>ROOM Sub Total</b>							<b>\$93,861</b>	
<b>Building Addition #'s 1 &amp; 2 (1961) Sub Total</b>							<b>\$5,435,022</b>	

**Building: SITE**

**Category: SITE**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Athletic		Baseball - Natural	SW site	6	21,354	SF	\$12,214	lawn maintenance
Athletic		Basketball - Asphalt	mid site	6	4,878	SF	\$3,697	cracks/sealant
Civil/Drainage		Catch Basin	throughout site	7	4	EA	\$0	
Civil/Drainage		Site Drain	N basement well	7	1	EA	\$0	
Civil/Drainage		Site Manhole	throughout site	7	3	EA	\$0	
Fencing		Chain Link	baseball backstop & N site	6	70	LF	\$1,004	
Fencing		Ornamental Iron	throughout site	6	1,429	LF	\$26,974	rust/paint
Landscape		Asphalt Play Area/Hardscape	mid site	6	5,654	SF	\$4,851	sealant/cracks
Landscape		Grass	throughout site	6	10,145	SF	\$4,062	
Landscape		Hardscape - Concrete	throughout site	6	8,358	SF	\$15,777	pitting/cleaning/minor cracks
Landscape		Irrigation	N site	6	5,058	SF	\$2,893	needs sprinkler heads
Landscape		Parkway trees	throughout site perimeter	7	30	EA	\$0	
Landscape		Planting Beds/ Areas	throughout site	6	7,514	SF	\$0	
Landscape		Retaining Wall - Concrete	Main Entrance	6	260	SF	\$6,135	
Landscape		Retaining Wall - Concrete	basement wells	7	640	SF	\$0	
Landscape		Retaining Wall - Concrete	N elevation, basement well	6	8	SF	\$189	producing water
Landscape		Trash Receptacles	throughout site	7	6	EA	\$0	
Landscape		Walking Path - Crushed Stone	S site	6	2,565	SF	\$0	
Parking Lot		Asphalt	S site	6	6,498	SF	\$5,575	minor cracking
Parking Lot		Asphalt	N site	4	6,538	SF	\$56,096	cracks & potholes
Parking Lot		Trash Enclosure	N site	7	953	SF	\$0	
Playground		Playground Equipment - Combo 3-12	W site	6	1	EA	\$0	graffiti
Playground		Playground Equipment - Combo 3-12	SE site	7	1	EA	\$0	
Playground		Playground Surfacing - Poured Surface	SE site	7	1,673	SF	\$0	
Playground		Playground Surfacing - Square Rubber Mats	W site	4	2,222	SF	\$49,251	

**Building: SITE**  
**Category: SITE**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Sidewalks		Internal Walks	throughout site	6	445	LF	\$4,200	minor cracks/cleaning
Sidewalks		Perimeter Sidewalks	throughout site perimeter	6	19,665	SF	\$37,120	minor cracks/cleaning
Signage		Flag Pole	NW site	7	1	EA	\$0	
Signage		Marquee - Free Standing Back Lighted w/ LED	NE site	7	1	EA	\$0	
<b>SITE Sub Total</b>							<b>\$230,037</b>	
<b>SITE Sub Total</b>							<b>\$230,037</b>	

**Total Campus Need <sup>2 3</sup> \$7,199,524**

<sup>1</sup> It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

<sup>2</sup> As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

<sup>3</sup> The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.

**Room Summary**

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
<b>Building: Main</b>														
120	847	1	0	10	40	232	116	1	N	Y	Y	Classroom		
121	847	1	0	70	40	145	72	1	N	N	N	Classroom		
123	780	1	6	12	40	145	72	0	N	Y	N	Classroom		
124	847	1	0	10	40	174	87	0	N	Y	Y	Classroom		
220	847	1	0	10	40	232	116	1	N	Y	Y	Classroom		
221	847	1	0	70	40	145	72	0	N	N	N	Classroom		
222	654	1	6	12	40	145	72	0	N	N	Y	Classroom		
223	847	1	0	10	40	145	72	0	N	Y	N	Classroom		
224	847	1	0	10	40	174	87	0	N	Y	Y	Classroom		
320	847	1	0	10	40	232	116	1	N	Y	Y	Classroom		
321	847	1	0	70	40	145	72	0	N	N	N	Classroom		
323	847	1	0	10	40	145	72	0	N	Y	N	Classroom		
324	847	1	0	10	40	174	87	0	N	Y	Y	Classroom		
B-2	908	1	1	14	40	126	56	0	N	N	N	Classroom		
Other	654			8					N	N	Y	Administrative Suites/Offices		Room 322 (304), Parent's Room
Other	60								N	N	N	Restroom	Staff Restroom	2nd Floor Women's Room
Other	2186								N	N	N	Corridors		Lower Level
Other	1878								N	N	N	Corridors		1st Floor
Other	1843								N	N	N	Corridors		2nd Floor
Other	1564								N	N	N	Corridors		3rd Floor
Other	692			10					N	N	N	Administrative Suites/Offices		Room 220, Teacher's Resource
Other	79								N	N	N	Restroom	Staff Restroom	3rd Floor
Other	636			10					N	N	Y	Administrative Suites/Offices		Main Office (Floor Plan Room 104)
Other	96			4					N	N	N	Administrative Suites/Offices		Lower Level Office 221-124
Other	405								N	N	N	Restroom	Children's Standard Student Restroom	1st Floor Boy's Room
Other	29								N	N	N	Restroom	Staff Restroom	In Main Office
Other	579								N	N	N	Restroom	Children's Standard Student Restroom	1st Floor Girl's Room
Other	54								N	N	N	Restroom	Staff Restroom	2nd Floor Men's Room

**Building: Addition #'s 1 & 2 (1961)**

101	780	1	6	12	50	192	96	0	N	N	N	Classroom		
102	770	1	6	18	40	168	84	1	N	Y	Y	Classroom		
103	780	1	6	12	50	192	96	0	N	N	N	Classroom		
104	1126	1	1	8	40	252	126	1	N	N	Y	Classroom		
105	780	1	6	12	50	192	96	0	N	N	N	Classroom		



**Room Summary**

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
107	780	1	6	12	50	192	96	0	N	N	N	Classroom		
108	1126	1	1	8	40	252	126	0	N	Y	Y	Classroom		
109	780	1	6	12	50	192	96	0	N	N	N	Classroom		
110	1157	1	1	8	40	252	126	0	N	Y	Y	Classroom		
112	732	1	1	8	40	168	84	0	N	Y	Y	Classroom		
113	780	1	6	12	50	192	96	0	N	N	N	Classroom		
116	343	1	1	8	40	84	42	0	N	N	Y	Classroom		
201	750	0	8	20	50	192	96	0	N	Y	Y	Classroom		
202	770	1	6	18	40	168	84	1	N	Y	Y	Classroom		
203	750	0	8	20	50	192	96	0	N	Y	Y	Classroom		
204	770	1	6	18	40	168	84	0	N	Y	Y	Classroom		
205	750	0	8	24	50	192	96	0	N	Y	Y	Classroom		
206	770	1	40	80	40	168	84	2	N	N	Y	Classroom		
207	735	0	6	16	50	150	78	2	N	Y	Y	Classroom		
208	770	1	6	18	40	168	84	0	N	Y	Y	Classroom		
210	1136	1	2	16	40	252	126	1	N	N	Y	Classroom		
211	735	0	6	16	50	150	78	2	N	Y	Y	Classroom		
212	711	1	6	18	40	168	84	1	N	Y	Y	Classroom		
213	735	0	6	16	50	150	78	2	N	Y	Y	Classroom		
214	711	1	6	18	40	168	84	0	N	Y	Y	Classroom		
215	735	0	6	18	50	150	78	2	N	Y	Y	Classroom		
216	711	1	6	18	40	168	84	0	N	Y	Y	Classroom		
217	735	0	18	42	50	150	78	1	N	Y	Y	Classroom		
Other	35								N	N	N	Restroom	Staff Restroom	2nd Floor Women's Room
Other	35								N	N	N	Restroom	Staff Restroom	1st Floor Women's Room
Other	557			6					N	N	N	Administrative Suites/Offices		Room 111, Assistant Principal's Office
Other	745			16					N	N	N	Administrative Suites/Offices		Room 113, Counselor's Office
Other	2087								N	N	N	Gymnasia	Gymnasium.Auditorium	1st Floor
Other	65			4					N	N	N	Administrative Suites/Offices		Gym Office
Other	5070								N	N	N	Corridors		2nd Floor
Other	6679								N	N	N	Corridors		1st Floor
Other	1593								N	N	N	Lunch & Multipurpose Room	Lunchroom	Basement
Other	498								N	N	N	Kitchen	Cooking Kitchen	Basement
Other	77								N	N	N	Restroom	Staff Restroom	In Room 209
Other	52								N	N	N	Restroom	Staff Restroom	In Kitchen Area
Other	732			8					N	N	Y	Administrative Suites/Offices		Room 114 (Floor Plan Room 112)
Other	66			4					N	N	Y	Administrative Suites/Offices		Kitchen Office

**Room Summary**

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	326								N	N	N	Lunch & Multipurpose Room	Lunchroom	Teacher's Lunchroom in Basement
Other	131								N	N	N	Restroom	Staff Restroom	In the Boiler Room Area
Other	276								N	N	N	Restroom	Children's Standard Student Restroom	2nd Floor South Boy's Room
Other	184			8					N	N	Y	Administrative Suites/Offices		Principal's Office in Main Office
Other	68			4					N	N	N	Administrative Suites/Offices		Engineer's Office
Other	23								N	N	N	Restroom	Early Childhood Student Restroom	In Kindergarten Room 110
Other	56								N	N	N	Restroom	Early Childhood Student Restroom	In Kindergarten Room 108
Other	79								N	N	N	Restroom	Early Childhood Student Restroom	In Pre-School Room 104
Other	1226								N	N	N	Library		Room 218
Other	276								N	N	N	Restroom	Children's Standard Student Restroom	1st Floor South Boy's Room
Other	363			8					N	N	Y	Administrative Suites/Offices		Main Office
Other	289			4					N	N	Y	Administrative Suites/Offices		Room 209
Other	276								N	N	N	Restroom	Children's Standard Student Restroom	2nd Floor North Boy's Room
Other	276								N	N	N	Restroom	Children's Standard Student Restroom	1st Floor North Boy's Room
Other	294								N	N	N	Restroom	Children's Standard Student Restroom	2nd Floor North Girl's Room
Other	294								N	N	N	Restroom	Children's Standard Student Restroom	2nd Floor South Girl's Room
Other	294								N	N	N	Restroom	Children's Standard Student Restroom	1st Floor South Girl's Room
Other	294								N	N	N	Restroom	Children's Standard Student Restroom	1st Floor North Girl's Room
Other	27								N	N	N	Restroom	Staff Restroom	In Main Office