

## Facility Assessment Report

This report contains a summary of the results from the facility assessment completed on the date noted in the document footer below. This report will roll-up each assessed item with identical rank and total the quantity into a single line, regardless of item location (for location data, see the detailed report) . Assessors rate each facility item by visual observation only; they do not test the operation of equipment or perform destructive testing of walls, ceilings or floors. Each facility item is ranked on a 7-point scale: rank 7 means the item is in new or in good condition and no work is required while rank 1 means the item has failed and has lead to an immediate life safety condition<sup>1</sup>. The remaining ranks choices generally mean that the item requires regular maintenance (rank 5 or 6) or full replacement (rank 2, 3 or 4). For additional detail and definition on rank values as they relate to each assessed item, please visit the "CPS Guide to Biennial Facility Assessments" found on the Facilities Standards webpage under CPS Policies and Guidelines at [http://www.cps.edu/About\\_CPS/Policies\\_and\\_guidelines/Pages/facilitystandards.aspx](http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx). Definitions for Quantity, Unit, Cost and Campus Total can be found at the end of this report.

Campus Summary				
Building Name	Year Constructed	Number of Floors	Building Area (Sq Ft)	Assessed Need
Main	2013	3	212,285	\$1,204,848
SITE				\$331,607
<b>Campus Total</b>			<b>212,285</b>	<b>\$1,536,455</b>

### Building: Main

#### Category: Building Exterior

Group	Item - Type	Quantity	Unit	Rank	Cost
<b>Entrance</b>					
	Entrance Control - Audio	1	EA	7	\$0
	Entrance Control - Audio and Video	6	EA	7	\$0
	Exterior Doors - Exterior Steel Door	12	EA	7	\$0
	Exterior Doors - Overhead Rolling/ Garage Door	1	EA	7	\$0
	Exterior Doors - Side lite	6	EA	7	\$0
	Exterior Doors - Store Front	24	EA	7	\$0
	Exterior Doors - Transom Lite	13	EA	7	\$0
	Exterior Stairs - Concrete	1,040	LF	7	\$0
	Power Door Operator and Controls	7	EA	7	\$0
	Ramp Handrail - Steel_Ramp Handrail	720	LF	7	\$0
	Ramps	125	LF	7	\$0
	Ramps - Concrete	235	LF	7	\$0
	Stair Handrail - Steel_Stair Handrail	230	LF	7	\$0
<b>Foundation</b>					
	Foundation - Concrete	1,783	LF	7	\$0
	Superstructure - Metal Deck/ Concrete Topping	212,285	SF	7	\$0
<b>Lighting</b>					
	Exterior Lighting - Wall Mounted	37	EA	6	\$10,684

**Building: Main**

**Category: Building Exterior**

Group	Item - Type	Quantity	Unit	Rank	Cost
<b>Roof System</b>					
	Chimney - Metal Flue	10	LF	7	\$0
	Coping - Metal	3,599	LF	7	\$0
	Downspouts - Interior Downspouts	1	LF	5	\$0
	Downspouts - Interior Downspouts	4,301	LF	7	\$0
	Parapet - 16" - 30" Height	1,422	LF	7	\$0
	Parapet - Parapet < 16" Height	1,535	LF	7	\$0
	Parapet - Parapet > 30"	642	LF	7	\$0
	Roof - Modified Bitumen	1,000	SF	3	\$51,437
	Roof - Modified Bitumen	85,505	SF	7	\$0
	Roof Structure - Steel / Metal Deck/ Concrete Topping	86,505	SF	7	\$0
<b>Walls</b>					
	Exterior Walls	2,547	SF	7	\$0
	Exterior Walls - Brick	100	SF	6	\$908
	Exterior Walls - Brick	3,761,594	SF	7	\$0
	Exterior Walls - Prefabricated Metal Panel Wall	12,559	SF	7	\$0
<b>Windows</b>					
	Clerestory - Glass Double-Pane	1,471	SF	7	\$0
	Curtain wall - Glazed Double Pane	13,533	SF	7	\$0
	Guard - Guards perforated	5,611	SF	7	\$0
	Lintels - Steel	913	LF	7	\$0
	Storefront Windows	2,504	SF	7	\$0
	Windows - Casement Aluminum Double-pane	10,951	SF	7	\$0
	Windows - Louver	288	SF	7	\$0

**Building Exterior Subtotal:**

**\$63,029**

**Building: Main**

**Category: Electrical System**

Group	Item - Type	Quantity	Unit	Rank	Cost
<b>Emergency System</b>					
	Automatic Transfer Switch	3	EA	7	\$0
	Emergency A/C Power - Corridors and Stairs	43,081	SF	7	\$0
	Emergency A/C Power - Gym	5,635	SF	7	\$0
	Emergency A/C Power - Lunchrooms	4,269	SF	7	\$0
	Emergency A/C Power - Pool	8,005	SF	7	\$0
	Emergency A/C Power - Students Toilets	4,734	SF	7	\$0

**Building: Main**

**Category: Electrical System**

Group	Item - Type	Quantity	Unit	Rank	Cost
<b>Emergency System</b>					
	Emergency Battery Packs - Auditorium and Aisle Lighting	4	EA	7	\$0
	Emergency Battery Packs - Corridors and Stairs	3	EA	7	\$0
	Emergency Generator- Indoor- Natural Gas - Above 250 KW	1	EA	7	\$0
	Exit Signs - Corridors and Stairs	24	EA	7	\$0
	Exit Signs - Gym	6	EA	7	\$0
	Exit Signs - Lunchroom	7	EA	7	\$0
	Exit Signs - Pool	5	EA	7	\$0
	Security System - CCTV	212,285	SF	7	\$0
	Security System - Intrusion Detection	212,285	SF	7	\$0
	UPS - Less than 30 KW	1	EA	7	\$0
<b>Main Service</b>					
	Independent Electrical Service for emergency power	1	EA	7	\$0
	Main Electrical Service - 2001 to 3000 A 277/480/3PH	1	EA	7	\$0
	Main Electrical Service - Greater than 3000 A 120/208/3PH	1	EA	7	\$0
	PA System	212,285	SF	7	\$0
<b>Power Distribution</b>					
	Lighting and Power Panels - 100 A	2	EA	7	\$0
	Lighting and Power Panels - Above 100 A	29	EA	7	\$0
	Main Distribution Panels - 400 - 600 amp	5	EA	7	\$0
	Main Distribution Panels - Greater than 600 amp	2	EA	7	\$0
	Transformers - 277/480 - 120/208	4	EA	7	\$0
<b>Electrical System Subtotal:</b>					<b>\$0</b>

**Building: Main**

**Category: Safty System**

Group	Item - Type	Quantity	Unit	Rank	Cost
<b>Fire Alarm</b>					
	Fire Alarm Panel	1	EA	7	\$0
	Fire Alarm Strobe Lights	212,285	SF	7	\$0
	Fire Alarm_System	212,285	SF	7	\$0
	Fire Pump Controller	1	EA	7	\$0
<b>Pump Room Assembly</b>					
	Fire Pump - 25-50 hp	1	EA	7	\$0
	Jockey Pump	1	EA	7	\$0

**Building: Main**

**Category: Safty System**

Group	Item - Type	Quantity	Unit	Rank	Cost
<b>Sprinkler System</b>					
	Dry Sprinkler System	4,000	SF	7	\$0
	Sprinkler Heads	212,285	SF	7	\$0
	Sprinkler Piping	212,285	SF	7	\$0
	Wet Sprinkler System	208,285	SF	7	\$0

**Safty System Subtotal: \$0**

**Building: Main**

**Category: Mechanical System**

Group	Item - Type	Quantity	Unit	Rank	Cost
<b>Air Conditioning</b>					
	Chemical Pot Feeder	1	EA	7	\$0
	Chiller-Air Cooled-Scroll Type-Roof Mounted - Greater than 200 tons	1	EA	7	\$0
	Condensing Unit- Roof Mounted - Less than 5 tons	4	EA	7	\$0
	Glycol Feed	1	EA	7	\$0
	Pipes - Chilled Water Pipe- Copper	1,000	LF	7	\$0
	Pressure Fill System	1	EA	7	\$0

**Air Handling Systems**

	Air Handling Unit-Package Single Zone- Indoor- Hot Water and Chilled Water Coils - 12001-20000 cfm	2	EA	7	\$0
	Air Handling Unit-Package Single Zone- Indoor- Hot Water and Chilled Water Coils - 20001-30000 cfm	1	EA	7	\$0
	Air Handling Unit-Package Single Zone- Indoor- Hot Water and Chilled Water Coils - Greater than 30,000 cfm	2	EA	7	\$0
	Air Intake	5	EA	7	\$0
	Dehumidification Unit- Indoor- Electric Heating- DX Cooling with Self Contained Compressor - Greater than 8000 cfm	1	EA	7	\$0
	Energy Recovery Unit	5	EA	7	\$0
	Fan Power Box - Fan Power Box with Hot Water Coil	30	EA	6	\$14,784
	Indoor Return Fans- Centrifugal Inline - 10001 - 20000 CFM	3	EA	7	\$0
	Indoor Return Fans- Centrifugal Inline - Greater than 20000 CFM	3	EA	7	\$0
	VAV Box	162	EA	7	\$0

**Boiler Systems**

	Boiler Auxiliary- Condensing Hot Water - 2001 - 3000 HP	3	EA	7	\$0
	Chemical Pot Feeder	1	EA	7	\$0
	Combustion Dampers	3	EA	7	\$0
	Condensing- Hot Water Boiler - 2001 - 3000 MBH	3	EA	7	\$0

**Building: Main**
**Category: Mechanical System**

Group	Item - Type	Quantity	Unit	Rank	Cost
<b>Boiler Systems</b>					
	Glycol Feed System	1	EA	7	\$0
	Water Fill System	1	EA	7	\$0
<b>Heating Devices</b>					
	Cabinet Heaters - With Hot Water Coil	10	EA	7	\$0
	Fin Tube - Hot Water	150	LF	7	\$0
	Unit Heater - Electric	4	EA	7	\$0
	Unit Heater - Hot Water	2	EA	7	\$0
<b>Mechanical Plumbing</b>					
	Chilled Water Pump - 10 - 20 HP	2	EA	7	\$0
	Chilled Water Pump - Less than 10	2	EA	7	\$0
	Hot Water Pump - 21 - 50 HP	2	EA	7	\$0
	Hot Water Pump - Less than 10	2	EA	7	\$0
	Hydronic Supply and Return - Copper	2,000	LF	7	\$0
<b>Temperature Control</b>					
	DDC System	212,285	SF	7	\$0
	Electric Thermostat	2	EA	7	\$0
	Thermostats - DDC	166	EA	7	\$0
<b>Ventilation</b>					
	Exhaust Fans- Indoor - Less than 500 CFM	5	EA	7	\$0
	Exhaust Fans- Roof Mounted - 1501 - 8000 CFM	2	EA	7	\$0
	Exhaust Fans- Roof Mounted - 500 - 1500 CFM	2	EA	7	\$0
	Lab Exhaust Hood	4	EA	7	\$0
	Type I Exhaust Hood- Kitchen	1	EA	7	\$0
	Type II Exhaust Hood- Warming Kitchen	2	EA	7	\$0
<b>Mechanical System Subtotal:</b>					<b>\$14,784</b>

**Building: Main**
**Category: Plumbing System**

Group	Item - Type	Quantity	Unit	Rank	Cost
<b>Hot Water</b>					
	Gas Heater - 300001 - 600000 BTU/HR	3	EA	7	\$0
<b>Piping</b>					
	Domestic Piping-Cold Water from Risers to Fixtures	212,285	SF	7	\$0

**Building: Main**

**Category: Plumbing System**

Group	Item - Type	Quantity	Unit	Rank	Cost
<b>Piping</b>					
	Domestic Piping-Cold Water Horizontal Lines	212,285	SF	7	\$0
	Domestic Piping-Cold Water Risers	212,285	SF	7	\$0
	Domestic Piping-Hot Water from Risers to Fixtures	212,285	SF	7	\$0
	Domestic Piping-Hot Water Horizontal Lines	212,285	SF	7	\$0
	Domestic Piping-Hot Water Return Lines	212,285	SF	7	\$0
	Domestic Piping-Hot Water Return Risers	212,285	SF	7	\$0
	Sanitary Piping	212,285	SF	7	\$0
	Storm Piping	212,285	SF	7	\$0
	Vent Piping	212,285	SF	7	\$0

**Pool Systems**

	Pool Drain Piping	100	LF	7	\$0
	Pool Filtration System including Pump	1	EA	7	\$0
	Pool Hot Water Heater - Gas Fired	1	EA	7	\$0
	Pool Supply and Return Piping	100	LF	7	\$0

**Pumps**

	Pumps - Domestic Booster Pump-Duplex	1	EA	7	\$0
	Pumps - Ejector-Simplex	1	EA	7	\$0
	Pumps - Sump-Duplex	2	EA	7	\$0
	Pumps - Sump-Simplex	2	EA	7	\$0

**Plumbing System Subtotal: \$0**

**Building: Main**

**Category: Classrooms**

Group	Item - Type	Quantity	Unit	Rank	Cost
<b>Art Room (2 rooms)</b>					
	Casework	120	LF	7	\$0
	Ceiling - Plaster/Drywall	2,196	SF	7	\$0
	Doors - Side-lite	60	SF	7	\$0
	Doors - Steel Doors incl hw	5	EA	7	\$0
	Floor - Tile	2,196	SF	7	\$0
	Lighting - Pendent/Surface	24	EA	7	\$0
	Walls - Plaster/Drywall	2,514	SF	7	\$0
	Work Sink	6	EA	7	\$0

**Building: Main**

**Category: Classrooms**

Group	Item - Type	Quantity	Unit	Rank	Cost
<b>Band Room (1 room)</b>					
	Casework	30	LF	7	\$0
	Ceiling - Plaster/Drywall	1,612	SF	7	\$0
	Doors - Side-lite	24	SF	7	\$0
	Doors - Steel Doors incl hw	3	EA	7	\$0
	Doors - Transom Window	10	SF	7	\$0
	Floor - Carpet	1,612	SF	7	\$0
	Instrument Storage Casework	106	LF	7	\$0
	Lighting - Pendent/Surface	19	EA	7	\$0
	Risers	18	LF	7	\$0
	Sound System	1	EA	7	\$0
	Walls - Plaster/Drywall	1,898	SF	7	\$0
<b>Choral Room (1 room)</b>					
	Ceiling - Plaster/Drywall	1,093	SF	7	\$0
	Doors - Steel Doors incl hw	2	EA	7	\$0
	Floor - Carpet	1,093	SF	7	\$0
	Lighting - Pendent/Surface	9	EA	7	\$0
	Sound System	1	EA	7	\$0
	Walls - Plaster/Drywall	1,224	SF	7	\$0
<b>Computer Lab (5 rooms)</b>					
	Casework	3	LF	6	\$76
	Casework	3	LF	7	\$0
	Ceiling - Lay-in	2,964	SF	6	\$8,901
	Ceiling - Lay-in	2,338	SF	7	\$0
	Charging Station	3	EA	6	\$1,454
	Doors - Side-lite	12	SF	6	\$201
	Doors - Side-lite	80	SF	7	\$0
	Doors - Steel Doors incl hw	1	EA	6	\$301
	Doors - Steel Doors incl hw	8	EA	7	\$0
	Doors - Transom Window	72	SF	7	\$0
	Floor - Carpet	744	SF	6	\$1,585
	Floor - Tile	2,220	SF	6	\$4,857
	Floor - Tile	2,338	SF	7	\$0
	Lighting - Lay-in	130	EA	7	\$0
	Marker Board	38	LF	7	\$0
	Storage/ Closet	79	SF	6	\$573
	Walls - Plaster/Drywall	4,124	SF	6	\$11,382

**Building: Main**
**Category: Classrooms**

Group	Item - Type	Quantity	Unit	Rank	Cost
<b>Computer Lab (5 rooms)</b>					
	Walls - Plaster/Drywall	3,348	SF	7	\$0
	Walls - Structural Glazed Tile	248	SF	7	\$0
	Wireless System	3	EA	6	\$1,115
	Wireless System	1	EA	7	\$0
<b>Fitness Room (1 room)</b>					
	Ceiling - Lay-in	1,305	SF	7	\$0
	Doors - Side-lite	20	SF	7	\$0
	Doors - Steel Doors incl hw	5	EA	7	\$0
	Doors - Transom Window	16	SF	7	\$0
	Floor - Weight/ Fitness Room Floor Matting	1,305	SF	7	\$0
	Lighting - Lay-in	16	EA	7	\$0
	Storage/ Closet	51	SF	7	\$0
	Walls - Concrete Block	1,000	SF	7	\$0
<b>Music Room (3 rooms)</b>					
	Ceiling - Lay-in	342	SF	7	\$0
	Doors - Side-lite	36	SF	7	\$0
	Doors - Steel Doors incl hw	3	EA	7	\$0
	Floor - Carpet	342	SF	7	\$0
	Lighting - Lay-in	6	EA	7	\$0
	Walls - Plaster/Drywall	1,190	SF	7	\$0
<b>Regular Classroom (27 rooms)</b>					
	Casework	32	LF	6	\$808
	Casework	397	LF	7	\$0
	Ceiling - Exposed	1,320	SF	7	\$0
	Ceiling - Lay-in	1	SF	4	\$14
	Ceiling - Lay-in	9,194	SF	6	\$27,610
	Ceiling - Lay-in	9,086	SF	7	\$0
	Ceiling - Plaster/Drywall	164	SF	7	\$0
	Doors - Side-lite	246	SF	7	\$0
	Doors - Steel Doors incl hw	30	EA	7	\$0
	Doors - Transom Window	234	SF	7	\$0
	Floor - Epoxy/ Painted	1,320	SF	7	\$0
	Floor - Tile	12,025	SF	6	\$26,309
	Floor - Tile	6,420	SF	7	\$0
	Lighting - Lay-in	465	EA	7	\$0
	Lighting - Pendent/Surface	14	EA	7	\$0



**Building: Main**
**Category: Classrooms**

Group	Item - Type	Quantity	Unit	Rank	Cost
<b>Regular Classroom (27 rooms)</b>					
	Marker Board	430	LF	7	\$0
	Storage/ Closet	22	SF	6	\$160
	Storage/ Closet	439	SF	7	\$0
	Walls - Concrete Block	1,698	SF	7	\$0
	Walls - Plaster/Drywall	4	SF	5	\$20
	Walls - Plaster/Drywall	15,042	SF	6	\$41,514
	Walls - Plaster/Drywall	13,660	SF	7	\$0
	Walls - Structural Glazed Tile	20	SF	6	\$63
	Walls - Structural Glazed Tile	786	SF	7	\$0
<b>Science (2 rooms)</b>					
	Casework	32	LF	7	\$0
	Ceiling - Lay-in	880	SF	7	\$0
	Ceiling - Plaster/Drywall	925	SF	7	\$0
	Doors - Steel Doors incl hw	4	EA	7	\$0
	Doors - Transom Window	10	SF	7	\$0
	Floor - Tile	1,792	SF	7	\$0
	Floor - Tile Ceramic/ Porcelain	13	SF	7	\$0
	Gas Line	26	EA	7	\$0
	Lighting - Lay-in	50	EA	7	\$0
	Marker Board	32	LF	7	\$0
	Science Lab Elements	146	SF	7	\$0
	Science Lab Shower	2	EA	7	\$0
	Walls - Plaster/Drywall	2,642	SF	7	\$0
	Walls - Structural Glazed Tile	84	SF	7	\$0
	Work Sink	13	EA	7	\$0
<b>Science Lab Level 1 (2 rooms)</b>					
	Casework	66	LF	7	\$0
	Ceiling - Lay-in	2,450	SF	6	\$7,357
	Doors - Side-lite	24	SF	7	\$0
	Doors - Steel Doors incl hw	3	EA	7	\$0
	Doors - Transom Window	24	SF	7	\$0
	Eye Wash Station	2	EA	6	\$672
	Floor - Tile	2,426	SF	6	\$5,308
	Floor - Tile Ceramic/ Porcelain	12	SF	6	\$25
	Floor - Tile Ceramic/ Porcelain	12	SF	7	\$0
	Gas Line	16	EA	6	\$8,146

**Building: Main**
**Category: Classrooms**

Group	Item - Type	Quantity	Unit	Rank	Cost
<b>Science Lab Level 1 (2 rooms)</b>					
	Lighting - Lay-in	52	EA	7	\$0
	Marker Board	32	LF	7	\$0
	Science Lab Elements	120	SF	6	\$813
	Science Lab Shower	2	EA	6	\$758
	Walls - Plaster/Drywall	1,196	SF	6	\$3,301
	Walls - Plaster/Drywall	1,196	SF	7	\$0
	Walls - Structural Glazed Tile	240	SF	7	\$0
	Work Sink	16	EA	6	\$6,064
<b>Science Lab Level 2 (1 room)</b>					
	Casework	33	LF	7	\$0
	Ceiling - Lay-in	1,225	SF	6	\$3,679
	Doors - Side-lite	16	SF	7	\$0
	Doors - Steel Doors incl hw	2	EA	7	\$0
	Doors - Transom Window	16	SF	7	\$0
	Eye Wash Station	1	EA	6	\$336
	Floor - Tile	1,213	SF	6	\$2,654
	Floor - Tile Ceramic/ Porcelain	12	SF	7	\$0
	Fume Hood	1	EA	6	\$816
	Gas Line	8	EA	6	\$4,073
	Lighting - Lay-in	26	EA	7	\$0
	Marker Board	16	LF	7	\$0
	Science Lab Elements	60	SF	6	\$407
	Science Lab Shower	1	EA	6	\$379
	Walls - Plaster/Drywall	120	SF	6	\$331
	Walls - Structural Glazed Tile	1,196	SF	7	\$0
	Work Sink	8	EA	6	\$3,032
<b>Science Lab Level 3 (1 room)</b>					
	Casework	16	LF	7	\$0
	Ceiling - Lay-in	925	SF	7	\$0
	Doors - Side-lite	24	SF	7	\$0
	Doors - Steel Doors incl hw	2	EA	7	\$0
	Doors - Transom Window	10	SF	7	\$0
	Eye Wash Station	1	EA	7	\$0
	Floor - Tile	912	SF	7	\$0
	Floor - Tile Ceramic/ Porcelain	13	SF	7	\$0
	Fume Hood	1	EA	7	\$0

**Building: Main**

**Category: Classrooms**

Group	Item - Type	Quantity	Unit	Rank	Cost
<b>Science Lab Level 3 (1 room)</b>					
	Gas Line	16	EA	7	\$0
	Lighting - Lay-in	25	EA	7	\$0
	Marker Board	16	LF	7	\$0
	Science Lab Elements	74	SF	7	\$0
	Science Lab Shower	1	EA	7	\$0
	Walls - Plaster/Drywall	1,356	SF	7	\$0
	Walls - Structural Glazed Tile	42	SF	7	\$0
	Work Sink	8	EA	7	\$0

**Classrooms Subtotal:**

**\$175,094**

**Building: Main**

**Category: Rooms (Other Than Classrooms)**

Group	Item - Type	Quantity	Unit	Rank	Cost
<b>Administrative Suites/Offices</b>					
	Ceiling - Exposed	354	SF	6	\$526
	Ceiling - Lay-in	8	SF	4	\$112
	Ceiling - Lay-in	6,911	SF	6	\$20,754
	Ceiling - Lay-in	2,143	SF	7	\$0
	Ceiling - Plaster/Drywall	446	SF	6	\$1,543
	Doors - Hardware	8	EA	7	\$0
	Doors - Side-lite	176	SF	6	\$2,942
	Doors - Side-lite	321	SF	7	\$0
	Doors - Steel Doors incl hw	32	EA	6	\$9,632
	Doors - Steel Doors incl hw	16	EA	7	\$0
	Doors - Store Front	4	EA	6	\$4,833
	Doors - Store Front	2	EA	7	\$0
	Doors - Transom Window	32	SF	7	\$0
	Floor - Carpet	4,673	SF	6	\$9,957
	Floor - Tile	2,684	SF	6	\$5,872
	Floor - Tile	2,335	SF	7	\$0
	Floor - Tile Ceramic/ Porcelain	170	SF	7	\$0
	Lighting - Lay-in	161	EA	7	\$0
	Lighting - Pendent/Surface	3	EA	6	\$372
	Lighting - Pendent/Surface	22	EA	7	\$0
	Power Distribution	494	EA	7	\$0
	Storage/ Closet	296	SF	6	\$2,146

**Building: Main**
**Category: Rooms (Other Than Classrooms)**

Group	Item - Type	Quantity	Unit	Rank	Cost
<b>Administrative Suites/Offices</b>					
	Storage/ Closet	135	SF	7	\$0
	Walls - Concrete Block	4,467	SF	6	\$13,095
	Walls - Concrete Block	2,362	SF	7	\$0
	Walls - Plaster/Drywall	13,381	SF	6	\$36,930
	Walls - Plaster/Drywall	2,583	SF	7	\$0
	Walls - Structural Glazed Tile	42	SF	7	\$0
	Walls - Tile Ceramic/ Porcelain	268	SF	7	\$0
	Work Slnk	4	EA	6	\$2,033
	Work Slnk	2	EA	7	\$0
<b>Clinic</b>					
	Ceiling - Lay-in	268	SF	7	\$0
	Doors - Side-lite	20	SF	7	\$0
	Doors - Steel Doors incl hw	2	EA	7	\$0
	Floor - Tile/Sheet	268	SF	7	\$0
	Lighting - Lay-in	4	EA	7	\$0
	Walls - Concrete Block	187	SF	7	\$0
	Walls - Plaster/Drywall	727	SF	7	\$0
<b>Gymnasia</b>					
	Bleacher Seating	600	EA	7	\$0
	Ceiling - Exposed	5,635	SF	7	\$0
	Doors - Steel Doors incl hw	12	EA	7	\$0
	Floor - Tile/Sheet	2,304	SF	7	\$0
	Floor - Wood	3,331	SF	7	\$0
	Lighting - Metal Halide/Sodium Vapor	58	EA	7	\$0
	Main Floor Seating	720	EA	7	\$0
	Scoreboards	1	EA	7	\$0
	Sound System	1	EA	7	\$0
	Stage	2,304	SF	7	\$0
	Stage Curtain	5	EA	7	\$0
	Stage Lift	1	EA	7	\$0
	Stage Lighting System	1	EA	7	\$0
	Walls - Concrete Block	3,536	SF	7	\$0
	Walls - Masonry	6,656	SF	7	\$0
	Walls - Metal Panel	7,360	SF	7	\$0
<b>Kitchen</b>					
	Ceiling - Lay-in	1,188	SF	6	\$3,568

**Building: Main**
**Category: Rooms (Other Than Classrooms)**

Group	Item - Type	Quantity	Unit	Rank	Cost
<b>Kitchen</b>					
	Doors - Steel Doors incl hw	5	EA	6	\$1,505
	Floor - Tile Ceramic/ Porcelain	1,188	SF	6	\$2,514
	Lighting - Lay-in	17	EA	7	\$0
	Storage/ Closet	300	SF	6	\$2,175
	Walls - Concrete Block	1,242	SF	6	\$3,641
<b>Library</b>					
	Casework	90	LF	7	\$0
	Ceiling - Lay-in	2,000	SF	6	\$6,006
	Ceiling - Lay-in	1,508	SF	7	\$0
	Ceiling - Plaster/Drywall	3,300	SF	6	\$11,420
	Doors - Side-lite	86	SF	6	\$1,438
	Doors - Side-lite	80	SF	7	\$0
	Doors - Steel Doors incl hw	3	EA	7	\$0
	Doors - Store Front	4	EA	6	\$4,833
	Doors - Transom Window	30	SF	6	\$508
	Floor - Carpet	5,235	SF	6	\$11,154
	Floor - Tile Ceramic/ Porcelain	65	SF	6	\$138
	Floor - Tile/Sheet	1,508	SF	7	\$0
	Lighting - Lay-in	74	EA	7	\$0
	Lighting - Pendent/Surface	110	EA	7	\$0
	Storage/ Closet	156	SF	6	\$1,131
	Walls - Concrete Block	500	SF	7	\$0
	Walls - Masonry	2,225	SF	6	\$7,000
	Walls - Plaster/Drywall	1,892	SF	6	\$5,222
	Walls - Plaster/Drywall	1,400	SF	7	\$0
	Walls - Structural Glazed Tile	35	SF	7	\$0
<b>Locker/Shower Room</b>					
	Accessories	2,306	SF	6	\$9,035
	Accessories	1,000	SF	7	\$0
	Benches, ped mounted	605	LF	7	\$0
	Ceiling - Exposed	2,306	SF	6	\$3,429
	Ceiling - Exposed	1,000	SF	7	\$0
	Doors - Steel Doors incl hw	12	EA	7	\$0
	Floor - Concrete Epoxy/ Painted	1,342	SF	7	\$0
	Floor - Epoxy/ Painted	1,322	SF	7	\$0
	Floor - Tile Ceramic/ Porcelain	642	SF	7	\$0

**Building: Main**

**Category: Rooms (Other Than Classrooms)**

Group	Item - Type	Quantity	Unit	Rank	Cost
<b>Locker/Shower Room</b>					
	Floor Drain	18	EA	7	\$0
	Hand Dryer	3	EA	7	\$0
	Lavatory	6	EA	7	\$0
	Lighting - Lay-in	74	EA	7	\$0
	Partitions	4	EA	7	\$0
	Showers	22	EA	7	\$0
	Student Lockers - One Tier	407	EA	7	\$0
	Student Lockers - Two Tier	384	EA	7	\$0
	Urinals	1	EA	7	\$0
	Walls - Concrete Block	5,654	SF	7	\$0
	Walls - Tile Ceramic/ Porcelain	1,048	SF	7	\$0
	Water Closet	5	EA	7	\$0
<b>Lunch &amp; Multipurpose Room</b>					
	Ceiling - Exposed	1,641	SF	6	\$2,440
	Ceiling - Lay-in	3,993	SF	6	\$11,991
	Ceiling - Plaster/Drywall	3	SF	5	\$37
	Ceiling - Plaster/Drywall	2,989	SF	6	\$10,344
	Doors - Side-lite	1,163	SF	6	\$19,442
	Doors - Steel Doors incl hw	6	EA	6	\$1,806
	Doors - Store Front	16	EA	6	\$19,331
	Doors - Transom Window	87	SF	6	\$1,473
	Floor - Carpet	1,184	SF	6	\$2,523
	Floor - Terrazzo	5,610	SF	6	\$12,274
	Floor - Wood	1,832	SF	6	\$12,915
	Lighting - Lay-in	67	EA	7	\$0
	Lighting - Pendent/Surface	61	EA	7	\$0
	Market Board	12	LF	7	\$0
	Serving Line	50	LF	6	\$2,976
	Storage/ Closet	85	SF	6	\$616
	Walls - Concrete Block	1,845	SF	6	\$5,409
	Walls - Masonry	1,291	SF	6	\$4,061
	Walls - Plaster/Drywall	731	SF	6	\$2,017
	Walls - Structural Glazed Tile	3,461	SF	6	\$10,888
<b>MDF_IDF</b>					
	Doors - Steel Doors incl hw	1	EA	6	\$301
	Finishes	275	SF	6	\$1,962

**Building: Main**

**Category: Rooms (Other Than Classrooms)**

Group	Item - Type	Quantity	Unit	Rank	Cost
<b>MDF_IDF</b>	Ventilation and Cooling	1	EA	6	\$1,855
<b>Mechanical/ Service Rooms</b>					
	Janitor's Closet	37	SF	6	\$265
	Janitor's Closet	211	SF	7	\$0
	Mechanical/ Service Rooms	398	SF	6	\$2,851
	Mechanical/ Service Rooms	8,532	SF	7	\$0
	Storage Room	579	SF	6	\$4,148
	Storage Room	2,944	SF	7	\$0
	Vaults	118	SF	6	\$845
<b>Pool &amp; Natatorium</b>					
	Accessories	1,948	SF	7	\$0
	Bleachers Seating/Plank Seating	115	EA	6	\$3,328
	Ceiling - Exposed	7,082	SF	7	\$0
	Ceiling - Plaster/ Drywall	500	SF	6	\$2,760
	Doors - Steel Doors incl hw	17	EA	7	\$0
	Floor - Concrete	923	SF	6	\$488
	Lighting - Lay-in	7	EA	7	\$0
	Lighting - Metal Halide/ High Pressure Sodium	37	EA	7	\$0
	Pool Basin	3,948	SF	7	\$0
	Pool Deck	3,134	SF	7	\$0
	Pool Deck Drains	6	EA	7	\$0
	Storage/ Closet	408	SF	7	\$0
	Walls - Masonry	3,200	SF	7	\$0
	Walls - Metal Panel	1,700	SF	7	\$0
	Walls - Structural Glazed Tile	4,304	SF	7	\$0
<b>Prep Room</b>					
	Casework	98	LF	7	\$0
	Ceiling - Exposed	1,312	SF	6	\$1,951
	Ceiling - Lay-in	1,023	SF	6	\$3,072
	Ceiling - Plaster/Drywall	530	SF	7	\$0
	Doors - Side-lite	16	SF	7	\$0
	Doors - Steel Doors incl hw	3	EA	6	\$903
	Doors - Steel Doors incl hw	12	EA	7	\$0
	Doors - Transom Window	36	SF	7	\$0
	Floor - Concrete Epoxy/ Painted	1,312	SF	6	\$694
	Floor - Tile	732	SF	6	\$1,602

**Building: Main**

**Category: Rooms (Other Than Classrooms)**

Group	Item - Type	Quantity	Unit	Rank	Cost
<b>Prep Room</b>					
	Floor - Tile	530	SF	7	\$0
	Floor - Tile Ceramic/ Porcelain	291	SF	6	\$616
	Lighting - Lay-in	44	EA	7	\$0
	Lighting - Pendent/Surface	20	EA	7	\$0
	Walls - Concrete Block	3,525	SF	6	\$10,334
	Walls - Plaster/Drywall	1,600	SF	6	\$4,416
	Walls - Plaster/Drywall	1,156	SF	7	\$0
	Walls - Structural Glazed Tile	84	SF	7	\$0
	Work Sink	4	EA	6	\$1,516
	Work Sink	2	EA	7	\$0
<b>Restroom</b>					
	Accessories	5,088	SF	6	\$46,929
	Accessories	891	SF	7	\$0
	Benches	8	LF	7	\$0
	Ceiling - Exposed	1,127	SF	6	\$1,718
	Ceiling - Exposed	1,270	SF	7	\$0
	Ceiling - Lay-in	361	SF	6	\$1,084
	Ceiling - Lay-in	112	SF	7	\$0
	Ceiling - Plaster/Drywall	6	SF	5	\$75
	Ceiling - Plaster/Drywall	2,856	SF	6	\$9,883
	Ceiling - Plaster/Drywall	247	SF	7	\$0
	Doors - Steel Doors incl hw	7	EA	6	\$2,107
	Doors - Steel Doors incl hw	13	EA	7	\$0
	Floor - Concrete Epoxy/ Painted	256	SF	7	\$0
	Floor - Tile	64	SF	7	\$0
	Floor - Tile Ceramic/ Porcelain	3,223	SF	6	\$6,821
	Floor - Tile Ceramic/ Porcelain	2,436	SF	7	\$0
	Floor Drain	17	EA	6	\$18,006
	Floor Drain	18	EA	7	\$0
	Hand Dryer	31	EA	6	\$7,131
	Hand Dryer	26	EA	7	\$0
	Lavatory	1	EA	5	\$1,590
	Lavatory	48	EA	6	\$15,341
	Lavatory	37	EA	7	\$0
	Lighting - Lay-in	101	EA	7	\$0
	Lighting - Pendent/Surface	100	EA	7	\$0
	Lighting - Wall Mounted	18	EA	7	\$0



**Building: Main**

**Category: Rooms (Other Than Classrooms)**

Group	Item - Type	Quantity	Unit	Rank	Cost
<b>Restroom</b>					
	Partitions	47	EA	6	\$13,955
	Partitions	29	EA	7	\$0
	Showers	4	EA	7	\$0
	Student Lockers - One Tier	8	EA	7	\$0
	Urinals	12	EA	6	\$4,032
	Urinals	11	EA	7	\$0
	Walls - Concrete Block	1,054	SF	6	\$3,090
	Walls - Concrete Block	4,436	SF	7	\$0
	Walls - Plaster/Drywall	230	SF	7	\$0
	Walls - Structural Glazed Tile	5,899	SF	6	\$18,558
	Walls - Structural Glazed Tile	2,764	SF	7	\$0
	Walls - Tile Ceramic/ Porcelain	542	SF	6	\$1,225
	Walls - Tile Ceramic/ Porcelain	476	SF	7	\$0
	Water Closet	60	EA	6	\$20,159
	Water Closet	40	EA	7	\$0

**Rooms (Other Than Classrooms) Subtotal:**

**\$521,621**

**Building: Main**

**Category: Building Interior**

Group	Item - Type	Quantity	Unit	Rank	Cost
<b>Corridor</b>					
	Ceiling - Exposed	197	SF	6	\$293
	Ceiling - Exposed	368	SF	7	\$0
	Ceiling - Lay-in	10	SF	4	\$156
	Ceiling - Lay-in	6,791	SF	6	\$20,393
	Ceiling - Lay-in	4,510	SF	7	\$0
	Ceiling - Plaster/Drywall	15,085	SF	6	\$94,185
	Ceiling - Plaster/Drywall	3,398	SF	7	\$0
	Doors - Side-lite	780	EA	7	\$0
	Doors - Steel Doors incl hw	37	EA	7	\$0
	Doors - Store Front	23	EA	7	\$0
	Doors - Transom Window	1,017	EA	7	\$0
	Drinking Fountains	4	EA	7	\$0
	Drinking Fountains - Single Water Cooler	4	EA	6	\$1,267
	Drinking Fountains - Single Water Cooler	6	EA	7	\$0
	Floor - Concrete Epoxy/ Painted	35	SF	7	\$0

**Building: Main**

**Category: Building Interior**

Group	Item - Type	Quantity	Unit	Rank	Cost
<b>Corridor</b>					
	Floor - Lay-in	908	SF	6	\$0
	Floor - Terrazzo	9,465	SF	6	\$79,450
	Floor - Terrazzo	27,447	SF	7	\$0
	Floor - Tile/Sheet	326	SF	7	\$0
	Lighting - Lay-in	587	EA	7	\$0
	Lighting - Pendent/Surface	10	EA	7	\$0
	Lighting - Wall Mounted	324	EA	7	\$0
	Student Lockers - One Tier	621	EA	6	\$57,651
	Student Lockers - One Tier	621	EA	7	\$0
	Walls - Concrete Block	532	SF	6	\$1,560
	Walls - Concrete Block	740	SF	7	\$0
	Walls - Masonry	4,947	SF	7	\$0
	Walls - Plaster/Drywall	11,944	SF	6	\$52,948
	Walls - Plaster/Drywall	342	SF	7	\$0
	Walls - Structural Glazed Tile	37,398	SF	7	\$0
<b>Safety</b>					
	Camera Viewing Station	3	EA	6	\$2,048
	Metal Dedector	3	EA	6	\$2,642
	Security Cameras	206	EA	6	\$39,972
<b>Stairs</b>					
	Ceiling - Plaster/Drywall	3,484	SF	6	\$25,508
	Ceiling - Plaster/Drywall	4,422	SF	7	\$0
	Floor - Asphalt	310	SF	7	\$0
	Floor - Concrete	1,031	SF	6	\$546
	Floor - Concrete	406	SF	7	\$0
	Floor - Terrazzo	309	SF	6	\$2,594
	Floor - Terrazzo	2,844	SF	7	\$0
	Handrails	44	LF	6	\$381
	Handrails	1,240	LF	7	\$0
	Lighting - Lay-in	54	EA	7	\$0
	Lighting - Pendent/Surface	58	EA	7	\$0
	Lighting - Wall Mounted	32	EA	7	\$0
	Stairs - Concrete	30	LF	6	\$249
	Stairs - Concrete	64	LF	7	\$0
	Stairs - Terrazzo	208	LF	6	\$1,930
	Stairs - Terrazzo	79	LF	7	\$0

**Building: Main**

**Category: Building Interior**

Group	Item - Type	Quantity	Unit	Rank	Cost
<b>Stairs</b>					
	Walls - Concrete Block	1,577	SF	6	\$4,623
	Walls - Concrete Block	7,353	SF	7	\$0
	Walls - Masonry	250	SF	6	\$787
	Walls - Masonry	2,891	SF	7	\$0
	Walls - Structural Glazed Tile	1,127	SF	6	\$3,546
	Walls - Structural Glazed Tile	6,981	SF	7	\$0
<b>Vertical Conveyance</b>					
	Elevator - Hydraulic Elevator	1	EA	6	\$19,238
	Elevator - Lula	1	EA	6	\$11,667
	Wheelchair Lift - Platform Lift	1	EA	6	\$6,690
<b>Building Interior Subtotal:</b>					<b>\$430,321</b>

**Total Building Cost**

**\$1,204,848**

**SITE**

**Category: Site**

Group	Item - Type	Quantity	Unit	Rank	Cost
<b>Athletic</b>					
	Metal Bleachers	2,520	LF	6	\$112,432
	Metal Bleachers	105	LF	7	\$0
	Surface - Asphalt	17,238	SF	7	\$0
	Surface - Natural	44,120	SF	6	\$36,593
	Surface - Synthetic	74,133	SF	7	\$0
<b>Civil/Drainage</b>					
	Civil/ Drainage - Catch Basin	28	EA	7	\$0
	Civil/ Drainage - Site Drain	2	EA	7	\$0
	Civil/ Drainage - Site Manhole	7	EA	7	\$0
<b>Fencing</b>					
	Fencing - Chain Link	1,604	LF	7	\$0
	Fencing - New Standard Ornamental	490	LF	7	\$0
<b>Landscape</b>					
	Benches	67	EA	7	\$0
	Irrigation	44,120	SF	6	\$49,842

**SITE**
**Category: Site**

Group	Item - Type	Quantity	Unit	Rank	Cost
<b>Landscape</b>					
	Landscape - Grass	29,741	SF	6	\$24,667
	Lighting	36	EA	6	\$0
	Lighting - Pole Mounted	24	EA	6	\$26,010
	Parkway trees	38	EA	6	\$25,082
	Planting Beds/ Area	1,085	SF	6	\$1,784
	Retaining Wall - Concrete	3,220	SF	7	\$0
	Retaining Wall - Masonry	602	SF	7	\$0
	Trash Receptacles	8	EA	6	\$2,498
<b>Parking Lot</b>					
	Interior Plantings	668	LF	6	\$28,418
	Lighting - Pole Mounted	12	EA	6	\$17,430
	Pavers	37,221	SF	7	\$0
	Trash Compactor	1	EA	6	\$0
	Vehicular Screening	85	LF	6	\$6,693
<b>Sidewalks</b>					
	Sidewalks - Internal Walks	10	LF	6	\$157
	Sidewalks - Internal Walks	7,777	LF	7	\$0
	Sidewalks - Perimeter Sidewalks	21,596	SF	7	\$0
<b>Signage</b>					
	Flag Pole - Flag Pole	3	EA	7	\$0
	Monument - Building Mounted Cut Letter Sign	1	EA	7	\$0
<b>Site Subtotal:</b>					<b>\$331,607</b>
<b>Total Site Cost</b>					<b>\$331,607</b>
<b>Campus Total <sup>2 3</sup></b>					<b>\$1,536,455</b>

<sup>1</sup> It is very rare for assessors to find a feature in this condition. If assessors do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in this report; by the time the report is compiled, they have been resolved.

<sup>2</sup> As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

<sup>3</sup> The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.

---

## Definitions

- **Quantity** means, for each item, the total number (or amount) of that item that exists and was evaluated.
  - **Unit** means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").
  - **Cost** means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.
  - **For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.**
  - **Campus Total** also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.
-

**Classroom Summary**

Current Usage	Intended Usage	Room Location	Room Number	Floor Plan Room Number	Area (SF)	Voice Outlets	Data Outlets	Elect. Outlets	Glazed Window Area	Operable Window Area	Noise Level	Window Stop	Power Strip	Smart-Board
<b>Main</b>														
Art Room	Art Room	2nd Floor	200B	NA	1,098	0	28	36	424	0	40	N	N	N
Art Room	Art Room	2nd Floor	200E	NA	1,098	0	28	34	424	0	40	N	N	N
Band Room	Band Room	2nd Floor	200I - Instrume	Instrumental	1,612	0	22	38	484	0	40	N	N	N
Choral Room	Choral Room	2nd Floor	200G - Choral	Choral	1,093	0	28	32	352	0	40	N	N	N
Computer Lab	Other Instructional Use	1st Floor	119	NA	744	1	22	50	0	0	40	N	N	N
Computer Lab	Computer Lab	2nd Floor	223	NA	1,227	1	60	68	193	42	40	N	N	N
Computer Lab	Computer Lab	2nd Floor	225	NA	1,111	1	58	66	193	42	40	N	N	N
Computer Lab	Computer Lab	3rd Floor	323	NA	1,110	1	38	80	174	44	40	N	N	Y
Computer Lab	Computer Lab	3rd Floor	325	NA	1,110	1	34	80	174	44	40	N	N	Y
Fitness Room	Fitness Room	Basement	008	Fitness	1,305	0	8	18	0	0	40	N	N	N
Music Room	Music Room	2nd Floor	200I-4	Practice Room	154	0	0	6	0	0	40	N	N	N
Music Room	Music Room	2nd Floor	200I-5	Practice Room	104	0	0	6	0	0	40	N	N	N
Music Room	Music Room	2nd Floor	200I-6	Practice Room	84	0	0	6	0	0	40	N	N	N
Regular Classroom	Vacant	Basement	010	Athletic Storag	1,320	0	0	0	0	0	40	N	N	N
Regular Classroom	Regular Classroom	2nd Floor	217	NA	718	0	16	20	109	22	40	N	N	N
Regular Classroom	Regular Classroom	2nd Floor	219	NA	718	0	16	20	109	22	40	N	N	N
Regular Classroom	Regular Classroom	2nd Floor	220	NA	718	0	16	20	37	6	40	N	N	N
Regular Classroom	Regular Classroom	2nd Floor	221	NA	680	0	6	18	109	22	40	N	N	N
Regular Classroom	Regular Classroom	2nd Floor	222	NA	680	0	6	18	190	36	40	N	N	N
Regular Classroom	Regular Classroom	2nd Floor	224	NA	718	0	16	20	109	22	20	N	N	N
Regular Classroom	Regular Classroom	2nd Floor	227	NA	735	0	16	20	109	22	40	N	N	N
Regular Classroom	Regular Classroom	2nd Floor	229	NA	735	0	16	20	109	22	40	N	N	N
Regular Classroom	Regular Classroom	2nd Floor	231	NA	735	0	10	20	109	22	40	N	N	N
Regular Classroom	Regular Classroom	2nd Floor	233	NA	718	0	16	20	109	22	40	N	N	N
Regular Classroom	Regular Classroom	2nd Floor	236	NA	735	0	10	20	113	22	40	N	N	N
Regular Classroom	Regular Classroom	2nd Floor	237	NA	680	0	6	18	190	36	40	N	N	N
Regular Classroom	Regular Classroom	2nd Floor	238	NA	680	0	6	18	190	36	40	N	N	N
Regular Classroom	Regular Classroom	3rd Floor	317	NA	718	0	7	28	116	29	40	N	N	N
Regular Classroom	Regular Classroom	3rd Floor	319	NA	718	0	5	20	116	29	40	N	N	N
Regular Classroom	Regular Classroom	3rd Floor	320	NA	718	0	7	28	116	29	40	N	N	N
Regular Classroom	Regular Classroom	3rd Floor	321	NA	680	0	5	20	174	44	40	N	N	N
Regular Classroom	Regular Classroom	3rd Floor	322	NA	680	0	5	20	174	44	40	N	N	N
Regular Classroom	Regular Classroom	3rd Floor	324	NA	680	0	5	20	174	44	40	N	N	N
Regular Classroom	Regular Classroom	3rd Floor	327	NA	735	0	7	28	116	29	40	N	N	N
Regular Classroom	Regular Classroom	3rd Floor	329	NA	735	0	7	28	116	29	40	N	N	N
Regular Classroom	Regular Classroom	3rd Floor	331	NA	735	0	7	28	116	29	40	N	N	N
Regular Classroom	Regular Classroom	3rd Floor	333	NA	718	0	7	28	116	29	40	N	N	N

**Classroom Summary**

Current Usage	Intended Usage	Room Location	Room Number	Floor Plan Room Number	Area (SF)	Voice Outlets	Data Outlets	Elect. Outlets	Glazed Window Area	Operable Window Area	Noise Level	Window Stop	Power Strip	Smart-Board
<b>Main</b>														
Regular Classroom	Regular Classroom	3rd Floor	336	NA	718	0	7	28	116	29	40	N	N	N
Regular Classroom	Regular Classroom	3rd Floor	337	NA	680	0	5	20	174	44	40	N	N	N
Regular Classroom	Regular Classroom	3rd Floor	338	NA	680	0	5	20	174	44	40	N	N	N
Science	Science	2nd Floor	226	NA	880	0	24	30	193	42	40	N	N	N
Science	Science	2nd Floor	230	NA	925	0	26	30	197	40	40	N	N	N
Science Lab Level 1	Science Lab Level 1	3rd Floor	326	NA	1,225	1	12	42	145	36	40	N	N	N
Science Lab Level 1	Science Lab Level 1	3rd Floor	330	NA	1,225	1	12	42	209	52	40	N	N	N
Science Lab Level 2	Science Lab Level 2	3rd Floor	334	NA	1,225	1	12	42	145	36	40	N	N	N
Science Lab Level 3	Science Lab Level 3	2nd Floor	234	NA	925	0	34	42	197	40	40	N	N	N