



**Sep 10, 2024**

**ADDAMS**

**10810 S AVENUE H, Chicago IL 60617.**

Dear **ADDAMS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**ADDAMS**

**10810 S AVENUE H, Chicago IL 60617.**

Estimadas familias de **ADDAMS**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarle y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51495	51495-1-S-KIT-KS02	Left Sink	Flush180	06-MAR-20	1.000	ug/L
51495	51495-1-S-KIT-KS02	Left Sink	Flush180	06-MAR-20	1.000	ug/L
51495	51495-1-S-KIT-KS02	Left Sink	Flush180	06-MAR-20	1.000	ug/L
51495	51495-1-S-KIT-KS02	Left Sink	Flush180	06-MAR-20	1.000	ug/L
51495	51495-1-S-KIT-KS02	Left Sink	Initial	06-MAR-20	1.000	ug/L
51495	51495-1-W-HAL-F05	Main- Across From Room 108, Fountain 1	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-W-HAL-F05	Main- Across From Room 108, Fountain 1	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-W-HAL-F05	Main- Across From Room 108, Fountain 1	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-W-HAL-F05	Main- Across From Room 108, Fountain 1	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-W-HAL-F05	Main- Across From Room 108, Fountain 1	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-W-HAL-F05	Main- Across From Room 108, Fountain 1	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-W-HAL-F05	Main- Across From Room 108, Fountain 1	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-W-HAL-F05	Main- Across From Room 108, Fountain 1	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-W-HAL-F05	Main- Across From Room 108, Fountain 1	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-W-HAL-F05	Main- Across From Room 108, Fountain 1	Flush180	06-MAR-20	1.000	ug/L
51495	51495-1-W-HAL-F05	Main- Across From Room 108, Fountain 1	Flush180	06-MAR-20	1.000	ug/L
51495	51495-1-W-HAL-F05	Main- Across From Room 108, Fountain 1	Initial	02-JUN-16	1.000	ppb
51495	51495-1-W-HAL-F05	Main- Across From Room 108, Fountain 1	Initial	02-JUN-16	1.000	ppb
51495	51495-1-W-HAL-F05	Main- Across From Room 108, Fountain 1	Initial	06-MAR-20	1.000	ug/L
51495	51495-1-W-HAL-F06	Main- Across From Room 108, Fountain 2	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-W-HAL-F06	Main- Across From Room 108, Fountain 2	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-W-HAL-F06	Main- Across From Room 108, Fountain 2	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-W-HAL-F06	Main- Across From Room 108, Fountain 2	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-W-HAL-F06	Main- Across From Room 108, Fountain 2	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-W-HAL-F06	Main- Across From Room 108, Fountain 2	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-W-HAL-F06	Main- Across From Room 108, Fountain 2	Flush180	06-MAR-20	1.000	ug/L
51495	51495-1-W-HAL-F06	Main- Across From Room 108, Fountain 2	Flush180	06-MAR-20	1.000	ug/L
51495	51495-1-W-HAL-F06	Main- Across From Room 108, Fountain 2	Flush180	06-MAR-20	1.000	ug/L
51495	51495-1-W-HAL-F06	Main- Across From Room 108, Fountain 2	Flush180	06-MAR-20	1.000	ug/L
51495	51495-1-W-HAL-F06	Main- Across From Room 108, Fountain 2	Initial	02-JUN-16	1.000	ppb
51495	51495-1-W-HAL-F06	Main- Across From Room 108, Fountain 2	Initial	02-JUN-16	1.000	ppb
51495	51495-1-W-HAL-F06	Main- Across From Room 108, Fountain 2	Initial	06-MAR-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51495	51495-2-W-HAL-F03	Main- Across From Room 208, Fountain 1	Flush180	02-JUN-16	1.000	ppb
51495	51495-2-W-HAL-F03	Main- Across From Room 208, Fountain 1	Flush180	06-MAR-20	1.310	ug/L
51495	51495-2-W-HAL-F03	Main- Across From Room 208, Fountain 1	Flush180	06-MAR-20	1.800	ug/L
51495	51495-2-W-HAL-F03	Main- Across From Room 208, Fountain 1	Flush180	06-MAR-20	1.590	ug/L
51495	51495-2-W-HAL-F03	Main- Across From Room 208, Fountain 1	Flush180	06-MAR-20	2.000	ug/L
51495	51495-2-W-HAL-F03	Main- Across From Room 208, Fountain 1	Flush180	23-JUL-20	1.120	ug/L
51495	51495-2-W-HAL-F03	Main- Across From Room 208, Fountain 1	Initial	02-JUN-16	1.000	ppb
51495	51495-2-W-HAL-F03	Main- Across From Room 208, Fountain 1	Initial	02-JUN-16	1.000	ppb
51495	51495-2-W-HAL-F03	Main- Across From Room 208, Fountain 1	Initial	06-MAR-20	1.000	ug/L
51495	51495-2-W-HAL-F03	Main- Across From Room 208, Fountain 1	Initial	23-JUL-20	2.340	ug/L
51495	51495-2-W-HAL-F04	Main- Across From Room 208, Fountain 2	Flush180	02-JUN-16	1.000	ppb
51495	51495-2-W-HAL-F04	Main- Across From Room 208, Fountain 2	Flush180	02-JUN-16	1.000	ppb
51495	51495-2-W-HAL-F04	Main- Across From Room 208, Fountain 2	Flush180	02-JUN-16	1.000	ppb
51495	51495-2-W-HAL-F04	Main- Across From Room 208, Fountain 2	Flush180	02-JUN-16	1.000	ppb
51495	51495-2-W-HAL-F04	Main- Across From Room 208, Fountain 2	Flush180	02-JUN-16	1.000	ppb
51495	51495-2-W-HAL-F04	Main- Across From Room 208, Fountain 2	Flush180	02-JUN-16	1.000	ppb
51495	51495-2-W-HAL-F04	Main- Across From Room 208, Fountain 2	Flush180	02-JUN-16	1.000	ppb
51495	51495-2-W-HAL-F04	Main- Across From Room 208, Fountain 2	Flush180	02-JUN-16	1.000	ppb
51495	51495-2-W-HAL-F04	Main- Across From Room 208, Fountain 2	Flush180	02-JUN-16	1.000	ppb
51495	51495-2-W-HAL-F04	Main- Across From Room 208, Fountain 2	Flush180	06-MAR-20	1.560	ug/L
51495	51495-2-W-HAL-F04	Main- Across From Room 208, Fountain 2	Flush180	06-MAR-20	1.820	ug/L
51495	51495-2-W-HAL-F04	Main- Across From Room 208, Fountain 2	Flush180	06-MAR-20	2.150	ug/L
51495	51495-2-W-HAL-F04	Main- Across From Room 208, Fountain 2	Flush180	06-MAR-20	1.580	ug/L
51495	51495-2-W-HAL-F04	Main- Across From Room 208, Fountain 2	Initial	02-JUN-16	1.000	ppb
51495	51495-2-W-HAL-F04	Main- Across From Room 208, Fountain 2	Initial	02-JUN-16	1.000	ppb
51495	51495-2-W-HAL-F04	Main- Across From Room 208, Fountain 2	Initial	06-MAR-20	1.060	ug/L
51495	51495-1-S-KIT-KS01	Main- Kitchen Sink	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-S-KIT-KS01	Main- Kitchen Sink	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-S-KIT-KS01	Main- Kitchen Sink	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-S-KIT-KS01	Main- Kitchen Sink	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-S-KIT-KS01	Main- Kitchen Sink	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-S-KIT-KS01	Main- Kitchen Sink	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-S-KIT-KS01	Main- Kitchen Sink	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-S-KIT-KS01	Main- Kitchen Sink	Flush180	06-MAR-20	1.000	ug/L
51495	51495-1-S-KIT-KS01	Main- Kitchen Sink	Flush180	06-MAR-20	1.000	ug/L
51495	51495-1-S-KIT-KS01	Main- Kitchen Sink	Flush180	06-MAR-20	1.010	ug/L
51495	51495-1-S-KIT-KS01	Main- Kitchen Sink	Flush180	06-MAR-20	1.000	ug/L
51495	51495-1-S-	Main- Kitchen Sink	Initial	02-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KIT-KS01					
51495	51495-1-S-KIT-KS01	Main- Kitchen Sink	Initial	02-JUN-16	1.000	ppb
51495	51495-1-S-KIT-KS01	Main- Kitchen Sink	Initial	06-MAR-20	1.000	ug/L
51495	51495-1-E-CAF-F02	Main- Lunchroom Fountain	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-E-CAF-F02	Main- Lunchroom Fountain	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-E-CAF-F02	Main- Lunchroom Fountain	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-E-CAF-F02	Main- Lunchroom Fountain	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-E-CAF-F02	Main- Lunchroom Fountain	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-E-CAF-F02	Main- Lunchroom Fountain	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-E-CAF-F02	Main- Lunchroom Fountain	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-E-CAF-F02	Main- Lunchroom Fountain	Flush180	06-MAR-20	1.000	ug/L
51495	51495-1-E-CAF-F02	Main- Lunchroom Fountain	Flush180	06-MAR-20	1.000	ug/L
51495	51495-1-E-CAF-F02	Main- Lunchroom Fountain	Flush180	06-MAR-20	1.000	ug/L
51495	51495-1-E-CAF-F02	Main- Lunchroom Fountain	Flush180	06-MAR-20	1.000	ug/L
51495	51495-1-E-CAF-F02	Main- Lunchroom Fountain	Initial	02-JUN-16	1.000	ppb
51495	51495-1-E-CAF-F02	Main- Lunchroom Fountain	Initial	02-JUN-16	1.000	ppb
51495	51495-1-E-CAF-F02	Main- Lunchroom Fountain	Initial	06-MAR-20	1.000	ug/L
51495	51495-1-E-HAL-F03	Main- Outside Main Office, Fountain 1	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-E-HAL-F03	Main- Outside Main Office, Fountain 1	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-E-HAL-F03	Main- Outside Main Office, Fountain 1	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-E-HAL-F03	Main- Outside Main Office, Fountain 1	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-E-HAL-F03	Main- Outside Main Office, Fountain 1	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-E-HAL-F03	Main- Outside Main Office, Fountain 1	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-E-HAL-F03	Main- Outside Main Office, Fountain 1	Flush180	06-MAR-20	1.000	ug/L
51495	51495-1-E-HAL-F03	Main- Outside Main Office, Fountain 1	Flush180	06-MAR-20	1.000	ug/L
51495	51495-1-E-HAL-F03	Main- Outside Main Office, Fountain 1	Flush180	06-MAR-20	1.000	ug/L
51495	51495-1-E-HAL-F03	Main- Outside Main Office, Fountain 1	Flush180	06-MAR-20	1.000	ug/L
51495	51495-1-E-HAL-F03	Main- Outside Main Office, Fountain 1	Flush180	23-JUL-20	2.120	ug/L
51495	51495-1-E-HAL-F03	Main- Outside Main Office, Fountain 1	Initial	02-JUN-16	1.000	ppb
51495	51495-1-E-HAL-F03	Main- Outside Main Office, Fountain 1	Initial	02-JUN-16	1.000	ppb
51495	51495-1-E-HAL-F03	Main- Outside Main Office, Fountain 1	Initial	06-MAR-20	1.000	ug/L
51495	51495-1-E-HAL-F03	Main- Outside Main Office, Fountain 1	Initial	23-JUL-20	1.000	ug/L
51495	51495-1-E-HAL-F04	Main- Outside Main Office, Fountain 2	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-E-HAL-F04	Main- Outside Main Office, Fountain 2	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-E-	Main- Outside Main Office,	Flush180	02-JUN-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F04	Fountain 2				
51495	51495-1-E-HAL-F04	Main- Outside Main Office, Fountain 2	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-E-HAL-F04	Main- Outside Main Office, Fountain 2	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-E-HAL-F04	Main- Outside Main Office, Fountain 2	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-E-HAL-F04	Main- Outside Main Office, Fountain 2	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-E-HAL-F04	Main- Outside Main Office, Fountain 2	Flush180	02-JUN-16	1.000	ppb
51495	51495-1-E-HAL-F04	Main- Outside Main Office, Fountain 2	Flush180	06-MAR-20	1.000	ug/L
51495	51495-1-E-HAL-F04	Main- Outside Main Office, Fountain 2	Flush180	06-MAR-20	1.000	ug/L
51495	51495-1-E-HAL-F04	Main- Outside Main Office, Fountain 2	Flush180	06-MAR-20	1.000	ug/L
51495	51495-1-E-HAL-F04	Main- Outside Main Office, Fountain 2	Flush180	06-MAR-20	1.000	ug/L
51495	51495-1-E-HAL-F04	Main- Outside Main Office, Fountain 2	Initial	02-JUN-16	1.000	ppb
51495	51495-1-E-HAL-F04	Main- Outside Main Office, Fountain 2	Initial	02-JUN-16	1.000	ppb
51495	51495-1-E-HAL-F04	Main- Outside Main Office, Fountain 2	Initial	06-MAR-20	1.000	ug/L
52383	52383-1-E-HAL-F01	Annex- Outside Boys Toilets, Fountain 1	Flush180	02-JUN-16	1.000	ppb
52383	52383-1-E-HAL-F01	Annex- Outside Boys Toilets, Fountain 1	Flush180	02-JUN-16	1.000	ppb
52383	52383-1-E-HAL-F01	Annex- Outside Boys Toilets, Fountain 1	Flush180	02-JUN-16	1.000	ppb
52383	52383-1-E-HAL-F01	Annex- Outside Boys Toilets, Fountain 1	Flush180	02-JUN-16	11.300	ppb
52383	52383-1-E-HAL-F01	Annex- Outside Boys Toilets, Fountain 1	Flush180	23-JUL-20	1.000	ug/L
52383	52383-1-E-HAL-F01	Annex- Outside Boys Toilets, Fountain 1	Initial	02-JUN-16	1.000	ppb
52383	52383-1-E-HAL-F01	Annex- Outside Boys Toilets, Fountain 1	Initial	23-JUL-20	1.000	ug/L
52383	52383-1-E-HAL-F02	Annex- Outside Boys Toilets, Fountain 2	Flush180	02-JUN-16	1.000	ppb
52383	52383-1-E-HAL-F02	Annex- Outside Boys Toilets, Fountain 2	Flush180	02-JUN-16	1.000	ppb
52383	52383-1-E-HAL-F02	Annex- Outside Boys Toilets, Fountain 2	Flush180	02-JUN-16	1.000	ppb
52383	52383-1-E-HAL-F02	Annex- Outside Boys Toilets, Fountain 2	Flush180	02-JUN-16	1.000	ppb
52383	52383-1-E-HAL-F02	Annex- Outside Boys Toilets, Fountain 2	Flush180	02-JUN-16	1.000	ppb
52383	52383-1-E-HAL-F02	Annex- Outside Boys Toilets, Fountain 2	Flush180	06-MAR-20	1.000	ug/L
52383	52383-1-E-HAL-F02	Annex- Outside Boys Toilets, Fountain 2	Flush180	06-MAR-20	1.000	ug/L
52383	52383-1-E-HAL-F02	Annex- Outside Boys Toilets, Fountain 2	Flush180	06-MAR-20	1.000	ug/L
52383	52383-1-E-HAL-F02	Annex- Outside Boys Toilets, Fountain 2	Flush180	06-MAR-20	1.000	ug/L
52383	52383-1-E-HAL-F02	Annex- Outside Boys Toilets, Fountain 2	Initial	02-JUN-16	1.000	ppb
52383	52383-1-E-HAL-F02	Annex- Outside Boys Toilets, Fountain 2	Initial	06-MAR-20	1.000	ug/L
53752	53752-1-HAL-BF02	Bottle Filler, Next to Rm 127 (south end) (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-HAL-BF02	Bottle Filler, Next to Rm 127 (south end) (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-HAL-BF02	Bottle Filler, Next to Rm 127 (south end) (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-HAL-BF02	Bottle Filler, Next to Rm 127 (south end) (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-HAL-BF02	Bottle Filler, Next to Rm 127 (south end) (East modular building)	Initial	18-AUG-23	1.000	ug/L
53752	53752-1-HAL-	Bottle Filler, Next to Rm 131 (north	Flush180	18-AUG-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	BF01	end) (East modular building)				
53752	53752-1-HAL-BF01	Bottle Filler, Next to Rm 131 (north end) (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-HAL-BF01	Bottle Filler, Next to Rm 131 (north end) (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-HAL-BF01	Bottle Filler, Next to Rm 131 (north end) (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-HAL-BF01	Bottle Filler, Next to Rm 131 (north end) (East modular building)	Initial	18-AUG-23	1.000	ug/L
53752	53752-1-124-F01	Drinking Fountain in Pre-K Classroom 124 (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-124-F01	Drinking Fountain in Pre-K Classroom 124 (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-124-F01	Drinking Fountain in Pre-K Classroom 124 (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-124-F01	Drinking Fountain in Pre-K Classroom 124 (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-124-F01	Drinking Fountain in Pre-K Classroom 124 (East modular building)	Initial	18-AUG-23	1.000	ug/L
53752	53752-1-125-F01	Drinking Fountain in Pre-K Classroom 125 (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-125-F01	Drinking Fountain in Pre-K Classroom 125 (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-125-F01	Drinking Fountain in Pre-K Classroom 125 (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-125-F01	Drinking Fountain in Pre-K Classroom 125 (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-125-F01	Drinking Fountain in Pre-K Classroom 125 (East modular building)	Initial	18-AUG-23	1.140	ug/L
53752	53752-1-W-HAL-F03	East Modular 1- Outside of Room 127, Fountain 1	Flush180	02-JUN-16	1.000	ppb
53752	53752-1-W-HAL-F03	East Modular 1- Outside of Room 127, Fountain 1	Flush180	02-JUN-16	1.000	ppb
53752	53752-1-W-HAL-F03	East Modular 1- Outside of Room 127, Fountain 1	Flush180	02-JUN-16	1.000	ppb
53752	53752-1-W-HAL-F03	East Modular 1- Outside of Room 127, Fountain 1	Flush180	02-JUN-16	1.000	ppb
53752	53752-1-W-HAL-F03	East Modular 1- Outside of Room 127, Fountain 1	Flush180	06-MAR-20	1.000	ug/L
53752	53752-1-W-HAL-F03	East Modular 1- Outside of Room 127, Fountain 1	Flush180	06-MAR-20	1.000	ug/L
53752	53752-1-W-HAL-F03	East Modular 1- Outside of Room 127, Fountain 1	Flush180	06-MAR-20	1.000	ug/L
53752	53752-1-W-HAL-F03	East Modular 1- Outside of Room 127, Fountain 1	Flush180	06-MAR-20	1.000	ug/L
53752	53752-1-W-HAL-F03	East Modular 1- Outside of Room 127, Fountain 1	Flush180	23-JUL-20	1.000	ug/L
53752	53752-1-W-HAL-F03	East Modular 1- Outside of Room 127, Fountain 1	Initial	02-JUN-16	1.000	ppb
53752	53752-1-W-HAL-F03	East Modular 1- Outside of Room 127, Fountain 1	Initial	06-MAR-20	1.000	ug/L
53752	53752-1-W-HAL-F03	East Modular 1- Outside of Room 127, Fountain 1	Initial	23-JUL-20	1.000	ug/L
53752	53752-1-W-HAL-F04	East Modular 1- Outside of Room 127, Fountain 2	Flush180	02-JUN-16	1.000	ppb
53752	53752-1-W-HAL-F04	East Modular 1- Outside of Room 127, Fountain 2	Flush180	02-JUN-16	1.000	ppb
53752	53752-1-W-HAL-F04	East Modular 1- Outside of Room 127, Fountain 2	Flush180	02-JUN-16	1.000	ppb
53752	53752-1-W-HAL-F04	East Modular 1- Outside of Room 127, Fountain 2	Flush180	02-JUN-16	1.000	ppb
53752	53752-1-W-HAL-F04	East Modular 1- Outside of Room 127, Fountain 2	Flush180	06-MAR-20	1.000	ug/L
53752	53752-1-W-	East Modular 1- Outside of Room	Flush180	06-MAR-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F04	127, Fountain 2				
53752	53752-1-W-HAL-F04	East Modular 1- Outside of Room 127, Fountain 2	Flush180	06-MAR-20	1.000	ug/L
53752	53752-1-W-HAL-F04	East Modular 1- Outside of Room 127, Fountain 2	Flush180	06-MAR-20	1.000	ug/L
53752	53752-1-W-HAL-F04	East Modular 1- Outside of Room 127, Fountain 2	Initial	02-JUN-16	1.000	ppb
53752	53752-1-W-HAL-F04	East Modular 1- Outside of Room 127, Fountain 2	Initial	06-MAR-20	1.000	ug/L
53752	53752-1-E-HAL-F01	East Modular 1- Outside of Room 131, Fountain 1	Flush180	02-JUN-16	1.000	ppb
53752	53752-1-E-HAL-F01	East Modular 1- Outside of Room 131, Fountain 1	Flush180	02-JUN-16	1.000	ppb
53752	53752-1-E-HAL-F01	East Modular 1- Outside of Room 131, Fountain 1	Flush180	02-JUN-16	1.000	ppb
53752	53752-1-E-HAL-F01	East Modular 1- Outside of Room 131, Fountain 1	Flush180	02-JUN-16	1.000	ppb
53752	53752-1-E-HAL-F01	East Modular 1- Outside of Room 131, Fountain 1	Flush180	23-JUL-20	1.000	ug/L
53752	53752-1-E-HAL-F01	East Modular 1- Outside of Room 131, Fountain 1	Flush180	06-MAR-20	1.000	ug/L
53752	53752-1-E-HAL-F01	East Modular 1- Outside of Room 131, Fountain 1	Flush180	06-MAR-20	1.000	ug/L
53752	53752-1-E-HAL-F01	East Modular 1- Outside of Room 131, Fountain 1	Flush180	06-MAR-20	1.000	ug/L
53752	53752-1-E-HAL-F01	East Modular 1- Outside of Room 131, Fountain 1	Initial	02-JUN-16	1.000	ppb
53752	53752-1-E-HAL-F01	East Modular 1- Outside of Room 131, Fountain 1	Initial	23-JUL-20	1.000	ug/L
53752	53752-1-E-HAL-F01	East Modular 1- Outside of Room 131, Fountain 1	Initial	06-MAR-20	1.000	ug/L
53752	53752-1-W-HAL-F02	East Modular 1- Outside of Room 131, Fountain 2	Flush180	02-JUN-16	1.000	ppb
53752	53752-1-W-HAL-F02	East Modular 1- Outside of Room 131, Fountain 2	Flush180	02-JUN-16	1.000	ppb
53752	53752-1-W-HAL-F02	East Modular 1- Outside of Room 131, Fountain 2	Flush180	02-JUN-16	1.000	ppb
53752	53752-1-W-HAL-F02	East Modular 1- Outside of Room 131, Fountain 2	Flush180	06-MAR-20	1.000	ug/L
53752	53752-1-W-HAL-F02	East Modular 1- Outside of Room 131, Fountain 2	Flush180	06-MAR-20	1.000	ug/L
53752	53752-1-W-HAL-F02	East Modular 1- Outside of Room 131, Fountain 2	Flush180	06-MAR-20	1.000	ug/L
53752	53752-1-W-HAL-F02	East Modular 1- Outside of Room 131, Fountain 2	Flush180	06-MAR-20	1.000	ug/L
53752	53752-1-W-HAL-F02	East Modular 1- Outside of Room 131, Fountain 2	Initial	02-JUN-16	1.000	ppb
53752	53752-1-W-HAL-F02	East Modular 1- Outside of Room 131, Fountain 2	Initial	06-MAR-20	1.000	ug/L
53752	53752-1-HAL-F07	Left Drinking Fountain, Next to Rm 127 (south end) (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-HAL-F07	Left Drinking Fountain, Next to Rm 127 (south end) (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-HAL-F07	Left Drinking Fountain, Next to Rm 127 (south end) (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-HAL-F07	Left Drinking Fountain, Next to Rm 127 (south end) (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-HAL-F07	Left Drinking Fountain, Next to Rm 127 (south end) (East modular building)	Initial	18-AUG-23	1.000	ug/L
53752	53752-1-HAL-F05	Left Drinking Fountain, Next to Rm 131 (north end) (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-HAL-F05	Left Drinking Fountain, Next to Rm 131 (north end) (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-HAL-	Left Drinking Fountain, Next to Rm	Flush180	18-AUG-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F05	131 (north end) (East modular building)				
53752	53752-1-HAL-F05	Left Drinking Fountain, Next to Rm 131 (north end) (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-HAL-F05	Left Drinking Fountain, Next to Rm 131 (north end) (East modular building)	Initial	18-AUG-23	1.000	ug/L
53752	53752-1-HAL-F08	Right Drinking Fountain, Next to Rm 127 (south end) (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-HAL-F08	Right Drinking Fountain, Next to Rm 127 (south end) (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-HAL-F08	Right Drinking Fountain, Next to Rm 127 (south end) (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-HAL-F08	Right Drinking Fountain, Next to Rm 127 (south end) (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-HAL-F08	Right Drinking Fountain, Next to Rm 127 (south end) (East modular building)	Initial	18-AUG-23	1.000	ug/L
53752	53752-1-HAL-F06	Right Drinking Fountain, Next to Rm 131 (north end) (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-HAL-F06	Right Drinking Fountain, Next to Rm 131 (north end) (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-HAL-F06	Right Drinking Fountain, Next to Rm 131 (north end) (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-HAL-F06	Right Drinking Fountain, Next to Rm 131 (north end) (East modular building)	Initial	18-AUG-23	1.000	ug/L
53752	53752-1-124-S01	Sink in Pre-K Classroom 124 (East modular building)	Flush180	18-AUG-23	1.150	ug/L
53752	53752-1-124-S01	Sink in Pre-K Classroom 124 (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-124-S01	Sink in Pre-K Classroom 124 (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-124-S01	Sink in Pre-K Classroom 124 (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-124-S01	Sink in Pre-K Classroom 124 (East modular building)	Initial	18-AUG-23	1.000	ug/L
53752	53752-1-125-S01	Sink in Pre-K Classroom 125 (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-125-S01	Sink in Pre-K Classroom 125 (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-125-S01	Sink in Pre-K Classroom 125 (East modular building)	Flush180	18-AUG-23	1.000	ug/L
53752	53752-1-125-S01	Sink in Pre-K Classroom 125 (East modular building)	Initial	18-AUG-23	1.000	ug/L
53753	53753-1-HAL-BF01	Bottle Filler, Next to Rm 120 (north modular building)	Flush180	18-AUG-23	1.000	ug/L
53753	53753-1-HAL-BF01	Bottle Filler, Next to Rm 120 (north modular building)	Flush180	18-AUG-23	1.000	ug/L
53753	53753-1-HAL-BF01	Bottle Filler, Next to Rm 120 (north modular building)	Flush180	18-AUG-23	1.000	ug/L
53753	53753-1-HAL-BF01	Bottle Filler, Next to Rm 120 (north modular building)	Flush180	18-AUG-23	1.000	ug/L
53753	53753-1-HAL-BF01	Bottle Filler, Next to Rm 120 (north modular building)	Initial	18-AUG-23	1.000	ug/L
53753	53753-1-120-F01	Drinking fountain in classroom 120. (north modular building)	Flush180	18-AUG-23	1.000	ug/L
53753	53753-1-120-F01	Drinking fountain in classroom 120. (north modular building)	Flush180	18-AUG-23	1.000	ug/L
53753	53753-1-120-F01	Drinking fountain in classroom 120. (north modular building)	Flush180	18-AUG-23	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
53753	53753-1-120-F01	Drinking fountain in classroom 120. (north modular building)	Flush180	18-AUG-23	1.000	ug/L
53753	53753-1-120-F01	Drinking fountain in classroom 120. (north modular building)	Initial	18-AUG-23	1.000	ug/L
53753	53753-1-HAL-F03	Left Drinking Fountain, Next to Rm 120 (north modular building)	Flush180	18-AUG-23	1.000	ug/L
53753	53753-1-HAL-F03	Left Drinking Fountain, Next to Rm 120 (north modular building)	Flush180	18-AUG-23	1.000	ug/L
53753	53753-1-HAL-F03	Left Drinking Fountain, Next to Rm 120 (north modular building)	Flush180	18-AUG-23	1.000	ug/L
53753	53753-1-HAL-F03	Left Drinking Fountain, Next to Rm 120 (north modular building)	Flush180	18-AUG-23	1.000	ug/L
53753	53753-1-HAL-F03	Left Drinking Fountain, Next to Rm 120 (north modular building)	Initial	18-AUG-23	1.000	ug/L
53753	53753-1-N-HAL-F01	North Modular 2- Fountain 1	Flush180	27-JUL-16	2.500	ppb
53753	53753-1-N-HAL-F01	North Modular 2- Fountain 1	Flush180	27-JUL-16	2.400	ppb
53753	53753-1-N-HAL-F01	North Modular 2- Fountain 1	Flush180	02-JUN-16	16.000	ppb
53753	53753-1-N-HAL-F01	North Modular 2- Fountain 1	Flush180	02-JUN-16	1.000	ppb
53753	53753-1-N-HAL-F01	North Modular 2- Fountain 1	Flush180	02-JUN-16	1.000	ppb
53753	53753-1-N-HAL-F01	North Modular 2- Fountain 1	Flush180	27-JUL-16	2.800	ppb
53753	53753-1-N-HAL-F01	North Modular 2- Fountain 1	Flush180	27-JUL-16	3.300	ppb
53753	53753-1-N-HAL-F01	North Modular 2- Fountain 1	Flush180	02-JUN-16	1.000	ppb
53753	53753-1-N-HAL-F01	North Modular 2- Fountain 1	Flush180	23-JUL-20	1.000	ug/L
53753	53753-1-N-HAL-F01	North Modular 2- Fountain 1	Flush180	06-MAR-20	1.000	ug/L
53753	53753-1-N-HAL-F01	North Modular 2- Fountain 1	Flush180	06-MAR-20	1.000	ug/L
53753	53753-1-N-HAL-F01	North Modular 2- Fountain 1	Flush180	06-MAR-20	1.000	ug/L
53753	53753-1-N-HAL-F01	North Modular 2- Fountain 1	Flush180	06-MAR-20	1.000	ug/L
53753	53753-1-N-HAL-F01	North Modular 2- Fountain 1	Initial	27-JUL-16	7.300	ppb
53753	53753-1-N-HAL-F01	North Modular 2- Fountain 1	Initial	02-JUN-16	1.000	ppb
53753	53753-1-N-HAL-F01	North Modular 2- Fountain 1	Initial	23-JUL-20	1.000	ug/L
53753	53753-1-N-HAL-F01	North Modular 2- Fountain 1	Initial	06-MAR-20	1.000	ug/L
53753	53753-1-N-HAL-F02	North Modular 2- Fountain 2	Flush180	02-JUN-16	1.000	ppb
53753	53753-1-N-HAL-F02	North Modular 2- Fountain 2	Flush180	02-JUN-16	1.000	ppb
53753	53753-1-N-HAL-F02	North Modular 2- Fountain 2	Flush180	02-JUN-16	1.000	ppb
53753	53753-1-N-HAL-F02	North Modular 2- Fountain 2	Flush180	02-JUN-16	1.000	ppb
53753	53753-1-N-HAL-F02	North Modular 2- Fountain 2	Flush180	06-MAR-20	1.000	ug/L
53753	53753-1-N-HAL-F02	North Modular 2- Fountain 2	Flush180	06-MAR-20	1.000	ug/L
53753	53753-1-N-HAL-F02	North Modular 2- Fountain 2	Flush180	06-MAR-20	1.000	ug/L
53753	53753-1-N-HAL-F02	North Modular 2- Fountain 2	Flush180	06-MAR-20	1.000	ug/L
53753	53753-1-N-HAL-F02	North Modular 2- Fountain 2	Initial	02-JUN-16	1.000	ppb
53753	53753-1-N-HAL-F02	North Modular 2- Fountain 2	Initial	06-MAR-20	1.000	ug/L
53753	53753-1-HAL-F04	Right Drinking Fountain, Next to Rm 120 (north modular building)	Flush180	18-AUG-23	1.000	ug/L
53753	53753-1-HAL-F04	Right Drinking Fountain, Next to Rm 120 (north modular building)	Flush180	18-AUG-23	1.000	ug/L
53753	53753-1-HAL-F04	Right Drinking Fountain, Next to Rm 120 (north modular building)	Flush180	18-AUG-23	1.000	ug/L
53753	53753-1-HAL-	Right Drinking Fountain, Next to	Flush180	18-AUG-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F04	Rm 120 (north modular building)				
53753	53753-1-HAL-F04	Right Drinking Fountain, Next to Rm 120 (north modular building)	Initial	18-AUG-23	1.000	ug/L
53753	53753-1-120-S01	Sink in Pre-K Classroom 120 (north modular building)	Flush180	18-AUG-23	1.000	ug/L
53753	53753-1-120-S01	Sink in Pre-K Classroom 120 (north modular building)	Flush180	18-AUG-23	1.000	ug/L
53753	53753-1-120-S01	Sink in Pre-K Classroom 120 (north modular building)	Flush180	18-AUG-23	1.000	ug/L
53753	53753-1-120-S01	Sink in Pre-K Classroom 120 (north modular building)	Flush180	18-AUG-23	1.000	ug/L
53753	53753-1-120-S01	Sink in Pre-K Classroom 120 (north modular building)	Initial	18-AUG-23	1.000	ug/L
55941	55941-1-HAL-BF01	Bottle Filler, Next to Rm 132 (South modular building)	Flush180	18-AUG-23	1.000	ug/L
55941	55941-1-HAL-BF01	Bottle Filler, Next to Rm 132 (South modular building)	Flush180	18-AUG-23	1.000	ug/L
55941	55941-1-HAL-BF01	Bottle Filler, Next to Rm 132 (South modular building)	Flush180	18-AUG-23	1.000	ug/L
55941	55941-1-HAL-BF01	Bottle Filler, Next to Rm 132 (South modular building)	Flush180	18-AUG-23	1.000	ug/L
55941	55941-1-HAL-BF01	Bottle Filler, Next to Rm 132 (South modular building)	Initial	18-AUG-23	1.000	ug/L
55941	55941-1-HAL-F03	Left Drinking Fountain, Next to Rm 132 (South modular building)	Flush180	18-AUG-23	1.000	ug/L
55941	55941-1-HAL-F03	Left Drinking Fountain, Next to Rm 132 (South modular building)	Flush180	18-AUG-23	1.000	ug/L
55941	55941-1-HAL-F03	Left Drinking Fountain, Next to Rm 132 (South modular building)	Flush180	18-AUG-23	1.000	ug/L
55941	55941-1-HAL-F03	Left Drinking Fountain, Next to Rm 132 (South modular building)	Flush180	18-AUG-23	1.000	ug/L
55941	55941-1-HAL-F03	Left Drinking Fountain, Next to Rm 132 (South modular building)	Initial	18-AUG-23	1.000	ug/L
55941	55941-1-HAL-F04	Right Drinking Fountain, Next to Rm 132 (South modular building)	Flush180	18-AUG-23	1.000	ug/L
55941	55941-1-HAL-F04	Right Drinking Fountain, Next to Rm 132 (South modular building)	Flush180	18-AUG-23	1.000	ug/L
55941	55941-1-HAL-F04	Right Drinking Fountain, Next to Rm 132 (South modular building)	Flush180	18-AUG-23	1.000	ug/L
55941	55941-1-HAL-F04	Right Drinking Fountain, Next to Rm 132 (South modular building)	Flush180	18-AUG-23	1.000	ug/L
55941	55941-1-HAL-F04	Right Drinking Fountain, Next to Rm 132 (South modular building)	Initial	18-AUG-23	1.000	ug/L
55941	55941-1-S-HAL-F01	South Modular 3- Fountain 1, Left Fountain	Flush180	02-JUN-16	1.000	ppb
55941	55941-1-S-HAL-F01	South Modular 3- Fountain 1, Left Fountain	Flush180	02-JUN-16	1.000	ppb
55941	55941-1-S-HAL-F01	South Modular 3- Fountain 1, Left Fountain	Flush180	02-JUN-16	1.000	ppb
55941	55941-1-S-HAL-F01	South Modular 3- Fountain 1, Left Fountain	Flush180	02-JUN-16	5.600	ppb
55941	55941-1-S-HAL-F01	South Modular 3- Fountain 1, Left Fountain	Flush180	23-JUL-20	1.000	ug/L
55941	55941-1-S-HAL-F01	South Modular 3- Fountain 1, Left Fountain	Flush180	06-MAR-20	1.000	ug/L
55941	55941-1-S-HAL-F01	South Modular 3- Fountain 1, Left Fountain	Flush180	06-MAR-20	1.000	ug/L
55941	55941-1-S-HAL-F01	South Modular 3- Fountain 1, Left Fountain	Flush180	06-MAR-20	1.000	ug/L
55941	55941-1-S-HAL-F01	South Modular 3- Fountain 1, Left Fountain	Initial	02-JUN-16	1.000	ppb
55941	55941-1-S-HAL-F01	South Modular 3- Fountain 1, Left Fountain	Initial	23-JUL-20	1.000	ug/L
55941	55941-1-S-HAL-F01	South Modular 3- Fountain 1, Left Fountain	Initial	06-MAR-20	1.000	ug/L
55941	55941-1-S-HAL-F02	South Modular 3- Fountain 2	Flush180	02-JUN-16	1.000	ppb
55941	55941-1-S-HAL-F02	South Modular 3- Fountain 2	Flush180	02-JUN-16	1.000	ppb
55941	55941-1-S-HAL-F02	South Modular 3- Fountain 2	Flush180	02-JUN-16	1.000	ppb
55941	55941-1-S-	South Modular 3- Fountain 2	Flush180	02-JUN-16	1.000	ppb

**Water Quality Assessment  
Jane Addams Elementary School**

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F02					
55941	55941-1-S-HAL-F02	South Modular 3- Fountain 2	Flush180	06-MAR-20	1.000	ug/L
55941	55941-1-S-HAL-F02	South Modular 3- Fountain 2	Flush180	06-MAR-20	1.000	ug/L
55941	55941-1-S-HAL-F02	South Modular 3- Fountain 2	Flush180	06-MAR-20	1.000	ug/L
55941	55941-1-S-HAL-F02	South Modular 3- Fountain 2	Flush180	06-MAR-20	1.000	ug/L
55941	55941-1-S-HAL-F02	South Modular 3- Fountain 2	Initial	02-JUN-16	1.000	ppb
55941	55941-1-S-HAL-F02	South Modular 3- Fountain 2	Initial	06-MAR-20	1.000	ug/L