



**Sep 10, 2024**

**ALDRIDGE**

**630 E 131ST ST, Chicago IL 60827.**

Dear **ALDRIDGE** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**ALDRIDGE**

**630 E 131ST ST, Chicago IL 60827.**

Estimadas familias de **ALDRIDGE**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarle y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51501	51501-1-N-KIT-KS02		Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-N-KIT-KS02		Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-N-KIT-KS02		Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-N-KIT-KS02		Flush180	12-MAR-20	1.050	ug/L
51501	51501-1-N-KIT-KS02		Initial	12-MAR-20	1.000	ug/L
51501	51501-1-E-HAL-F14	1st Floor By Boys Washroom, Fountain	Flush180	18-JUN-16	0.125	ppb
51501	51501-1-E-HAL-F14	1st Floor By Boys Washroom, Fountain	Flush180	18-JUN-16	0.207	ppb
51501	51501-1-E-HAL-F14	1st Floor By Boys Washroom, Fountain	Flush180	18-JUN-16	0.247	ppb
51501	51501-1-E-HAL-F14	1st Floor By Boys Washroom, Fountain	Flush180	18-JUN-16	0.952	ppb
51501	51501-1-E-HAL-F14	1st Floor By Boys Washroom, Fountain	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-E-HAL-F14	1st Floor By Boys Washroom, Fountain	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-E-HAL-F14	1st Floor By Boys Washroom, Fountain	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-E-HAL-F14	1st Floor By Boys Washroom, Fountain	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-E-HAL-F14	1st Floor By Boys Washroom, Fountain	Initial	18-JUN-16	1.000	ppb
51501	51501-1-E-HAL-F14	1st Floor By Boys Washroom, Fountain	Initial	12-MAR-20	1.100	ug/L
51501	51501-1-W-HAL-F15	1st Floor By Girls Washroom, Fountain	Flush180	18-JUN-16	1.390	ppb
51501	51501-1-W-HAL-F15	1st Floor By Girls Washroom, Fountain	Flush180	18-JUN-16	0.971	ppb
51501	51501-1-W-HAL-F15	1st Floor By Girls Washroom, Fountain	Flush180	18-JUN-16	0.497	ppb
51501	51501-1-W-HAL-F15	1st Floor By Girls Washroom, Fountain	Flush180	18-JUN-16	0.580	ppb
51501	51501-1-W-HAL-F15	1st Floor By Girls Washroom, Fountain	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-W-HAL-F15	1st Floor By Girls Washroom, Fountain	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-W-HAL-F15	1st Floor By Girls Washroom, Fountain	Flush180	12-MAR-20	2.140	ug/L
51501	51501-1-W-HAL-F15	1st Floor By Girls Washroom, Fountain	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-W-HAL-F15	1st Floor By Girls Washroom, Fountain	Initial	18-JUN-16	0.536	ppb
51501	51501-1-W-HAL-F15	1st Floor By Girls Washroom, Fountain	Initial	12-MAR-20	1.410	ug/L
51501	51501-1-W-HAL-F04	1st Floor By Gym, Fountain 1	Flush180	13-SEP-23	1.000	ug/L
51501	51501-1-W-HAL-F04	1st Floor By Gym, Fountain 1	Flush180	13-SEP-23	1.000	ug/L
51501	51501-1-W-HAL-F04	1st Floor By Gym, Fountain 1	Flush180	13-SEP-23	1.000	ug/L
51501	51501-1-W-HAL-F04	1st Floor By Gym, Fountain 1	Flush180	13-SEP-23	1.000	ug/L
51501	51501-1-W-HAL-F04	1st Floor By Gym, Fountain 1	Flush180	18-JUN-16	0.123	ppb
51501	51501-1-W-HAL-F04	1st Floor By Gym, Fountain 1	Flush180	18-JUN-16	0.185	ppb
51501	51501-1-W-HAL-F04	1st Floor By Gym, Fountain 1	Flush180	18-JUN-16	1.310	ppb
51501	51501-1-W-HAL-F04	1st Floor By Gym, Fountain 1	Flush180	18-JUN-16	0.193	ppb
51501	51501-1-W-HAL-F04	1st Floor By Gym, Fountain 1	Flush180	12-MAR-20	1.240	ug/L
51501	51501-1-W-HAL-F04	1st Floor By Gym, Fountain 1	Flush180	12-MAR-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51501	51501-1-W-HAL-F04	1st Floor By Gym, Fountain 1	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-W-HAL-F04	1st Floor By Gym, Fountain 1	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-W-HAL-F04	1st Floor By Gym, Fountain 1	Flush180	21-JUL-20	1.000	ug/L
51501	51501-1-W-HAL-F04	1st Floor By Gym, Fountain 1	Initial	13-SEP-23	1.000	ug/L
51501	51501-1-W-HAL-F04	1st Floor By Gym, Fountain 1	Initial	18-JUN-16	1.000	ppb
51501	51501-1-W-HAL-F04	1st Floor By Gym, Fountain 1	Initial	12-MAR-20	1.060	ug/L
51501	51501-1-W-HAL-F04	1st Floor By Gym, Fountain 1	Initial	21-JUL-20	1.000	ug/L
51501	51501-1-W-HAL-F05	1st Floor By Gym, Fountain 2	Flush180	18-JUN-16	1.000	ppb
51501	51501-1-W-HAL-F05	1st Floor By Gym, Fountain 2	Flush180	18-JUN-16	0.302	ppb
51501	51501-1-W-HAL-F05	1st Floor By Gym, Fountain 2	Flush180	18-JUN-16	1.000	ppb
51501	51501-1-W-HAL-F05	1st Floor By Gym, Fountain 2	Flush180	18-JUN-16	1.000	ppb
51501	51501-1-W-HAL-F05	1st Floor By Gym, Fountain 2	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-W-HAL-F05	1st Floor By Gym, Fountain 2	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-W-HAL-F05	1st Floor By Gym, Fountain 2	Flush180	12-MAR-20	1.080	ug/L
51501	51501-1-W-HAL-F05	1st Floor By Gym, Fountain 2	Initial	18-JUN-16	1.000	ppb
51501	51501-1-W-HAL-F05	1st Floor By Gym, Fountain 2	Initial	12-MAR-20	1.000	ug/L
51501	51501-1-W-HAL-RBF01	1st Floor By Gym, Retrofit BF 1	Flush180	13-SEP-23	2.550	ug/L
51501	51501-1-W-HAL-RBF01	1st Floor By Gym, Retrofit BF 1	Flush180	13-SEP-23	1.000	ug/L
51501	51501-1-W-HAL-RBF01	1st Floor By Gym, Retrofit BF 1	Flush180	13-SEP-23	1.310	ug/L
51501	51501-1-W-HAL-RBF01	1st Floor By Gym, Retrofit BF 1	Flush180	13-SEP-23	3.570	ug/L
51501	51501-1-W-HAL-RBF01	1st Floor By Gym, Retrofit BF 1	Initial	13-SEP-23	1.000	ug/L
51501	51501-1-HAL-F10	1st Floor By Janitors Closet, Fountain 1	Flush180	18-JUN-16	1.750	ppb
51501	51501-1-HAL-F10	1st Floor By Janitors Closet, Fountain 1	Flush180	18-JUN-16	1.770	ppb
51501	51501-1-HAL-F10	1st Floor By Janitors Closet, Fountain 1	Flush180	18-JUN-16	1.880	ppb
51501	51501-1-HAL-F10	1st Floor By Janitors Closet, Fountain 1	Flush180	18-JUN-16	1.760	ppb
51501	51501-1-HAL-F10	1st Floor By Janitors Closet, Fountain 1	Initial	18-JUN-16	1.710	ppb
51501	51501-1-E-HAL-F11	1st Floor By Janitors Closet, Fountain 2	Flush180	23-APR-20	3.600	ug/L
51501	51501-1-E-HAL-F11	1st Floor By Janitors Closet, Fountain 2	Flush180	23-APR-20	1.560	ug/L
51501	51501-1-E-HAL-F11	1st Floor By Janitors Closet, Fountain 2	Flush180	23-APR-20	1.910	ug/L
51501	51501-1-E-HAL-F11	1st Floor By Janitors Closet, Fountain 2	Flush180	23-APR-20	2.710	ug/L
51501	51501-1-E-HAL-F11	1st Floor By Janitors Closet, Fountain 2	Flush180	12-MAR-20	4.770	ug/L
51501	51501-1-E-HAL-F11	1st Floor By Janitors Closet, Fountain 2	Flush180	12-MAR-20	6.440	ug/L
51501	51501-1-E-HAL-F11	1st Floor By Janitors Closet, Fountain 2	Flush180	12-MAR-20	11.300	ug/L
51501	51501-1-E-HAL-F11	1st Floor By Janitors Closet, Fountain 2	Flush180	12-MAR-20	4.440	ug/L
51501	51501-1-E-HAL-F11	1st Floor By Janitors Closet, Fountain 2	Flush180	20-MAY-20	3.240	ug/L
51501	51501-1-E-HAL-F11	1st Floor By Janitors Closet, Fountain 2	Flush180	20-MAY-20	2.950	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51501	51501-1-E-HAL-F11	1st Floor By Janitors Closet, Fountain 2	Flush180	20-MAY-20	2.280	ug/L
51501	51501-1-E-HAL-F11	1st Floor By Janitors Closet, Fountain 2	Flush180	20-MAY-20	2.280	ug/L
51501	51501-1-E-HAL-F11	1st Floor By Janitors Closet, Fountain 2	Flush180	18-JUN-16	5.760	ppb
51501	51501-1-E-HAL-F11	1st Floor By Janitors Closet, Fountain 2	Flush180	18-JUN-16	1.810	ppb
51501	51501-1-E-HAL-F11	1st Floor By Janitors Closet, Fountain 2	Flush180	18-JUN-16	1.650	ppb
51501	51501-1-E-HAL-F11	1st Floor By Janitors Closet, Fountain 2	Flush180	18-JUN-16	1.840	ppb
51501	51501-1-E-HAL-F11	1st Floor By Janitors Closet, Fountain 2	Initial	23-APR-20	6.030	ug/L
51501	51501-1-E-HAL-F11	1st Floor By Janitors Closet, Fountain 2	Initial	12-MAR-20	4.220	ug/L
51501	51501-1-E-HAL-F11	1st Floor By Janitors Closet, Fountain 2	Initial	20-MAY-20	6.490	ug/L
51501	51501-1-E-HAL-F11	1st Floor By Janitors Closet, Fountain 2	Initial	18-JUN-16	2.130	ppb
51501	51501-1-S-HAL-F07	1st Floor By Room 105, Fountain 1	Flush180	18-JUN-16	1.840	ppb
51501	51501-1-S-HAL-F07	1st Floor By Room 105, Fountain 1	Flush180	18-JUN-16	0.272	ppb
51501	51501-1-S-HAL-F07	1st Floor By Room 105, Fountain 1	Flush180	18-JUN-16	0.595	ppb
51501	51501-1-S-HAL-F07	1st Floor By Room 105, Fountain 1	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-S-HAL-F07	1st Floor By Room 105, Fountain 1	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-S-HAL-F07	1st Floor By Room 105, Fountain 1	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-S-HAL-F07	1st Floor By Room 105, Fountain 1	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-S-HAL-F07	1st Floor By Room 105, Fountain 1	Flush180	18-JUN-16	0.203	ppb
51501	51501-1-S-HAL-F07	1st Floor By Room 105, Fountain 1	Initial	12-MAR-20	1.000	ug/L
51501	51501-1-S-HAL-F07	1st Floor By Room 105, Fountain 1	Initial	18-JUN-16	1.000	ppb
51501	51501-1-S-HAL-F08	1st Floor By Room 105, Fountain 2	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-S-HAL-F08	1st Floor By Room 105, Fountain 2	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-S-HAL-F08	1st Floor By Room 105, Fountain 2	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-S-HAL-F08	1st Floor By Room 105, Fountain 2	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-S-HAL-F08	1st Floor By Room 105, Fountain 2	Flush180	18-JUN-16	0.214	ppb
51501	51501-1-S-HAL-F08	1st Floor By Room 105, Fountain 2	Flush180	18-JUN-16	1.000	ppb
51501	51501-1-S-HAL-F08	1st Floor By Room 105, Fountain 2	Flush180	18-JUN-16	1.000	ppb
51501	51501-1-S-HAL-F08	1st Floor By Room 105, Fountain 2	Initial	12-MAR-20	1.000	ug/L
51501	51501-1-S-HAL-F08	1st Floor By Room 105, Fountain 2	Initial	18-JUN-16	1.000	ppb
51501	51501-1-S-HAL-F09	1st Floor By Room 105, Fountain 3	Flush180	12-MAR-20	1.280	ug/L
51501	51501-1-S-HAL-F09	1st Floor By Room 105, Fountain 3	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-S-HAL-F09	1st Floor By Room 105, Fountain 3	Flush180	12-MAR-20	2.470	ug/L
51501	51501-1-S-HAL-F09	1st Floor By Room 105, Fountain 3	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-S-HAL-F09	1st Floor By Room 105, Fountain 3	Flush180	18-JUN-16	1.000	ppb
51501	51501-1-S-HAL-F09	1st Floor By Room 105, Fountain 3	Flush180	18-JUN-16	1.000	ppb
51501	51501-1-S-HAL-F09	1st Floor By Room 105, Fountain 3	Flush180	18-JUN-16	1.000	ppb
51501	51501-1-S-	1st Floor By Room 105, Fountain 3	Flush180	18-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F09					
51501	51501-1-S-HAL-F09	1st Floor By Room 105, Fountain 3	Initial	12-MAR-20	1.290	ug/L
51501	51501-1-S-HAL-F09	1st Floor By Room 105, Fountain 3	Initial	18-JUN-16	0.350	ppb
51501	51501-1-E-HAL-F12	1st Floor By Room 121, Fountain 1	Flush180	18-JUN-16	0.706	ppb
51501	51501-1-E-HAL-F12	1st Floor By Room 121, Fountain 1	Flush180	18-JUN-16	1.470	ppb
51501	51501-1-E-HAL-F12	1st Floor By Room 121, Fountain 1	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-E-HAL-F12	1st Floor By Room 121, Fountain 1	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-E-HAL-F12	1st Floor By Room 121, Fountain 1	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-E-HAL-F12	1st Floor By Room 121, Fountain 1	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-E-HAL-F12	1st Floor By Room 121, Fountain 1	Flush180	18-JUN-16	2.160	ppb
51501	51501-1-E-HAL-F12	1st Floor By Room 121, Fountain 1	Flush180	18-JUN-16	0.892	ppb
51501	51501-1-E-HAL-F12	1st Floor By Room 121, Fountain 1	Initial	12-MAR-20	1.250	ug/L
51501	51501-1-E-HAL-F12	1st Floor By Room 121, Fountain 1	Initial	18-JUN-16	0.575	ppb
51501	51501-1-E-HAL-F13	1st Floor By Room 121, Fountain 2	Flush180	18-JUN-16	0.655	ppb
51501	51501-1-E-HAL-F13	1st Floor By Room 121, Fountain 2	Flush180	18-JUN-16	0.182	ppb
51501	51501-1-E-HAL-F13	1st Floor By Room 121, Fountain 2	Flush180	18-JUN-16	0.233	ppb
51501	51501-1-E-HAL-F13	1st Floor By Room 121, Fountain 2	Flush180	18-JUN-16	0.157	ppb
51501	51501-1-E-HAL-F13	1st Floor By Room 121, Fountain 2	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-E-HAL-F13	1st Floor By Room 121, Fountain 2	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-E-HAL-F13	1st Floor By Room 121, Fountain 2	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-E-HAL-F13	1st Floor By Room 121, Fountain 2	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-E-HAL-F13	1st Floor By Room 121, Fountain 2	Initial	18-JUN-16	1.420	ppb
51501	51501-1-E-HAL-F13	1st Floor By Room 121, Fountain 2	Initial	12-MAR-20	1.000	ug/L
51501	51501-1-S-100-F01	1st Floor Inside Room 100, Fountain	Flush180	18-JUN-16	0.933	ppb
51501	51501-1-S-100-F01	1st Floor Inside Room 100, Fountain	Flush180	18-JUN-16	0.336	ppb
51501	51501-1-S-100-F01	1st Floor Inside Room 100, Fountain	Flush180	18-JUN-16	0.350	ppb
51501	51501-1-S-100-F01	1st Floor Inside Room 100, Fountain	Flush180	18-JUN-16	0.158	ppb
51501	51501-1-S-100-F01	1st Floor Inside Room 100, Fountain	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-S-100-F01	1st Floor Inside Room 100, Fountain	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-S-100-F01	1st Floor Inside Room 100, Fountain	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-S-100-F01	1st Floor Inside Room 100, Fountain	Initial	18-JUN-16	0.779	ppb
51501	51501-1-S-100-F01	1st Floor Inside Room 100, Fountain	Initial	12-MAR-20	1.000	ug/L
51501	51501-1-S-100-S02	1st Floor Inside Room 100, Sink	Flush180	18-JUN-16	0.230	ppb
51501	51501-1-S-100-S02	1st Floor Inside Room 100, Sink	Flush180	18-JUN-16	0.226	ppb
51501	51501-1-S-100-S02	1st Floor Inside Room 100, Sink	Flush180	18-JUN-16	0.235	ppb
51501	51501-1-S-100-S02	1st Floor Inside Room 100, Sink	Flush180	18-JUN-16	1.140	ppb
51501	51501-1-S-	1st Floor Inside Room 100, Sink	Flush180	12-MAR-20	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	100-S02					
51501	51501-1-S-100-S02	1st Floor Inside Room 100, Sink	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-S-100-S02	1st Floor Inside Room 100, Sink	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-S-100-S02	1st Floor Inside Room 100, Sink	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-S-100-S02	1st Floor Inside Room 100, Sink	Initial	18-JUN-16	0.224	ppb
51501	51501-1-S-100-S02	1st Floor Inside Room 100, Sink	Initial	12-MAR-20	1.000	ug/L
51501	51501-1-S-105-S06	1st Floor Inside Room 105, Sink	Flush180	18-JUN-16	0.458	ppb
51501	51501-1-S-105-S06	1st Floor Inside Room 105, Sink	Flush180	18-JUN-16	0.804	ppb
51501	51501-1-S-105-S06	1st Floor Inside Room 105, Sink	Flush180	18-JUN-16	1.400	ppb
51501	51501-1-S-105-S06	1st Floor Inside Room 105, Sink	Flush180	18-JUN-16	1.230	ppb
51501	51501-1-S-105-S06	1st Floor Inside Room 105, Sink	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-S-105-S06	1st Floor Inside Room 105, Sink	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-S-105-S06	1st Floor Inside Room 105, Sink	Flush180	12-MAR-20	1.230	ug/L
51501	51501-1-S-105-S06	1st Floor Inside Room 105, Sink	Flush180	12-MAR-20	1.340	ug/L
51501	51501-1-S-105-S06	1st Floor Inside Room 105, Sink	Initial	18-JUN-16	1.340	ppb
51501	51501-1-S-105-S06	1st Floor Inside Room 105, Sink	Initial	12-MAR-20	1.000	ug/L
51501	51501-1-N-KIT-KS03	1st Floor Kitchen, Sink	Flush180	18-JUN-16	0.378	ppb
51501	51501-1-N-KIT-KS03	1st Floor Kitchen, Sink	Flush180	18-JUN-16	0.364	ppb
51501	51501-1-N-KIT-KS03	1st Floor Kitchen, Sink	Flush180	18-JUN-16	3.720	ppb
51501	51501-1-N-KIT-KS03	1st Floor Kitchen, Sink	Flush180	18-JUN-16	2.450	ppb
51501	51501-1-N-KIT-KS03	1st Floor Kitchen, Sink	Flush180	12-MAR-20	1.040	ug/L
51501	51501-1-N-KIT-KS03	1st Floor Kitchen, Sink	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-N-KIT-KS03	1st Floor Kitchen, Sink	Flush180	12-MAR-20	1.000	ug/L
51501	51501-1-N-KIT-KS03	1st Floor Kitchen, Sink	Flush180	12-MAR-20	1.060	ug/L
51501	51501-1-N-KIT-KS03	1st Floor Kitchen, Sink	Initial	18-JUN-16	1.090	ppb
51501	51501-1-N-KIT-KS03	1st Floor Kitchen, Sink	Initial	12-MAR-20	1.000	ug/L
51501	51501-2-E-HAL-F01	2nd Floor By Boys Washroom, Fountain	Flush180	18-JUN-16	0.915	ppb
51501	51501-2-E-HAL-F01	2nd Floor By Boys Washroom, Fountain	Flush180	18-JUN-16	2.640	ppb
51501	51501-2-E-HAL-F01	2nd Floor By Boys Washroom, Fountain	Flush180	18-JUN-16	0.982	ppb
51501	51501-2-E-HAL-F01	2nd Floor By Boys Washroom, Fountain	Flush180	18-JUN-16	5.620	ppb
51501	51501-2-E-HAL-F01	2nd Floor By Boys Washroom, Fountain	Flush180	12-MAR-20	1.000	ug/L
51501	51501-2-E-HAL-F01	2nd Floor By Boys Washroom, Fountain	Flush180	12-MAR-20	1.000	ug/L
51501	51501-2-E-HAL-F01	2nd Floor By Boys Washroom, Fountain	Flush180	12-MAR-20	1.000	ug/L
51501	51501-2-E-HAL-F01	2nd Floor By Boys Washroom, Fountain	Flush180	12-MAR-20	1.000	ug/L
51501	51501-2-E-HAL-F01	2nd Floor By Boys Washroom, Fountain	Initial	18-JUN-16	3.070	ppb
51501	51501-2-E-HAL-F01	2nd Floor By Boys Washroom, Fountain	Initial	12-MAR-20	1.000	ug/L
51501	51501-2-W-HAL-F02	2nd Floor By Girls Washroom, Fountain	Flush180	18-JUN-16	0.356	ppb
51501	51501-2-W-HAL-F02	2nd Floor By Girls Washroom, Fountain	Flush180	18-JUN-16	0.344	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51501	51501-2-W-HAL-F02	2nd Floor By Girls Washroom, Fountain	Flush180	18-JUN-16	0.332	ppb
51501	51501-2-W-HAL-F02	2nd Floor By Girls Washroom, Fountain	Flush180	18-JUN-16	0.612	ppb
51501	51501-2-W-HAL-F02	2nd Floor By Girls Washroom, Fountain	Flush180	21-JUL-20	1.770	ug/L
51501	51501-2-W-HAL-F02	2nd Floor By Girls Washroom, Fountain	Flush180	12-MAR-20	1.000	ug/L
51501	51501-2-W-HAL-F02	2nd Floor By Girls Washroom, Fountain	Flush180	12-MAR-20	1.000	ug/L
51501	51501-2-W-HAL-F02	2nd Floor By Girls Washroom, Fountain	Flush180	12-MAR-20	1.000	ug/L
51501	51501-2-W-HAL-F02	2nd Floor By Girls Washroom, Fountain	Flush180	12-MAR-20	1.000	ug/L
51501	51501-2-W-HAL-F02	2nd Floor By Girls Washroom, Fountain	Initial	18-JUN-16	0.849	ppb
51501	51501-2-W-HAL-F02	2nd Floor By Girls Washroom, Fountain	Initial	21-JUL-20	2.450	ug/L
51501	51501-2-W-HAL-F02	2nd Floor By Girls Washroom, Fountain	Initial	12-MAR-20	1.000	ug/L