



Sep 10, 2024

AMUNDSEN HS

5110 N DAMEN AVE, Chicago IL 60625.

Dear **AMUNDSEN HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

AMUNDSEN HS

5110 N DAMEN AVE, Chicago IL 60625.

Estimadas familias de **AMUNDSEN HS:**

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51531	51531-3-HAL-F06	Main-Fountain (Center) Across from Cafeteria S. Wa	Flush180	30-SEP-16	1.000	ppb
51531	51531-3-HAL-F06	Main-Fountain (Center) Across from Cafeteria S. Wa	Flush180	30-SEP-16	1.000	ppb
51531	51531-3-HAL-F06	Main-Fountain (Center) Across from Cafeteria S. Wa	Flush180	30-SEP-16	1.000	ppb
51531	51531-3-HAL-F06	Main-Fountain (Center) Across from Cafeteria S. Wa	Flush180	30-SEP-16	1.000	ppb
51531	51531-3-HAL-F06	Main-Fountain (Center) Across from Cafeteria S. Wa	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F06	Main-Fountain (Center) Across from Cafeteria S. Wa	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F06	Main-Fountain (Center) Across from Cafeteria S. Wa	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F06	Main-Fountain (Center) Across from Cafeteria S. Wa	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F06	Main-Fountain (Center) Across from Cafeteria S. Wa	Initial	30-SEP-16	1.000	ppb
51531	51531-3-HAL-F06	Main-Fountain (Center) Across from Cafeteria S. Wa	Initial	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F02	Main-Fountain (Center) by Room 128 S. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-1-HAL-F02	Main-Fountain (Center) by Room 128 S. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-1-HAL-F02	Main-Fountain (Center) by Room 128 S. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-1-HAL-F02	Main-Fountain (Center) by Room 128 S. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-1-HAL-F02	Main-Fountain (Center) by Room 128 S. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F02	Main-Fountain (Center) by Room 128 S. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F02	Main-Fountain (Center) by Room 128 S. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F02	Main-Fountain (Center) by Room 128 S. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F02	Main-Fountain (Center) by Room 128 S. Wall	Initial	30-SEP-16	1.000	ppb
51531	51531-1-HAL-F02	Main-Fountain (Center) by Room 128 S. Wall	Initial	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F02	Main-Fountain (Center) by Room 228 S. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-2-HAL-F02	Main-Fountain (Center) by Room 228 S. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-2-HAL-F02	Main-Fountain (Center) by Room 228 S. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-2-HAL-F02	Main-Fountain (Center) by Room 228 S. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F02	Main-Fountain (Center) by Room 228 S. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F02	Main-Fountain (Center) by Room 228 S. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F02	Main-Fountain (Center) by Room 228 S. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F02	Main-Fountain (Center) by Room 228 S. Wall	Initial	30-SEP-16	1.000	ppb
51531	51531-2-HAL-F02	Main-Fountain (Center) by Room 228 S. Wall	Initial	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F07	Main-Fountain (Left) Across from Cafeteria S. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-3-HAL-F07	Main-Fountain (Left) Across from Cafeteria S. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-3-HAL-F07	Main-Fountain (Left) Across from Cafeteria S. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-3-HAL-F07	Main-Fountain (Left) Across from Cafeteria S. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-3-HAL-F07	Main-Fountain (Left) Across from Cafeteria S. Wall	Flush180	25-SEP-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F06	218 E. Wall				
51531	51531-2-HAL-F06	Main-Fountain (Left) Next to Room 218 E. Wall	Initial	30-SEP-16	0.221	ppb
51531	51531-2-HAL-F06	Main-Fountain (Left) Next to Room 218 E. Wall	Initial	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F04	Main-Fountain (Left) Next to Room 224 E. Wall	Flush180	30-SEP-16	0.166	ppb
51531	51531-2-HAL-F04	Main-Fountain (Left) Next to Room 224 E. Wall	Flush180	30-SEP-16	0.131	ppb
51531	51531-2-HAL-F04	Main-Fountain (Left) Next to Room 224 E. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-2-HAL-F04	Main-Fountain (Left) Next to Room 224 E. Wall	Flush180	30-SEP-16	0.163	ppb
51531	51531-2-HAL-F04	Main-Fountain (Left) Next to Room 224 E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F04	Main-Fountain (Left) Next to Room 224 E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F04	Main-Fountain (Left) Next to Room 224 E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F04	Main-Fountain (Left) Next to Room 224 E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F04	Main-Fountain (Left) Next to Room 224 E. Wall	Initial	30-SEP-16	1.000	ppb
51531	51531-2-HAL-F04	Main-Fountain (Left) Next to Room 224 E. Wall	Initial	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F13	Main-Fountain (Left) Next to Room 307 N. Wall	Flush180	30-SEP-16	0.221	ppb
51531	51531-3-HAL-F13	Main-Fountain (Left) Next to Room 307 N. Wall	Flush180	30-SEP-16	0.223	ppb
51531	51531-3-HAL-F13	Main-Fountain (Left) Next to Room 307 N. Wall	Flush180	30-SEP-16	0.377	ppb
51531	51531-3-HAL-F13	Main-Fountain (Left) Next to Room 307 N. Wall	Flush180	30-SEP-16	0.328	ppb
51531	51531-3-HAL-F13	Main-Fountain (Left) Next to Room 307 N. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F13	Main-Fountain (Left) Next to Room 307 N. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F13	Main-Fountain (Left) Next to Room 307 N. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F13	Main-Fountain (Left) Next to Room 307 N. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F13	Main-Fountain (Left) Next to Room 307 N. Wall	Initial	30-SEP-16	0.249	ppb
51531	51531-3-HAL-F13	Main-Fountain (Left) Next to Room 307 N. Wall	Initial	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F10	Main-Fountain (Left) Next to Room 318 E. Wall	Flush180	30-SEP-16	0.343	ppb
51531	51531-3-HAL-F10	Main-Fountain (Left) Next to Room 318 E. Wall	Flush180	30-SEP-16	0.546	ppb
51531	51531-3-HAL-F10	Main-Fountain (Left) Next to Room 318 E. Wall	Flush180	30-SEP-16	0.395	ppb
51531	51531-3-HAL-F10	Main-Fountain (Left) Next to Room 318 E. Wall	Flush180	30-SEP-16	0.273	ppb
51531	51531-3-HAL-F10	Main-Fountain (Left) Next to Room 318 E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F10	Main-Fountain (Left) Next to Room 318 E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F10	Main-Fountain (Left) Next to Room 318 E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F10	Main-Fountain (Left) Next to Room 318 E. Wall	Initial	30-SEP-16	0.179	ppb
51531	51531-3-HAL-F10	Main-Fountain (Left) Next to Room 318 E. Wall	Initial	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F08	Main-Fountain (Left) Next to Room 324 E. Wall	Flush180	30-SEP-16	0.345	ppb
51531	51531-3-HAL-F08	Main-Fountain (Left) Next to Room 324 E. Wall	Flush180	30-SEP-16	0.728	ppb
51531	51531-3-HAL-F08	Main-Fountain (Left) Next to Room 324 E. Wall	Flush180	30-SEP-16	0.418	ppb
51531	51531-3-HAL-F08	Main-Fountain (Left) Next to Room 324 E. Wall	Flush180	30-SEP-16	0.322	ppb
51531	51531-3-HAL-	Main-Fountain (Left) Next to Room	Flush180	25-SEP-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F08	324 E. Wall				
51531	51531-3-HAL-F08	Main-Fountain (Left) Next to Room 324 E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F08	Main-Fountain (Left) Next to Room 324 E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F08	Main-Fountain (Left) Next to Room 324 E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F08	Main-Fountain (Left) Next to Room 324 E. Wall	Initial	30-SEP-16	0.223	ppb
51531	51531-3-HAL-F08	Main-Fountain (Left) Next to Room 324 E. Wall	Initial	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F09	Main-Fountain (Left) by Room 107 N. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-1-HAL-F09	Main-Fountain (Left) by Room 107 N. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-1-HAL-F09	Main-Fountain (Left) by Room 107 N. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-1-HAL-F09	Main-Fountain (Left) by Room 107 N. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-1-HAL-F09	Main-Fountain (Left) by Room 107 N. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F09	Main-Fountain (Left) by Room 107 N. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F09	Main-Fountain (Left) by Room 107 N. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F09	Main-Fountain (Left) by Room 107 N. Wall	Initial	30-SEP-16	1.000	ppb
51531	51531-1-HAL-F09	Main-Fountain (Left) by Room 107 N. Wall	Initial	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F03	Main-Fountain (Left) by Room 128 S. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-1-HAL-F03	Main-Fountain (Left) by Room 128 S. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-1-HAL-F03	Main-Fountain (Left) by Room 128 S. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-1-HAL-F03	Main-Fountain (Left) by Room 128 S. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-1-HAL-F03	Main-Fountain (Left) by Room 128 S. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F03	Main-Fountain (Left) by Room 128 S. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F03	Main-Fountain (Left) by Room 128 S. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F03	Main-Fountain (Left) by Room 128 S. Wall	Initial	30-SEP-16	1.000	ppb
51531	51531-1-HAL-F03	Main-Fountain (Left) by Room 128 S. Wall	Initial	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F03	Main-Fountain (Left) by Room 228 S. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-2-HAL-F03	Main-Fountain (Left) by Room 228 S. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-2-HAL-F03	Main-Fountain (Left) by Room 228 S. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-2-HAL-F03	Main-Fountain (Left) by Room 228 S. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-2-HAL-F03	Main-Fountain (Left) by Room 228 S. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F03	Main-Fountain (Left) by Room 228 S. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F03	Main-Fountain (Left) by Room 228 S. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F03	Main-Fountain (Left) by Room 228 S. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F03	Main-Fountain (Left) by Room 228 S. Wall	Initial	30-SEP-16	1.000	ppb
51531	51531-2-HAL-F03	Main-Fountain (Left) by Room 228 S. Wall	Initial	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F05	Main-Fountain (Right) Across from Cafeteria S. Wal	Flush180	30-SEP-16	1.000	ppb
51531	51531-3-HAL-F05	Main-Fountain (Right) Across from Cafeteria S. Wal	Flush180	30-SEP-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51531	51531-3-HAL-F05	Main-Fountain (Right) Across from Cafeteria S. Wal	Flush180	30-SEP-16	1.000	ppb
51531	51531-3-HAL-F05	Main-Fountain (Right) Across from Cafeteria S. Wal	Flush180	30-SEP-16	1.000	ppb
51531	51531-3-HAL-F05	Main-Fountain (Right) Across from Cafeteria S. Wal	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F05	Main-Fountain (Right) Across from Cafeteria S. Wal	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F05	Main-Fountain (Right) Across from Cafeteria S. Wal	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F05	Main-Fountain (Right) Across from Cafeteria S. Wal	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F05	Main-Fountain (Right) Across from Cafeteria S. Wal	Initial	30-SEP-16	1.000	ppb
51531	51531-3-HAL-F05	Main-Fountain (Right) Across from Cafeteria S. Wal	Initial	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F08	Main-Fountain (Right) Across from Gym N. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-2-HAL-F08	Main-Fountain (Right) Across from Gym N. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-2-HAL-F08	Main-Fountain (Right) Across from Gym N. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-2-HAL-F08	Main-Fountain (Right) Across from Gym N. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F08	Main-Fountain (Right) Across from Gym N. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F08	Main-Fountain (Right) Across from Gym N. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F08	Main-Fountain (Right) Across from Gym N. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F08	Main-Fountain (Right) Across from Gym N. Wall	Initial	30-SEP-16	1.000	ppb
51531	51531-2-HAL-F08	Main-Fountain (Right) Across from Gym N. Wall	Initial	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F11	Main-Fountain (Right) Across from Room 103 S. Wall	Flush180	30-SEP-16	0.215	ppb
51531	51531-1-HAL-F11	Main-Fountain (Right) Across from Room 103 S. Wall	Flush180	30-SEP-16	0.483	ppb
51531	51531-1-HAL-F11	Main-Fountain (Right) Across from Room 103 S. Wall	Flush180	30-SEP-16	0.313	ppb
51531	51531-1-HAL-F11	Main-Fountain (Right) Across from Room 103 S. Wall	Flush180	30-SEP-16	0.269	ppb
51531	51531-1-HAL-F11	Main-Fountain (Right) Across from Room 103 S. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F11	Main-Fountain (Right) Across from Room 103 S. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F11	Main-Fountain (Right) Across from Room 103 S. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F11	Main-Fountain (Right) Across from Room 103 S. Wall	Initial	30-SEP-16	0.366	ppb
51531	51531-1-HAL-F11	Main-Fountain (Right) Across from Room 103 S. Wall	Initial	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F07	Main-Fountain (Right) Across from Room 115 E. Wall	Flush180	30-SEP-16	0.130	ppb
51531	51531-1-HAL-F07	Main-Fountain (Right) Across from Room 115 E. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-1-HAL-F07	Main-Fountain (Right) Across from Room 115 E. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-1-HAL-F07	Main-Fountain (Right) Across from Room 115 E. Wall	Flush180	30-SEP-16	0.148	ppb
51531	51531-1-HAL-F07	Main-Fountain (Right) Across from Room 115 E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F07	Main-Fountain (Right) Across from Room 115 E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F07	Main-Fountain (Right) Across from Room 115 E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F07	Main-Fountain (Right) Across from Room 115 E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F07	Main-Fountain (Right) Across from Room 115 E. Wall	Initial	30-SEP-16	0.242	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51531	51531-1-HAL-F07	Main-Fountain (Right) Across from Room 115 E. Wall	Initial	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F11	Main-Fountain (Right) Across from Room 203 S. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-2-HAL-F11	Main-Fountain (Right) Across from Room 203 S. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-2-HAL-F11	Main-Fountain (Right) Across from Room 203 S. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-2-HAL-F11	Main-Fountain (Right) Across from Room 203 S. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-2-HAL-F11	Main-Fountain (Right) Across from Room 203 S. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F11	Main-Fountain (Right) Across from Room 203 S. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F11	Main-Fountain (Right) Across from Room 203 S. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F11	Main-Fountain (Right) Across from Room 203 S. Wall	Initial	30-SEP-16	0.158	ppb
51531	51531-2-HAL-F11	Main-Fountain (Right) Across from Room 203 S. Wall	Initial	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F15	Main-Fountain (Right) Across from Room 303 S. Wall	Flush180	30-SEP-16	0.442	ppb
51531	51531-3-HAL-F15	Main-Fountain (Right) Across from Room 303 S. Wall	Flush180	30-SEP-16	0.316	ppb
51531	51531-3-HAL-F15	Main-Fountain (Right) Across from Room 303 S. Wall	Flush180	30-SEP-16	0.385	ppb
51531	51531-3-HAL-F15	Main-Fountain (Right) Across from Room 303 S. Wall	Flush180	30-SEP-16	0.339	ppb
51531	51531-3-HAL-F15	Main-Fountain (Right) Across from Room 303 S. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F15	Main-Fountain (Right) Across from Room 303 S. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F15	Main-Fountain (Right) Across from Room 303 S. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F15	Main-Fountain (Right) Across from Room 303 S. Wall	Initial	30-SEP-16	0.334	ppb
51531	51531-3-HAL-F15	Main-Fountain (Right) Across from Room 303 S. Wall	Initial	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F05	Main-Fountain (Right) Next to Room 124A E. Wall	Flush180	30-SEP-16	0.130	ppb
51531	51531-1-HAL-F05	Main-Fountain (Right) Next to Room 124A E. Wall	Flush180	30-SEP-16	0.170	ppb
51531	51531-1-HAL-F05	Main-Fountain (Right) Next to Room 124A E. Wall	Flush180	30-SEP-16	0.172	ppb
51531	51531-1-HAL-F05	Main-Fountain (Right) Next to Room 124A E. Wall	Flush180	30-SEP-16	0.138	ppb
51531	51531-1-HAL-F05	Main-Fountain (Right) Next to Room 124A E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F05	Main-Fountain (Right) Next to Room 124A E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F05	Main-Fountain (Right) Next to Room 124A E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F05	Main-Fountain (Right) Next to Room 124A E. Wall	Initial	30-SEP-16	0.254	ppb
51531	51531-1-HAL-F05	Main-Fountain (Right) Next to Room 124A E. Wall	Initial	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F07	Main-Fountain (Right) Next to Room 218 E. Wall	Flush180	30-SEP-16	0.234	ppb
51531	51531-2-HAL-F07	Main-Fountain (Right) Next to Room 218 E. Wall	Flush180	30-SEP-16	0.270	ppb
51531	51531-2-HAL-F07	Main-Fountain (Right) Next to Room 218 E. Wall	Flush180	30-SEP-16	0.350	ppb
51531	51531-2-HAL-F07	Main-Fountain (Right) Next to Room 218 E. Wall	Flush180	30-SEP-16	0.197	ppb
51531	51531-2-HAL-F07	Main-Fountain (Right) Next to Room 218 E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F07	Main-Fountain (Right) Next to Room 218 E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F07	Main-Fountain (Right) Next to Room 218 E. Wall	Flush180	25-SEP-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F07	Room 218 E. Wall				
51531	51531-2-HAL-F07	Main-Fountain (Right) Next to Room 218 E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F07	Main-Fountain (Right) Next to Room 218 E. Wall	Initial	30-SEP-16	0.258	ppb
51531	51531-2-HAL-F07	Main-Fountain (Right) Next to Room 218 E. Wall	Initial	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F05	Main-Fountain (Right) Next to Room 224 E. Wall	Flush180	30-SEP-16	0.210	ppb
51531	51531-2-HAL-F05	Main-Fountain (Right) Next to Room 224 E. Wall	Flush180	30-SEP-16	0.222	ppb
51531	51531-2-HAL-F05	Main-Fountain (Right) Next to Room 224 E. Wall	Flush180	30-SEP-16	0.247	ppb
51531	51531-2-HAL-F05	Main-Fountain (Right) Next to Room 224 E. Wall	Flush180	30-SEP-16	0.248	ppb
51531	51531-2-HAL-F05	Main-Fountain (Right) Next to Room 224 E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F05	Main-Fountain (Right) Next to Room 224 E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F05	Main-Fountain (Right) Next to Room 224 E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F05	Main-Fountain (Right) Next to Room 224 E. Wall	Initial	30-SEP-16	0.275	ppb
51531	51531-2-HAL-F05	Main-Fountain (Right) Next to Room 224 E. Wall	Initial	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F12	Main-Fountain (Right) Next to Room 307 N. Wall	Flush180	30-SEP-16	0.339	ppb
51531	51531-3-HAL-F12	Main-Fountain (Right) Next to Room 307 N. Wall	Flush180	30-SEP-16	0.323	ppb
51531	51531-3-HAL-F12	Main-Fountain (Right) Next to Room 307 N. Wall	Flush180	30-SEP-16	0.460	ppb
51531	51531-3-HAL-F12	Main-Fountain (Right) Next to Room 307 N. Wall	Flush180	30-SEP-16	0.411	ppb
51531	51531-3-HAL-F12	Main-Fountain (Right) Next to Room 307 N. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F12	Main-Fountain (Right) Next to Room 307 N. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F12	Main-Fountain (Right) Next to Room 307 N. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F12	Main-Fountain (Right) Next to Room 307 N. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F12	Main-Fountain (Right) Next to Room 307 N. Wall	Initial	30-SEP-16	0.330	ppb
51531	51531-3-HAL-F12	Main-Fountain (Right) Next to Room 307 N. Wall	Initial	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F11	Main-Fountain (Right) Next to Room 318 E. Wall	Flush180	30-SEP-16	0.180	ppb
51531	51531-3-HAL-F11	Main-Fountain (Right) Next to Room 318 E. Wall	Flush180	30-SEP-16	0.201	ppb
51531	51531-3-HAL-F11	Main-Fountain (Right) Next to Room 318 E. Wall	Flush180	30-SEP-16	0.215	ppb
51531	51531-3-HAL-F11	Main-Fountain (Right) Next to Room 318 E. Wall	Flush180	30-SEP-16	0.186	ppb
51531	51531-3-HAL-F11	Main-Fountain (Right) Next to Room 318 E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F11	Main-Fountain (Right) Next to Room 318 E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F11	Main-Fountain (Right) Next to Room 318 E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F11	Main-Fountain (Right) Next to Room 318 E. Wall	Initial	30-SEP-16	0.183	ppb
51531	51531-3-HAL-F11	Main-Fountain (Right) Next to Room 318 E. Wall	Initial	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F09	Main-Fountain (Right) Next to Room 324 E. Wall	Flush180	30-SEP-16	0.328	ppb
51531	51531-3-HAL-F09	Main-Fountain (Right) Next to Room 324 E. Wall	Flush180	30-SEP-16	0.321	ppb
51531	51531-3-HAL-F09	Main-Fountain (Right) Next to Room 324 E. Wall	Flush180	30-SEP-16	0.331	ppb
51531	51531-3-HAL-	Main-Fountain (Right) Next to	Flush180	30-SEP-16	0.283	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F09	Room 324 E. Wall				
51531	51531-3-HAL-F09	Main-Fountain (Right) Next to Room 324 E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F09	Main-Fountain (Right) Next to Room 324 E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F09	Main-Fountain (Right) Next to Room 324 E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F09	Main-Fountain (Right) Next to Room 324 E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-HAL-F09	Main-Fountain (Right) Next to Room 324 E. Wall	Initial	30-SEP-16	0.148	ppb
51531	51531-3-HAL-F09	Main-Fountain (Right) Next to Room 324 E. Wall	Initial	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F08	Main-Fountain (Right) by Room 107 N. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-1-HAL-F08	Main-Fountain (Right) by Room 107 N. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-1-HAL-F08	Main-Fountain (Right) by Room 107 N. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-1-HAL-F08	Main-Fountain (Right) by Room 107 N. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-1-HAL-F08	Main-Fountain (Right) by Room 107 N. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F08	Main-Fountain (Right) by Room 107 N. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F08	Main-Fountain (Right) by Room 107 N. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F08	Main-Fountain (Right) by Room 107 N. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F08	Main-Fountain (Right) by Room 107 N. Wall	Initial	30-SEP-16	1.000	ppb
51531	51531-1-HAL-F08	Main-Fountain (Right) by Room 107 N. Wall	Initial	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F01	Main-Fountain (Right) by Room 128 S. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-1-HAL-F01	Main-Fountain (Right) by Room 128 S. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-1-HAL-F01	Main-Fountain (Right) by Room 128 S. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-1-HAL-F01	Main-Fountain (Right) by Room 128 S. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F01	Main-Fountain (Right) by Room 128 S. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F01	Main-Fountain (Right) by Room 128 S. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F01	Main-Fountain (Right) by Room 128 S. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-1-HAL-F01	Main-Fountain (Right) by Room 128 S. Wall	Initial	30-SEP-16	0.231	ppb
51531	51531-1-HAL-F01	Main-Fountain (Right) by Room 128 S. Wall	Initial	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F01	Main-Fountain (Right) by Room 228 S. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-2-HAL-F01	Main-Fountain (Right) by Room 228 S. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-2-HAL-F01	Main-Fountain (Right) by Room 228 S. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-2-HAL-F01	Main-Fountain (Right) by Room 228 S. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-2-HAL-F01	Main-Fountain (Right) by Room 228 S. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F01	Main-Fountain (Right) by Room 228 S. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F01	Main-Fountain (Right) by Room 228 S. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F01	Main-Fountain (Right) by Room 228 S. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F01	Main-Fountain (Right) by Room 228 S. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-2-HAL-F01	Main-Fountain (Right) by Room 228 S. Wall	Initial	30-SEP-16	1.000	ppb
51531	51531-2-HAL-F01	Main-Fountain (Right) by Room 228 S. Wall	Initial	25-SEP-19	1.000	ug/L
51531	51531-3-KIT-KS02	Main-Kitchen Sink (Center) E. Wall	Flush180	30-SEP-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51531	51531-3-KIT-KS02	Main-Kitchen Sink (Center) E. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-3-KIT-KS02	Main-Kitchen Sink (Center) E. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-3-KIT-KS02	Main-Kitchen Sink (Center) E. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-3-KIT-KS02	Main-Kitchen Sink (Center) E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-KIT-KS02	Main-Kitchen Sink (Center) E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-KIT-KS02	Main-Kitchen Sink (Center) E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-KIT-KS02	Main-Kitchen Sink (Center) E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-KIT-KS02	Main-Kitchen Sink (Center) E. Wall	Initial	30-SEP-16	1.000	ppb
51531	51531-3-KIT-KS02	Main-Kitchen Sink (Center) E. Wall	Initial	25-SEP-19	1.000	ug/L
51531	51531-3-KIT-KS03	Main-Kitchen Sink (Left) E. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-3-KIT-KS03	Main-Kitchen Sink (Left) E. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-3-KIT-KS03	Main-Kitchen Sink (Left) E. Wall	Flush180	30-SEP-16	0.189	ppb
51531	51531-3-KIT-KS03	Main-Kitchen Sink (Left) E. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-3-KIT-KS03	Main-Kitchen Sink (Left) E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-KIT-KS03	Main-Kitchen Sink (Left) E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-KIT-KS03	Main-Kitchen Sink (Left) E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-KIT-KS03	Main-Kitchen Sink (Left) E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-KIT-KS03	Main-Kitchen Sink (Left) E. Wall	Initial	30-SEP-16	1.000	ppb
51531	51531-3-KIT-KS03	Main-Kitchen Sink (Left) E. Wall	Initial	25-SEP-19	1.000	ug/L
51531	51531-3-KIT-KS01	Main-Kitchen Sink (Right) E. Wall	Flush180	30-SEP-16	0.198	ppb
51531	51531-3-KIT-KS01	Main-Kitchen Sink (Right) E. Wall	Flush180	30-SEP-16	0.248	ppb
51531	51531-3-KIT-KS01	Main-Kitchen Sink (Right) E. Wall	Flush180	30-SEP-16	0.344	ppb
51531	51531-3-KIT-KS01	Main-Kitchen Sink (Right) E. Wall	Flush180	30-SEP-16	1.000	ppb
51531	51531-3-KIT-KS01	Main-Kitchen Sink (Right) E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-KIT-KS01	Main-Kitchen Sink (Right) E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-KIT-KS01	Main-Kitchen Sink (Right) E. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-KIT-KS01	Main-Kitchen Sink (Right) E. Wall	Initial	30-SEP-16	0.677	ppb
51531	51531-3-KIT-KS01	Main-Kitchen Sink (Right) E. Wall	Initial	25-SEP-19	1.000	ug/L
51531	51531-3-BAKERY-S04	Main-Sink Inside Bakery N. Wall	Flush180	30-SEP-16	1.340	ppb
51531	51531-3-BAKERY-S04	Main-Sink Inside Bakery N. Wall	Flush180	30-SEP-16	1.020	ppb
51531	51531-3-BAKERY-S04	Main-Sink Inside Bakery N. Wall	Flush180	30-SEP-16	1.290	ppb
51531	51531-3-BAKERY-S04	Main-Sink Inside Bakery N. Wall	Flush180	30-SEP-16	0.992	ppb
51531	51531-3-BAKERY-S04	Main-Sink Inside Bakery N. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-BAKERY-S04	Main-Sink Inside Bakery N. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-BAKERY-S04	Main-Sink Inside Bakery N. Wall	Flush180	25-SEP-19	1.000	ug/L
51531	51531-3-BAKERY-S04	Main-Sink Inside Bakery N. Wall	Flush180	25-SEP-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51531	51531-3-BAKERY-S04	Main-Sink Inside Bakery N. Wall	Initial	30-SEP-16	0.862	ppb
51531	51531-3-BAKERY-S04	Main-Sink Inside Bakery N. Wall	Initial	25-SEP-19	1.000	ug/L
51531	51531-1-N-HAL-F02	NORTH HALLWAY	Flush180	10-DEC-20	1.000	ug/L
51531	51531-1-N-HAL-F02	NORTH HALLWAY	Initial	10-DEC-20	1.000	ug/L
51531	51531-1-104-S12	Room 104, Sink	Flush180	01-SEP-17	1.000	ppb
51531	51531-1-104-S12	Room 104, Sink	Flush180	01-SEP-17	1.000	ppb
51531	51531-1-104-S12	Room 104, Sink	Flush180	01-SEP-17	1.000	ppb
51531	51531-1-104-S12	Room 104, Sink	Flush180	01-SEP-17	1.000	ppb
51531	51531-1-104-S12	Room 104, Sink	Flush180	25-SEP-19	1.000	ug/L
51531	51531-1-104-S12	Room 104, Sink	Flush180	25-SEP-19	1.000	ug/L
51531	51531-1-104-S12	Room 104, Sink	Flush180	25-SEP-19	1.000	ug/L
51531	51531-1-104-S12	Room 104, Sink	Flush180	25-SEP-19	1.000	ug/L
51531	51531-1-104-S12	Room 104, Sink	Initial	01-SEP-17	1.000	ppb
51531	51531-1-104-S12	Room 104, Sink	Initial	25-SEP-19	1.000	ug/L