



Sep 10, 2024

**ARMSTRONG G**

**2110 W GREENLEAF AVE, Chicago IL 60645.**

Dear **ARMSTRONG G** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**ARMSTRONG G**

**2110 W GREENLEAF AVE, Chicago IL 60645.**

Estimadas familias de **ARMSTRONG G**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51044	51044-ANX-1-HAL-F01	Annex, 1st Floor Hallway, Fountain (1)	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-HAL-F01	Annex, 1st Floor Hallway, Fountain (1)	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-HAL-F01	Annex, 1st Floor Hallway, Fountain (1)	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-HAL-F01	Annex, 1st Floor Hallway, Fountain (1)	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-HAL-F01	Annex, 1st Floor Hallway, Fountain (1)	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-HAL-F01	Annex, 1st Floor Hallway, Fountain (1)	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-HAL-F01	Annex, 1st Floor Hallway, Fountain (1)	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-HAL-F01	Annex, 1st Floor Hallway, Fountain (1)	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-HAL-F01	Annex, 1st Floor Hallway, Fountain (1)	Initial	27-MAY-16	1.000	ppb
51044	51044-ANX-1-HAL-F01	Annex, 1st Floor Hallway, Fountain (1)	Initial	27-MAY-16	1.000	ppb
51044	51044-ANX-1-HAL-F02	Annex, 1st Floor Hallway, Fountain (2)	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-HAL-F02	Annex, 1st Floor Hallway, Fountain (2)	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-HAL-F02	Annex, 1st Floor Hallway, Fountain (2)	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-HAL-F02	Annex, 1st Floor Hallway, Fountain (2)	Flush180	27-MAY-16	1.110	ppb
51044	51044-ANX-1-HAL-F02	Annex, 1st Floor Hallway, Fountain (2)	Flush180	27-MAY-16	1.110	ppb
51044	51044-ANX-1-HAL-F02	Annex, 1st Floor Hallway, Fountain (2)	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-HAL-F02	Annex, 1st Floor Hallway, Fountain (2)	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-HAL-F02	Annex, 1st Floor Hallway, Fountain (2)	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-HAL-F02	Annex, 1st Floor Hallway, Fountain (2)	Initial	27-MAY-16	1.000	ppb
51044	51044-ANX-1-HAL-F02	Annex, 1st Floor Hallway, Fountain (2)	Initial	27-MAY-16	1.000	ppb
51044	51044-ANX-2-HAL-F01	Annex, 2nd Floor Hallway, Fountain (1)	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-2-HAL-F01	Annex, 2nd Floor Hallway, Fountain (1)	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-2-HAL-F01	Annex, 2nd Floor Hallway, Fountain (1)	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-2-HAL-F01	Annex, 2nd Floor Hallway, Fountain (1)	Flush180	27-MAY-16	1.000	ppb
51044	51044-2-ANN-HAL-F01	Annex, 2nd Floor Hallway, Fountain (1)	Flush180	27-MAY-16	1.000	ppb
51044	51044-2-ANN-HAL-F01	Annex, 2nd Floor Hallway, Fountain (1)	Flush180	27-MAY-16	1.000	ppb
51044	51044-2-ANN-HAL-F01	Annex, 2nd Floor Hallway, Fountain (1)	Flush180	27-MAY-16	1.000	ppb
51044	51044-2-ANN-HAL-F01	Annex, 2nd Floor Hallway, Fountain (1)	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-2-HAL-F01	Annex, 2nd Floor Hallway, Fountain (1)	Initial	27-MAY-16	0.125	ppb
51044	51044-2-ANN-HAL-F01	Annex, 2nd Floor Hallway, Fountain (1)	Initial	27-MAY-16	0.125	ppb
51044	51044-ANX-2-HAL-F02	Annex, 2nd Floor Hallway, Fountain (2)	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-2-HAL-F02	Annex, 2nd Floor Hallway, Fountain (2)	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-2-HAL-F02	Annex, 2nd Floor Hallway, Fountain (2)	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-2-HAL-F02	Annex, 2nd Floor Hallway, Fountain (2)	Flush180	27-MAY-16	1.000	ppb
51044	51044-2-ANN-HAL-F02	Annex, 2nd Floor Hallway, Fountain (2)	Flush180	27-MAY-16	1.000	ppb







Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	115-F04					
51044	51044-ANX-1-115-F04	Annex, Inside Room 115, Fountain	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-115-F04	Annex, Inside Room 115, Fountain	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-115-F04	Annex, Inside Room 115, Fountain	Initial	27-MAY-16	1.000	ppb
51044	51044-ANX-1-115-F04	Annex, Inside Room 115, Fountain	Initial	27-MAY-16	1.000	ppb
51044	51044-ANX-1-116-F03	Annex, Inside Room 116, Fountain	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-116-F03	Annex, Inside Room 116, Fountain	Flush180	27-MAY-16	0.121	ppb
51044	51044-ANX-1-116-F03	Annex, Inside Room 116, Fountain	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-116-F03	Annex, Inside Room 116, Fountain	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-116-F03	Annex, Inside Room 116, Fountain	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-116-F03	Annex, Inside Room 116, Fountain	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-116-F03	Annex, Inside Room 116, Fountain	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-116-F03	Annex, Inside Room 116, Fountain	Flush180	27-MAY-16	0.121	ppb
51044	51044-ANX-1-116-F03	Annex, Inside Room 116, Fountain	Initial	27-MAY-16	1.000	ppb
51044	51044-ANX-1-116-F03	Annex, Inside Room 116, Fountain	Initial	27-MAY-16	1.000	ppb
51044	51044-1-ANN-KS02	Annex, Kitchen 2 Comp, Sink	Flush180	27-MAY-16	1.000	ppb
51044	51044-1-ANN-KS02	Annex, Kitchen 2 Comp, Sink	Flush180	27-MAY-16	1.000	ppb
51044	51044-1-ANN-KS02	Annex, Kitchen 2 Comp, Sink	Flush180	27-MAY-16	1.000	ppb
51044	51044-1-ANN-KS02	Annex, Kitchen 2 Comp, Sink	Flush180	27-MAY-16	1.320	ppb
51044	51044-ANX-1-KIT-KS11	Annex, Kitchen 2 Comp, Sink	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-KIT-KS11	Annex, Kitchen 2 Comp, Sink	Flush180	27-MAY-16	1.320	ppb
51044	51044-ANX-1-KIT-KS11	Annex, Kitchen 2 Comp, Sink	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-KIT-KS11	Annex, Kitchen 2 Comp, Sink	Flush180	27-MAY-16	1.000	ppb
51044	51044-1-ANN-KS02	Annex, Kitchen 2 Comp, Sink	Initial	27-MAY-16	0.850	ppb
51044	51044-ANX-1-KIT-KS11	Annex, Kitchen 2 Comp, Sink	Initial	27-MAY-16	0.850	ppb
51044	51044-1-ANN-KS01	Annex, Kitchen 3 Comp, Sink	Flush180	27-MAY-16	1.000	ppb
51044	51044-1-ANN-KS01	Annex, Kitchen 3 Comp, Sink	Flush180	27-MAY-16	1.000	ppb
51044	51044-1-ANN-KS01	Annex, Kitchen 3 Comp, Sink	Flush180	27-MAY-16	1.000	ppb
51044	51044-1-ANN-KS01	Annex, Kitchen 3 Comp, Sink	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-KIT-KS10	Annex, Kitchen 3 Comp, Sink	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-KIT-KS10	Annex, Kitchen 3 Comp, Sink	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-KIT-KS10	Annex, Kitchen 3 Comp, Sink	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-KIT-KS10	Annex, Kitchen 3 Comp, Sink	Flush180	27-MAY-16	1.000	ppb
51044	51044-1-ANN-KS01	Annex, Kitchen 3 Comp, Sink	Initial	27-MAY-16	1.000	ppb
51044	51044-ANX-1-KIT-KS10	Annex, Kitchen 3 Comp, Sink	Initial	27-MAY-16	1.000	ppb
51044	51044-1-ANN-KS04	Annex, Kitchen Pasta Cover, Sink	Flush180	27-MAY-16	1.000	ppb
51044	51044-1-ANN-KS04	Annex, Kitchen Pasta Cover, Sink	Flush180	27-MAY-16	1.000	ppb
51044	51044-1-ANN-KS04	Annex, Kitchen Pasta Cover, Sink	Flush180	27-MAY-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS04					
51044	51044-1-ANN-KS04	Annex, Kitchen Pasta Cover, Sink	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-KIT-KS13	Annex, Kitchen Pasta Cover, Sink	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-KIT-KS13	Annex, Kitchen Pasta Cover, Sink	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-KIT-KS13	Annex, Kitchen Pasta Cover, Sink	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-KIT-KS13	Annex, Kitchen Pasta Cover, Sink	Flush180	27-MAY-16	1.000	ppb
51044	51044-1-ANN-KS04	Annex, Kitchen Pasta Cover, Sink	Initial	27-MAY-16	0.354	ppb
51044	51044-ANX-1-KIT-KS13	Annex, Kitchen Pasta Cover, Sink	Initial	27-MAY-16	0.354	ppb
51044	51044-1-ANN-KS03	Annex, Kitchen Steam Kettle, Sink	Flush180	27-MAY-16	0.400	ppb
51044	51044-1-ANN-KS03	Annex, Kitchen Steam Kettle, Sink	Flush180	27-MAY-16	0.197	ppb
51044	51044-1-ANN-KS03	Annex, Kitchen Steam Kettle, Sink	Flush180	27-MAY-16	0.211	ppb
51044	51044-1-ANN-KS03	Annex, Kitchen Steam Kettle, Sink	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-KIT-KS12	Annex, Kitchen Steam Kettle, Sink	Flush180	27-MAY-16	0.400	ppb
51044	51044-ANX-1-KIT-KS12	Annex, Kitchen Steam Kettle, Sink	Flush180	27-MAY-16	0.197	ppb
51044	51044-ANX-1-KIT-KS12	Annex, Kitchen Steam Kettle, Sink	Flush180	27-MAY-16	0.211	ppb
51044	51044-ANX-1-KIT-KS12	Annex, Kitchen Steam Kettle, Sink	Flush180	27-MAY-16	1.000	ppb
51044	51044-1-ANN-KS03	Annex, Kitchen Steam Kettle, Sink	Initial	27-MAY-16	1.000	ppb
51044	51044-ANX-1-KIT-KS12	Annex, Kitchen Steam Kettle, Sink	Initial	27-MAY-16	1.000	ppb
51044	51044-ANX-1-110-F09	Annex, Inside Room 110, Fountain	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-110-F09	Annex, Inside Room 110, Fountain	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-110-F09	Annex, Inside Room 110, Fountain	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-110-F09	Annex, Inside Room 110, Fountain	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-110-F09	Annex, Inside Room 110, Fountain	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-110-F09	Annex, Inside Room 110, Fountain	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-110-F09	Annex, Inside Room 110, Fountain	Flush180	27-MAY-16	1.000	ppb
51044	51044-ANX-1-110-F09	Annex, Inside Room 110, Fountain	Initial	27-MAY-16	1.000	ppb
51044	51044-ANX-1-110-F09	Annex, Inside Room 110, Fountain	Initial	27-MAY-16	1.000	ppb
51044	51044-1-HAL-F01	Main Building, 1st Floor Hallway North, Fountain	Flush180	27-MAY-16	2.780	ppb
51044	51044-1-HAL-F01	Main Building, 1st Floor Hallway North, Fountain	Flush180	27-MAY-16	2.780	ppb
51044	51044-1-HAL-F01	Main Building, 1st Floor Hallway North, Fountain	Flush180	27-MAY-16	1.280	ppb
51044	51044-1-HAL-F01	Main Building, 1st Floor Hallway North, Fountain	Flush180	27-MAY-16	0.756	ppb
51044	51044-1-HAL-F01	Main Building, 1st Floor Hallway North, Fountain	Flush180	27-MAY-16	2.370	ppb
51044	51044-1-HAL-F01	Main Building, 1st Floor Hallway North, Fountain	Flush180	27-MAY-16	2.370	ppb
51044	51044-1-HAL-F01	Main Building, 1st Floor Hallway North, Fountain	Flush180	27-MAY-16	1.280	ppb
51044	51044-1-HAL-F01	Main Building, 1st Floor Hallway North, Fountain	Flush180	27-MAY-16	0.756	ppb
51044	51044-1-HAL-F01	Main Building, 1st Floor Hallway North, Fountain	Initial	27-MAY-16	2.430	ppb
51044	51044-1-HAL-F01	Main Building, 1st Floor Hallway North, Fountain	Initial	27-MAY-16	2.430	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51044	51044-1-E-HAL-F02	Main Building, 1st Floor Hallway South, Fountain	Flush180	27-MAY-16	1.300	ppb
51044	51044-1-E-HAL-F02	Main Building, 1st Floor Hallway South, Fountain	Flush180	27-MAY-16	1.520	ppb
51044	51044-1-E-HAL-F02	Main Building, 1st Floor Hallway South, Fountain	Flush180	27-MAY-16	2.100	ppb
51044	51044-1-E-HAL-F02	Main Building, 1st Floor Hallway South, Fountain	Flush180	27-MAY-16	1.300	ppb
51044	51044-1-E-HAL-F02	Main Building, 1st Floor Hallway South, Fountain	Flush180	27-MAY-16	2.100	ppb
51044	51044-1-E-HAL-F02	Main Building, 1st Floor Hallway South, Fountain	Flush180	27-MAY-16	1.520	ppb
51044	51044-1-E-HAL-F02	Main Building, 1st Floor Hallway South, Fountain	Flush180	27-MAY-16	1.270	ppb
51044	51044-1-E-HAL-F02	Main Building, 1st Floor Hallway South, Fountain	Flush180	27-MAY-16	1.270	ppb
51044	51044-1-E-HAL-F02	Main Building, 1st Floor Hallway South, Fountain	Flush180	21-JUL-20	1.160	ug/L
51044	51044-1-E-HAL-F02	Main Building, 1st Floor Hallway South, Fountain	Initial	27-MAY-16	3.090	ppb
51044	51044-1-E-HAL-F02	Main Building, 1st Floor Hallway South, Fountain	Initial	27-MAY-16	3.090	ppb
51044	51044-1-E-HAL-F02	Main Building, 1st Floor Hallway South, Fountain	Initial	21-JUL-20	2.100	ug/L
51044	51044-2-HAL-F01	Main Building, 2nd Floor Hallway North, Fountain	Flush180	27-MAY-16	0.250	ppb
51044	51044-2-HAL-F01	Main Building, 2nd Floor Hallway North, Fountain	Flush180	27-MAY-16	0.414	ppb
51044	51044-2-HAL-F01	Main Building, 2nd Floor Hallway North, Fountain	Flush180	27-MAY-16	0.184	ppb
51044	51044-2-HAL-F01	Main Building, 2nd Floor Hallway North, Fountain	Flush180	27-MAY-16	1.000	ppb
51044	51044-2-HAL-F01	Main Building, 2nd Floor Hallway North, Fountain	Flush180	27-MAY-16	1.000	ppb
51044	51044-2-HAL-F01	Main Building, 2nd Floor Hallway North, Fountain	Flush180	27-MAY-16	0.414	ppb
51044	51044-2-HAL-F01	Main Building, 2nd Floor Hallway North, Fountain	Flush180	27-MAY-16	0.250	ppb
51044	51044-2-HAL-F01	Main Building, 2nd Floor Hallway North, Fountain	Flush180	27-MAY-16	0.184	ppb
51044	51044-2-HAL-F01	Main Building, 2nd Floor Hallway North, Fountain	Initial	27-MAY-16	0.339	ppb
51044	51044-2-HAL-F01	Main Building, 2nd Floor Hallway North, Fountain	Initial	27-MAY-16	0.339	ppb
51044	51044-2-HAL-F02	Main Building, 2nd Floor Hallway South, Fountain	Flush180	27-MAY-16	0.607	ppb
51044	51044-2-HAL-F02	Main Building, 2nd Floor Hallway South, Fountain	Flush180	27-MAY-16	0.224	ppb
51044	51044-2-HAL-F02	Main Building, 2nd Floor Hallway South, Fountain	Flush180	27-MAY-16	0.224	ppb
51044	51044-2-HAL-F02	Main Building, 2nd Floor Hallway South, Fountain	Flush180	27-MAY-16	1.000	ppb
51044	51044-2-HAL-F02	Main Building, 2nd Floor Hallway South, Fountain	Flush180	27-MAY-16	0.607	ppb
51044	51044-2-HAL-F02	Main Building, 2nd Floor Hallway South, Fountain	Flush180	27-MAY-16	0.132	ppb
51044	51044-2-HAL-F02	Main Building, 2nd Floor Hallway South, Fountain	Flush180	27-MAY-16	1.000	ppb
51044	51044-2-HAL-F02	Main Building, 2nd Floor Hallway South, Fountain	Flush180	27-MAY-16	0.132	ppb
51044	51044-2-HAL-F02	Main Building, 2nd Floor Hallway South, Fountain	Initial	27-MAY-16	0.141	ppb
51044	51044-2-HAL-F02	Main Building, 2nd Floor Hallway South, Fountain	Initial	27-MAY-16	0.141	ppb
51044	51044-3-HAL-F01	Main Building, 3rd Floor Hallway North, Fountain	Flush180	27-MAY-16	0.229	ppb
51044	51044-3-HAL-F01	Main Building, 3rd Floor Hallway North, Fountain	Flush180	27-MAY-16	0.442	ppb
51044	51044-3-HAL-F01	Main Building, 3rd Floor Hallway North, Fountain	Flush180	27-MAY-16	0.442	ppb
51044	51044-3-HAL-F01	Main Building, 3rd Floor Hallway North, Fountain	Flush180	27-MAY-16	0.229	ppb
51044	51044-3-HAL-F01	Main Building, 3rd Floor Hallway North, Fountain	Flush180	27-MAY-16	0.177	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51044	51044-3-HAL-F01	Main Building, 3rd Floor Hallway North, Fountain	Flush180	27-MAY-16	0.177	ppb
51044	51044-3-HAL-F01	Main Building, 3rd Floor Hallway North, Fountain	Flush180	27-MAY-16	0.225	ppb
51044	51044-3-HAL-F01	Main Building, 3rd Floor Hallway North, Fountain	Flush180	27-MAY-16	0.225	ppb
51044	51044-3-HAL-F01	Main Building, 3rd Floor Hallway North, Fountain	Initial	27-MAY-16	0.144	ppb
51044	51044-3-HAL-F01	Main Building, 3rd Floor Hallway North, Fountain	Initial	27-MAY-16	0.144	ppb
51044	51044-3-S-HAL-F02	Main Building, 3rd Floor Hallway South, Fountain	Flush180	27-MAY-16	1.000	ppb
51044	51044-3-S-HAL-F02	Main Building, 3rd Floor Hallway South, Fountain	Flush180	27-MAY-16	1.000	ppb
51044	51044-3-S-HAL-F02	Main Building, 3rd Floor Hallway South, Fountain	Flush180	27-MAY-16	1.000	ppb
51044	51044-3-S-HAL-F02	Main Building, 3rd Floor Hallway South, Fountain	Flush180	27-MAY-16	1.000	ppb
51044	51044-3-S-HAL-F02	Main Building, 3rd Floor Hallway South, Fountain	Flush180	27-MAY-16	1.000	ppb
51044	51044-3-S-HAL-F02	Main Building, 3rd Floor Hallway South, Fountain	Flush180	27-MAY-16	1.000	ppb
51044	51044-3-S-HAL-F02	Main Building, 3rd Floor Hallway South, Fountain	Flush180	27-MAY-16	1.000	ppb
51044	51044-3-S-HAL-F02	Main Building, 3rd Floor Hallway South, Fountain	Flush180	27-MAY-16	1.000	ppb
51044	51044-3-S-HAL-F02	Main Building, 3rd Floor Hallway South, Fountain	Flush180	21-JUL-20	1.000	ug/L
51044	51044-3-S-HAL-F02	Main Building, 3rd Floor Hallway South, Fountain	Initial	27-MAY-16	1.000	ppb
51044	51044-3-S-HAL-F02	Main Building, 3rd Floor Hallway South, Fountain	Initial	27-MAY-16	1.000	ppb
51044	51044-3-S-HAL-F02	Main Building, 3rd Floor Hallway South, Fountain	Initial	21-JUL-20	1.000	ug/L