



Sep 10, 2024

BATEMAN

4220 N RICHMOND ST, Chicago IL 60618.

Dear **BATEMAN** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

BATEMAN

4220 N RICHMOND ST, Chicago IL 60618.

Estimadas familias de **BATEMAN**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51046	51046-1-N-HAL-F07	Addition Outside main Office, Fountain 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-N-HAL-F07	Addition Outside main Office, Fountain 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-N-HAL-F07	Addition Outside main Office, Fountain 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-N-HAL-F07	Addition Outside main Office, Fountain 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-N-HAL-F07	Addition Outside main Office, Fountain 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-N-HAL-F07	Addition Outside main Office, Fountain 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-N-HAL-F07	Addition Outside main Office, Fountain 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-N-HAL-F07	Addition Outside main Office, Fountain 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-N-HAL-F07	Addition Outside main Office, Fountain 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-N-HAL-F07	Addition Outside main Office, Fountain 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-N-HAL-F07	Addition Outside main Office, Fountain 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-N-HAL-F07	Addition Outside main Office, Fountain 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-N-HAL-F07	Addition Outside main Office, Fountain 1	Initial	27-MAY-16	1.000	ppb
51046	51046-1-N-HAL-F07	Addition Outside main Office, Fountain 1	Initial	27-MAY-16	1.000	ppb
51046	51046-1-N-HAL-F07	Addition Outside main Office, Fountain 1	Initial	21-NOV-19	1.000	ug/L
51046	51046-1-N-HAL-F08	Addition Outside main Office, Fountain 2	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-N-HAL-F08	Addition Outside main Office, Fountain 2	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-N-HAL-F08	Addition Outside main Office, Fountain 2	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-N-HAL-F08	Addition Outside main Office, Fountain 2	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-N-HAL-F08	Addition Outside main Office, Fountain 2	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-N-HAL-F08	Addition Outside main Office, Fountain 2	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-N-HAL-F08	Addition Outside main Office, Fountain 2	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-N-HAL-F08	Addition Outside main Office, Fountain 2	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-N-HAL-F08	Addition Outside main Office, Fountain 2	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-N-HAL-F08	Addition Outside main Office, Fountain 2	Flush180	22-JUL-20	1.000	ug/L
51046	51046-1-N-HAL-F08	Addition Outside main Office, Fountain 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-N-HAL-F08	Addition Outside main Office, Fountain 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-N-HAL-F08	Addition Outside main Office, Fountain 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-N-HAL-F08	Addition Outside main Office, Fountain 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-N-HAL-F08	Addition Outside main Office, Fountain 2	Initial	27-MAY-16	1.000	ppb
51046	51046-1-N-HAL-F08	Addition Outside main Office, Fountain 2	Initial	27-MAY-16	1.000	ppb
51046	51046-1-N-HAL-F08	Addition Outside main Office, Fountain 2	Initial	22-JUL-20	1.000	ug/L
51046	51046-1-N-HAL-F08	Addition Outside main Office, Fountain 2	Initial	21-NOV-19	1.000	ug/L
51046	51046-1-W-KIT-KS02	Kitchen Center Sink 2	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-KIT-KS02	Kitchen Center Sink 2	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-KIT-KS02	Kitchen Center Sink 2	Flush180	27-MAY-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51046	51046-1-W-KIT-KS02	Kitchen Center Sink 2	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-KIT-KS02	Kitchen Center Sink 2	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-KIT-KS02	Kitchen Center Sink 2	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-KIT-KS02	Kitchen Center Sink 2	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-KIT-KS02	Kitchen Center Sink 2	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-KIT-KS02	Kitchen Center Sink 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-W-KIT-KS02	Kitchen Center Sink 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-W-KIT-KS02	Kitchen Center Sink 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-W-KIT-KS02	Kitchen Center Sink 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-W-KIT-KS02	Kitchen Center Sink 2	Initial	27-MAY-16	0.257	ppb
51046	51046-1-W-KIT-KS02	Kitchen Center Sink 2	Initial	27-MAY-16	0.257	ppb
51046	51046-1-W-KIT-KS02	Kitchen Center Sink 2	Initial	21-NOV-19	1.000	ug/L
51046	51046-1-W-KIT-KS01	Kitchen Dish Wash Sink 1	Flush180	27-MAY-16	0.153	ppb
51046	51046-1-W-KIT-KS01	Kitchen Dish Wash Sink 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-KIT-KS01	Kitchen Dish Wash Sink 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-KIT-KS01	Kitchen Dish Wash Sink 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-KIT-KS01	Kitchen Dish Wash Sink 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-KIT-KS01	Kitchen Dish Wash Sink 1	Flush180	27-MAY-16	0.153	ppb
51046	51046-1-W-KIT-KS01	Kitchen Dish Wash Sink 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-KIT-KS01	Kitchen Dish Wash Sink 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-KIT-KS01	Kitchen Dish Wash Sink 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-W-KIT-KS01	Kitchen Dish Wash Sink 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-W-KIT-KS01	Kitchen Dish Wash Sink 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-W-KIT-KS01	Kitchen Dish Wash Sink 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-W-KIT-KS01	Kitchen Dish Wash Sink 1	Initial	27-MAY-16	0.527	ppb
51046	51046-1-W-KIT-KS01	Kitchen Dish Wash Sink 1	Initial	27-MAY-16	0.527	ppb
51046	51046-1-W-KIT-KS01	Kitchen Dish Wash Sink 1	Initial	21-NOV-19	1.000	ug/L
51046	51046-1-W-KIT-KS03	Kitchen Food Prep Sink 3	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-KIT-KS03	Kitchen Food Prep Sink 3	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-KIT-KS03	Kitchen Food Prep Sink 3	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-KIT-KS03	Kitchen Food Prep Sink 3	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-KIT-KS03	Kitchen Food Prep Sink 3	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-KIT-KS03	Kitchen Food Prep Sink 3	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-KIT-KS03	Kitchen Food Prep Sink 3	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-KIT-KS03	Kitchen Food Prep Sink 3	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-KIT-KS03	Kitchen Food Prep Sink 3	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-W-KIT-KS03	Kitchen Food Prep Sink 3	Flush180	21-NOV-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51046	51046-1-W-KIT-KS03	Kitchen Food Prep Sink 3	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-W-KIT-KS03	Kitchen Food Prep Sink 3	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-W-KIT-KS03	Kitchen Food Prep Sink 3	Initial	27-MAY-16	0.354	ppb
51046	51046-1-W-KIT-KS03	Kitchen Food Prep Sink 3	Initial	27-MAY-16	0.354	ppb
51046	51046-1-W-KIT-KS03	Kitchen Food Prep Sink 3	Initial	21-NOV-19	1.000	ug/L
51046	51046-1-E-HAL-F11	Main Corridor Outside 107, Fountain	Flush180	27-MAY-16	1.860	ppb
51046	51046-1-E-HAL-F11	Main Corridor Outside 107, Fountain	Flush180	27-MAY-16	2.040	ppb
51046	51046-1-E-HAL-F11	Main Corridor Outside 107, Fountain	Flush180	27-MAY-16	1.860	ppb
51046	51046-1-E-HAL-F11	Main Corridor Outside 107, Fountain	Flush180	27-MAY-16	2.040	ppb
51046	51046-1-E-HAL-F11	Main Corridor Outside 107, Fountain	Flush180	27-MAY-16	1.900	ppb
51046	51046-1-E-HAL-F11	Main Corridor Outside 107, Fountain	Flush180	27-MAY-16	1.880	ppb
51046	51046-1-E-HAL-F11	Main Corridor Outside 107, Fountain	Flush180	27-MAY-16	1.900	ppb
51046	51046-1-E-HAL-F11	Main Corridor Outside 107, Fountain	Flush180	27-MAY-16	1.880	ppb
51046	51046-1-E-HAL-F11	Main Corridor Outside 107, Fountain	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-E-HAL-F11	Main Corridor Outside 107, Fountain	Flush180	21-NOV-19	1.140	ug/L
51046	51046-1-E-HAL-F11	Main Corridor Outside 107, Fountain	Flush180	21-NOV-19	1.220	ug/L
51046	51046-1-E-HAL-F11	Main Corridor Outside 107, Fountain	Flush180	21-NOV-19	1.250	ug/L
51046	51046-1-E-HAL-F11	Main Corridor Outside 107, Fountain	Initial	27-MAY-16	2.060	ppb
51046	51046-1-E-HAL-F11	Main Corridor Outside 107, Fountain	Initial	27-MAY-16	2.060	ppb
51046	51046-1-E-HAL-F11	Main Corridor Outside 107, Fountain	Initial	21-NOV-19	1.000	ug/L
51046	51046-1-E-HAL-F12	Main Corridor Outside Room 102, Fountain 1	Flush180	27-MAY-16	0.840	ppb
51046	51046-1-E-HAL-F12	Main Corridor Outside Room 102, Fountain 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-E-HAL-F12	Main Corridor Outside Room 102, Fountain 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-E-HAL-F12	Main Corridor Outside Room 102, Fountain 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-E-HAL-F12	Main Corridor Outside Room 102, Fountain 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-E-HAL-F12	Main Corridor Outside Room 102, Fountain 1	Flush180	27-MAY-16	0.719	ppb
51046	51046-1-E-HAL-F12	Main Corridor Outside Room 102, Fountain 1	Flush180	27-MAY-16	0.840	ppb
51046	51046-1-E-HAL-F12	Main Corridor Outside Room 102, Fountain 1	Flush180	27-MAY-16	1.080	ppb
51046	51046-1-E-HAL-F12	Main Corridor Outside Room 102, Fountain 1	Flush180	27-MAY-16	0.735	ppb
51046	51046-1-E-HAL-F12	Main Corridor Outside Room 102, Fountain 1	Flush180	27-MAY-16	1.080	ppb
51046	51046-1-E-HAL-F12	Main Corridor Outside Room 102, Fountain 1	Flush180	27-MAY-16	0.719	ppb
51046	51046-1-E-HAL-F12	Main Corridor Outside Room 102, Fountain 1	Flush180	27-MAY-16	0.735	ppb
51046	51046-1-E-HAL-F12	Main Corridor Outside Room 102, Fountain 1	Initial	27-MAY-16	0.605	ppb
51046	51046-1-E-HAL-F12	Main Corridor Outside Room 102, Fountain 1	Initial	21-NOV-19	1.000	ug/L
51046	51046-1-E-HAL-F12	Main Corridor Outside Room 102, Fountain 1	Initial	27-MAY-16	0.605	ppb
51046	51046-1-E-HAL-F13	Main Corridor Outside Room 102, Fountain 2	Flush180	27-MAY-16	0.924	ppb
51046	51046-1-E-HAL-F13	Main Corridor Outside Room 102, Fountain 2	Flush180	27-MAY-16	0.916	ppb
51046	51046-1-E-	Main Corridor Outside Room 102,	Flush180	27-MAY-16	0.916	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F13	Fountain 2				
51046	51046-1-E-HAL-F13	Main Corridor Outside Room 102, Fountain 2	Flush180	27-MAY-16	1.230	ppb
51046	51046-1-E-HAL-F13	Main Corridor Outside Room 102, Fountain 2	Flush180	27-MAY-16	1.040	ppb
51046	51046-1-E-HAL-F13	Main Corridor Outside Room 102, Fountain 2	Flush180	22-JUL-20	13.100	ug/L
51046	51046-1-E-HAL-F13	Main Corridor Outside Room 102, Fountain 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-E-HAL-F13	Main Corridor Outside Room 102, Fountain 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-E-HAL-F13	Main Corridor Outside Room 102, Fountain 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-E-HAL-F13	Main Corridor Outside Room 102, Fountain 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-E-HAL-F13	Main Corridor Outside Room 102, Fountain 2	Flush180	13-OCT-20	13.800	ug/L
51046	51046-1-E-HAL-F13	Main Corridor Outside Room 102, Fountain 2	Flush180	13-OCT-20	12.500	ug/L
51046	51046-1-E-HAL-F13	Main Corridor Outside Room 102, Fountain 2	Flush180	13-OCT-20	21.800	ug/L
51046	51046-1-E-HAL-F13	Main Corridor Outside Room 102, Fountain 2	Flush180	13-OCT-20	17.000	ug/L
51046	51046-1-E-HAL-F13	Main Corridor Outside Room 102, Fountain 2	Flush180	03-DEC-20	1.400	ug/L
51046	51046-1-E-HAL-F13	Main Corridor Outside Room 102, Fountain 2	Flush180	03-DEC-20	1.560	ug/L
51046	51046-1-E-HAL-F13	Main Corridor Outside Room 102, Fountain 2	Flush180	03-DEC-20	1.360	ug/L
51046	51046-1-E-HAL-F13	Main Corridor Outside Room 102, Fountain 2	Flush180	03-DEC-20	1.060	ug/L
51046	51046-1-E-HAL-F13	Main Corridor Outside Room 102, Fountain 2	Flush180	27-MAY-16	0.924	ppb
51046	51046-1-E-HAL-F13	Main Corridor Outside Room 102, Fountain 2	Flush180	27-MAY-16	1.040	ppb
51046	51046-1-E-HAL-F13	Main Corridor Outside Room 102, Fountain 2	Flush180	27-MAY-16	1.230	ppb
51046	51046-1-E-HAL-F13	Main Corridor Outside Room 102, Fountain 2	Initial	27-MAY-16	0.901	ppb
51046	51046-1-E-HAL-F13	Main Corridor Outside Room 102, Fountain 2	Initial	22-JUL-20	6.320	ug/L
51046	51046-1-E-HAL-F13	Main Corridor Outside Room 102, Fountain 2	Initial	21-NOV-19	1.000	ug/L
51046	51046-1-E-HAL-F13	Main Corridor Outside Room 102, Fountain 2	Initial	13-OCT-20	21.000	ug/L
51046	51046-1-E-HAL-F13	Main Corridor Outside Room 102, Fountain 2	Initial	03-DEC-20	1.340	ug/L
51046	51046-1-E-HAL-F13	Main Corridor Outside Room 102, Fountain 2	Initial	27-MAY-16	0.901	ppb
51046	51046-2-E-HAL-F01	Main Corridor Outside Room 201, Fountain 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-2-E-HAL-F01	Main Corridor Outside Room 201, Fountain 1	Flush180	27-MAY-16	0.567	ppb
51046	51046-2-E-HAL-F01	Main Corridor Outside Room 201, Fountain 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-2-E-HAL-F01	Main Corridor Outside Room 201, Fountain 1	Flush180	27-MAY-16	0.532	ppb
51046	51046-2-E-HAL-F01	Main Corridor Outside Room 201, Fountain 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-2-E-HAL-F01	Main Corridor Outside Room 201, Fountain 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-2-E-HAL-F01	Main Corridor Outside Room 201, Fountain 1	Flush180	27-MAY-16	0.581	ppb
51046	51046-2-E-HAL-F01	Main Corridor Outside Room 201, Fountain 1	Flush180	27-MAY-16	0.583	ppb
51046	51046-2-E-HAL-F01	Main Corridor Outside Room 201, Fountain 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-2-E-HAL-F01	Main Corridor Outside Room 201, Fountain 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-2-E-HAL-F01	Main Corridor Outside Room 201, Fountain 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-2-E-HAL-F01	Main Corridor Outside Room 201, Fountain 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-2-E-HAL-F01	Main Corridor Outside Room 201, Fountain 1	Initial	27-MAY-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F01	Fountain 1				
51046	51046-2-E-HAL-F01	Main Corridor Outside Room 201, Fountain 1	Initial	27-MAY-16	0.451	ppb
51046	51046-2-E-HAL-F01	Main Corridor Outside Room 201, Fountain 1	Initial	21-NOV-19	1.000	ug/L
51046	51046-2-E-HAL-F02	Main Corridor Outside Room 201, Fountain 2	Flush180	27-MAY-16	0.579	ppb
51046	51046-2-E-HAL-F02	Main Corridor Outside Room 201, Fountain 2	Flush180	27-MAY-16	0.579	ppb
51046	51046-2-E-HAL-F02	Main Corridor Outside Room 201, Fountain 2	Flush180	27-MAY-16	0.576	ppb
51046	51046-2-E-HAL-F02	Main Corridor Outside Room 201, Fountain 2	Flush180	27-MAY-16	0.529	ppb
51046	51046-2-E-HAL-F02	Main Corridor Outside Room 201, Fountain 2	Flush180	27-MAY-16	0.454	ppb
51046	51046-2-E-HAL-F02	Main Corridor Outside Room 201, Fountain 2	Flush180	27-MAY-16	0.576	ppb
51046	51046-2-E-HAL-F02	Main Corridor Outside Room 201, Fountain 2	Flush180	27-MAY-16	0.529	ppb
51046	51046-2-E-HAL-F02	Main Corridor Outside Room 201, Fountain 2	Flush180	27-MAY-16	0.454	ppb
51046	51046-2-E-HAL-F02	Main Corridor Outside Room 201, Fountain 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-2-E-HAL-F02	Main Corridor Outside Room 201, Fountain 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-2-E-HAL-F02	Main Corridor Outside Room 201, Fountain 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-2-E-HAL-F02	Main Corridor Outside Room 201, Fountain 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-2-E-HAL-F02	Main Corridor Outside Room 201, Fountain 2	Initial	27-MAY-16	0.523	ppb
51046	51046-2-E-HAL-F02	Main Corridor Outside Room 201, Fountain 2	Initial	27-MAY-16	0.523	ppb
51046	51046-2-E-HAL-F02	Main Corridor Outside Room 201, Fountain 2	Initial	21-NOV-19	1.000	ug/L
51046	51046-2-E-HAL-F03	Main Corridor Outside Room 207, Fountain 1	Flush180	27-MAY-16	0.780	ppb
51046	51046-2-E-HAL-F03	Main Corridor Outside Room 207, Fountain 1	Flush180	27-MAY-16	1.010	ppb
51046	51046-2-E-HAL-F03	Main Corridor Outside Room 207, Fountain 1	Flush180	27-MAY-16	0.824	ppb
51046	51046-2-E-HAL-F03	Main Corridor Outside Room 207, Fountain 1	Flush180	27-MAY-16	1.010	ppb
51046	51046-2-E-HAL-F03	Main Corridor Outside Room 207, Fountain 1	Flush180	27-MAY-16	0.824	ppb
51046	51046-2-E-HAL-F03	Main Corridor Outside Room 207, Fountain 1	Flush180	27-MAY-16	0.780	ppb
51046	51046-2-E-HAL-F03	Main Corridor Outside Room 207, Fountain 1	Flush180	27-MAY-16	0.952	ppb
51046	51046-2-E-HAL-F03	Main Corridor Outside Room 207, Fountain 1	Flush180	27-MAY-16	0.952	ppb
51046	51046-2-E-HAL-F03	Main Corridor Outside Room 207, Fountain 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-2-E-HAL-F03	Main Corridor Outside Room 207, Fountain 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-2-E-HAL-F03	Main Corridor Outside Room 207, Fountain 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-2-E-HAL-F03	Main Corridor Outside Room 207, Fountain 1	Initial	27-MAY-16	0.768	ppb
51046	51046-2-E-HAL-F03	Main Corridor Outside Room 207, Fountain 1	Initial	27-MAY-16	0.768	ppb
51046	51046-2-E-HAL-F03	Main Corridor Outside Room 207, Fountain 1	Initial	21-NOV-19	1.000	ug/L
51046	51046-2-E-HAL-F04	Main Corridor Outside Room 207, Fountain 2	Flush180	27-MAY-16	0.817	ppb
51046	51046-2-E-HAL-F04	Main Corridor Outside Room 207, Fountain 2	Flush180	27-MAY-16	0.964	ppb
51046	51046-2-E-HAL-F04	Main Corridor Outside Room 207, Fountain 2	Flush180	27-MAY-16	0.765	ppb
51046	51046-2-E-HAL-F04	Main Corridor Outside Room 207, Fountain 2	Flush180	27-MAY-16	0.817	ppb
51046	51046-2-E-HAL-F04	Main Corridor Outside Room 207, Fountain 2	Flush180	27-MAY-16	0.559	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51046	51046-2-E-HAL-F04	Main Corridor Outside Room 207, Fountain 2	Flush180	27-MAY-16	0.964	ppb
51046	51046-2-E-HAL-F04	Main Corridor Outside Room 207, Fountain 2	Flush180	27-MAY-16	0.559	ppb
51046	51046-2-E-HAL-F04	Main Corridor Outside Room 207, Fountain 2	Flush180	27-MAY-16	0.765	ppb
51046	51046-2-E-HAL-F04	Main Corridor Outside Room 207, Fountain 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-2-E-HAL-F04	Main Corridor Outside Room 207, Fountain 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-2-E-HAL-F04	Main Corridor Outside Room 207, Fountain 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-2-E-HAL-F04	Main Corridor Outside Room 207, Fountain 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-2-E-HAL-F04	Main Corridor Outside Room 207, Fountain 2	Initial	27-MAY-16	0.757	ppb
51046	51046-2-E-HAL-F04	Main Corridor Outside Room 207, Fountain 2	Initial	27-MAY-16	0.757	ppb
51046	51046-2-E-HAL-F04	Main Corridor Outside Room 207, Fountain 2	Initial	21-NOV-19	1.000	ug/L
51046	51046-2-N-HAL-F05	Main Corridor Outside Room 220, Fountain 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-2-N-HAL-F05	Main Corridor Outside Room 220, Fountain 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-2-N-HAL-F05	Main Corridor Outside Room 220, Fountain 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-2-N-HAL-F05	Main Corridor Outside Room 220, Fountain 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-2-N-HAL-F05	Main Corridor Outside Room 220, Fountain 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-2-N-HAL-F05	Main Corridor Outside Room 220, Fountain 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-2-N-HAL-F05	Main Corridor Outside Room 220, Fountain 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-2-N-HAL-F05	Main Corridor Outside Room 220, Fountain 1	Initial	27-MAY-16	1.000	ppb
51046	51046-2-N-HAL-F05	Main Corridor Outside Room 220, Fountain 1	Initial	21-NOV-19	1.000	ug/L
51046	51046-2-N-HAL-F06	Main Corridor Outside Room 220, Fountain 2	Flush180	27-MAY-16	1.000	ppb
51046	51046-2-N-HAL-F06	Main Corridor Outside Room 220, Fountain 2	Flush180	27-MAY-16	1.000	ppb
51046	51046-2-N-HAL-F06	Main Corridor Outside Room 220, Fountain 2	Flush180	27-MAY-16	1.000	ppb
51046	51046-2-N-HAL-F06	Main Corridor Outside Room 220, Fountain 2	Flush180	27-MAY-16	1.000	ppb
51046	51046-2-N-HAL-F06	Main Corridor Outside Room 220, Fountain 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-2-N-HAL-F06	Main Corridor Outside Room 220, Fountain 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-2-N-HAL-F06	Main Corridor Outside Room 220, Fountain 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-2-N-HAL-F06	Main Corridor Outside Room 220, Fountain 2	Initial	27-MAY-16	1.000	ppb
51046	51046-2-N-HAL-F06	Main Corridor Outside Room 220, Fountain 2	Initial	21-NOV-19	1.000	ug/L
51046	51046-3-E-HAL-F01	Main Corridor Outside Room 301, Fountain	Flush180	27-MAY-16	0.623	ppb
51046	51046-3-E-HAL-F01	Main Corridor Outside Room 301, Fountain	Flush180	27-MAY-16	0.578	ppb
51046	51046-3-E-HAL-F01	Main Corridor Outside Room 301, Fountain	Flush180	27-MAY-16	0.608	ppb
51046	51046-3-E-HAL-F01	Main Corridor Outside Room 301, Fountain	Flush180	27-MAY-16	0.639	ppb
51046	51046-3-E-HAL-F01	Main Corridor Outside Room 301, Fountain	Flush180	27-MAY-16	0.578	ppb
51046	51046-3-E-HAL-F01	Main Corridor Outside Room 301, Fountain	Flush180	27-MAY-16	0.639	ppb
51046	51046-3-E-HAL-F01	Main Corridor Outside Room 301, Fountain	Flush180	27-MAY-16	0.608	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51046	51046-3-E-HAL-F01	Main Corridor Outside Room 301, Fountain	Flush180	27-MAY-16	0.623	ppb
51046	51046-3-E-HAL-F01	Main Corridor Outside Room 301, Fountain	Flush180	21-NOV-19	1.000	ug/L
51046	51046-3-E-HAL-F01	Main Corridor Outside Room 301, Fountain	Flush180	21-NOV-19	1.000	ug/L
51046	51046-3-E-HAL-F01	Main Corridor Outside Room 301, Fountain	Flush180	21-NOV-19	1.000	ug/L
51046	51046-3-E-HAL-F01	Main Corridor Outside Room 301, Fountain	Flush180	21-NOV-19	1.000	ug/L
51046	51046-3-E-HAL-F01	Main Corridor Outside Room 301, Fountain	Initial	27-MAY-16	0.473	ppb
51046	51046-3-E-HAL-F01	Main Corridor Outside Room 301, Fountain	Initial	27-MAY-16	0.473	ppb
51046	51046-3-E-HAL-F01	Main Corridor Outside Room 301, Fountain	Initial	21-NOV-19	1.000	ug/L
51046	51046-3-E-HAL-F02	Main Corridor Outside Room 307, Fountain	Flush180	27-MAY-16	1.130	ppb
51046	51046-3-E-HAL-F02	Main Corridor Outside Room 307, Fountain	Flush180	27-MAY-16	1.080	ppb
51046	51046-3-E-HAL-F02	Main Corridor Outside Room 307, Fountain	Flush180	27-MAY-16	1.080	ppb
51046	51046-3-E-HAL-F02	Main Corridor Outside Room 307, Fountain	Flush180	27-MAY-16	1.090	ppb
51046	51046-3-E-HAL-F02	Main Corridor Outside Room 307, Fountain	Flush180	27-MAY-16	1.090	ppb
51046	51046-3-E-HAL-F02	Main Corridor Outside Room 307, Fountain	Flush180	27-MAY-16	1.080	ppb
51046	51046-3-E-HAL-F02	Main Corridor Outside Room 307, Fountain	Flush180	27-MAY-16	1.080	ppb
51046	51046-3-E-HAL-F02	Main Corridor Outside Room 307, Fountain	Flush180	27-MAY-16	1.130	ppb
51046	51046-3-E-HAL-F02	Main Corridor Outside Room 307, Fountain	Flush180	21-NOV-19	1.000	ug/L
51046	51046-3-E-HAL-F02	Main Corridor Outside Room 307, Fountain	Flush180	21-NOV-19	1.000	ug/L
51046	51046-3-E-HAL-F02	Main Corridor Outside Room 307, Fountain	Flush180	21-NOV-19	1.000	ug/L
51046	51046-3-E-HAL-F02	Main Corridor Outside Room 307, Fountain	Flush180	21-NOV-19	1.000	ug/L
51046	51046-3-E-HAL-F02	Main Corridor Outside Room 307, Fountain	Flush180	22-JUL-20	1.000	ug/L
51046	51046-3-E-HAL-F02	Main Corridor Outside Room 307, Fountain	Initial	27-MAY-16	1.340	ppb
51046	51046-3-E-HAL-F02	Main Corridor Outside Room 307, Fountain	Initial	27-MAY-16	1.340	ppb
51046	51046-3-E-HAL-F02	Main Corridor Outside Room 307, Fountain	Initial	21-NOV-19	1.000	ug/L
51046	51046-3-E-HAL-F02	Main Corridor Outside Room 307, Fountain	Initial	22-JUL-20	1.330	ug/L
51046	51046-3-N-HAL-F03	Main Corridor Outside Room 318, Fountain 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-3-N-HAL-F03	Main Corridor Outside Room 318, Fountain 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-3-N-HAL-F03	Main Corridor Outside Room 318, Fountain 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-3-N-HAL-F03	Main Corridor Outside Room 318, Fountain 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-3-N-HAL-F03	Main Corridor Outside Room 318, Fountain 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-3-N-HAL-F03	Main Corridor Outside Room 318, Fountain 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-3-N-HAL-F03	Main Corridor Outside Room 318, Fountain 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-3-N-HAL-F03	Main Corridor Outside Room 318, Fountain 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-3-N-HAL-F03	Main Corridor Outside Room 318, Fountain 1	Initial	27-MAY-16	1.000	ppb
51046	51046-3-N-HAL-F03	Main Corridor Outside Room 318, Fountain 1	Initial	21-NOV-19	1.000	ug/L
51046	51046-3-N-HAL-F04	Main Corridor Outside Room 318, Fountain 2	Flush180	27-MAY-16	1.000	ppb
51046	51046-3-N-HAL-F04	Main Corridor Outside Room 318, Fountain 2	Flush180	27-MAY-16	1.000	ppb
51046	51046-3-N-	Main Corridor Outside Room 318, Fountain 2	Flush180	27-MAY-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F04	Fountain 2				
51046	51046-3-N-HAL-F04	Main Corridor Outside Room 318, Fountain 2	Flush180	27-MAY-16	1.000	ppb
51046	51046-3-N-HAL-F04	Main Corridor Outside Room 318, Fountain 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-3-N-HAL-F04	Main Corridor Outside Room 318, Fountain 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-3-N-HAL-F04	Main Corridor Outside Room 318, Fountain 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-3-N-HAL-F04	Main Corridor Outside Room 318, Fountain 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-3-N-HAL-F04	Main Corridor Outside Room 318, Fountain 2	Flush180	22-JUL-20	1.000	ug/L
51046	51046-3-N-HAL-F04	Main Corridor Outside Room 318, Fountain 2	Initial	27-MAY-16	1.000	ppb
51046	51046-3-N-HAL-F04	Main Corridor Outside Room 318, Fountain 2	Initial	21-NOV-19	1.000	ug/L
51046	51046-3-N-HAL-F04	Main Corridor Outside Room 318, Fountain 2	Initial	22-JUL-20	1.000	ug/L
51046	51046-1-E-HAL-F10	Main Hall Outside Room 108, Fountain	Flush180	27-MAY-16	1.960	ppb
51046	51046-1-E-HAL-F10	Main Hall Outside Room 108, Fountain	Flush180	27-MAY-16	2.400	ppb
51046	51046-1-E-HAL-F10	Main Hall Outside Room 108, Fountain	Flush180	27-MAY-16	2.050	ppb
51046	51046-1-E-HAL-F10	Main Hall Outside Room 108, Fountain	Flush180	27-MAY-16	1.880	ppb
51046	51046-1-E-HAL-F10	Main Hall Outside Room 108, Fountain	Flush180	27-MAY-16	1.880	ppb
51046	51046-1-E-HAL-F10	Main Hall Outside Room 108, Fountain	Flush180	27-MAY-16	2.050	ppb
51046	51046-1-E-HAL-F10	Main Hall Outside Room 108, Fountain	Flush180	27-MAY-16	2.400	ppb
51046	51046-1-E-HAL-F10	Main Hall Outside Room 108, Fountain	Flush180	27-MAY-16	1.960	ppb
51046	51046-1-E-HAL-F10	Main Hall Outside Room 108, Fountain	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-E-HAL-F10	Main Hall Outside Room 108, Fountain	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-E-HAL-F10	Main Hall Outside Room 108, Fountain	Flush180	21-NOV-19	1.090	ug/L
51046	51046-1-E-HAL-F10	Main Hall Outside Room 108, Fountain	Flush180	21-NOV-19	1.140	ug/L
51046	51046-1-E-HAL-F10	Main Hall Outside Room 108, Fountain	Initial	27-MAY-16	2.190	ppb
51046	51046-1-E-HAL-F10	Main Hall Outside Room 108, Fountain	Initial	27-MAY-16	2.190	ppb
51046	51046-1-E-HAL-F10	Main Hall Outside Room 108, Fountain	Initial	21-NOV-19	1.000	ug/L
51046	51046-1-W-102-S14	North Sink 1 Inside Room 102	Flush180	27-MAY-16	0.936	ppb
51046	51046-1-W-102-S14	North Sink 1 Inside Room 102	Flush180	27-MAY-16	1.400	ppb
51046	51046-1-W-102-S14	North Sink 1 Inside Room 102	Flush180	27-MAY-16	1.400	ppb
51046	51046-1-W-102-S14	North Sink 1 Inside Room 102	Flush180	27-MAY-16	1.410	ppb
51046	51046-1-W-102-S14	North Sink 1 Inside Room 102	Flush180	27-MAY-16	0.936	ppb
51046	51046-1-W-102-S14	North Sink 1 Inside Room 102	Flush180	27-MAY-16	1.010	ppb
51046	51046-1-W-102-S14	North Sink 1 Inside Room 102	Flush180	27-MAY-16	1.410	ppb
51046	51046-1-W-102-S14	North Sink 1 Inside Room 102	Flush180	27-MAY-16	1.010	ppb
51046	51046-1-W-102-S14	North Sink 1 Inside Room 102	Flush180	21-NOV-19	1.370	ug/L
51046	51046-1-W-102-S14	North Sink 1 Inside Room 102	Flush180	21-NOV-19	1.970	ug/L
51046	51046-1-W-102-S14	North Sink 1 Inside Room 102	Flush180	21-NOV-19	1.110	ug/L
51046	51046-1-W-102-S14	North Sink 1 Inside Room 102	Flush180	21-NOV-19	1.080	ug/L
51046	51046-1-W-	North Sink 1 Inside Room 102	Initial	27-MAY-16	0.922	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	102-S14					
51046	51046-1-W-102-S14	North Sink 1 Inside Room 102	Initial	27-MAY-16	0.922	ppb
51046	51046-1-W-102-S14	North Sink 1 Inside Room 102	Initial	21-NOV-19	1.000	ug/L
51046	51046-1-W-119-S05	Room 119 North, Sink 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-119-S05	Room 119 North, Sink 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-119-S05	Room 119 North, Sink 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-119-S05	Room 119 North, Sink 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-119-S05	Room 119 North, Sink 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-119-S05	Room 119 North, Sink 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-119-S05	Room 119 North, Sink 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-119-S05	Room 119 North, Sink 1	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-119-S05	Room 119 North, Sink 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-W-119-S05	Room 119 North, Sink 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-W-119-S05	Room 119 North, Sink 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-W-119-S05	Room 119 North, Sink 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-W-119-S05	Room 119 North, Sink 1	Initial	27-MAY-16	1.000	ppb
51046	51046-1-W-119-S05	Room 119 North, Sink 1	Initial	27-MAY-16	1.000	ppb
51046	51046-1-W-119-S05	Room 119 North, Sink 1	Initial	21-NOV-19	1.000	ug/L
51046	51046-1-W-119-S04	Room 119 South, Sink 2	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-119-S04	Room 119 South, Sink 2	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-119-S04	Room 119 South, Sink 2	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-119-S04	Room 119 South, Sink 2	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-119-S04	Room 119 South, Sink 2	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-119-S04	Room 119 South, Sink 2	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-119-S04	Room 119 South, Sink 2	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-119-S04	Room 119 South, Sink 2	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-119-S04	Room 119 South, Sink 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-W-119-S04	Room 119 South, Sink 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-W-119-S04	Room 119 South, Sink 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-W-119-S04	Room 119 South, Sink 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-W-119-S04	Room 119 South, Sink 2	Initial	27-MAY-16	1.000	ppb
51046	51046-1-W-119-S04	Room 119 South, Sink 2	Initial	27-MAY-16	1.000	ppb
51046	51046-1-W-119-S04	Room 119 South, Sink 2	Initial	21-NOV-19	1.000	ug/L
51046	51046-1-W-119-F06	Room 119, Fountain	Flush180	27-MAY-16	0.128	ppb
51046	51046-1-W-119-F06	Room 119, Fountain	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-119-F06	Room 119, Fountain	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-119-F06	Room 119, Fountain	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-119-F06	Room 119, Fountain	Flush180	27-MAY-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51046	51046-1-W-119-F06	Room 119, Fountain	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-119-F06	Room 119, Fountain	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-W-119-F06	Room 119, Fountain	Flush180	27-MAY-16	0.128	ppb
51046	51046-1-W-119-F06	Room 119, Fountain	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-W-119-F06	Room 119, Fountain	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-W-119-F06	Room 119, Fountain	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-W-119-F06	Room 119, Fountain	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-W-119-F06	Room 119, Fountain	Initial	27-MAY-16	1.000	ppb
51046	51046-1-W-119-F06	Room 119, Fountain	Initial	27-MAY-16	1.000	ppb
51046	51046-1-W-119-F06	Room 119, Fountain	Initial	21-NOV-19	1.000	ug/L
51046	51046-1-S-126-S09	Room 126 Pre-k, Sink	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-S-126-S09	Room 126 Pre-k, Sink	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-S-126-S09	Room 126 Pre-k, Sink	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-S-126-S09	Room 126 Pre-k, Sink	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-S-126-S09	Room 126 Pre-k, Sink	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-S-126-S09	Room 126 Pre-k, Sink	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-S-126-S09	Room 126 Pre-k, Sink	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-S-126-S09	Room 126 Pre-k, Sink	Flush180	27-MAY-16	1.000	ppb
51046	51046-1-S-126-S09	Room 126 Pre-k, Sink	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-S-126-S09	Room 126 Pre-k, Sink	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-S-126-S09	Room 126 Pre-k, Sink	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-S-126-S09	Room 126 Pre-k, Sink	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-S-126-S09	Room 126 Pre-k, Sink	Initial	27-MAY-16	1.000	ppb
51046	51046-1-S-126-S09	Room 126 Pre-k, Sink	Initial	27-MAY-16	1.000	ppb
51046	51046-1-S-126-S09	Room 126 Pre-k, Sink	Initial	21-NOV-19	1.000	ug/L
51046	51046-1-W-102-S15	South Sink 2 Inside Room 102	Flush180	27-MAY-16	1.600	ppb
51046	51046-1-W-102-S15	South Sink 2 Inside Room 102	Flush180	27-MAY-16	1.600	ppb
51046	51046-1-W-102-S15	South Sink 2 Inside Room 102	Flush180	27-MAY-16	1.950	ppb
51046	51046-1-W-102-S15	South Sink 2 Inside Room 102	Flush180	27-MAY-16	0.872	ppb
51046	51046-1-W-102-S15	South Sink 2 Inside Room 102	Flush180	27-MAY-16	0.872	ppb
51046	51046-1-W-102-S15	South Sink 2 Inside Room 102	Flush180	27-MAY-16	1.950	ppb
51046	51046-1-W-102-S15	South Sink 2 Inside Room 102	Flush180	27-MAY-16	1.240	ppb
51046	51046-1-W-102-S15	South Sink 2 Inside Room 102	Flush180	27-MAY-16	1.240	ppb
51046	51046-1-W-102-S15	South Sink 2 Inside Room 102	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-W-102-S15	South Sink 2 Inside Room 102	Flush180	21-NOV-19	1.980	ug/L
51046	51046-1-W-102-S15	South Sink 2 Inside Room 102	Flush180	21-NOV-19	3.150	ug/L
51046	51046-1-W-102-S15	South Sink 2 Inside Room 102	Flush180	21-NOV-19	1.680	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51046	51046-1-W-102-S15	South Sink 2 Inside Room 102	Initial	27-MAY-16	0.474	ppb
51046	51046-1-W-102-S15	South Sink 2 Inside Room 102	Initial	27-MAY-16	0.474	ppb
51046	51046-1-W-102-S15	South Sink 2 Inside Room 102	Initial	21-NOV-19	1.350	ug/L
51046	51046-1-N-TL-S16	Teacher lounge North Sink 1	Flush180	27-MAY-16	0.689	ppb
51046	51046-1-N-TL-S16	Teacher lounge North Sink 1	Flush180	27-MAY-16	0.643	ppb
51046	51046-1-N-TL-S16	Teacher lounge North Sink 1	Flush180	27-MAY-16	0.519	ppb
51046	51046-1-N-TL-S16	Teacher lounge North Sink 1	Flush180	27-MAY-16	0.643	ppb
51046	51046-1-N-TL-S16	Teacher lounge North Sink 1	Flush180	27-MAY-16	0.579	ppb
51046	51046-1-N-TL-S16	Teacher lounge North Sink 1	Flush180	27-MAY-16	0.689	ppb
51046	51046-1-N-TL-S16	Teacher lounge North Sink 1	Flush180	27-MAY-16	0.519	ppb
51046	51046-1-N-TL-S16	Teacher lounge North Sink 1	Flush180	27-MAY-16	0.579	ppb
51046	51046-1-N-TL-S16	Teacher lounge North Sink 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-N-TL-S16	Teacher lounge North Sink 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-N-TL-S16	Teacher lounge North Sink 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-N-TL-S16	Teacher lounge North Sink 1	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-N-TL-S16	Teacher lounge North Sink 1	Initial	27-MAY-16	0.715	ppb
51046	51046-1-N-TL-S16	Teacher lounge North Sink 1	Initial	27-MAY-16	0.715	ppb
51046	51046-1-N-TL-S16	Teacher lounge North Sink 1	Initial	21-NOV-19	1.000	ug/L
51046	51046-1-E-TL-S17	Teacher lounge South Sink 2	Flush180	27-MAY-16	0.750	ppb
51046	51046-1-E-TL-S17	Teacher lounge South Sink 2	Flush180	27-MAY-16	0.561	ppb
51046	51046-1-E-TL-S17	Teacher lounge South Sink 2	Flush180	27-MAY-16	0.750	ppb
51046	51046-1-E-TL-S17	Teacher lounge South Sink 2	Flush180	27-MAY-16	0.548	ppb
51046	51046-1-E-TL-S17	Teacher lounge South Sink 2	Flush180	27-MAY-16	0.548	ppb
51046	51046-1-E-TL-S17	Teacher lounge South Sink 2	Flush180	27-MAY-16	0.575	ppb
51046	51046-1-E-TL-S17	Teacher lounge South Sink 2	Flush180	27-MAY-16	0.561	ppb
51046	51046-1-E-TL-S17	Teacher lounge South Sink 2	Flush180	27-MAY-16	0.575	ppb
51046	51046-1-E-TL-S17	Teacher lounge South Sink 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-E-TL-S17	Teacher lounge South Sink 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-E-TL-S17	Teacher lounge South Sink 2	Flush180	21-NOV-19	1.000	ug/L
51046	51046-1-E-TL-S17	Teacher lounge South Sink 2	Initial	27-MAY-16	0.572	ppb
51046	51046-1-E-TL-S17	Teacher lounge South Sink 2	Initial	27-MAY-16	0.572	ppb
51046	51046-1-E-TL-S17	Teacher lounge South Sink 2	Initial	21-NOV-19	1.000	ug/L