



Sep 10, 2024

BEARD

6445 W STRONG ST, Chicago IL 60656.

Dear **BEARD** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

BEARD

6445 W STRONG ST, Chicago IL 60656.

Estimadas familias de **BEARD**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51021	51021-1-N-HAL-F09	Main Building- Hallway by boys toilet, Left Founta	Flush180	19-JUL-23	1.000	ug/L
51021	51021-1-N-HAL-F09	Main Building- Hallway by boys toilet, Left Founta	Flush180	19-JUL-23	1.000	ug/L
51021	51021-1-N-HAL-F09	Main Building- Hallway by boys toilet, Left Founta	Flush180	19-JUL-23	1.000	ug/L
51021	51021-1-N-HAL-F09	Main Building- Hallway by boys toilet, Left Founta	Flush180	19-JUL-23	1.000	ug/L
51021	51021-1-N-HAL-F09	Main Building- Hallway by boys toilet, Left Founta	Flush180	28-MAY-16	1.000	ppb
51021	51021-1-N-HAL-F09	Main Building- Hallway by boys toilet, Left Founta	Flush180	28-MAY-16	1.000	ppb
51021	51021-1-N-HAL-F09	Main Building- Hallway by boys toilet, Left Founta	Flush180	28-MAY-16	1.000	ppb
51021	51021-1-N-HAL-F09	Main Building- Hallway by boys toilet, Left Founta	Flush180	28-MAY-16	1.000	ppb
51021	51021-1-N-HAL-F09	Main Building- Hallway by boys toilet, Left Founta	Flush180	28-MAY-16	1.000	ppb
51021	51021-1-N-HAL-F09	Main Building- Hallway by boys toilet, Left Founta	Flush180	28-MAY-16	1.000	ppb
51021	51021-1-N-HAL-F09	Main Building- Hallway by boys toilet, Left Founta	Flush180	28-MAY-16	1.000	ppb
51021	51021-1-N-HAL-F09	Main Building- Hallway by boys toilet, Left Founta	Flush180	28-MAY-16	1.000	ppb
51021	51021-1-N-HAL-F09	Main Building- Hallway by boys toilet, Left Founta	Flush180	28-MAY-16	1.000	ppb
51021	51021-1-N-HAL-F09	Main Building- Hallway by boys toilet, Left Founta	Flush180	28-MAY-16	1.000	ppb
51021	51021-1-N-HAL-F09	Main Building- Hallway by boys toilet, Left Founta	Flush180	21-JUL-20	23.200	ug/L
51021	51021-1-N-HAL-F09	Main Building- Hallway by boys toilet, Left Founta	Flush180	22-DEC-20	110.000	ug/L
51021	51021-1-N-HAL-F09	Main Building- Hallway by boys toilet, Left Founta	Flush180	22-DEC-20	12.700	ug/L
51021	51021-1-N-HAL-F09	Main Building- Hallway by boys toilet, Left Founta	Flush180	22-DEC-20	10.700	ug/L
51021	51021-1-N-HAL-F09	Main Building- Hallway by boys toilet, Left Founta	Flush180	22-DEC-20	13.000	ug/L
51021	51021-1-N-HAL-F09	Main Building- Hallway by boys toilet, Left Founta	Initial	19-JUL-23	1.100	ug/L
51021	51021-1-N-HAL-F09	Main Building- Hallway by boys toilet, Left Founta	Initial	28-MAY-16	1.000	ppb
51021	51021-1-N-HAL-F09	Main Building- Hallway by boys toilet, Left Founta	Initial	28-MAY-16	1.000	ppb
51021	51021-1-N-HAL-F09	Main Building- Hallway by boys toilet, Left Founta	Initial	21-JUL-20	132.000	ug/L
51021	51021-1-N-HAL-F09	Main Building- Hallway by boys toilet, Left Founta	Initial	22-DEC-20	42.000	ug/L
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Flush180	28-MAY-16	1.000	ppb
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Flush180	28-MAY-16	1.000	ppb
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Flush180	28-MAY-16	1.000	ppb
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Flush180	28-MAY-16	1.000	ppb
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Flush180	28-MAY-16	1.000	ppb
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Flush180	28-MAY-16	1.000	ppb
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Flush180	28-MAY-16	1.000	ppb
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Flush180	28-MAY-16	1.000	ppb
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Flush180	21-JUL-20	2.370	ug/L
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Flush180	22-DEC-20	59.500	ug/L
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Flush180	22-DEC-20	14.300	ug/L
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Flush180	22-DEC-20	14.000	ug/L
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Flush180	22-DEC-20	10.100	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Flush180	04-FEB-21	2.440	ug/L
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Flush180	04-FEB-21	2.030	ug/L
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Flush180	04-FEB-21	2.400	ug/L
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Flush180	04-FEB-21	1.770	ug/L
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Flush180	08-DEC-20	8.210	ug/L
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Flush180	06-JAN-21	5.180	ug/L
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Flush180	06-JAN-21	4.090	ug/L
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Flush180	06-JAN-21	3.490	ug/L
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Flush180	06-JAN-21	8.040	ug/L
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Flush180	08-DEC-20	15.300	ug/L
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Flush180	08-DEC-20	434.000	ug/L
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Flush180	08-DEC-20	332.000	ug/L
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Flush180	30-OCT-20	8.920	ug/L
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Flush180	30-OCT-20	7.700	ug/L
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Flush180	30-OCT-20	26.300	ug/L
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Flush180	30-OCT-20	49.100	ug/L
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Initial	28-MAY-16	1.000	ppb
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Initial	28-MAY-16	1.000	ppb
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Initial	21-JUL-20	7.480	ug/L
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Initial	22-DEC-20	63.100	ug/L
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Initial	04-FEB-21	2.920	ug/L
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Initial	08-DEC-20	12.500	ug/L
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Initial	06-JAN-21	6.660	ug/L
51021	51021-1-N-HAL-F10	Main Building- Hallway by girls toilet, Right Foun	Initial	30-OCT-20	28.700	ug/L
51021	51021-1-104-S13	Main Building- Inside Room 104, Sink	Flush180	28-MAY-16	1.000	ppb
51021	51021-1-104-S13	Main Building- Inside Room 104, Sink	Flush180	28-MAY-16	1.000	ppb
51021	51021-1-104-S13	Main Building- Inside Room 104, Sink	Flush180	28-MAY-16	1.000	ppb
51021	51021-1-104-S13	Main Building- Inside Room 104, Sink	Flush180	28-MAY-16	1.000	ppb
51021	51021-1-104-S13	Main Building- Inside Room 104, Sink	Flush180	28-MAY-16	1.000	ppb
51021	51021-1-104-S13	Main Building- Inside Room 104, Sink	Flush180	28-MAY-16	1.000	ppb
51021	51021-1-104-S13	Main Building- Inside Room 104, Sink	Flush180	28-MAY-16	1.000	ppb
51021	51021-1-104-S13	Main Building- Inside Room 104, Sink	Initial	28-MAY-16	1.000	ppb
51021	51021-1-104-S13	Main Building- Inside Room 104, Sink	Initial	28-MAY-16	1.000	ppb
52519	52519-1-E-HAL-WC01		Flush180	28-MAY-16	1.000	ppb
52519	52519-1-E-HAL-WC01		Flush180	28-MAY-16	1.000	ppb
52519	52519-1-E-HAL-WC01		Flush180	28-MAY-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52519	52519-1-E-HAL-WC01		Flush180	28-MAY-16	1.000	ppb
52519	52519-1-W-HAL-WC03		Flush180	28-MAY-16	1.000	ppb
52519	52519-1-W-HAL-WC03		Flush180	28-MAY-16	1.000	ppb
52519	52519-1-W-HAL-WC03		Flush180	28-MAY-16	1.000	ppb
52519	52519-1-W-HAL-WC03		Flush180	28-MAY-16	1.000	ppb
52519	52519-1-E-HAL-WC01		Flush180	21-JUL-20	1.000	ug/L
52519	52519-1-W-HAL-WC03		Flush180	21-JUL-20	1.000	ug/L
52519	52519-1-E-HAL-WC01		Flush180	06-JAN-21	1.000	ug/L
52519	52519-1-W-HAL-WC03		Flush180	06-JAN-21	1.000	ug/L
52519	52519-1-E-HAL-WC01		Initial	28-MAY-16	1.000	ppb
52519	52519-1-W-HAL-WC03		Initial	28-MAY-16	1.000	ppb
52519	52519-1-E-HAL-WC01		Initial	21-JUL-20	1.000	ug/L
52519	52519-1-W-HAL-WC03		Initial	21-JUL-20	1.000	ug/L
52519	52519-1-E-HAL-WC01		Initial	06-JAN-21	1.000	ug/L
52519	52519-1-W-HAL-WC03		Initial	06-JAN-21	4.800	ug/L
52519	52519-1-KIT-KS01	3-Basin Sink, Left Faucet	Flush180	01-SEP-21	1.160	ug/L
52519	52519-1-KIT-KS01	3-Basin Sink, Left Faucet	Flush180	01-SEP-21	1.250	ug/L
52519	52519-1-KIT-KS01	3-Basin Sink, Left Faucet	Flush180	01-SEP-21	2.090	ug/L
52519	52519-1-KIT-KS01	3-Basin Sink, Left Faucet	Flush180	01-SEP-21	48.000	ug/L
52519	52519-1-KIT-KS01	3-Basin Sink, Left Faucet	Flush180	01-OCT-21	1.000	ug/L
52519	52519-1-KIT-KS01	3-Basin Sink, Left Faucet	Flush180	01-OCT-21	1.000	ug/L
52519	52519-1-KIT-KS01	3-Basin Sink, Left Faucet	Flush180	01-OCT-21	1.000	ug/L
52519	52519-1-KIT-KS01	3-Basin Sink, Left Faucet	Flush180	01-OCT-21	1.000	ug/L
52519	52519-1-KIT-KS01	3-Basin Sink, Left Faucet	Flush180	01-OCT-21	1.000	ug/L
52519	52519-1-KIT-KS01	3-Basin Sink, Left Faucet	Flush180	15-SEP-21	1.000	ug/L
52519	52519-1-KIT-KS01	3-Basin Sink, Left Faucet	Flush180	15-SEP-21	1.000	ug/L
52519	52519-1-KIT-KS01	3-Basin Sink, Left Faucet	Flush180	15-SEP-21	1.000	ug/L
52519	52519-1-KIT-KS01	3-Basin Sink, Left Faucet	Flush180	15-SEP-21	1.000	ug/L
52519	52519-1-KIT-KS01	3-Basin Sink, Left Faucet	Initial	01-SEP-21	1.160	ug/L
52519	52519-1-KIT-KS01	3-Basin Sink, Left Faucet	Initial	01-OCT-21	1.000	ug/L
52519	52519-1-KIT-KS01	3-Basin Sink, Left Faucet	Initial	15-SEP-21	9.140	ug/L
52519	52519-1-KIT-KS02	3-Basin Sink, Right Faucet	Flush180	01-SEP-21	3.330	ug/L
52519	52519-1-KIT-KS02	3-Basin Sink, Right Faucet	Flush180	01-SEP-21	1.970	ug/L
52519	52519-1-KIT-KS02	3-Basin Sink, Right Faucet	Flush180	01-SEP-21	1.980	ug/L
52519	52519-1-KIT-KS02	3-Basin Sink, Right Faucet	Flush180	01-SEP-21	1.360	ug/L
52519	52519-1-KIT-KS02	3-Basin Sink, Right Faucet	Flush180	01-OCT-21	1.000	ug/L
52519	52519-1-KIT-KS02	3-Basin Sink, Right Faucet	Flush180	01-OCT-21	1.000	ug/L
52519	52519-1-KIT-KS02	3-Basin Sink, Right Faucet	Flush180	01-OCT-21	1.000	ug/L
52519	52519-1-KIT-KS02	3-Basin Sink, Right Faucet	Flush180	01-OCT-21	1.000	ug/L
52519	52519-1-KIT-KS02	3-Basin Sink, Right Faucet	Flush180	01-OCT-21	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS02					
52519	52519-1-KIT-KS02	3-Basin Sink, Right Faucet	Flush180	15-SEP-21	1.230	ug/L
52519	52519-1-KIT-KS02	3-Basin Sink, Right Faucet	Flush180	15-SEP-21	1.000	ug/L
52519	52519-1-KIT-KS02	3-Basin Sink, Right Faucet	Flush180	15-SEP-21	1.000	ug/L
52519	52519-1-KIT-KS02	3-Basin Sink, Right Faucet	Flush180	15-SEP-21	1.000	ug/L
52519	52519-1-KIT-KS02	3-Basin Sink, Right Faucet	Initial	01-SEP-21	57.300	ug/L
52519	52519-1-KIT-KS02	3-Basin Sink, Right Faucet	Initial	01-OCT-21	1.000	ug/L
52519	52519-1-KIT-KS02	3-Basin Sink, Right Faucet	Initial	15-SEP-21	15.900	ug/L
52519	52519-1-HAL-RBF01	Additional Building- Hallway between rooms 117-119, Left Bottle Filler	Flush180	20-JUL-22	1.000	ug/L
52519	52519-1-HAL-RBF01	Additional Building- Hallway between rooms 117-119, Left Bottle Filler	Flush180	20-JUL-22	1.000	ug/L
52519	52519-1-HAL-RBF01	Additional Building- Hallway between rooms 117-119, Left Bottle Filler	Flush180	20-JUL-22	1.000	ug/L
52519	52519-1-HAL-RBF01	Additional Building- Hallway between rooms 117-119, Left Bottle Filler	Flush180	20-JUL-22	1.000	ug/L
52519	52519-1-HAL-RBF01	Additional Building- Hallway between rooms 117-119, Left Bottle Filler	Initial	20-JUL-22	1.000	ug/L
52519	52519-1-HAL-WC05	Additional Building- Hallway between rooms 117-119, Middle Fountain	Flush180	20-JUL-22	1.000	ug/L
52519	52519-1-HAL-WC05	Additional Building- Hallway between rooms 117-119, Middle Fountain	Flush180	20-JUL-22	1.000	ug/L
52519	52519-1-HAL-WC05	Additional Building- Hallway between rooms 117-119, Middle Fountain	Flush180	20-JUL-22	1.000	ug/L
52519	52519-1-HAL-WC05	Additional Building- Hallway between rooms 117-119, Middle Fountain	Initial	20-JUL-22	1.000	ug/L
52519	52519-1-HAL-WC04	Additional Building- Hallway between rooms 117-119,Left Fountain	Flush180	28-MAY-16	1.000	ppb
52519	52519-1-HAL-WC04	Additional Building- Hallway between rooms 117-119,Left Fountain	Flush180	28-MAY-16	1.000	ppb
52519	52519-1-HAL-WC04	Additional Building- Hallway between rooms 117-119,Left Fountain	Flush180	28-MAY-16	1.000	ppb
52519	52519-1-HAL-WC04	Additional Building- Hallway between rooms 117-119,Left Fountain	Flush180	28-MAY-16	1.000	ppb
52519	52519-1-HAL-WC04	Additional Building- Hallway between rooms 117-119,Left Fountain	Flush180	20-JUL-22	1.000	ug/L
52519	52519-1-HAL-WC04	Additional Building- Hallway between rooms 117-119,Left Fountain	Flush180	20-JUL-22	1.000	ug/L
52519	52519-1-HAL-WC04	Additional Building- Hallway between rooms 117-119,Left Fountain	Flush180	20-JUL-22	1.000	ug/L
52519	52519-1-HAL-WC04	Additional Building- Hallway between rooms 117-119,Left Fountain	Flush180	20-JUL-22	1.000	ug/L
52519	52519-1-HAL-WC04	Additional Building- Hallway between rooms 117-119,Left Fountain	Initial	28-MAY-16	1.000	ppb
52519	52519-1-HAL-WC04	Additional Building- Hallway between rooms 117-119,Left Fountain	Initial	20-JUL-22	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
		Fountain				
52519	52519-1-125-S08	Additional Building- Inside Kindergarden Room 125,	Flush180	28-MAY-16	1.000	ppb
52519	52519-1-125-S08	Additional Building- Inside Kindergarden Room 125,	Flush180	28-MAY-16	1.000	ppb
52519	52519-1-125-S08	Additional Building- Inside Kindergarden Room 125,	Flush180	28-MAY-16	1.000	ppb
52519	52519-1-125-S08	Additional Building- Inside Kindergarden Room 125,	Flush180	28-MAY-16	1.000	ppb
52519	52519-1-125-S08	Additional Building- Inside Kindergarden Room 125,	Initial	28-MAY-16	1.000	ppb
52519	52519-1-123-S07	Additional Building- Inside Pre-K Room 123, Sink	Flush180	28-MAY-16	1.000	ppb
52519	52519-1-123-S07	Additional Building- Inside Pre-K Room 123, Sink	Flush180	28-MAY-16	1.000	ppb
52519	52519-1-123-S07	Additional Building- Inside Pre-K Room 123, Sink	Flush180	28-MAY-16	1.000	ppb
52519	52519-1-123-S07	Additional Building- Inside Pre-K Room 123, Sink	Flush180	28-MAY-16	1.000	ppb
52519	52519-1-123-S07	Additional Building- Inside Pre-K Room 123, Sink	Initial	28-MAY-16	1.000	ppb
52519	52519-1-117-S11	Additional Building- Inside Room 117, Sink	Flush180	28-MAY-16	1.000	ppb
52519	52519-1-117-S11	Additional Building- Inside Room 117, Sink	Flush180	28-MAY-16	1.000	ppb
52519	52519-1-117-S11	Additional Building- Inside Room 117, Sink	Flush180	28-MAY-16	1.000	ppb
52519	52519-1-117-S11	Additional Building- Inside Room 117, Sink	Flush180	28-MAY-16	1.000	ppb
52519	52519-1-117-S11	Additional Building- Inside Room 117, Sink	Flush180	20-JUL-22	1.000	ug/L
52519	52519-1-117-S11	Additional Building- Inside Room 117, Sink	Flush180	20-JUL-22	1.040	ug/L
52519	52519-1-117-S11	Additional Building- Inside Room 117, Sink	Flush180	20-JUL-22	1.000	ug/L
52519	52519-1-117-S11	Additional Building- Inside Room 117, Sink	Flush180	20-JUL-22	1.000	ug/L
52519	52519-1-117-S11	Additional Building- Inside Room 117, Sink	Initial	28-MAY-16	1.000	ppb
52519	52519-1-117-S11	Additional Building- Inside Room 117, Sink	Initial	20-JUL-22	1.000	ug/L
52519	52519-1-122-S12	Additional Building- Inside Room 122, Sink	Flush180	28-MAY-16	1.000	ppb
52519	52519-1-122-S12	Additional Building- Inside Room 122, Sink	Flush180	28-MAY-16	1.000	ppb
52519	52519-1-122-S12	Additional Building- Inside Room 122, Sink	Flush180	28-MAY-16	1.000	ppb
52519	52519-1-122-S12	Additional Building- Inside Room 122, Sink	Flush180	28-MAY-16	1.000	ppb
52519	52519-1-122-S12	Additional Building- Inside Room 122, Sink	Initial	28-MAY-16	1.000	ppb
52519	52519-1-KIT-KS05	Additional Building- Kitchen, Large Sink	Flush180	28-MAY-16	1.000	ppb
52519	52519-1-KIT-KS05	Additional Building- Kitchen, Large Sink	Flush180	28-MAY-16	1.000	ppb
52519	52519-1-KIT-KS05	Additional Building- Kitchen, Large Sink	Flush180	28-MAY-16	1.000	ppb
52519	52519-1-KIT-KS05	Additional Building- Kitchen, Large Sink	Flush180	28-MAY-16	1.000	ppb
52519	52519-1-KIT-KS05	Additional Building- Kitchen, Large Sink	Flush180	06-JAN-21	1.000	ug/L
52519	52519-1-KIT-KS05	Additional Building- Kitchen, Large Sink	Initial	28-MAY-16	1.000	ppb
52519	52519-1-KIT-KS05	Additional Building- Kitchen, Large Sink	Initial	06-JAN-21	1.000	ug/L
52519	52519-1-KIT-KS06	Additional Building- Kitchen, Small Sink	Flush180	28-MAY-16	1.000	ppb
52519	52519-1-KIT-KS06	Additional Building- Kitchen, Small Sink	Flush180	28-MAY-16	1.000	ppb
52519	52519-1-KIT-KS06	Additional Building- Kitchen, Small Sink	Flush180	28-MAY-16	1.000	ppb
52519	52519-1-KIT-KS06	Additional Building- Kitchen, Small Sink	Flush180	28-MAY-16	1.000	ppb
52519	52519-1-KIT-KS06	Additional Building- Kitchen, Small Sink	Initial	28-MAY-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52519	52519-1-HAL-BF01	East End, Bottle Filler	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-HAL-BF01	East End, Bottle Filler	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-HAL-BF01	East End, Bottle Filler	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-HAL-BF01	East End, Bottle Filler	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-HAL-BF01	East End, Bottle Filler	Initial	26-AUG-21	1.000	ug/L
52519	52519-1-HAL-F02	East End, Center Fountain	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-HAL-F02	East End, Center Fountain	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-HAL-F02	East End, Center Fountain	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-HAL-F02	East End, Center Fountain	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-HAL-F02	East End, Center Fountain	Initial	26-AUG-21	1.000	ug/L
52519	52519-1-HAL-F01	East End, Left Fountain	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-HAL-F01	East End, Left Fountain	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-HAL-F01	East End, Left Fountain	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-HAL-F01	East End, Left Fountain	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-HAL-F01	East End, Left Fountain	Initial	26-AUG-21	1.000	ug/L
52519	52519-1-HAL-F03	East End, Right Fountain	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-HAL-F03	East End, Right Fountain	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-HAL-F03	East End, Right Fountain	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-HAL-F03	East End, Right Fountain	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-HAL-F03	East End, Right Fountain	Initial	26-AUG-21	1.000	ug/L
52519	52519-1-MPR-F01	Multi-Purpose Room, Left Fountain	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-MPR-F01	Multi-Purpose Room, Left Fountain	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-MPR-F01	Multi-Purpose Room, Left Fountain	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-MPR-F01	Multi-Purpose Room, Left Fountain	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-MPR-F01	Multi-Purpose Room, Left Fountain	Initial	26-AUG-21	1.000	ug/L
52519	52519-1-MPR-F02	Multi-Purpose Room, Right Fountain	Flush180	26-AUG-21	2.790	ug/L
52519	52519-1-MPR-F02	Multi-Purpose Room, Right Fountain	Flush180	26-AUG-21	2.200	ug/L
52519	52519-1-MPR-F02	Multi-Purpose Room, Right Fountain	Flush180	26-AUG-21	1.830	ug/L
52519	52519-1-MPR-F02	Multi-Purpose Room, Right Fountain	Flush180	26-AUG-21	1.450	ug/L
52519	52519-1-MPR-F02	Multi-Purpose Room, Right Fountain	Initial	26-AUG-21	2.200	ug/L
52519	52519-1-201-S02	Pre-K Room 201 Bathroom	Flush180	26-AUG-21	1.220	ug/L
52519	52519-1-201-S02	Pre-K Room 201 Bathroom	Flush180	26-AUG-21	1.260	ug/L
52519	52519-1-201-S02	Pre-K Room 201 Bathroom	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-201-S02	Pre-K Room 201 Bathroom	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-201-S02	Pre-K Room 201 Bathroom	Initial	26-AUG-21	2.430	ug/L
52519	52519-1-201-WC01	Pre-K Room 201	Flush	25-APR-2024	1.000	ug/L
52519	52519-1-201-WC01	Pre-K Room 201	Flush	25-APR-2024	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52519	52519-1-201-WC01	Pre-K Room 201	Flush	25-APR-2024	1.000	ug/L
52519	52519-1-201-WC01	Pre-K Room 201	Flush	25-APR-2024	1.000	ug/L
52519	52519-1-201-WC01	Pre-K Room 201	Flush180	26-AUG-21	1.440	ug/L
52519	52519-1-201-WC01	Pre-K Room 201	Flush180	26-AUG-21	1.700	ug/L
52519	52519-1-201-WC01	Pre-K Room 201	Flush180	26-AUG-21	1.550	ug/L
52519	52519-1-201-WC01	Pre-K Room 201	Flush180	26-AUG-21	2.090	ug/L
52519	52519-1-201-WC01	Pre-K Room 201	Initial	26-AUG-21	5.500	ug/L
52519	52519-1-201-WC01	Pre-K Room 201	Initial	25-APR-2024	1.000	ug/L
52519	52519-1-202-S02	Pre-K Room 202 Bathroom	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-202-S02	Pre-K Room 202 Bathroom	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-202-S02	Pre-K Room 202 Bathroom	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-202-S02	Pre-K Room 202 Bathroom	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-202-S02	Pre-K Room 202 Bathroom	Initial	26-AUG-21	2.400	ug/L
52519	52519-1-202-WC01	Pre-K Room 202	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-202-WC01	Pre-K Room 202	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-202-WC01	Pre-K Room 202	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-202-WC01	Pre-K Room 202	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-202-WC01	Pre-K Room 202	Initial	26-AUG-21	1.000	ug/L
52519	52519-1-203-S02	Pre-K Room 203 Bathroom	Flush180	26-AUG-21	1.600	ug/L
52519	52519-1-203-S02	Pre-K Room 203 Bathroom	Flush180	26-AUG-21	1.890	ug/L
52519	52519-1-203-S02	Pre-K Room 203 Bathroom	Flush180	26-AUG-21	1.330	ug/L
52519	52519-1-203-S02	Pre-K Room 203 Bathroom	Flush180	26-AUG-21	1.260	ug/L
52519	52519-1-203-S02	Pre-K Room 203 Bathroom	Initial	26-AUG-21	1.980	ug/L
52519	52519-1-203-WC01	Pre-K Room 203	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-203-WC01	Pre-K Room 203	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-203-WC01	Pre-K Room 203	Flush180	26-AUG-21	2.030	ug/L
52519	52519-1-203-WC01	Pre-K Room 203	Flush180	26-AUG-21	2.140	ug/L
52519	52519-1-203-WC01	Pre-K Room 203	Initial	26-AUG-21	1.000	ug/L
52519	52519-1-204-S02	Pre-K Room 204 Bathroom	Flush	25-APR-2024	1.000	ug/L
52519	52519-1-204-S02	Pre-K Room 204 Bathroom	Flush	25-APR-2024	1.000	ug/L
52519	52519-1-204-S02	Pre-K Room 204 Bathroom	Flush	25-APR-2024	1.000	ug/L
52519	52519-1-204-S02	Pre-K Room 204 Bathroom	Flush	25-APR-2024	1.000	ug/L
52519	52519-1-204-S02	Pre-K Room 204 Bathroom	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-204-S02	Pre-K Room 204 Bathroom	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-204-S02	Pre-K Room 204 Bathroom	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-204-S02	Pre-K Room 204 Bathroom	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-204-S02	Pre-K Room 204 Bathroom	Initial	26-AUG-21	5.670	ug/L
52519	52519-1-204-S02	Pre-K Room 204 Bathroom	Initial	25-APR-2024	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S02					
52519	52519-1-204-WC01	Pre-K Room 204	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-204-WC01	Pre-K Room 204	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-204-WC01	Pre-K Room 204	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-204-WC01	Pre-K Room 204	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-204-WC01	Pre-K Room 204	Initial	26-AUG-21	1.000	ug/L
52519	52519-1-205-S02	Pre-K Room 205 Bathroom	Flush180	26-AUG-21	1.160	ug/L
52519	52519-1-205-S02	Pre-K Room 205 Bathroom	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-205-S02	Pre-K Room 205 Bathroom	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-205-S02	Pre-K Room 205 Bathroom	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-205-S02	Pre-K Room 205 Bathroom	Initial	26-AUG-21	1.990	ug/L
52519	52519-1-205-WC01	Pre-K Room 205	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-205-WC01	Pre-K Room 205	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-205-WC01	Pre-K Room 205	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-205-WC01	Pre-K Room 205	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-205-WC01	Pre-K Room 205	Initial	26-AUG-21	1.000	ug/L
52519	52519-1-206-S02	Pre-K Room 206 Bathroom	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-206-S02	Pre-K Room 206 Bathroom	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-206-S02	Pre-K Room 206 Bathroom	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-206-S02	Pre-K Room 206 Bathroom	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-206-S02	Pre-K Room 206 Bathroom	Initial	26-AUG-21	2.880	ug/L
52519	52519-1-206-WC01	Pre-K Room 206	Flush	25-APR-2024	1.000	ug/L
52519	52519-1-206-WC01	Pre-K Room 206	Flush	25-APR-2024	1.000	ug/L
52519	52519-1-206-WC01	Pre-K Room 206	Flush	25-APR-2024	1.000	ug/L
52519	52519-1-206-WC01	Pre-K Room 206	Flush	25-APR-2024	1.000	ug/L
52519	52519-1-206-WC01	Pre-K Room 206	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-206-WC01	Pre-K Room 206	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-206-WC01	Pre-K Room 206	Flush180	26-AUG-21	6.450	ug/L
52519	52519-1-206-WC01	Pre-K Room 206	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-206-WC01	Pre-K Room 206	Initial	26-AUG-21	1.000	ug/L
52519	52519-1-206-WC01	Pre-K Room 206	Initial	25-APR-2024	1.000	ug/L
52519	52519-1-207-S02	Pre-K Room 207 Bathroom	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-207-S02	Pre-K Room 207 Bathroom	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-207-S02	Pre-K Room 207 Bathroom	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-207-S02	Pre-K Room 207 Bathroom	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-207-S02	Pre-K Room 207 Bathroom	Initial	26-AUG-21	1.000	ug/L
52519	52519-1-207-WC01	Pre-K Room 207	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-207-	Pre-K Room 207	Flush180	26-AUG-21	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	WC01					
52519	52519-1-207-WC01	Pre-K Room 207	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-207-WC01	Pre-K Room 207	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-207-WC01	Pre-K Room 207	Initial	26-AUG-21	1.000	ug/L
52519	52519-1-208-S02	Pre-K Room 208 Bathroom	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-208-S02	Pre-K Room 208 Bathroom	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-208-S02	Pre-K Room 208 Bathroom	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-208-S02	Pre-K Room 208 Bathroom	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-208-S02	Pre-K Room 208 Bathroom	Initial	26-AUG-21	2.120	ug/L
52519	52519-1-208-WC01	Pre-K Room 208	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-208-WC01	Pre-K Room 208	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-208-WC01	Pre-K Room 208	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-208-WC01	Pre-K Room 208	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-208-WC01	Pre-K Room 208	Initial	26-AUG-21	1.000	ug/L
52519	52519-1-209-S02	Pre-K Room 209 Bathroom	Flush180	26-AUG-21	1.030	ug/L
52519	52519-1-209-S02	Pre-K Room 209 Bathroom	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-209-S02	Pre-K Room 209 Bathroom	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-209-S02	Pre-K Room 209 Bathroom	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-209-S02	Pre-K Room 209 Bathroom	Initial	26-AUG-21	2.070	ug/L
52519	52519-1-209-WC01	Pre-K Room 209	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-209-WC01	Pre-K Room 209	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-209-WC01	Pre-K Room 209	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-209-WC01	Pre-K Room 209	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-209-WC01	Pre-K Room 209	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-209-WC01	Pre-K Room 209	Initial	26-AUG-21	1.000	ug/L
52519	52519-1-210-S02	Pre-K Room 210 Bathroom	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-210-S02	Pre-K Room 210 Bathroom	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-210-S02	Pre-K Room 210 Bathroom	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-210-S02	Pre-K Room 210 Bathroom	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-210-S02	Pre-K Room 210 Bathroom	Initial	26-AUG-21	2.320	ug/L
52519	52519-1-210-WC01	Pre-K Room 210	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-210-WC01	Pre-K Room 210	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-210-WC01	Pre-K Room 210	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-210-WC01	Pre-K Room 210	Flush180	26-AUG-21	1.000	ug/L
52519	52519-1-210-WC01	Pre-K Room 210	Initial	26-AUG-21	1.000	ug/L
52519	52519-1-201-S01	Room 201 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-201-S01	Room 201 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-201-S01	Room 201 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-201-S01	Room 201 Sink	Flush180	01-SEP-21	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52519	52519-1-201-S01	Room 201 Sink	Initial	01-SEP-21	3.540	ug/L
52519	52519-1-202-S01	Room 202 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-202-S01	Room 202 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-202-S01	Room 202 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-202-S01	Room 202 Sink	Flush180	15-SEP-21	1.000	ug/L
52519	52519-1-202-S01	Room 202 Sink	Flush180	15-SEP-21	1.000	ug/L
52519	52519-1-202-S01	Room 202 Sink	Flush180	15-SEP-21	1.000	ug/L
52519	52519-1-202-S01	Room 202 Sink	Flush180	15-SEP-21	1.000	ug/L
52519	52519-1-202-S01	Room 202 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-202-S01	Room 202 Sink	Initial	15-SEP-21	1.710	ug/L
52519	52519-1-202-S01	Room 202 Sink	Initial	01-SEP-21	5.880	ug/L
52519	52519-1-203-S01	Room 203 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-203-S01	Room 203 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-203-S01	Room 203 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-203-S01	Room 203 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-203-S01	Room 203 Sink	Initial	01-SEP-21	3.350	ug/L
52519	52519-1-204-S01	Room 204 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-204-S01	Room 204 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-204-S01	Room 204 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-204-S01	Room 204 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-204-S01	Room 204 Sink	Initial	01-SEP-21	2.390	ug/L
52519	52519-1-205-S01	Room 205 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-205-S01	Room 205 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-205-S01	Room 205 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-205-S01	Room 205 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-205-S01	Room 205 Sink	Initial	01-SEP-21	3.570	ug/L
52519	52519-1-206-S01	Room 206 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-206-S01	Room 206 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-206-S01	Room 206 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-206-S01	Room 206 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-206-S01	Room 206 Sink	Initial	01-SEP-21	4.970	ug/L
52519	52519-1-207-S01	Room 207 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-207-S01	Room 207 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-207-S01	Room 207 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-207-S01	Room 207 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-207-S01	Room 207 Sink	Flush180	15-SEP-21	1.000	ug/L
52519	52519-1-207-S01	Room 207 Sink	Flush180	15-SEP-21	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52519	52519-1-207-S01	Room 207 Sink	Flush180	15-SEP-21	1.000	ug/L
52519	52519-1-207-S01	Room 207 Sink	Flush180	15-SEP-21	1.000	ug/L
52519	52519-1-207-S01	Room 207 Sink	Initial	01-SEP-21	8.780	ug/L
52519	52519-1-207-S01	Room 207 Sink	Initial	15-SEP-21	1.190	ug/L
52519	52519-1-208-S01	Room 208 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-208-S01	Room 208 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-208-S01	Room 208 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-208-S01	Room 208 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-208-S01	Room 208 Sink	Flush180	15-SEP-21	1.000	ug/L
52519	52519-1-208-S01	Room 208 Sink	Flush180	15-SEP-21	1.000	ug/L
52519	52519-1-208-S01	Room 208 Sink	Flush180	15-SEP-21	1.000	ug/L
52519	52519-1-208-S01	Room 208 Sink	Flush180	15-SEP-21	1.000	ug/L
52519	52519-1-208-S01	Room 208 Sink	Initial	01-SEP-21	5.450	ug/L
52519	52519-1-208-S01	Room 208 Sink	Initial	15-SEP-21	2.680	ug/L
52519	52519-1-209-S01	Room 209 Sink	Flush180	15-SEP-21	1.000	ug/L
52519	52519-1-209-S01	Room 209 Sink	Flush180	15-SEP-21	1.000	ug/L
52519	52519-1-209-S01	Room 209 Sink	Flush180	15-SEP-21	1.000	ug/L
52519	52519-1-209-S01	Room 209 Sink	Flush180	15-SEP-21	1.000	ug/L
52519	52519-1-209-S01	Room 209 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-209-S01	Room 209 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-209-S01	Room 209 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-209-S01	Room 209 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-209-S01	Room 209 Sink	Initial	01-SEP-21	5.560	ug/L
52519	52519-1-209-S01	Room 209 Sink	Initial	15-SEP-21	1.590	ug/L
52519	52519-1-210-S01	Room 210 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-210-S01	Room 210 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-210-S01	Room 210 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-210-S01	Room 210 Sink	Flush180	01-SEP-21	1.000	ug/L
52519	52519-1-210-S01	Room 210 Sink	Flush180	15-SEP-21	1.000	ug/L
52519	52519-1-210-S01	Room 210 Sink	Flush180	15-SEP-21	1.000	ug/L
52519	52519-1-210-S01	Room 210 Sink	Flush180	15-SEP-21	1.000	ug/L
52519	52519-1-210-S01	Room 210 Sink	Flush180	15-SEP-21	1.000	ug/L
52519	52519-1-210-S01	Room 210 Sink	Flush180	15-SEP-21	1.000	ug/L
52519	52519-1-210-S01	Room 210 Sink	Initial	01-SEP-21	5.340	ug/L
52519	52519-1-210-S01	Room 210 Sink	Initial	15-SEP-21	1.480	ug/L