



Sep 10, 2024

BEASLEY

5255 S STATE ST, Chicago IL 60609.

Dear **BEASLEY** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

BEASLEY

5255 S STATE ST, Chicago IL 60609.

Estimadas familias de **BEASLEY**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51361	51361-2-HAL-BF01	2nd Floor Hallway	Flush180	25-AUG-23	1.000	ug/L
51361	51361-2-HAL-BF01	2nd Floor Hallway	Flush180	25-AUG-23	1.000	ug/L
51361	51361-2-HAL-BF01	2nd Floor Hallway	Flush180	25-AUG-23	1.000	ug/L
51361	51361-2-HAL-BF01	2nd Floor Hallway	Flush180	25-AUG-23	1.000	ug/L
51361	51361-2-HAL-BF01	2nd Floor Hallway	Flush180	22-DEC-20	3.260	ug/L
51361	51361-2-HAL-BF01	2nd Floor Hallway	Flush180	22-DEC-20	5.090	ug/L
51361	51361-2-HAL-BF01	2nd Floor Hallway	Flush180	22-DEC-20	5.260	ug/L
51361	51361-2-HAL-BF01	2nd Floor Hallway	Flush180	22-DEC-20	5.080	ug/L
51361	51361-2-HAL-BF01	2nd Floor Hallway	Initial	25-AUG-23	1.000	ug/L
51361	51361-2-HAL-BF01	2nd Floor Hallway	Initial	22-DEC-20	4.080	ug/L
51361	51361-2-E-HAL-BF01	Center Bottle Filler, Outside Band Room	Flush	12-DEC-2023	1.000	ug/L
51361	51361-2-E-HAL-BF01	Center Bottle Filler, Outside Band Room	Flush	12-DEC-2023	1.000	ug/L
51361	51361-2-E-HAL-BF01	Center Bottle Filler, Outside Band Room	Flush	12-DEC-2023	1.000	ug/L
51361	51361-2-E-HAL-BF01	Center Bottle Filler, Outside Band Room	Flush	12-DEC-2023	1.000	ug/L
51361	51361-2-E-HAL-BF01	Center Bottle Filler, Outside Band Room	Initial	12-DEC-2023	1.000	ug/L
51361	51361-2-E-HAL-F05	Center Fountain, Outside Band Room	Flush	12-DEC-2023	1.000	ug/L
51361	51361-2-E-HAL-F05	Center Fountain, Outside Band Room	Flush	12-DEC-2023	1.000	ug/L
51361	51361-2-E-HAL-F05	Center Fountain, Outside Band Room	Flush	12-DEC-2023	1.000	ug/L
51361	51361-2-E-HAL-F05	Center Fountain, Outside Band Room	Flush	12-DEC-2023	1.000	ug/L
51361	51361-2-E-HAL-F05	Center Fountain, Outside Band Room	Flush180	26-MAY-16	0.795	ppb
51361	51361-2-E-HAL-F05	Center Fountain, Outside Band Room	Flush180	26-MAY-16	0.562	ppb
51361	51361-2-E-HAL-F05	Center Fountain, Outside Band Room	Flush180	26-MAY-16	0.706	ppb
51361	51361-2-E-HAL-F05	Center Fountain, Outside Band Room	Flush180	26-MAY-16	0.183	ppb
51361	51361-2-E-HAL-F05	Center Fountain, Outside Band Room	Flush180	05-JAN-21	2.830	ug/L
51361	51361-2-E-HAL-F05	Center Fountain, Outside Band Room	Initial	26-MAY-16	0.301	ppb
51361	51361-2-E-HAL-F05	Center Fountain, Outside Band Room	Initial	05-JAN-21	2.480	ug/L
51361	51361-2-E-HAL-F05	Center Fountain, Outside Band Room	Initial	12-DEC-2023	1.000	ug/L
51361	51361-1-E-HAL-F03	Center Fountain, Outside Door 1	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-E-HAL-F03	Center Fountain, Outside Door 1	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-E-HAL-F03	Center Fountain, Outside Door 1	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-E-HAL-F03	Center Fountain, Outside Door 1	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-E-HAL-F02	Center Fountain, Outside Door 1	Flush180	26-MAY-16	0.143	ppb
51361	51361-1-E-HAL-F02	Center Fountain, Outside Door 1	Flush180	26-MAY-16	0.136	ppb
51361	51361-1-E-HAL-F02	Center Fountain, Outside Door 1	Flush180	26-MAY-16	0.138	ppb
51361	51361-1-E-HAL-F02	Center Fountain, Outside Door 1	Flush180	26-MAY-16	0.127	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51361	51361-1-E-HAL-F03	Center Fountain, Outside Door 1	Flush180	26-MAY-16	0.152	ppb
51361	51361-1-E-HAL-F03	Center Fountain, Outside Door 1	Flush180	26-MAY-16	0.157	ppb
51361	51361-1-E-HAL-F03	Center Fountain, Outside Door 1	Flush180	26-MAY-16	0.168	ppb
51361	51361-1-E-HAL-F03	Center Fountain, Outside Door 1	Flush180	26-MAY-16	0.144	ppb
51361	51361-1-E-HAL-F02	Center Fountain, Outside Door 1	Initial	26-MAY-16	1.000	ppb
51361	51361-1-E-HAL-F03	Center Fountain, Outside Door 1	Initial	26-MAY-16	0.142	ppb
51361	51361-1-E-HAL-F03	Center Fountain, Outside Door 1	Initial	12-DEC-2023	1.000	ug/L
51361	51361-1-E-HAL-F05	Center Fountain, Outside Door 6	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-E-HAL-F05	Center Fountain, Outside Door 6	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-E-HAL-F05	Center Fountain, Outside Door 6	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-E-HAL-F05	Center Fountain, Outside Door 6	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-E-HAL-F05	Center Fountain, Outside Door 6	Flush180	26-MAY-16	0.200	ppb
51361	51361-1-E-HAL-F05	Center Fountain, Outside Door 6	Flush180	26-MAY-16	0.250	ppb
51361	51361-1-E-HAL-F05	Center Fountain, Outside Door 6	Flush180	26-MAY-16	0.238	ppb
51361	51361-1-E-HAL-F05	Center Fountain, Outside Door 6	Flush180	26-MAY-16	0.244	ppb
51361	51361-1-E-HAL-F05	Center Fountain, Outside Door 6	Initial	26-MAY-16	0.163	ppb
51361	51361-1-E-HAL-F05	Center Fountain, Outside Door 6	Initial	12-DEC-2023	1.000	ug/L
51361	51361-2-E-HAL-F02	Center Fountain, Outside Room 236	Flush	12-DEC-2023	1.000	ug/L
51361	51361-2-E-HAL-F02	Center Fountain, Outside Room 236	Flush	12-DEC-2023	1.000	ug/L
51361	51361-2-E-HAL-F02	Center Fountain, Outside Room 236	Flush	12-DEC-2023	1.000	ug/L
51361	51361-2-E-HAL-F02	Center Fountain, Outside Room 236	Flush	12-DEC-2023	1.000	ug/L
51361	51361-2-E-HAL-F02	Center Fountain, Outside Room 236	Flush180	26-MAY-16	0.147	ppb
51361	51361-2-E-HAL-F02	Center Fountain, Outside Room 236	Flush180	26-MAY-16	0.368	ppb
51361	51361-2-E-HAL-F02	Center Fountain, Outside Room 236	Flush180	26-MAY-16	0.460	ppb
51361	51361-2-E-HAL-F02	Center Fountain, Outside Room 236	Flush180	26-MAY-16	0.233	ppb
51361	51361-2-E-HAL-F02	Center Fountain, Outside Room 236	Initial	26-MAY-16	0.530	ppb
51361	51361-2-E-HAL-F02	Center Fountain, Outside Room 236	Initial	12-DEC-2023	1.000	ug/L
51361	51361-1-HAL-BF01	First Floor Hallway	Flush180	22-DEC-20	2.550	ug/L
51361	51361-1-HAL-BF01	First Floor Hallway	Flush180	22-DEC-20	2.270	ug/L
51361	51361-1-HAL-BF01	First Floor Hallway	Flush180	22-DEC-20	2.560	ug/L
51361	51361-1-HAL-BF01	First Floor Hallway	Flush180	22-DEC-20	22.800	ug/L
51361	51361-1-HAL-BF01	First Floor Hallway	Initial	22-DEC-20	3.370	ug/L
51361	51361-1-W-OFF-S01	Inside Main Office Sink	Flush	03-APR-2024	1.000	ug/L
51361	51361-1-W-OFF-S01	Inside Main Office Sink	Flush	03-APR-2024	1.000	ug/L
51361	51361-1-W-OFF-S01	Inside Main Office Sink	Flush	03-APR-2024	1.000	ug/L
51361	51361-1-W-OFF-S01	Inside Main Office Sink	Flush	03-APR-2024	1.000	ug/L
51361	51361-1-W-OFF-S01	Inside Main Office Sink	Initial	03-APR-2024	1.390	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51361	51361-1-W-OFF-F01	Inside Main Office, Fountain	Flush180	26-MAY-16	4.470	ppb
51361	51361-1-W-OFF-F01	Inside Main Office, Fountain	Flush180	26-MAY-16	6.070	ppb
51361	51361-1-W-OFF-F01	Inside Main Office, Fountain	Flush180	26-MAY-16	3.780	ppb
51361	51361-1-W-OFF-F01	Inside Main Office, Fountain	Flush180	26-MAY-16	6.530	ppb
51361	51361-1-W-OFF-F01	Inside Main Office, Fountain	Flush180	07-MAY-20	97.800	ug/L
51361	51361-1-W-OFF-F01	Inside Main Office, Fountain	Flush180	07-MAY-20	74.000	ug/L
51361	51361-1-W-OFF-F01	Inside Main Office, Fountain	Flush180	07-MAY-20	83.800	ug/L
51361	51361-1-W-OFF-F01	Inside Main Office, Fountain	Flush180	07-MAY-20	69.100	ug/L
51361	51361-1-W-OFF-F01	Inside Main Office, Fountain	Flush180	28-JAN-20	14.800	ug/L
51361	51361-1-W-OFF-F01	Inside Main Office, Fountain	Flush180	28-JAN-20	8.560	ug/L
51361	51361-1-W-OFF-F01	Inside Main Office, Fountain	Flush180	28-JAN-20	5.770	ug/L
51361	51361-1-W-OFF-F01	Inside Main Office, Fountain	Flush180	28-JAN-20	20.200	ug/L
51361	51361-1-W-OFF-F01	Inside Main Office, Fountain	Initial	26-MAY-16	3.230	ppb
51361	51361-1-W-OFF-F01	Inside Main Office, Fountain	Initial	07-MAY-20	44.800	ug/L
51361	51361-1-W-OFF-F01	Inside Main Office, Fountain	Initial	28-JAN-20	4.660	ug/L
51361	51361-1-W-OFF-F01	Inside Main Office, Sink	Flush	04-JAN-2024	5.090	ug/L
51361	51361-1-W-OFF-F01	Inside Main Office, Sink	Flush	04-JAN-2024	3.630	ug/L
51361	51361-1-W-OFF-F01	Inside Main Office, Sink	Flush	04-JAN-2024	1.250	ug/L
51361	51361-1-W-OFF-F01	Inside Main Office, Sink	Flush	04-JAN-2024	1.040	ug/L
51361	51361-1-W-OFF-F01	Inside Main Office, Sink	Flush	12-DEC-2023	2.190	ug/L
51361	51361-1-W-OFF-F01	Inside Main Office, Sink	Flush	12-DEC-2023	29.800	ug/L
51361	51361-1-W-OFF-F01	Inside Main Office, Sink	Flush	12-DEC-2023	8.020	ug/L
51361	51361-1-W-OFF-F01	Inside Main Office, Sink	Flush	12-DEC-2023	3.590	ug/L
51361	51361-1-W-OFF-F01	Inside Main Office, Sink	Initial	04-JAN-2024	4.040	ug/L
51361	51361-1-W-OFF-F01	Inside Main Office, Sink	Initial	12-DEC-2023	5.290	ug/L
51361	51361-2-W-234-S01	Inside Room 234 Sink 1, DOES NOT MEET TESTING PROTOCOL	Flush180	26-MAY-16	140.000	ppb
51361	51361-2-W-234-S01	Inside Room 234 Sink 1, DOES NOT MEET TESTING PROTOCOL	Flush180	26-MAY-16	965.000	ppb
51361	51361-2-W-234-S01	Inside Room 234 Sink 1, DOES NOT MEET TESTING PROTOCOL	Flush180	21-JUL-16	16.900	ppb
51361	51361-2-W-234-S01	Inside Room 234 Sink 1, DOES NOT MEET TESTING PROTOCOL	Flush180	21-JUL-16	17.600	ppb
51361	51361-2-W-234-S01	Inside Room 234 Sink 1, DOES NOT MEET TESTING PROTOCOL	Flush180	21-JUL-16	2.920	ppb
51361	51361-2-W-234-S01	Inside Room 234 Sink 1, DOES NOT MEET TESTING PROTOCOL	Flush180	21-JUL-16	11.100	ppb
51361	51361-2-W-234-S01	Inside Room 234 Sink 1, DOES NOT MEET TESTING PROTOCOL	Flush180	18-AUG-16	4.100	ppb
51361	51361-2-W-234-S01	Inside Room 234 Sink 1, DOES NOT MEET TESTING PROTOCOL	Flush180	18-AUG-16	11.000	ppb
51361	51361-2-W-	Inside Room 234 Sink 1, DOES	Flush180	18-AUG-16	4.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	234-S01	NOT MEET TESTING PROTOCOL				
51361	51361-2-W-234-S01	Inside Room 234 Sink 1, DOES NOT MEET TESTING PROTOCOL	Flush180	18-AUG-16	3.800	ppb
51361	51361-2-W-234-S01	Inside Room 234 Sink 1, DOES NOT MEET TESTING PROTOCOL	Flush180	08-SEP-16	3.000	ppb
51361	51361-2-W-234-S01	Inside Room 234 Sink 1, DOES NOT MEET TESTING PROTOCOL	Flush180	08-SEP-16	1.000	ppb
51361	51361-2-W-234-S01	Inside Room 234 Sink 1, DOES NOT MEET TESTING PROTOCOL	Flush180	26-MAY-16	64.400	ppb
51361	51361-2-W-234-S01	Inside Room 234 Sink 1, DOES NOT MEET TESTING PROTOCOL	Flush180	08-SEP-16	1.000	ppb
51361	51361-2-W-234-S01	Inside Room 234 Sink 1, DOES NOT MEET TESTING PROTOCOL	Flush180	08-SEP-16	12.000	ppb
51361	51361-2-W-234-S01	Inside Room 234 Sink 1, DOES NOT MEET TESTING PROTOCOL	Flush180	26-MAY-16	214.00 0	ppb
51361	51361-2-W-234-S01	Inside Room 234 Sink 1, DOES NOT MEET TESTING PROTOCOL	Flush180	28-JAN-20	6.590	ug/L
51361	51361-2-W-234-S01	Inside Room 234 Sink 1, DOES NOT MEET TESTING PROTOCOL	Flush180	28-JAN-20	3.910	ug/L
51361	51361-2-W-234-S01	Inside Room 234 Sink 1, DOES NOT MEET TESTING PROTOCOL	Flush180	28-JAN-20	1.130	ug/L
51361	51361-2-W-234-S01	Inside Room 234 Sink 1, DOES NOT MEET TESTING PROTOCOL	Flush180	28-JAN-20	1.250	ug/L
51361	51361-2-W-234-S01	Inside Room 234 Sink 1, DOES NOT MEET TESTING PROTOCOL	Initial	26-MAY-16	950.00 0	ppb
51361	51361-2-W-234-S01	Inside Room 234 Sink 1, DOES NOT MEET TESTING PROTOCOL	Initial	21-JUL-16	53.400	ppb
51361	51361-2-W-234-S01	Inside Room 234 Sink 1, DOES NOT MEET TESTING PROTOCOL	Initial	18-AUG-16	17.000	ppb
51361	51361-2-W-234-S01	Inside Room 234 Sink 1, DOES NOT MEET TESTING PROTOCOL	Initial	08-SEP-16	3.400	ppb
51361	51361-2-W-234-S01	Inside Room 234 Sink 1, DOES NOT MEET TESTING PROTOCOL	Initial	28-JAN-20	2.600	ug/L
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Flush180	26-MAY-16	2.330	ppb
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Flush180	26-MAY-16	24.800	ppb
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Flush180	21-JUL-16	78.000	ppb
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Flush180	21-JUL-16	2.860	ppb
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Flush180	21-JUL-16	4.720	ppb
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Flush180	21-JUL-16	14.300	ppb
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Flush180	18-AUG-16	2.200	ppb
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Flush180	18-AUG-16	4.400	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Flush180	18-AUG-16	1.000	ppb
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Flush180	18-AUG-16	16.000	ppb
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Flush180	02-NOV-16	4.800	ppb
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Flush180	02-NOV-16	13.000	ppb
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Flush180	08-SEP-16	6.900	ppb
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Flush180	08-SEP-16	60.000	ppb
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Flush180	08-SEP-16	16.000	ppb
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Flush180	08-SEP-16	5.800	ppb
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Flush180	23-SEP-16	21.000	ppb
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Flush180	23-SEP-16	8.500	ppb
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Flush180	23-SEP-16	1.000	ppb
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Flush180	02-NOV-16	1.000	ppb
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Flush180	02-NOV-16	2.300	ppb
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Flush180	26-MAY-16	7.240	ppb
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Flush180	26-MAY-16	2.150	ppb
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Flush180	23-SEP-16	3.000	ppb
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Flush180	28-JAN-20	15.800	ug/L
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Flush180	28-JAN-20	5.110	ug/L
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Flush180	28-JAN-20	2.560	ug/L
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Flush180	28-JAN-20	1.850	ug/L
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Initial	26-MAY-16	9.040	ppb
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Initial	18-AUG-16	13.000	ppb
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Initial	21-JUL-16	15.700	ppb
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Initial	08-SEP-16	28.000	ppb
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Initial	23-SEP-16	4.900	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Initial	02-NOV-16	12.000	ppb
51361	51361-2-N-234-S02	Inside Room 234 South Wall Sink, DOES NOT MEET TESTING PROTOCOL	Initial	28-JAN-20	9.620	ug/L
51361	51361-1-E-TL-F01	Inside Teachers Lounge, Sink	Flush	12-DEC-2023	3.760	ug/L
51361	51361-1-E-TL-F01	Inside Teachers Lounge, Sink	Flush	12-DEC-2023	3.180	ug/L
51361	51361-1-E-TL-F01	Inside Teachers Lounge, Sink	Flush	12-DEC-2023	2.290	ug/L
51361	51361-1-E-TL-F01	Inside Teachers Lounge, Sink	Flush	12-DEC-2023	2.040	ug/L
51361	51361-1-E-TL-F01	Inside Teachers Lounge, Sink	Flush180	26-MAY-16	2.350	ppb
51361	51361-1-E-TL-F01	Inside Teachers Lounge, Sink	Flush180	26-MAY-16	2.240	ppb
51361	51361-1-E-TL-F01	Inside Teachers Lounge, Sink	Flush180	26-MAY-16	5.110	ppb
51361	51361-1-E-TL-F01	Inside Teachers Lounge, Sink	Flush180	26-MAY-16	1.700	ppb
51361	51361-1-E-TL-F01	Inside Teachers Lounge, Sink	Flush180	28-JAN-20	3.370	ug/L
51361	51361-1-E-TL-F01	Inside Teachers Lounge, Sink	Flush180	28-JAN-20	2.220	ug/L
51361	51361-1-E-TL-F01	Inside Teachers Lounge, Sink	Flush180	28-JAN-20	1.440	ug/L
51361	51361-1-E-TL-F01	Inside Teachers Lounge, Sink	Flush180	28-JAN-20	1.000	ug/L
51361	51361-1-E-TL-F01	Inside Teachers Lounge, Sink	Initial	26-MAY-16	4.870	ppb
51361	51361-1-E-TL-F01	Inside Teachers Lounge, Sink	Initial	28-JAN-20	2.910	ug/L
51361	51361-1-E-TL-F01	Inside Teachers Lounge, Sink	Initial	12-DEC-2023	2.900	ug/L
51361	51361-1-E-KIT-KS05	Kitchen Dish Sink	Flush180	26-MAY-16	1.660	ppb
51361	51361-1-E-KIT-KS05	Kitchen Dish Sink	Flush180	26-MAY-16	0.655	ppb
51361	51361-1-E-KIT-KS05	Kitchen Dish Sink	Flush180	26-MAY-16	2.670	ppb
51361	51361-1-E-KIT-KS05	Kitchen Dish Sink	Flush180	26-MAY-16	0.788	ppb
51361	51361-1-E-KIT-KS05	Kitchen Dish Sink	Flush180	05-JAN-21	1.000	ug/L
51361	51361-1-E-KIT-KS05	Kitchen Dish Sink	Initial	26-MAY-16	1.220	ppb
51361	51361-1-E-KIT-KS05	Kitchen Dish Sink	Initial	05-JAN-21	1.000	ug/L
51361	51361-1-E-KIT-KS05	Kitchen Dish Sink (Sprayer)	Flush	03-APR-2024	1.000	ug/L
51361	51361-1-E-KIT-KS05	Kitchen Dish Sink (Sprayer)	Flush	03-APR-2024	1.100	ug/L
51361	51361-1-E-KIT-KS05	Kitchen Dish Sink (Sprayer)	Flush	03-APR-2024	1.210	ug/L
51361	51361-1-E-KIT-KS05	Kitchen Dish Sink (Sprayer)	Flush	03-APR-2024	1.010	ug/L
51361	51361-1-E-KIT-KS05	Kitchen Dish Sink (Sprayer)	Flush	12-DEC-2023	10.800	ug/L
51361	51361-1-E-KIT-KS05	Kitchen Dish Sink (Sprayer)	Flush	12-DEC-2023	6.570	ug/L
51361	51361-1-E-KIT-KS05	Kitchen Dish Sink (Sprayer)	Flush	12-DEC-2023	10.300	ug/L
51361	51361-1-E-KIT-KS05	Kitchen Dish Sink (Sprayer)	Flush	12-DEC-2023	5.380	ug/L
51361	51361-1-E-KIT-KS05	Kitchen Dish Sink (Sprayer)	Initial	03-APR-2024	1.000	ug/L
51361	51361-1-E-KIT-KS05	Kitchen Dish Sink (Sprayer)	Initial	12-DEC-2023	5.900	ug/L
51361	51361-1-N-KIT-KS01	Kitchen Left Prep Sink	Flush	12-DEC-2023	2.020	ug/L
51361	51361-1-N-KIT-KS01	Kitchen Left Prep Sink	Flush	12-DEC-2023	1.310	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51361	51361-1-N-KIT-KS01	Kitchen Left Prep Sink	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-N-KIT-KS01	Kitchen Left Prep Sink	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-N-KIT-KS01	Kitchen Left Prep Sink	Flush180	26-MAY-16	2.360	ppb
51361	51361-1-N-KIT-KS01	Kitchen Left Prep Sink	Flush180	26-MAY-16	0.975	ppb
51361	51361-1-N-KIT-KS01	Kitchen Left Prep Sink	Flush180	26-MAY-16	0.809	ppb
51361	51361-1-N-KIT-KS01	Kitchen Left Prep Sink	Flush180	26-MAY-16	1.900	ppb
51361	51361-1-N-KIT-KS01	Kitchen Left Prep Sink	Flush180	18-AUG-16	1.000	ppb
51361	51361-1-N-KIT-KS01	Kitchen Left Prep Sink	Flush180	18-AUG-16	1.000	ppb
51361	51361-1-N-KIT-KS01	Kitchen Left Prep Sink	Flush180	18-AUG-16	6.000	ppb
51361	51361-1-N-KIT-KS01	Kitchen Left Prep Sink	Flush180	18-AUG-16	2.200	ppb
51361	51361-1-N-KIT-KS01	Kitchen Left Prep Sink	Flush180	05-JAN-21	1.000	ug/L
51361	51361-1-N-KIT-KS01	Kitchen Left Prep Sink	Initial	18-AUG-16	3.600	ppb
51361	51361-1-N-KIT-KS01	Kitchen Left Prep Sink	Initial	26-MAY-16	2.340	ppb
51361	51361-1-N-KIT-KS01	Kitchen Left Prep Sink	Initial	05-JAN-21	1.000	ug/L
51361	51361-1-N-KIT-KS01	Kitchen Left Prep Sink	Initial	12-DEC-2023	1.000	ug/L
51361	51361-1-N-KIT-KS02	Kitchen Right Prep Sink	Flush	03-APR-2024	46.800	ug/L
51361	51361-1-N-KIT-KS02	Kitchen Right Prep Sink	Flush	03-APR-2024	101.000	ug/L
51361	51361-1-N-KIT-KS02	Kitchen Right Prep Sink	Flush	03-APR-2024	310.000	ug/L
51361	51361-1-N-KIT-KS02	Kitchen Right Prep Sink	Flush	03-APR-2024	192.000	ug/L
51361	51361-1-N-KIT-KS02	Kitchen Right Prep Sink	Flush	08-MAY-2024	103.000	ug/L
51361	51361-1-N-KIT-KS02	Kitchen Right Prep Sink	Flush	08-MAY-2024	4.940	ug/L
51361	51361-1-N-KIT-KS02	Kitchen Right Prep Sink	Flush	08-MAY-2024	107.000	ug/L
51361	51361-1-N-KIT-KS02	Kitchen Right Prep Sink	Flush	08-MAY-2024	2.200	ug/L
51361	51361-1-N-KIT-KS02	Kitchen Right Prep Sink	Flush	04-JAN-2024	1.000	ug/L
51361	51361-1-N-KIT-KS02	Kitchen Right Prep Sink	Flush	04-JAN-2024	1.000	ug/L
51361	51361-1-N-KIT-KS02	Kitchen Right Prep Sink	Flush	04-JAN-2024	1.020	ug/L
51361	51361-1-N-KIT-KS02	Kitchen Right Prep Sink	Flush	04-JAN-2024	1.000	ug/L
51361	51361-1-N-KIT-KS02	Kitchen Right Prep Sink	Flush	12-DEC-2023	30.600	ug/L
51361	51361-1-N-KIT-KS02	Kitchen Right Prep Sink	Flush	12-DEC-2023	9.790	ug/L
51361	51361-1-N-KIT-KS02	Kitchen Right Prep Sink	Flush	12-DEC-2023	9.090	ug/L
51361	51361-1-N-KIT-KS02	Kitchen Right Prep Sink	Flush	12-DEC-2023	37.800	ug/L
51361	51361-1-N-KIT-KS02	Kitchen Right Prep Sink	Flush180	18-AUG-16	2.600	ppb
51361	51361-1-N-KIT-KS02	Kitchen Right Prep Sink	Flush180	18-AUG-16	7.000	ppb
51361	51361-1-N-KIT-KS02	Kitchen Right Prep Sink	Flush180	18-AUG-16	6.700	ppb
51361	51361-1-N-KIT-KS02	Kitchen Right Prep Sink	Flush180	18-AUG-16	2.700	ppb
51361	51361-1-N-KIT-KS02	Kitchen Right Prep Sink	Initial	18-AUG-16	9.000	ppb
51361	51361-1-N-KIT-KS02	Kitchen Right Prep Sink	Initial	03-APR-2024	45.200	ug/L
51361	51361-1-N-KIT-KS02	Kitchen Right Prep Sink	Initial	08-MAY-2024	53.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KIT-KS02					
51361	51361-1-N-KIT-KS02	Kitchen Right Prep Sink	Initial	04-JAN-2024	8.420	ug/L
51361	51361-1-N-KIT-KS02	Kitchen Right Prep Sink	Initial	12-DEC-2023	98.000	ug/L
51361	51361-1-KIT-KS04	Kitchen Soup Sink	Flush180	25-AUG-23	5.510	ug/L
51361	51361-1-KIT-KS04	Kitchen Soup Sink	Flush180	25-AUG-23	2.420	ug/L
51361	51361-1-KIT-KS04	Kitchen Soup Sink	Flush180	25-AUG-23	3.160	ug/L
51361	51361-1-KIT-KS04	Kitchen Soup Sink	Flush180	25-AUG-23	2.150	ug/L
51361	51361-1-KIT-KS04	Kitchen Soup Sink	Initial	25-AUG-23	6.800	ug/L
51361	51361-1-KIT-KS04	Kitchen Soup Sink	Initial	26-MAY-16	7.660	ppb
51361	51361-1-S-KIT-KS03	Kitchen Wash Sink	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-S-KIT-KS03	Kitchen Wash Sink	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-S-KIT-KS03	Kitchen Wash Sink	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-S-KIT-KS03	Kitchen Wash Sink	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-S-KIT-KS03	Kitchen Wash Sink	Flush180	26-MAY-16	402.000	ppb
51361	51361-1-S-KIT-KS03	Kitchen Wash Sink	Flush180	26-MAY-16	403.000	ppb
51361	51361-1-S-KIT-KS03	Kitchen Wash Sink	Flush180	26-MAY-16	174.000	ppb
51361	51361-1-S-KIT-KS03	Kitchen Wash Sink	Flush180	26-MAY-16	87.300	ppb
51361	51361-1-S-KIT-KS03	Kitchen Wash Sink	Flush180	21-JUL-16	9.770	ppb
51361	51361-1-S-KIT-KS03	Kitchen Wash Sink	Flush180	21-JUL-16	7.090	ppb
51361	51361-1-S-KIT-KS03	Kitchen Wash Sink	Flush180	21-JUL-16	3.000	ppb
51361	51361-1-S-KIT-KS03	Kitchen Wash Sink	Flush180	21-JUL-16	3.660	ppb
51361	51361-1-S-KIT-KS03	Kitchen Wash Sink	Flush180	18-AUG-16	1.000	ppb
51361	51361-1-S-KIT-KS03	Kitchen Wash Sink	Flush180	18-AUG-16	4.800	ppb
51361	51361-1-S-KIT-KS03	Kitchen Wash Sink	Flush180	18-AUG-16	1.000	ppb
51361	51361-1-S-KIT-KS03	Kitchen Wash Sink	Flush180	18-AUG-16	2.400	ppb
51361	51361-1-S-KIT-KS03	Kitchen Wash Sink	Flush180	22-SEP-17	10.500	ppb
51361	51361-1-S-KIT-KS03	Kitchen Wash Sink	Flush180	22-SEP-17	22.400	ppb
51361	51361-1-S-KIT-KS03	Kitchen Wash Sink	Flush180	22-SEP-17	52.600	ppb
51361	51361-1-S-KIT-KS03	Kitchen Wash Sink	Flush180	22-SEP-17	18.900	ppb
51361	51361-1-S-KIT-KS03	Kitchen Wash Sink	Flush180	05-JAN-21	1.000	ug/L
51361	51361-1-S-KIT-KS03	Kitchen Wash Sink	Initial	26-MAY-16	7.770	ppb
51361	51361-1-S-KIT-KS03	Kitchen Wash Sink	Initial	21-JUL-16	30.000	ppb
51361	51361-1-S-KIT-KS03	Kitchen Wash Sink	Initial	18-AUG-16	6.400	ppb
51361	51361-1-S-KIT-KS03	Kitchen Wash Sink	Initial	22-SEP-17	83.800	ppb
51361	51361-1-S-KIT-KS03	Kitchen Wash Sink	Initial	05-JAN-21	1.000	ug/L
51361	51361-1-S-KIT-KS03	Kitchen Wash Sink	Initial	12-DEC-2023	1.000	ug/L
51361	51361-1-S-KIT-KS04	Kitchen dish sink right	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-S-	Kitchen dish sink right	Flush	12-DEC-2023	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KIT-KS04					
51361	51361-1-S-KIT-KS04	Kitchen dish sink right	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-S-KIT-KS04	Kitchen dish sink right	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-S-KIT-KS04	Kitchen dish sink right	Flush180	26-MAY-16	1.120	ppb
51361	51361-1-S-KIT-KS04	Kitchen dish sink right	Flush180	26-MAY-16	3.660	ppb
51361	51361-1-S-KIT-KS04	Kitchen dish sink right	Flush180	26-MAY-16	2.030	ppb
51361	51361-1-S-KIT-KS04	Kitchen dish sink right	Flush180	26-MAY-16	2.270	ppb
51361	51361-1-S-KIT-KS04	Kitchen dish sink right	Initial	12-DEC-2023	1.000	ug/L
51361	51361-1-E-HAL-F01	Left Fountain, Outside Door 1	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-E-HAL-F01	Left Fountain, Outside Door 1	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-E-HAL-F01	Left Fountain, Outside Door 1	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-E-HAL-F01	Left Fountain, Outside Door 1	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-E-HAL-F01	Left Fountain, Outside Door 1	Initial	12-DEC-2023	1.000	ug/L
51361	51361-1-W-CAF-F01	Lunchroom, North Fountain	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-W-CAF-F01	Lunchroom, North Fountain	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-W-CAF-F01	Lunchroom, North Fountain	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-W-CAF-F01	Lunchroom, North Fountain	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-W-CAF-F01	Lunchroom, North Fountain	Flush180	26-MAY-16	0.551	ppb
51361	51361-1-W-CAF-F01	Lunchroom, North Fountain	Flush180	26-MAY-16	0.740	ppb
51361	51361-1-W-CAF-F01	Lunchroom, North Fountain	Flush180	26-MAY-16	1.120	ppb
51361	51361-1-W-CAF-F01	Lunchroom, North Fountain	Flush180	26-MAY-16	1.240	ppb
51361	51361-1-W-CAF-F01	Lunchroom, North Fountain	Initial	26-MAY-16	0.422	ppb
51361	51361-1-W-CAF-F01	Lunchroom, North Fountain	Initial	12-DEC-2023	1.000	ug/L
51361	51361-1-W-CAF-BF01	Lunchroom, South Bottle Filler	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-W-CAF-BF01	Lunchroom, South Bottle Filler	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-W-CAF-BF01	Lunchroom, South Bottle Filler	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-W-CAF-BF01	Lunchroom, South Bottle Filler	Initial	12-DEC-2023	1.000	ug/L
51361	51361-1-W-CAF-F02	Lunchroom, South Fountain	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-W-CAF-F02	Lunchroom, South Fountain	Flush	12-DEC-2023	1.890	ug/L
51361	51361-1-W-CAF-F02	Lunchroom, South Fountain	Flush	12-DEC-2023	1.480	ug/L
51361	51361-1-W-CAF-F02	Lunchroom, South Fountain	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-W-CAF-F02	Lunchroom, South Fountain	Flush180	26-MAY-16	0.994	ppb
51361	51361-1-W-CAF-F02	Lunchroom, South Fountain	Flush180	26-MAY-16	1.030	ppb
51361	51361-1-W-CAF-F02	Lunchroom, South Fountain	Flush180	26-MAY-16	1.040	ppb
51361	51361-1-W-CAF-F02	Lunchroom, South Fountain	Flush180	26-MAY-16	1.050	ppb
51361	51361-1-W-CAF-F02	Lunchroom, South Fountain	Flush180	20-OCT-20	1.000	ug/L
51361	51361-1-W-CAF-F02	Lunchroom, South Fountain	Initial	26-MAY-16	0.935	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51361	51361-1-W-CAF-F02	Lunchroom, South Fountain	Initial	20-OCT-20	2.600	ug/L
51361	51361-1-W-CAF-F02	Lunchroom, South Fountain	Initial	12-DEC-2023	2.350	ug/L
51361	51361-1-E-HAL-F01	N Fountain, Outside Door 1	Flush180	26-MAY-16	0.136	ppb
51361	51361-1-E-HAL-F01	N Fountain, Outside Door 1	Flush180	26-MAY-16	0.132	ppb
51361	51361-1-E-HAL-F01	N Fountain, Outside Door 1	Flush180	26-MAY-16	1.000	ppb
51361	51361-1-E-HAL-F01	N Fountain, Outside Door 1	Flush180	26-MAY-16	1.000	ppb
51361	51361-1-E-HAL-F01	N Fountain, Outside Door 1	Initial	26-MAY-16	1.000	ppb
51361	51361-1-CAF-F03	N. Cafeteria, Across Rm 174 Fountain	Flush	12-DEC-2023	2.090	ug/L
51361	51361-1-CAF-F03	N. Cafeteria, Across Rm 174 Fountain	Flush	12-DEC-2023	2.570	ug/L
51361	51361-1-CAF-F03	N. Cafeteria, Across Rm 174 Fountain	Flush	12-DEC-2023	2.680	ug/L
51361	51361-1-CAF-F03	N. Cafeteria, Across Rm 174 Fountain	Flush	12-DEC-2023	2.340	ug/L
51361	51361-1-CAF-F03	N. Cafeteria, Across Rm 174 Fountain	Initial	12-DEC-2023	1.740	ug/L
51361	51361-2-E-HAL-F04	North Fountain, Outside Band Room	Flush	12-DEC-2023	1.000	ug/L
51361	51361-2-E-HAL-F04	North Fountain, Outside Band Room	Flush	12-DEC-2023	1.000	ug/L
51361	51361-2-E-HAL-F04	North Fountain, Outside Band Room	Flush	12-DEC-2023	1.000	ug/L
51361	51361-2-E-HAL-F04	North Fountain, Outside Band Room	Flush	12-DEC-2023	1.000	ug/L
51361	51361-2-E-HAL-F04	North Fountain, Outside Band Room	Flush180	26-MAY-16	0.971	ppb
51361	51361-2-E-HAL-F04	North Fountain, Outside Band Room	Flush180	26-MAY-16	0.532	ppb
51361	51361-2-E-HAL-F04	North Fountain, Outside Band Room	Flush180	26-MAY-16	0.176	ppb
51361	51361-2-E-HAL-F04	North Fountain, Outside Band Room	Flush180	26-MAY-16	0.735	ppb
51361	51361-2-E-HAL-F04	North Fountain, Outside Band Room	Initial	26-MAY-16	0.151	ppb
51361	51361-2-E-HAL-F04	North Fountain, Outside Band Room	Initial	12-DEC-2023	1.000	ug/L
51361	51361-1-E-HAL-F06	North Fountain, Outside Door 6	Flush180	26-MAY-16	0.188	ppb
51361	51361-1-E-HAL-F06	North Fountain, Outside Door 6	Flush180	26-MAY-16	1.000	ppb
51361	51361-1-E-HAL-F06	North Fountain, Outside Door 6	Flush180	26-MAY-16	0.176	ppb
51361	51361-1-E-HAL-F06	North Fountain, Outside Door 6	Flush180	26-MAY-16	1.000	ppb
51361	51361-1-E-HAL-F06	North Fountain, Outside Door 6	Initial	26-MAY-16	0.153	ppb
51361	51361-2-E-HAL-F01	North Fountain, Outside Room 236	Flush	12-DEC-2023	1.000	ug/L
51361	51361-2-E-HAL-F01	North Fountain, Outside Room 236	Flush	12-DEC-2023	1.000	ug/L
51361	51361-2-E-HAL-F01	North Fountain, Outside Room 236	Flush	12-DEC-2023	1.000	ug/L
51361	51361-2-E-HAL-F01	North Fountain, Outside Room 236	Flush	12-DEC-2023	1.000	ug/L
51361	51361-2-E-HAL-F01	North Fountain, Outside Room 236	Flush180	26-MAY-16	1.550	ppb
51361	51361-2-E-HAL-F01	North Fountain, Outside Room 236	Flush180	26-MAY-16	1.240	ppb
51361	51361-2-E-HAL-F01	North Fountain, Outside Room 236	Flush180	26-MAY-16	1.300	ppb
51361	51361-2-E-HAL-F01	North Fountain, Outside Room 236	Flush180	26-MAY-16	2.280	ppb
51361	51361-2-E-HAL-F03	North Fountain, Outside Room 236	Flush180	26-MAY-16	0.455	ppb
51361	51361-2-E-HAL-F03	North Fountain, Outside Room 236	Flush180	26-MAY-16	0.132	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51361	51361-2-E-HAL-F03	North Fountain, Outside Room 236	Flush180	26-MAY-16	0.410	ppb
51361	51361-2-E-HAL-F03	North Fountain, Outside Room 236	Flush180	26-MAY-16	0.183	ppb
51361	51361-2-E-HAL-F01	North Fountain, Outside Room 236	Initial	26-MAY-16	1.140	ppb
51361	51361-2-E-HAL-F03	North Fountain, Outside Room 236	Initial	26-MAY-16	0.305	ppb
51361	51361-2-E-HAL-F01	North Fountain, Outside Room 236	Initial	12-DEC-2023	1.000	ug/L
51361	51361-1-E-POOL-F02	Pool Area Boy's Bathroom Fountain	Flush	12-DEC-2023	2.340	ug/L
51361	51361-1-E-POOL-F02	Pool Area Boy's Bathroom Fountain	Flush	12-DEC-2023	2.690	ug/L
51361	51361-1-E-POOL-F02	Pool Area Boy's Bathroom Fountain	Flush	12-DEC-2023	2.860	ug/L
51361	51361-1-E-POOL-F02	Pool Area Boy's Bathroom Fountain	Flush	12-DEC-2023	3.120	ug/L
51361	51361-1-E-POOL-F02	Pool Area Boy's Bathroom Fountain	Flush180	26-MAY-16	1.640	ppb
51361	51361-1-E-POOL-F02	Pool Area Boy's Bathroom Fountain	Flush180	26-MAY-16	2.000	ppb
51361	51361-1-E-POOL-F02	Pool Area Boy's Bathroom Fountain	Flush180	26-MAY-16	2.140	ppb
51361	51361-1-E-POOL-F02	Pool Area Boy's Bathroom Fountain	Flush180	26-MAY-16	1.200	ppb
51361	51361-1-E-POOL-F02	Pool Area Boy's Bathroom Fountain	Initial	26-MAY-16	0.858	ppb
51361	51361-1-E-POOL-F02	Pool Area Boy's Bathroom Fountain	Initial	12-DEC-2023	1.080	ug/L
51361	51361-1-S-POOL-F01	Pool Area Fountain	Flush180	08-SEP-16	2.300	ppb
51361	51361-1-S-POOL-F01	Pool Area Fountain	Flush180	08-SEP-16	5.100	ppb
51361	51361-1-S-POOL-F01	Pool Area Fountain	Flush180	08-SEP-16	2.300	ppb
51361	51361-1-S-POOL-F01	Pool Area Fountain	Flush180	26-MAY-16	2.490	ppb
51361	51361-1-S-POOL-F01	Pool Area Fountain	Flush180	26-MAY-16	1.830	ppb
51361	51361-1-S-POOL-F01	Pool Area Fountain	Flush180	26-MAY-16	10.000	ppb
51361	51361-1-S-POOL-F01	Pool Area Fountain	Flush180	26-MAY-16	3.350	ppb
51361	51361-1-S-POOL-F01	Pool Area Fountain	Flush180	21-JUL-16	2.070	ppb
51361	51361-1-S-POOL-F01	Pool Area Fountain	Flush180	21-JUL-16	4.800	ppb
51361	51361-1-S-POOL-F01	Pool Area Fountain	Flush180	21-JUL-16	3.350	ppb
51361	51361-1-S-POOL-F01	Pool Area Fountain	Flush180	21-JUL-16	2.080	ppb
51361	51361-1-S-POOL-F01	Pool Area Fountain	Flush180	08-SEP-17	3.950	ppb
51361	51361-1-S-POOL-F01	Pool Area Fountain	Flush180	08-SEP-17	2.110	ppb
51361	51361-1-S-POOL-F01	Pool Area Fountain	Flush180	08-SEP-17	4.810	ppb
51361	51361-1-S-POOL-F01	Pool Area Fountain	Flush180	08-SEP-17	8.450	ppb
51361	51361-1-S-POOL-F01	Pool Area Fountain	Flush180	22-SEP-17	3.310	ppb
51361	51361-1-S-POOL-F01	Pool Area Fountain	Flush180	22-SEP-17	1.000	ppb
51361	51361-1-S-POOL-F01	Pool Area Fountain	Flush180	22-SEP-17	1.000	ppb
51361	51361-1-S-POOL-F01	Pool Area Fountain	Flush180	22-SEP-17	18.800	ppb
51361	51361-1-S-POOL-F01	Pool Area Fountain	Flush180	18-AUG-16	1.000	ppb
51361	51361-1-S-POOL-F01	Pool Area Fountain	Flush180	18-AUG-16	1.000	ppb
51361	51361-1-S-POOL-F01	Pool Area Fountain	Flush180	18-AUG-16	1.000	ppb
51361	51361-1-S-	Pool Area Fountain	Flush180	18-AUG-16	3.500	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	POOL-F01					
51361	51361-1-S-POOL-F01	Pool Area Fountain	Flush180	08-SEP-16	3.700	ppb
51361	51361-1-S-POOL-F01	Pool Area Fountain	Initial	21-JUL-16	24.800	ppb
51361	51361-1-S-POOL-F01	Pool Area Fountain	Initial	26-MAY-16	65.600	ppb
51361	51361-1-S-POOL-F01	Pool Area Fountain	Initial	18-AUG-16	16.000	ppb
51361	51361-1-S-POOL-F01	Pool Area Fountain	Initial	08-SEP-17	19.600	ppb
51361	51361-1-S-POOL-F01	Pool Area Fountain	Initial	22-SEP-17	1.000	ppb
51361	51361-1-S-POOL-F01	Pool Area Fountain	Initial	08-SEP-16	33.000	ppb
51361	51361-1-E-HAL-F02	Right Fountain, Outside Door 1	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-E-HAL-F02	Right Fountain, Outside Door 1	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-E-HAL-F02	Right Fountain, Outside Door 1	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-E-HAL-F02	Right Fountain, Outside Door 1	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-E-HAL-F02	Right Fountain, Outside Door 1	Initial	12-DEC-2023	1.000	ug/L
51361	51361-1-E-HAL-F06	Right Fountain, Outside Door 6	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-E-HAL-F06	Right Fountain, Outside Door 6	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-E-HAL-F06	Right Fountain, Outside Door 6	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-E-HAL-F06	Right Fountain, Outside Door 6	Flush	12-DEC-2023	1.000	ug/L
51361	51361-1-E-HAL-F06	Right Fountain, Outside Door 6	Initial	12-DEC-2023	1.340	ug/L
51361	51361-2-E-HAL-F06	South Fountain, Outside Band Room	Flush	12-DEC-2023	1.000	ug/L
51361	51361-2-E-HAL-F06	South Fountain, Outside Band Room	Flush	12-DEC-2023	1.000	ug/L
51361	51361-2-E-HAL-F06	South Fountain, Outside Band Room	Flush	12-DEC-2023	1.000	ug/L
51361	51361-2-E-HAL-F06	South Fountain, Outside Band Room	Flush	12-DEC-2023	1.000	ug/L
51361	51361-2-E-HAL-F06	South Fountain, Outside Band Room	Flush180	26-MAY-16	1.180	ppb
51361	51361-2-E-HAL-F06	South Fountain, Outside Band Room	Flush180	26-MAY-16	1.330	ppb
51361	51361-2-E-HAL-F06	South Fountain, Outside Band Room	Flush180	26-MAY-16	2.640	ppb
51361	51361-2-E-HAL-F06	South Fountain, Outside Band Room	Flush180	26-MAY-16	1.100	ppb
51361	51361-2-E-HAL-F06	South Fountain, Outside Band Room	Initial	26-MAY-16	1.140	ppb
51361	51361-2-E-HAL-F06	South Fountain, Outside Band Room	Initial	12-DEC-2023	1.730	ug/L
51361	51361-1-E-HAL-F04	South Fountain, Outside Door 6	Flush180	26-MAY-16	0.393	ppb
51361	51361-1-E-HAL-F04	South Fountain, Outside Door 6	Flush180	26-MAY-16	0.539	ppb
51361	51361-1-E-HAL-F04	South Fountain, Outside Door 6	Flush180	26-MAY-16	0.922	ppb
51361	51361-1-E-HAL-F04	South Fountain, Outside Door 6	Flush180	26-MAY-16	0.346	ppb
51361	51361-1-E-HAL-F04	South Fountain, Outside Door 6	Flush180	22-JAN-21	1.380	ug/L
51361	51361-1-E-HAL-F04	South Fountain, Outside Door 6	Flush180	22-JAN-21	1.280	ug/L
51361	51361-1-E-HAL-F04	South Fountain, Outside Door 6	Flush180	22-JAN-21	1.000	ug/L
51361	51361-1-E-HAL-F04	South Fountain, Outside Door 6	Flush180	22-JAN-21	1.000	ug/L
51361	51361-1-E-HAL-F04	South Fountain, Outside Door 6	Flush180	05-JAN-21	2.660	ug/L
51361	51361-1-E-	South Fountain, Outside Door 6	Flush180	20-OCT-20	1.590	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F04					
51361	51361-1-E-HAL-F04	South Fountain, Outside Door 6	Initial	26-MAY-16	2.980	ppb
51361	51361-1-E-HAL-F04	South Fountain, Outside Door 6	Initial	22-JAN-21	3.320	ug/L
51361	51361-1-E-HAL-F04	South Fountain, Outside Door 6	Initial	05-JAN-21	5.360	ug/L
51361	51361-1-E-HAL-F04	South Fountain, Outside Door 6	Initial	20-OCT-20	1.300	ug/L
51361	51361-2-E-HAL-F03	South Fountain, Outside Room 236	Flush	12-DEC-2023	1.000	ug/L
51361	51361-2-E-HAL-F03	South Fountain, Outside Room 236	Flush	12-DEC-2023	1.000	ug/L
51361	51361-2-E-HAL-F03	South Fountain, Outside Room 236	Flush	12-DEC-2023	1.000	ug/L
51361	51361-2-E-HAL-F03	South Fountain, Outside Room 236	Flush	12-DEC-2023	1.000	ug/L
51361	51361-2-E-HAL-F03	South Fountain, Outside Room 236	Initial	12-DEC-2023	1.000	ug/L
51361	51361-1-E-POOL-F01	pool area fountain	Flush	08-MAY-2024	16.900	ug/L
51361	51361-1-E-POOL-F01	pool area fountain	Flush	08-MAY-2024	7.610	ug/L
51361	51361-1-E-POOL-F01	pool area fountain	Flush	03-APR-2024	7.050	ug/L
51361	51361-1-E-POOL-F01	pool area fountain	Flush	03-APR-2024	4.260	ug/L
51361	51361-1-E-POOL-F01	pool area fountain	Flush	08-MAY-2024	29.500	ug/L
51361	51361-1-E-POOL-F01	pool area fountain	Flush	04-JAN-2024	13.800	ug/L
51361	51361-1-E-POOL-F01	pool area fountain	Flush	04-JAN-2024	18.500	ug/L
51361	51361-1-E-POOL-F01	pool area fountain	Flush	04-JAN-2024	15.800	ug/L
51361	51361-1-E-POOL-F01	pool area fountain	Flush	04-JAN-2024	9.420	ug/L
51361	51361-1-E-POOL-F01	pool area fountain	Flush	03-APR-2024	3.220	ug/L
51361	51361-1-E-POOL-F01	pool area fountain	Flush	03-APR-2024	6.700	ug/L
51361	51361-1-E-POOL-F01	pool area fountain	Flush	08-MAY-2024	31.900	ug/L
51361	51361-1-E-POOL-F01	pool area fountain	Initial	03-APR-2024	9.550	ug/L
51361	51361-1-E-POOL-F01	pool area fountain	Initial	04-JAN-2024	16.100	ug/L
51361	51361-1-E-POOL-F01	pool area fountain	Initial	08-MAY-2024	4.990	ug/L
51368	51368-1-CAF-S01	ANNEX	Flush180	17-DEC-20	1.520	ug/L
51368	51368-1-CAF-S01	ANNEX	Flush180	17-DEC-20	1.980	ug/L
51368	51368-1-CAF-S01	ANNEX	Flush180	17-DEC-20	2.040	ug/L
51368	51368-1-CAF-S01	ANNEX	Flush180	17-DEC-20	2.170	ug/L
51368	51368-1-CAF-S01	ANNEX	Initial	17-DEC-20	1.060	ug/L
51368	51368-1-ANX-S01	Annex Inside Parent Room, Sink	Flush	12-DEC-2023	3.030	ug/L
51368	51368-1-ANX-S01	Annex Inside Parent Room, Sink	Flush	12-DEC-2023	1.330	ug/L
51368	51368-1-ANX-S01	Annex Inside Parent Room, Sink	Flush	12-DEC-2023	1.000	ug/L
51368	51368-1-ANX-S01	Annex Inside Parent Room, Sink	Flush	12-DEC-2023	1.000	ug/L
51368	51368-1-ANX-S01	Annex Inside Parent Room, Sink	Flush180	26-MAY-16	0.942	ppb
51368	51368-1-ANX-S01	Annex Inside Parent Room, Sink	Flush180	26-MAY-16	0.618	ppb
51368	51368-1-ANX-S01	Annex Inside Parent Room, Sink	Flush180	26-MAY-16	0.906	ppb
51368	51368-1-ANX-S01	Annex Inside Parent Room, Sink	Flush180	26-MAY-16	1.380	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51368	51368-1-ANX-S01	Annex Inside Parent Room, Sink	Initial	26-MAY-16	1.290	ppb
51368	51368-1-ANX-S01	Annex Inside Parent Room, Sink	Initial	12-DEC-2023	3.600	ug/L
51368	51368-1-S-001-S01	Annex Inside Room 1, Sink	Flush	12-DEC-2023	1.290	ug/L
51368	51368-1-S-001-S01	Annex Inside Room 1, Sink	Flush	12-DEC-2023	1.150	ug/L
51368	51368-1-S-001-S01	Annex Inside Room 1, Sink	Flush	12-DEC-2023	1.000	ug/L
51368	51368-1-S-001-S01	Annex Inside Room 1, Sink	Flush	12-DEC-2023	1.010	ug/L
51368	51368-1-S-001-S01	Annex Inside Room 1, Sink	Flush180	26-MAY-16	0.856	ppb
51368	51368-1-S-001-S01	Annex Inside Room 1, Sink	Flush180	26-MAY-16	1.020	ppb
51368	51368-1-S-001-S01	Annex Inside Room 1, Sink	Flush180	26-MAY-16	0.985	ppb
51368	51368-1-S-001-S01	Annex Inside Room 1, Sink	Flush180	26-MAY-16	0.921	ppb
51368	51368-1-S-001-S01	Annex Inside Room 1, Sink	Initial	26-MAY-16	0.972	ppb
51368	51368-1-S-001-S01	Annex Inside Room 1, Sink	Initial	12-DEC-2023	1.000	ug/L
51368	51368-1-N-002-S01	Annex Inside Room 2, Sink	Flush	12-DEC-2023	1.220	ug/L
51368	51368-1-N-002-S01	Annex Inside Room 2, Sink	Flush	12-DEC-2023	1.070	ug/L
51368	51368-1-N-002-S01	Annex Inside Room 2, Sink	Flush	12-DEC-2023	1.100	ug/L
51368	51368-1-N-002-S01	Annex Inside Room 2, Sink	Flush	12-DEC-2023	1.000	ug/L
51368	51368-1-N-002-S01	Annex Inside Room 2, Sink	Flush180	26-MAY-16	0.970	ppb
51368	51368-1-N-002-S01	Annex Inside Room 2, Sink	Flush180	26-MAY-16	0.905	ppb
51368	51368-1-N-002-S01	Annex Inside Room 2, Sink	Flush180	26-MAY-16	0.982	ppb
51368	51368-1-N-002-S01	Annex Inside Room 2, Sink	Flush180	26-MAY-16	0.982	ppb
51368	51368-1-N-002-S01	Annex Inside Room 2, Sink	Initial	26-MAY-16	1.300	ppb
51368	51368-1-N-002-S01	Annex Inside Room 2, Sink	Initial	12-DEC-2023	1.000	ug/L
51368	51368-1-N-003-S01	Annex Inside Room 3, Sink	Flush	12-DEC-2023	1.610	ug/L
51368	51368-1-N-003-S01	Annex Inside Room 3, Sink	Flush	12-DEC-2023	1.270	ug/L
51368	51368-1-N-003-S01	Annex Inside Room 3, Sink	Flush	12-DEC-2023	1.000	ug/L
51368	51368-1-N-003-S01	Annex Inside Room 3, Sink	Flush	12-DEC-2023	1.000	ug/L
51368	51368-1-N-003-S01	Annex Inside Room 3, Sink	Flush180	26-MAY-16	2.720	ppb
51368	51368-1-N-003-S01	Annex Inside Room 3, Sink	Flush180	26-MAY-16	1.550	ppb
51368	51368-1-N-003-S01	Annex Inside Room 3, Sink	Flush180	26-MAY-16	4.820	ppb
51368	51368-1-N-003-S01	Annex Inside Room 3, Sink	Flush180	26-MAY-16	1.510	ppb
51368	51368-1-N-003-S01	Annex Inside Room 3, Sink	Initial	26-MAY-16	1.380	ppb
51368	51368-1-N-003-S01	Annex Inside Room 3, Sink	Initial	12-DEC-2023	1.130	ug/L
51368	51368-1-N-004-S01	Annex Inside Room 4, Sink	Flush	12-DEC-2023	1.570	ug/L
51368	51368-1-N-004-S01	Annex Inside Room 4, Sink	Flush	12-DEC-2023	1.430	ug/L
51368	51368-1-N-004-S01	Annex Inside Room 4, Sink	Flush	12-DEC-2023	1.450	ug/L
51368	51368-1-N-004-S01	Annex Inside Room 4, Sink	Flush	12-DEC-2023	1.450	ug/L
51368	51368-1-N-004-S01	Annex Inside Room 4, Sink	Flush180	26-MAY-16	0.486	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51368	51368-1-N-004-S01	Annex Inside Room 4, Sink	Flush180	26-MAY-16	0.570	ppb
51368	51368-1-N-004-S01	Annex Inside Room 4, Sink	Flush180	26-MAY-16	0.787	ppb
51368	51368-1-N-004-S01	Annex Inside Room 4, Sink	Flush180	26-MAY-16	0.833	ppb
51368	51368-1-N-004-S01	Annex Inside Room 4, Sink	Flush180	20-OCT-20	2.990	ug/L
51368	51368-1-N-004-S01	Annex Inside Room 4, Sink	Initial	26-MAY-16	0.785	ppb
51368	51368-1-N-004-S01	Annex Inside Room 4, Sink	Initial	20-OCT-20	2.100	ug/L
51368	51368-1-N-004-S01	Annex Inside Room 4, Sink	Initial	12-DEC-2023	2.410	ug/L
51368	51368-1-N-005-S01	Annex Inside Room 5, Sink	Flush	12-DEC-2023	1.490	ug/L
51368	51368-1-N-005-S01	Annex Inside Room 5, Sink	Flush	12-DEC-2023	1.570	ug/L
51368	51368-1-N-005-S01	Annex Inside Room 5, Sink	Flush	12-DEC-2023	1.480	ug/L
51368	51368-1-N-005-S01	Annex Inside Room 5, Sink	Flush	12-DEC-2023	1.440	ug/L
51368	51368-1-N-005-S01	Annex Inside Room 5, Sink	Flush180	26-MAY-16	1.200	ppb
51368	51368-1-N-005-S01	Annex Inside Room 5, Sink	Flush180	26-MAY-16	1.360	ppb
51368	51368-1-N-005-S01	Annex Inside Room 5, Sink	Flush180	26-MAY-16	1.340	ppb
51368	51368-1-N-005-S01	Annex Inside Room 5, Sink	Flush180	26-MAY-16	1.300	ppb
51368	51368-1-N-005-S01	Annex Inside Room 5, Sink	Initial	26-MAY-16	1.710	ppb
51368	51368-1-N-005-S01	Annex Inside Room 5, Sink	Initial	12-DEC-2023	1.140	ug/L
51368	51368-1-S-006-S01	Annex Inside Room 6, Sink	Flush	12-DEC-2023	1.510	ug/L
51368	51368-1-S-006-S01	Annex Inside Room 6, Sink	Flush	12-DEC-2023	1.000	ug/L
51368	51368-1-S-006-S01	Annex Inside Room 6, Sink	Flush	12-DEC-2023	1.000	ug/L
51368	51368-1-S-006-S01	Annex Inside Room 6, Sink	Flush	12-DEC-2023	1.250	ug/L
51368	51368-1-S-006-S01	Annex Inside Room 6, Sink	Flush180	26-MAY-16	1.220	ppb
51368	51368-1-S-006-S01	Annex Inside Room 6, Sink	Flush180	26-MAY-16	1.210	ppb
51368	51368-1-S-006-S01	Annex Inside Room 6, Sink	Flush180	26-MAY-16	1.190	ppb
51368	51368-1-S-006-S01	Annex Inside Room 6, Sink	Flush180	26-MAY-16	1.300	ppb
51368	51368-1-S-006-S01	Annex Inside Room 6, Sink	Initial	26-MAY-16	1.640	ppb
51368	51368-1-S-006-S01	Annex Inside Room 6, Sink	Initial	12-DEC-2023	1.640	ug/L
51368	51368-1-W-TL-S01	Annex Inside Teachers Lounge, Sink	Flush	12-DEC-2023	1.000	ug/L
51368	51368-1-W-TL-S01	Annex Inside Teachers Lounge, Sink	Flush	12-DEC-2023	1.120	ug/L
51368	51368-1-W-TL-S01	Annex Inside Teachers Lounge, Sink	Flush	12-DEC-2023	1.170	ug/L
51368	51368-1-W-TL-S01	Annex Inside Teachers Lounge, Sink	Flush	12-DEC-2023	1.000	ug/L
51368	51368-1-W-TL-S01	Annex Inside Teachers Lounge, Sink	Flush180	26-MAY-16	1.200	ppb
51368	51368-1-W-TL-S01	Annex Inside Teachers Lounge, Sink	Flush180	26-MAY-16	1.160	ppb
51368	51368-1-W-TL-S01	Annex Inside Teachers Lounge, Sink	Flush180	26-MAY-16	1.280	ppb
51368	51368-1-W-TL-S01	Annex Inside Teachers Lounge, Sink	Flush180	26-MAY-16	1.200	ppb
51368	51368-1-W-TL-S01	Annex Inside Teachers Lounge, Sink	Initial	26-MAY-16	1.070	ppb
51368	51368-1-W-TL-S01	Annex Inside Teachers Lounge, Sink	Initial	12-DEC-2023	1.380	ug/L
51368	51368-1-KIT-	Annex Kitchen, Sink	Flush180	26-MAY-16	1.710	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS02					
51368	51368-1-KIT-KS02	Annex Kitchen, Sink	Flush180	26-MAY-16	0.708	ppb
51368	51368-1-KIT-KS02	Annex Kitchen, Sink	Flush180	26-MAY-16	0.792	ppb
51368	51368-1-KIT-KS02	Annex Kitchen, Sink	Flush180	26-MAY-16	1.610	ppb
51368	51368-1-KIT-KS02	Annex Kitchen, Sink	Flush180	22-JAN-21	1.930	ug/L
51368	51368-1-KIT-KS02	Annex Kitchen, Sink	Flush180	22-JAN-21	2.090	ug/L
51368	51368-1-KIT-KS02	Annex Kitchen, Sink	Flush180	05-JAN-21	1.280	ug/L
51368	51368-1-KIT-KS02	Annex Kitchen, Sink	Flush180	22-JAN-21	2.210	ug/L
51368	51368-1-KIT-KS02	Annex Kitchen, Sink	Flush180	22-JAN-21	2.770	ug/L
51368	51368-1-KIT-KS02	Annex Kitchen, Sink	Initial	26-MAY-16	1.220	ppb
51368	51368-1-KIT-KS02	Annex Kitchen, Sink	Initial	05-JAN-21	56.100	ug/L
51368	51368-1-KIT-KS02	Annex Kitchen, Sink	Initial	22-JAN-21	1.800	ug/L
51368	51368-1-S-HAL-F01	Annex Outside Parent Room, Left Fountain	Flush180	26-MAY-16	1.280	ppb
51368	51368-1-S-HAL-F01	Annex Outside Parent Room, Left Fountain	Flush180	26-MAY-16	0.837	ppb
51368	51368-1-S-HAL-F01	Annex Outside Parent Room, Left Fountain	Flush180	26-MAY-16	1.500	ppb
51368	51368-1-S-HAL-F01	Annex Outside Parent Room, Left Fountain	Flush180	26-MAY-16	1.430	ppb
51368	51368-1-S-HAL-F01	Annex Outside Parent Room, Left Fountain	Flush180	05-JAN-21	1.330	ug/L
51368	51368-1-S-HAL-F01	Annex Outside Parent Room, Left Fountain	Flush180	22-JAN-21	1.000	ug/L
51368	51368-1-S-HAL-F01	Annex Outside Parent Room, Left Fountain	Flush180	22-JAN-21	1.000	ug/L
51368	51368-1-S-HAL-F01	Annex Outside Parent Room, Left Fountain	Flush180	22-JAN-21	1.000	ug/L
51368	51368-1-S-HAL-F01	Annex Outside Parent Room, Left Fountain	Initial	26-MAY-16	1.420	ppb
51368	51368-1-S-HAL-F01	Annex Outside Parent Room, Left Fountain	Initial	05-JAN-21	48.500	ug/L
51368	51368-1-S-HAL-F01	Annex Outside Parent Room, Left Fountain	Initial	22-JAN-21	1.000	ug/L
51368	51368-1-S-HAL-F02	Annex Outside Parent Room, Right Fountain	Flush	12-DEC-2023	1.000	ug/L
51368	51368-1-S-HAL-F02	Annex Outside Parent Room, Right Fountain	Flush	12-DEC-2023	1.000	ug/L
51368	51368-1-S-HAL-F02	Annex Outside Parent Room, Right Fountain	Flush	12-DEC-2023	1.000	ug/L
51368	51368-1-S-HAL-F02	Annex Outside Parent Room, Right Fountain	Flush	12-DEC-2023	1.000	ug/L
51368	51368-1-S-HAL-F02	Annex Outside Parent Room, Right Fountain	Flush180	26-MAY-16	0.613	ppb
51368	51368-1-S-HAL-F02	Annex Outside Parent Room, Right Fountain	Flush180	26-MAY-16	0.528	ppb
51368	51368-1-S-HAL-F02	Annex Outside Parent Room, Right Fountain	Flush180	26-MAY-16	0.545	ppb
51368	51368-1-S-HAL-F02	Annex Outside Parent Room, Right Fountain	Flush180	26-MAY-16	0.202	ppb
51368	51368-1-S-HAL-F02	Annex Outside Parent Room, Right Fountain	Flush180	17-DEC-20	2.270	ug/L
51368	51368-1-S-HAL-F02	Annex Outside Parent Room, Right Fountain	Flush180	17-DEC-20	2.320	ug/L
51368	51368-1-S-HAL-F02	Annex Outside Parent Room, Right Fountain	Flush180	17-DEC-20	2.510	ug/L
51368	51368-1-S-HAL-F02	Annex Outside Parent Room, Right Fountain	Flush180	17-DEC-20	2.060	ug/L
51368	51368-1-S-HAL-F02	Annex Outside Parent Room, Right Fountain	Flush180	05-JAN-21	1.240	ug/L
51368	51368-1-S-	Annex Outside Parent Room,	Flush180	05-JAN-21	1.020	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F02	Right Fountain				
51368	51368-1-S-HAL-F02	Annex Outside Parent Room, Right Fountain	Flush180	05-JAN-21	1.050	ug/L
51368	51368-1-S-HAL-F02	Annex Outside Parent Room, Right Fountain	Flush180	05-JAN-21	1.020	ug/L
51368	51368-1-S-HAL-F02	Annex Outside Parent Room, Right Fountain	Flush180	20-OCT-20	9.790	ug/L
51368	51368-1-S-HAL-F02	Annex Outside Parent Room, Right Fountain	Initial	26-MAY-16	1.200	ppb
51368	51368-1-S-HAL-F02	Annex Outside Parent Room, Right Fountain	Initial	17-DEC-20	10.100	ug/L
51368	51368-1-S-HAL-F02	Annex Outside Parent Room, Right Fountain	Initial	05-JAN-21	4.620	ug/L
51368	51368-1-S-HAL-F02	Annex Outside Parent Room, Right Fountain	Initial	20-OCT-20	6.570	ug/L
51368	51368-1-S-HAL-F02	Annex Outside Parent Room, Right Fountain	Initial	12-DEC-2023	1.700	ug/L
51368	51368-1-S-001-F01	Annex inside room 1, water spout built in sink	Flush	12-DEC-2023	1.240	ug/L
51368	51368-1-S-001-F01	Annex inside room 1, water spout built in sink	Flush	12-DEC-2023	1.190	ug/L
51368	51368-1-S-001-F01	Annex inside room 1, water spout built in sink	Flush	12-DEC-2023	1.480	ug/L
51368	51368-1-S-001-F01	Annex inside room 1, water spout built in sink	Flush	12-DEC-2023	1.000	ug/L
51368	51368-1-S-001-F01	Annex inside room 1, water spout built in sink	Initial	12-DEC-2023	3.580	ug/L
51368	51368-1-N-003-F01	Annex inside room 3, water spout built in sink	Flush	12-DEC-2023	3.910	ug/L
51368	51368-1-N-003-F01	Annex inside room 3, water spout built in sink	Flush	12-DEC-2023	1.860	ug/L
51368	51368-1-N-003-F01	Annex inside room 3, water spout built in sink	Flush	12-DEC-2023	1.360	ug/L
51368	51368-1-N-003-F01	Annex inside room 3, water spout built in sink	Flush	12-DEC-2023	2.970	ug/L
51368	51368-1-N-003-F01	Annex inside room 3, water spout built in sink	Initial	12-DEC-2023	3.130	ug/L
51368	51368-1-N-004-F01	Annex inside room 4, water spout built in sink	Flush	12-DEC-2023	2.740	ug/L
51368	51368-1-N-004-F01	Annex inside room 4, water spout built in sink	Flush	12-DEC-2023	2.530	ug/L
51368	51368-1-N-004-F01	Annex inside room 4, water spout built in sink	Flush	12-DEC-2023	2.200	ug/L
51368	51368-1-N-004-F01	Annex inside room 4, water spout built in sink	Flush	12-DEC-2023	2.640	ug/L
51368	51368-1-N-004-F01	Annex inside room 4, water spout built in sink	Initial	12-DEC-2023	2.750	ug/L
51368	51368-1-N-005-F01	Annex inside room 5, water spout built in sink	Flush	12-DEC-2023	6.460	ug/L
51368	51368-1-N-005-F01	Annex inside room 5, water spout built in sink	Flush	12-DEC-2023	3.600	ug/L
51368	51368-1-N-005-F01	Annex inside room 5, water spout built in sink	Flush	12-DEC-2023	8.020	ug/L
51368	51368-1-N-005-F01	Annex inside room 5, water spout built in sink	Flush	12-DEC-2023	3.490	ug/L
51368	51368-1-N-005-F01	Annex inside room 5, water spout built in sink	Initial	12-DEC-2023	5.230	ug/L
51368	51368-1-S-HAL-RBF01	Annex outside parent room left Retrofit bf	Flush	12-DEC-2023	1.000	ug/L
51368	51368-1-S-HAL-RBF01	Annex outside parent room left Retrofit bf	Flush	12-DEC-2023	1.000	ug/L
51368	51368-1-S-HAL-RBF01	Annex outside parent room left Retrofit bf	Flush	12-DEC-2023	1.000	ug/L
51368	51368-1-S-HAL-RBF01	Annex outside parent room left Retrofit bf	Flush	12-DEC-2023	1.000	ug/L
51368	51368-1-S-HAL-RBF01	Annex outside parent room left Retrofit bf	Initial	12-DEC-2023	1.310	ug/L