



Sep 10, 2024

BELL

3730 N OAKLEY AVE, Chicago IL 60618.

Dear **BELL** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

BELL

3730 N OAKLEY AVE, Chicago IL 60618.

Estimadas familias de **BELL**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51047	51047-1-ADD-KIT-KS03	Addition - Kitchen, Center Table Sink	Flush180	18-JUN-16	1.000	ppb
51047	51047-ADD-1-KIT-KS03	Addition - Kitchen, Center Table Sink	Flush180	18-JUN-16	1.000	ppb
51047	51047-ADD-1-KIT-KS03	Addition - Kitchen, Center Table Sink	Flush180	18-JUN-16	1.000	ppb
51047	51047-ADD-1-KIT-KS03	Addition - Kitchen, Center Table Sink	Flush180	18-JUN-16	1.000	ppb
51047	51047-ADD-1-KIT-KS03	Addition - Kitchen, Center Table Sink	Flush180	18-JUN-16	1.000	ppb
51047	51047-1-ADD-KIT-KS03	Addition - Kitchen, Center Table Sink	Flush180	18-JUN-16	1.000	ppb
51047	51047-1-ADD-KIT-KS03	Addition - Kitchen, Center Table Sink	Flush180	18-JUN-16	1.000	ppb
51047	51047-1-ADD-KIT-KS03	Addition - Kitchen, Center Table Sink	Flush180	18-JUN-16	1.000	ppb
51047	51047-1-ADD-KIT-KS03	Addition - Kitchen, Center Table Sink	Flush180	16-FEB-22	1.000	ug/L
51047	51047-1-ADD-KIT-KS03	Addition - Kitchen, Center Table Sink	Flush180	16-FEB-22	1.000	ug/L
51047	51047-1-ADD-KIT-KS03	Addition - Kitchen, Center Table Sink	Flush180	16-FEB-22	1.000	ug/L
51047	51047-1-ADD-KIT-KS03	Addition - Kitchen, Center Table Sink	Flush180	16-FEB-22	1.000	ug/L
51047	51047-1-ADD-KIT-KS03	Addition - Kitchen, Center Table Sink	Flush180	16-FEB-22	1.000	ug/L
51047	51047-ADD-1-KIT-KS03	Addition - Kitchen, Center Table Sink	Initial	18-JUN-16	1.000	ppb
51047	51047-1-ADD-KIT-KS03	Addition - Kitchen, Center Table Sink	Initial	18-JUN-16	1.000	ppb
51047	51047-1-ADD-KIT-KS03	Addition - Kitchen, Center Table Sink	Initial	16-FEB-22	1.000	ug/L
51047	51047-ADD-1-GYM-F04	Addition- Gym, North Fountain 1	Flush180	18-JUN-16	1.000	ppb
51047	51047-ADD-1-GYM-F04	Addition- Gym, North Fountain 1	Flush180	18-JUN-16	1.000	ppb
51047	51047-ADD-1-GYM-F04	Addition- Gym, North Fountain 1	Flush180	18-JUN-16	1.000	ppb
51047	51047-ADD-1-GYM-F04	Addition- Gym, North Fountain 1	Flush180	18-JUN-16	1.000	ppb
51047	51047-1-ADD-GYM-F04	Addition- Gym, North Fountain 1	Flush180	18-JUN-16	1.000	ppb
51047	51047-1-ADD-GYM-F04	Addition- Gym, North Fountain 1	Flush180	18-JUN-16	1.000	ppb
51047	51047-1-ADD-GYM-F04	Addition- Gym, North Fountain 1	Flush180	18-JUN-16	1.000	ppb
51047	51047-1-ADD-GYM-F04	Addition- Gym, North Fountain 1	Flush180	18-JUN-16	1.000	ppb
51047	51047-1-ADD-GYM-F04	Addition- Gym, North Fountain 1	Flush180	18-JUN-16	1.000	ppb
51047	51047-1-ADD-GYM-F04	Addition- Gym, North Fountain 1	Flush180	18-JUN-16	1.000	ppb
51047	51047-ADD-1-GYM-F04	Addition- Gym, North Fountain 1	Initial	18-JUN-16	1.000	ppb
51047	51047-1-ADD-GYM-F04	Addition- Gym, North Fountain 1	Initial	18-JUN-16	1.000	ppb
51047	51047-ADD-1-GYM-F04	Addition- Gym, North Fountain 1	Initial	16-FEB-22	1.000	ug/L
51047	51047-1-ADD-GYM-F05	Addition- Gym, South Fountain 2	Flush180	18-JUN-16	1.000	ppb
51047	51047-ADD-1-GYM-F05	Addition- Gym, South Fountain 2	Flush180	18-JUN-16	1.000	ppb
51047	51047-ADD-1-GYM-F05	Addition- Gym, South Fountain 2	Flush180	18-JUN-16	1.000	ppb
51047	51047-ADD-1-GYM-F05	Addition- Gym, South Fountain 2	Flush180	18-JUN-16	1.000	ppb
51047	51047-ADD-1-GYM-F05	Addition- Gym, South Fountain 2	Flush180	18-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51047	51047-1-ADD-GYM-F05	Addition- Gym, South Fountain 2	Flush180	18-JUN-16	1.000	ppb
51047	51047-1-ADD-GYM-F05	Addition- Gym, South Fountain 2	Flush180	18-JUN-16	1.000	ppb
51047	51047-1-ADD-GYM-F05	Addition- Gym, South Fountain 2	Flush180	18-JUN-16	1.000	ppb
51047	51047-ADD-1-GYM-F05	Addition- Gym, South Fountain 2	Flush180	16-FEB-22	1.000	ug/L
51047	51047-ADD-1-GYM-F05	Addition- Gym, South Fountain 2	Flush180	16-FEB-22	1.000	ug/L
51047	51047-ADD-1-GYM-F05	Addition- Gym, South Fountain 2	Flush180	16-FEB-22	1.000	ug/L
51047	51047-ADD-1-GYM-F05	Addition- Gym, South Fountain 2	Flush180	16-FEB-22	1.000	ug/L
51047	51047-ADD-1-GYM-F05	Addition- Gym, South Fountain 2	Initial	18-JUN-16	1.000	ppb
51047	51047-1-ADD-GYM-F05	Addition- Gym, South Fountain 2	Initial	18-JUN-16	1.000	ppb
51047	51047-ADD-1-GYM-F05	Addition- Gym, South Fountain 2	Initial	16-FEB-22	1.000	ug/L
51047	51047-1-ADD-GYM-F06	Addition- Gym, South Right Fountain	Flush180	16-FEB-22	1.000	ug/L
51047	51047-1-ADD-GYM-F06	Addition- Gym, South Right Fountain	Flush180	16-FEB-22	1.000	ug/L
51047	51047-1-ADD-GYM-F06	Addition- Gym, South Right Fountain	Flush180	16-FEB-22	1.000	ug/L
51047	51047-1-ADD-GYM-F06	Addition- Gym, South Right Fountain	Flush180	16-FEB-22	1.000	ug/L
51047	51047-1-ADD-GYM-F06	Addition- Gym, South Right Fountain	Initial	16-FEB-22	1.000	ug/L
51047	51047-1-ADD-KIT-KS02	Addition- Kitchen, Sink Kettle	Flush180	18-JUN-16	3.360	ppb
51047	51047-1-ADD-KIT-KS02	Addition- Kitchen, Sink Kettle	Flush180	18-JUN-16	1.250	ppb
51047	51047-1-ADD-KIT-KS02	Addition- Kitchen, Sink Kettle	Flush180	18-JUN-16	0.827	ppb
51047	51047-1-ADD-KIT-KS02	Addition- Kitchen, Sink Kettle	Flush180	18-JUN-16	1.510	ppb
51047	51047-ADD-1-KIT-KS02	Addition- Kitchen, Sink Kettle	Flush180	18-JUN-16	1.250	ppb
51047	51047-ADD-1-KIT-KS02	Addition- Kitchen, Sink Kettle	Flush180	18-JUN-16	3.360	ppb
51047	51047-ADD-1-KIT-KS02	Addition- Kitchen, Sink Kettle	Flush180	18-JUN-16	0.827	ppb
51047	51047-ADD-1-KIT-KS02	Addition- Kitchen, Sink Kettle	Flush180	18-JUN-16	1.510	ppb
51047	51047-1-ADD-KIT-KS02	Addition- Kitchen, Sink Kettle	Flush180	16-FEB-22	1.000	ug/L
51047	51047-1-ADD-KIT-KS02	Addition- Kitchen, Sink Kettle	Flush180	16-FEB-22	1.000	ug/L
51047	51047-1-ADD-KIT-KS02	Addition- Kitchen, Sink Kettle	Flush180	16-FEB-22	1.000	ug/L
51047	51047-1-ADD-KIT-KS02	Addition- Kitchen, Sink Kettle	Initial	18-JUN-16	2.540	ppb
51047	51047-ADD-1-KIT-KS02	Addition- Kitchen, Sink Kettle	Initial	18-JUN-16	2.540	ppb
51047	51047-1-ADD-KIT-KS02	Addition- Kitchen, Sink Kettle	Initial	16-FEB-22	1.000	ug/L
51047	51047-1-ADD-KIT-KS01	Addition- Kitchen, West Sink	Flush180	18-JUN-16	0.274	ppb
51047	51047-1-ADD-KIT-KS01	Addition- Kitchen, West Sink	Flush180	18-JUN-16	0.287	ppb
51047	51047-1-ADD-KIT-KS01	Addition- Kitchen, West Sink	Flush180	18-JUN-16	0.303	ppb
51047	51047-1-ADD-KIT-KS01	Addition- Kitchen, West Sink	Flush180	18-JUN-16	0.609	ppb
51047	51047-ADD-1-KIT-KS01	Addition- Kitchen, West Sink	Flush180	18-JUN-16	0.287	ppb
51047	51047-ADD-1-KIT-KS01	Addition- Kitchen, West Sink	Flush180	18-JUN-16	0.609	ppb
51047	51047-ADD-1-KIT-KS01	Addition- Kitchen, West Sink	Flush180	18-JUN-16	0.274	ppb

Water Quality Assessment Alexander Graham Bell Elementary School

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51047	51047-ADD-1-KIT-KS01	Addition- Kitchen, West Sink	Flush180	18-JUN-16	0.303	ppb
51047	51047-1-ADD-KIT-KS01	Addition- Kitchen, West Sink	Flush180	16-FEB-22	1.000	ug/L
51047	51047-1-ADD-KIT-KS01	Addition- Kitchen, West Sink	Flush180	16-FEB-22	1.000	ug/L
51047	51047-1-ADD-KIT-KS01	Addition- Kitchen, West Sink	Flush180	16-FEB-22	1.000	ug/L
51047	51047-1-ADD-KIT-KS01	Addition- Kitchen, West Sink	Flush180	16-FEB-22	1.000	ug/L
51047	51047-1-ADD-KIT-KS01	Addition- Kitchen, West Sink	Initial	18-JUN-16	6.010	ppb
51047	51047-ADD-1-KIT-KS01	Addition- Kitchen, West Sink	Initial	18-JUN-16	6.010	ppb
51047	51047-1-ADD-KIT-KS01	Addition- Kitchen, West Sink	Initial	16-FEB-22	1.000	ug/L
51047	51047-1-HAL-F01	Main- Next To Room 102, North Fountain 1	Flush180	18-JUN-16	1.000	ppb
51047	51047-1-HAL-F01	Main- Next To Room 102, North Fountain 1	Flush180	18-JUN-16	1.000	ppb
51047	51047-1-HAL-F01	Main- Next To Room 102, North Fountain 1	Flush180	18-JUN-16	1.000	ppb
51047	51047-1-HAL-F01	Main- Next To Room 102, North Fountain 1	Flush180	18-JUN-16	1.000	ppb
51047	51047-1-HAL-F01	Main- Next To Room 102, North Fountain 1	Flush180	18-JUN-16	1.000	ppb
51047	51047-1-HAL-F01	Main- Next To Room 102, North Fountain 1	Flush180	18-JUN-16	1.000	ppb
51047	51047-1-HAL-F01	Main- Next To Room 102, North Fountain 1	Initial	18-JUN-16	1.000	ppb
51047	51047-1-HAL-F01	Main- Next To Room 102, North Fountain 1	Initial	18-JUN-16	1.000	ppb
51047	51047-1-HAL-F03	Main- Next To Room 102, South Fountain 2	Flush180	18-JUN-16	0.625	ppb
51047	51047-1-HAL-F03	Main- Next To Room 102, South Fountain 2	Flush180	18-JUN-16	0.625	ppb
51047	51047-1-HAL-F03	Main- Next To Room 102, South Fountain 2	Flush180	18-JUN-16	0.935	ppb
51047	51047-1-HAL-F03	Main- Next To Room 102, South Fountain 2	Flush180	18-JUN-16	0.500	ppb
51047	51047-1-HAL-F03	Main- Next To Room 102, South Fountain 2	Flush180	18-JUN-16	0.935	ppb
51047	51047-1-HAL-F03	Main- Next To Room 102, South Fountain 2	Flush180	18-JUN-16	0.854	ppb
51047	51047-1-HAL-F03	Main- Next To Room 102, South Fountain 2	Flush180	18-JUN-16	0.854	ppb
51047	51047-1-HAL-F02	Main- Next To Room 102, South Fountain 2	Flush180	18-JUN-16	1.000	ppb
51047	51047-1-HAL-F02	Main- Next To Room 102, South Fountain 2	Flush180	18-JUN-16	1.000	ppb
51047	51047-1-HAL-F02	Main- Next To Room 102, South Fountain 2	Flush180	18-JUN-16	1.000	ppb
51047	51047-1-HAL-F02	Main- Next To Room 102, South Fountain 2	Flush180	18-JUN-16	1.000	ppb
51047	51047-1-HAL-F02	Main- Next To Room 102, South Fountain 2	Flush180	18-JUN-16	1.000	ppb
51047	51047-1-HAL-F02	Main- Next To Room 102, South Fountain 2	Flush180	18-JUN-16	1.000	ppb
51047	51047-1-HAL-F02	Main- Next To Room 102, South Fountain 2	Flush180	18-JUN-16	1.000	ppb
51047	51047-1-HAL-F03	Main- Next To Room 102, South Fountain 2	Flush180	18-JUN-16	0.500	ppb
51047	51047-1-HAL-F02	Main- Next To Room 102, South Fountain 2	Flush180	16-FEB-22	1.000	ug/L
51047	51047-1-HAL-F02	Main- Next To Room 102, South Fountain 2	Flush180	16-FEB-22	1.000	ug/L
51047	51047-1-HAL-F02	Main- Next To Room 102, South Fountain 2	Flush180	16-FEB-22	1.000	ug/L
51047	51047-1-HAL-F02	Main- Next To Room 102, South Fountain 2	Flush180	16-FEB-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02	Fountain 2				
51047	51047-1-HAL-F03	Main- Next To Room 102, South Fountain 2	Flush180	16-FEB-22	1.000	ug/L
51047	51047-1-HAL-F03	Main- Next To Room 102, South Fountain 2	Flush180	16-FEB-22	1.000	ug/L
51047	51047-1-HAL-F03	Main- Next To Room 102, South Fountain 2	Flush180	16-FEB-22	1.000	ug/L
51047	51047-1-HAL-F03	Main- Next To Room 102, South Fountain 2	Flush180	16-FEB-22	1.000	ug/L
51047	51047-1-HAL-F03	Main- Next To Room 102, South Fountain 2	Initial	18-JUN-16	1.940	ppb
51047	51047-1-HAL-F03	Main- Next To Room 102, South Fountain 2	Initial	18-JUN-16	1.940	ppb
51047	51047-1-HAL-F02	Main- Next To Room 102, South Fountain 2	Initial	18-JUN-16	1.000	ppb
51047	51047-1-HAL-F02	Main- Next To Room 102, South Fountain 2	Initial	18-JUN-16	1.000	ppb
51047	51047-1-HAL-F02	Main- Next To Room 102, South Fountain 2	Initial	16-FEB-22	1.000	ug/L
51047	51047-1-HAL-F03	Main- Next To Room 102, South Fountain 2	Initial	16-FEB-22	1.000	ug/L
51047	51047-1-HAL-BF06	Main- Next To Room 118, Bottle Filler	Flush180	16-FEB-22	1.000	ug/L
51047	51047-1-HAL-BF06	Main- Next To Room 118, Bottle Filler	Flush180	16-FEB-22	1.000	ug/L
51047	51047-1-HAL-BF06	Main- Next To Room 118, Bottle Filler	Flush180	16-FEB-22	1.000	ug/L
51047	51047-1-HAL-BF06	Main- Next To Room 118, Bottle Filler	Flush180	16-FEB-22	1.000	ug/L
51047	51047-1-HAL-BF06	Main- Next To Room 118, Bottle Filler	Initial	16-FEB-22	1.000	ug/L
51047	51047-1-HAL-F04	Main- Next To Room 118, North Fountain 1	Flush180	18-JUN-16	0.324	ppb
51047	51047-1-HAL-F04	Main- Next To Room 118, North Fountain 1	Flush180	18-JUN-16	0.285	ppb
51047	51047-1-HAL-F04	Main- Next To Room 118, North Fountain 1	Flush180	18-JUN-16	0.234	ppb
51047	51047-1-HAL-F04	Main- Next To Room 118, North Fountain 1	Flush180	18-JUN-16	0.285	ppb
51047	51047-1-HAL-F04	Main- Next To Room 118, North Fountain 1	Flush180	18-JUN-16	0.324	ppb
51047	51047-1-HAL-F04	Main- Next To Room 118, North Fountain 1	Flush180	18-JUN-16	0.300	ppb
51047	51047-1-HAL-F04	Main- Next To Room 118, North Fountain 1	Flush180	18-JUN-16	0.234	ppb
51047	51047-1-HAL-F04	Main- Next To Room 118, North Fountain 1	Flush180	18-JUN-16	0.300	ppb
51047	51047-1-HAL-F04	Main- Next To Room 118, North Fountain 1	Flush180	16-FEB-22	1.000	ug/L
51047	51047-1-HAL-F04	Main- Next To Room 118, North Fountain 1	Flush180	16-FEB-22	1.000	ug/L
51047	51047-1-HAL-F04	Main- Next To Room 118, North Fountain 1	Flush180	16-FEB-22	1.000	ug/L
51047	51047-1-HAL-F04	Main- Next To Room 118, North Fountain 1	Initial	18-JUN-16	0.179	ppb
51047	51047-1-HAL-F04	Main- Next To Room 118, North Fountain 1	Initial	18-JUN-16	0.179	ppb
51047	51047-1-HAL-F04	Main- Next To Room 118, North Fountain 1	Initial	16-FEB-22	1.000	ug/L
51047	51047-1-HAL-F05	Main- Next To Room 118, South Fountain 2	Flush180	18-JUN-16	0.416	ppb
51047	51047-1-HAL-F05	Main- Next To Room 118, South Fountain 2	Flush180	18-JUN-16	0.458	ppb
51047	51047-1-HAL-F05	Main- Next To Room 118, South Fountain 2	Flush180	18-JUN-16	0.459	ppb
51047	51047-1-HAL-F05	Main- Next To Room 118, South Fountain 2	Flush180	18-JUN-16	0.386	ppb
51047	51047-1-HAL-F05	Main- Next To Room 118, South Fountain 2	Flush180	18-JUN-16	0.416	ppb
51047	51047-1-HAL-F05	Main- Next To Room 118, South Fountain 2	Flush180	18-JUN-16	0.458	ppb
51047	51047-1-HAL-F05	Main- Next To Room 118, South Fountain 2	Flush180	18-JUN-16	0.459	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F05	Fountain 2				
51047	51047-1-HAL-F05	Main- Next To Room 118, South Fountain 2	Flush180	18-JUN-16	0.386	ppb
51047	51047-1-HAL-F05	Main- Next To Room 118, South Fountain 2	Initial	18-JUN-16	0.500	ppb
51047	51047-1-HAL-F05	Main- Next To Room 118, South Fountain 2	Initial	18-JUN-16	0.500	ppb
51047	51047-2-HAL-BF04	Main- Next To Room 202, Bottle Filler	Flush180	16-FEB-22	1.000	ug/L
51047	51047-2-HAL-BF04	Main- Next To Room 202, Bottle Filler	Flush180	16-FEB-22	1.000	ug/L
51047	51047-2-HAL-BF04	Main- Next To Room 202, Bottle Filler	Flush180	16-FEB-22	1.000	ug/L
51047	51047-2-HAL-BF04	Main- Next To Room 202, Bottle Filler	Initial	16-FEB-22	1.000	ug/L
51047	51047-2-HAL-F01	Main- Next To Room 202, North Fountain 1	Flush180	18-JUN-16	0.387	ppb
51047	51047-2-HAL-F01	Main- Next To Room 202, North Fountain 1	Flush180	18-JUN-16	0.387	ppb
51047	51047-2-HAL-F01	Main- Next To Room 202, North Fountain 1	Flush180	18-JUN-16	0.425	ppb
51047	51047-2-HAL-F01	Main- Next To Room 202, North Fountain 1	Flush180	18-JUN-16	0.387	ppb
51047	51047-2-HAL-F01	Main- Next To Room 202, North Fountain 1	Flush180	18-JUN-16	0.387	ppb
51047	51047-2-HAL-F01	Main- Next To Room 202, North Fountain 1	Flush180	18-JUN-16	0.425	ppb
51047	51047-2-HAL-F01	Main- Next To Room 202, North Fountain 1	Flush180	18-JUN-16	0.420	ppb
51047	51047-2-HAL-F01	Main- Next To Room 202, North Fountain 1	Flush180	18-JUN-16	0.420	ppb
51047	51047-2-HAL-F01	Main- Next To Room 202, North Fountain 1	Initial	18-JUN-16	0.415	ppb
51047	51047-2-HAL-F01	Main- Next To Room 202, North Fountain 1	Initial	18-JUN-16	0.415	ppb
51047	51047-2-HAL-F02	Main- Next To Room 202, South Fountain 2	Flush180	18-JUN-16	0.391	ppb
51047	51047-2-HAL-F02	Main- Next To Room 202, South Fountain 2	Flush180	18-JUN-16	0.255	ppb
51047	51047-2-HAL-F02	Main- Next To Room 202, South Fountain 2	Flush180	18-JUN-16	0.320	ppb
51047	51047-2-HAL-F02	Main- Next To Room 202, South Fountain 2	Flush180	18-JUN-16	0.450	ppb
51047	51047-2-HAL-F02	Main- Next To Room 202, South Fountain 2	Flush180	18-JUN-16	0.391	ppb
51047	51047-2-HAL-F02	Main- Next To Room 202, South Fountain 2	Flush180	18-JUN-16	0.450	ppb
51047	51047-2-HAL-F02	Main- Next To Room 202, South Fountain 2	Flush180	18-JUN-16	0.320	ppb
51047	51047-2-HAL-F02	Main- Next To Room 202, South Fountain 2	Flush180	18-JUN-16	0.255	ppb
51047	51047-2-HAL-F02	Main- Next To Room 202, South Fountain 2	Flush180	16-FEB-22	1.000	ug/L
51047	51047-2-HAL-F02	Main- Next To Room 202, South Fountain 2	Flush180	24-FEB-22	1.000	ug/L
51047	51047-2-HAL-F02	Main- Next To Room 202, South Fountain 2	Flush180	16-FEB-22	1.000	ug/L
51047	51047-2-HAL-F02	Main- Next To Room 202, South Fountain 2	Flush180	16-FEB-22	1.000	ug/L
51047	51047-2-HAL-F02	Main- Next To Room 202, South Fountain 2	Initial	18-JUN-16	0.146	ppb
51047	51047-2-HAL-F02	Main- Next To Room 202, South Fountain 2	Initial	18-JUN-16	0.146	ppb
51047	51047-2-HAL-F02	Main- Next To Room 202, South Fountain 2	Initial	16-FEB-22	1.000	ug/L
51047	51047-2-HAL-BF03	Main- Next To Room 218, Bottle Filler	Flush180	16-FEB-22	1.000	ug/L
51047	51047-2-HAL-BF03	Main- Next To Room 218, Bottle Filler	Flush180	16-FEB-22	1.000	ug/L
51047	51047-2-HAL-BF03	Main- Next To Room 218, Bottle Filler	Flush180	16-FEB-22	1.000	ug/L
51047	51047-2-HAL-BF03	Main- Next To Room 218, Bottle Filler	Flush180	16-FEB-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51047	51047-2-HAL-BF03	Main- Next To Room 218, Bottle Filler	Initial	16-FEB-22	1.000	ug/L
51047	51047-2-HAL-F03	Main- Next To Room 218, North Fountain 1	Flush180	18-JUN-16	0.267	ppb
51047	51047-2-HAL-F03	Main- Next To Room 218, North Fountain 1	Flush180	18-JUN-16	0.267	ppb
51047	51047-2-HAL-F03	Main- Next To Room 218, North Fountain 1	Flush180	18-JUN-16	0.311	ppb
51047	51047-2-HAL-F03	Main- Next To Room 218, North Fountain 1	Flush180	18-JUN-16	0.294	ppb
51047	51047-2-HAL-F03	Main- Next To Room 218, North Fountain 1	Flush180	18-JUN-16	0.311	ppb
51047	51047-2-HAL-F03	Main- Next To Room 218, North Fountain 1	Flush180	18-JUN-16	0.252	ppb
51047	51047-2-HAL-F03	Main- Next To Room 218, North Fountain 1	Flush180	18-JUN-16	0.294	ppb
51047	51047-2-HAL-F03	Main- Next To Room 218, North Fountain 1	Flush180	18-JUN-16	0.252	ppb
51047	51047-2-HAL-F03	Main- Next To Room 218, North Fountain 1	Initial	18-JUN-16	0.227	ppb
51047	51047-2-HAL-F03	Main- Next To Room 218, North Fountain 1	Initial	18-JUN-16	0.227	ppb
51047	51047-2-HAL-F04	Main- Next To Room 218, South Fountain 2	Flush180	18-JUN-16	0.186	ppb
51047	51047-2-HAL-F04	Main- Next To Room 218, South Fountain 2	Flush180	18-JUN-16	0.225	ppb
51047	51047-2-HAL-F04	Main- Next To Room 218, South Fountain 2	Flush180	18-JUN-16	0.225	ppb
51047	51047-2-HAL-F04	Main- Next To Room 218, South Fountain 2	Flush180	18-JUN-16	0.169	ppb
51047	51047-2-HAL-F04	Main- Next To Room 218, South Fountain 2	Flush180	18-JUN-16	0.137	ppb
51047	51047-2-HAL-F04	Main- Next To Room 218, South Fountain 2	Flush180	18-JUN-16	0.169	ppb
51047	51047-2-HAL-F04	Main- Next To Room 218, South Fountain 2	Flush180	18-JUN-16	0.137	ppb
51047	51047-2-HAL-F04	Main- Next To Room 218, South Fountain 2	Flush180	18-JUN-16	0.186	ppb
51047	51047-2-HAL-F04	Main- Next To Room 218, South Fountain 2	Flush180	16-FEB-22	1.000	ug/L
51047	51047-2-HAL-F04	Main- Next To Room 218, South Fountain 2	Flush180	16-FEB-22	1.000	ug/L
51047	51047-2-HAL-F04	Main- Next To Room 218, South Fountain 2	Flush180	16-FEB-22	1.000	ug/L
51047	51047-2-HAL-F04	Main- Next To Room 218, South Fountain 2	Flush180	16-FEB-22	1.000	ug/L
51047	51047-2-HAL-F04	Main- Next To Room 218, South Fountain 2	Initial	18-JUN-16	1.000	ppb
51047	51047-2-HAL-F04	Main- Next To Room 218, South Fountain 2	Initial	18-JUN-16	1.000	ppb
51047	51047-2-HAL-F04	Main- Next To Room 218, South Fountain 2	Initial	16-FEB-22	1.000	ug/L
51047	51047-3-HAL-BF02	Main- Next To Room 302, Bottle Filler	Flush180	16-FEB-22	1.000	ug/L
51047	51047-3-HAL-BF02	Main- Next To Room 302, Bottle Filler	Flush180	16-FEB-22	1.000	ug/L
51047	51047-3-HAL-BF02	Main- Next To Room 302, Bottle Filler	Flush180	16-FEB-22	1.000	ug/L
51047	51047-3-HAL-BF02	Main- Next To Room 302, Bottle Filler	Flush180	16-FEB-22	1.000	ug/L
51047	51047-3-HAL-BF02	Main- Next To Room 302, Bottle Filler	Initial	16-FEB-22	1.000	ug/L
51047	51047-3-HAL-F01	Main- Next To Room 302, North Fountain 1	Flush180	18-JUN-16	0.404	ppb
51047	51047-3-HAL-F01	Main- Next To Room 302, North Fountain 1	Flush180	18-JUN-16	0.309	ppb
51047	51047-3-HAL-F01	Main- Next To Room 302, North Fountain 1	Flush180	18-JUN-16	0.187	ppb
51047	51047-3-HAL-F01	Main- Next To Room 302, North Fountain 1	Flush180	18-JUN-16	0.363	ppb
51047	51047-3-HAL-F01	Main- Next To Room 302, North Fountain 1	Flush180	18-JUN-16	0.363	ppb
51047	51047-3-HAL-F01	Main- Next To Room 302, North Fountain 1	Flush180	18-JUN-16	0.309	ppb

Water Quality Assessment Alexander Graham Bell Elementary School

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51047	51047-3-HAL-F01	Main- Next To Room 302, North Fountain 1	Flush180	18-JUN-16	0.187	ppb
51047	51047-3-HAL-F01	Main- Next To Room 302, North Fountain 1	Flush180	18-JUN-16	0.404	ppb
51047	51047-3-HAL-F01	Main- Next To Room 302, North Fountain 1	Flush180	16-FEB-22	1.000	ug/L
51047	51047-3-HAL-F01	Main- Next To Room 302, North Fountain 1	Flush180	16-FEB-22	1.000	ug/L
51047	51047-3-HAL-F01	Main- Next To Room 302, North Fountain 1	Flush180	16-FEB-22	1.000	ug/L
51047	51047-3-HAL-F01	Main- Next To Room 302, North Fountain 1	Flush180	16-FEB-22	1.000	ug/L
51047	51047-3-HAL-F01	Main- Next To Room 302, North Fountain 1	Initial	18-JUN-16	1.000	ppb
51047	51047-3-HAL-F01	Main- Next To Room 302, North Fountain 1	Initial	18-JUN-16	1.000	ppb
51047	51047-3-HAL-F01	Main- Next To Room 302, North Fountain 1	Initial	16-FEB-22	1.000	ug/L
51047	51047-3-HAL-F02	Main- Next To Room 302, South Fountain 2	Flush180	18-JUN-16	0.321	ppb
51047	51047-3-HAL-F02	Main- Next To Room 302, South Fountain 2	Flush180	18-JUN-16	0.271	ppb
51047	51047-3-HAL-F02	Main- Next To Room 302, South Fountain 2	Flush180	18-JUN-16	0.220	ppb
51047	51047-3-HAL-F02	Main- Next To Room 302, South Fountain 2	Flush180	18-JUN-16	0.362	ppb
51047	51047-3-HAL-F02	Main- Next To Room 302, South Fountain 2	Flush180	18-JUN-16	0.220	ppb
51047	51047-3-HAL-F02	Main- Next To Room 302, South Fountain 2	Flush180	18-JUN-16	0.362	ppb
51047	51047-3-HAL-F02	Main- Next To Room 302, South Fountain 2	Flush180	18-JUN-16	0.321	ppb
51047	51047-3-HAL-F02	Main- Next To Room 302, South Fountain 2	Flush180	18-JUN-16	0.271	ppb
51047	51047-3-HAL-F02	Main- Next To Room 302, South Fountain 2	Initial	18-JUN-16	0.148	ppb
51047	51047-3-HAL-F02	Main- Next To Room 302, South Fountain 2	Initial	18-JUN-16	0.148	ppb
51047	51047-3-HAL-BF01	Main- Next To Room 318, Bottle Filler	Flush180	16-FEB-22	1.000	ug/L
51047	51047-3-HAL-BF01	Main- Next To Room 318, Bottle Filler	Flush180	16-FEB-22	1.000	ug/L
51047	51047-3-HAL-BF01	Main- Next To Room 318, Bottle Filler	Flush180	16-FEB-22	1.000	ug/L
51047	51047-3-HAL-BF01	Main- Next To Room 318, Bottle Filler	Initial	16-FEB-22	1.000	ug/L
51047	51047-3-HAL-F03	Main- Next To Room 318, North Fountain 1	Flush180	18-JUN-16	0.166	ppb
51047	51047-3-HAL-F03	Main- Next To Room 318, North Fountain 1	Flush180	18-JUN-16	0.166	ppb
51047	51047-3-HAL-F03	Main- Next To Room 318, North Fountain 1	Flush180	18-JUN-16	0.281	ppb
51047	51047-3-HAL-F03	Main- Next To Room 318, North Fountain 1	Flush180	18-JUN-16	0.213	ppb
51047	51047-3-HAL-F03	Main- Next To Room 318, North Fountain 1	Flush180	18-JUN-16	0.281	ppb
51047	51047-3-HAL-F03	Main- Next To Room 318, North Fountain 1	Flush180	18-JUN-16	0.213	ppb
51047	51047-3-HAL-F03	Main- Next To Room 318, North Fountain 1	Flush180	18-JUN-16	0.251	ppb
51047	51047-3-HAL-F03	Main- Next To Room 318, North Fountain 1	Flush180	18-JUN-16	0.251	ppb
51047	51047-3-HAL-F03	Main- Next To Room 318, North Fountain 1	Initial	18-JUN-16	0.120	ppb
51047	51047-3-HAL-F03	Main- Next To Room 318, North Fountain 1	Initial	18-JUN-16	0.120	ppb
51047	51047-3-HAL-F04	Main- Next To Room 318, South Fountain 2	Flush180	18-JUN-16	0.337	ppb
51047	51047-3-HAL-F04	Main- Next To Room 318, South Fountain 2	Flush180	18-JUN-16	0.432	ppb
51047	51047-3-HAL-F04	Main- Next To Room 318, South Fountain 2	Flush180	18-JUN-16	0.337	ppb
51047	51047-3-HAL-F04	Main- Next To Room 318, South Fountain 2	Flush180	18-JUN-16	0.404	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F04	Fountain 2				
51047	51047-3-HAL-F04	Main- Next To Room 318, South Fountain 2	Flush180	18-JUN-16	0.404	ppb
51047	51047-3-HAL-F04	Main- Next To Room 318, South Fountain 2	Flush180	18-JUN-16	0.404	ppb
51047	51047-3-HAL-F04	Main- Next To Room 318, South Fountain 2	Flush180	18-JUN-16	0.404	ppb
51047	51047-3-HAL-F04	Main- Next To Room 318, South Fountain 2	Flush180	18-JUN-16	0.432	ppb
51047	51047-3-HAL-F04	Main- Next To Room 318, South Fountain 2	Initial	18-JUN-16	0.198	ppb
51047	51047-3-HAL-F04	Main- Next To Room 318, South Fountain 2	Initial	18-JUN-16	0.198	ppb