



Sep 10, 2024

BLAINE

1420 W GRACE ST, Chicago IL 60613.

Dear **BLAINE** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

BLAINE

1420 W GRACE ST, Chicago IL 60613.

Estimadas familias de **BLAINE**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51048	51048-B-CAF-BF01	Bottle Filler 1, Left - Basement Lunch Room, Mian Bldg.	Flush180	09-MAR-22	3.840	ug/L
51048	51048-B-CAF-BF01	Bottle Filler 1, Left - Basement Lunch Room, Mian Bldg.	Flush180	09-MAR-22	6.940	ug/L
51048	51048-B-CAF-BF01	Bottle Filler 1, Left - Basement Lunch Room, Mian Bldg.	Flush180	09-MAR-22	7.140	ug/L
51048	51048-B-CAF-BF01	Bottle Filler 1, Left - Basement Lunch Room, Mian Bldg.	Flush180	09-MAR-22	4.610	ug/L
51048	51048-B-CAF-BF01	Bottle Filler 1, Left - Basement Lunch Room, Mian Bldg.	Flush180	15-APR-22	1.270	ug/L
51048	51048-B-CAF-BF01	Bottle Filler 1, Left - Basement Lunch Room, Mian Bldg.	Flush180	15-APR-22	1.360	ug/L
51048	51048-B-CAF-BF01	Bottle Filler 1, Left - Basement Lunch Room, Mian Bldg.	Flush180	15-APR-22	1.200	ug/L
51048	51048-B-CAF-BF01	Bottle Filler 1, Left - Basement Lunch Room, Mian Bldg.	Flush180	15-APR-22	1.140	ug/L
51048	51048-B-CAF-BF01	Bottle Filler 1, Left - Basement Lunch Room, Mian Bldg.	Initial	09-MAR-22	5.870	ug/L
51048	51048-B-CAF-BF01	Bottle Filler 1, Left - Basement Lunch Room, Mian Bldg.	Initial	15-APR-22	2.040	ug/L
51048	51048-2-HAL-BF01	Bottle Filler 1, Left - Outside Room 202, 2nd Fl. Main Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-2-HAL-BF01	Bottle Filler 1, Left - Outside Room 202, 2nd Fl. Main Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-2-HAL-BF01	Bottle Filler 1, Left - Outside Room 202, 2nd Fl. Main Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-2-HAL-BF01	Bottle Filler 1, Left - Outside Room 202, 2nd Fl. Main Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-2-HAL-BF01	Bottle Filler 1, Left - Outside Room 202, 2nd Fl. Main Bldg.	Initial	09-MAR-22	1.000	ug/L
51048	51048-B-CAF-BF02	Bottle Filler 2, Right - Basement Lunch Room, Mian Bldg.	Flush180	09-MAR-22	2.920	ug/L
51048	51048-B-CAF-BF02	Bottle Filler 2, Right - Basement Lunch Room, Mian Bldg.	Flush180	09-MAR-22	2.740	ug/L
51048	51048-B-CAF-BF02	Bottle Filler 2, Right - Basement Lunch Room, Mian Bldg.	Flush180	09-MAR-22	1.780	ug/L
51048	51048-B-CAF-BF02	Bottle Filler 2, Right - Basement Lunch Room, Mian Bldg.	Flush180	09-MAR-22	1.420	ug/L
51048	51048-B-CAF-BF02	Bottle Filler 2, Right - Basement Lunch Room, Mian Bldg.	Initial	09-MAR-22	3.130	ug/L
51048	51048-2-HAL-BF02	Bottle Filler 2, Right - Outside Room 202, 2nd Fl. Main Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-2-HAL-BF02	Bottle Filler 2, Right - Outside Room 202, 2nd Fl. Main Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-2-HAL-BF02	Bottle Filler 2, Right - Outside Room 202, 2nd Fl. Main Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-2-HAL-BF02	Bottle Filler 2, Right - Outside Room 202, 2nd Fl. Main Bldg.	Initial	09-MAR-22	1.000	ug/L
51048	51048-2-HAL-F01	Fountain - Outside Room 206, 2nd Fl. Main Bldg.	Flush180	27-MAY-16	0.649	ppb
51048	51048-2-HAL-F01	Fountain - Outside Room 206, 2nd Fl. Main Bldg.	Flush180	27-MAY-16	0.724	ppb
51048	51048-2-HAL-F01	Fountain - Outside Room 206, 2nd Fl. Main Bldg.	Flush180	27-MAY-16	0.706	ppb
51048	51048-2-HAL-F01	Fountain - Outside Room 206, 2nd Fl. Main Bldg.	Flush180	27-MAY-16	0.706	ppb
51048	51048-2-HAL-F01	Fountain - Outside Room 206, 2nd Fl. Main Bldg.	Flush180	27-MAY-16	0.649	ppb
51048	51048-2-HAL-F01	Fountain - Outside Room 206, 2nd Fl. Main Bldg.	Flush180	27-MAY-16	0.688	ppb
51048	51048-2-HAL-F01	Fountain - Outside Room 206, 2nd Fl. Main Bldg.	Flush180	27-MAY-16	0.688	ppb
51048	51048-2-HAL-F01	Fountain - Outside Room 206, 2nd Fl. Main Bldg.	Flush180	27-MAY-16	0.724	ppb
51048	51048-2-HAL-F01	Fountain - Outside Room 206, 2nd Fl. Main Bldg.	Flush180	09-MAR-22	5.140	ug/L
51048	51048-2-HAL-F01	Fountain - Outside Room 206, 2nd Fl. Main Bldg.	Flush180	09-MAR-22	1.950	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51048	51048-2-HAL-F01	Fountain - Outside Room 206, 2nd Fl. Main Bldg.	Flush180	09-MAR-22	1.620	ug/L
51048	51048-2-HAL-F01	Fountain - Outside Room 206, 2nd Fl. Main Bldg.	Flush180	09-MAR-22	1.320	ug/L
51048	51048-2-HAL-F01	Fountain - Outside Room 206, 2nd Fl. Main Bldg.	Flush180	15-APR-22	2.670	ug/L
51048	51048-2-HAL-F01	Fountain - Outside Room 206, 2nd Fl. Main Bldg.	Flush180	15-APR-22	2.040	ug/L
51048	51048-2-HAL-F01	Fountain - Outside Room 206, 2nd Fl. Main Bldg.	Flush180	15-APR-22	1.480	ug/L
51048	51048-2-HAL-F01	Fountain - Outside Room 206, 2nd Fl. Main Bldg.	Flush180	15-APR-22	2.510	ug/L
51048	51048-2-HAL-F01	Fountain - Outside Room 206, 2nd Fl. Main Bldg.	Initial	27-MAY-16	0.908	ppb
51048	51048-2-HAL-F01	Fountain - Outside Room 206, 2nd Fl. Main Bldg.	Initial	27-MAY-16	0.908	ppb
51048	51048-2-HAL-F01	Fountain - Outside Room 206, 2nd Fl. Main Bldg.	Initial	09-MAR-22	3.790	ug/L
51048	51048-2-HAL-F01	Fountain - Outside Room 206, 2nd Fl. Main Bldg.	Initial	15-APR-22	2.840	ug/L
51048	51048-3-HAL-F01	Fountain - Outside Room 306, 2nd Fl. Main Bldg.	Flush180	27-MAY-16	0.544	ppb
51048	51048-3-HAL-F01	Fountain - Outside Room 306, 2nd Fl. Main Bldg.	Flush180	27-MAY-16	0.544	ppb
51048	51048-3-HAL-F01	Fountain - Outside Room 306, 2nd Fl. Main Bldg.	Flush180	27-MAY-16	0.452	ppb
51048	51048-3-HAL-F01	Fountain - Outside Room 306, 2nd Fl. Main Bldg.	Flush180	27-MAY-16	0.379	ppb
51048	51048-3-HAL-F01	Fountain - Outside Room 306, 2nd Fl. Main Bldg.	Flush180	27-MAY-16	0.379	ppb
51048	51048-3-HAL-F01	Fountain - Outside Room 306, 2nd Fl. Main Bldg.	Flush180	27-MAY-16	0.452	ppb
51048	51048-3-HAL-F01	Fountain - Outside Room 306, 2nd Fl. Main Bldg.	Flush180	27-MAY-16	0.508	ppb
51048	51048-3-HAL-F01	Fountain - Outside Room 306, 2nd Fl. Main Bldg.	Flush180	27-MAY-16	0.508	ppb
51048	51048-3-HAL-F01	Fountain - Outside Room 306, 2nd Fl. Main Bldg.	Flush180	06-AUG-20	2.020	ug/L
51048	51048-3-HAL-F01	Fountain - Outside Room 306, 2nd Fl. Main Bldg.	Flush180	09-MAR-22	93.600	ug/L
51048	51048-3-HAL-F01	Fountain - Outside Room 306, 2nd Fl. Main Bldg.	Flush180	09-MAR-22	125.000	ug/L
51048	51048-3-HAL-F01	Fountain - Outside Room 306, 2nd Fl. Main Bldg.	Flush180	09-MAR-22	69.200	ug/L
51048	51048-3-HAL-F01	Fountain - Outside Room 306, 2nd Fl. Main Bldg.	Flush180	09-MAR-22	78.200	ug/L
51048	51048-3-HAL-F01	Fountain - Outside Room 306, 2nd Fl. Main Bldg.	Flush180	29-JUN-22	1.780	ug/L
51048	51048-3-HAL-F01	Fountain - Outside Room 306, 2nd Fl. Main Bldg.	Flush180	29-JUN-22	2.010	ug/L
51048	51048-3-HAL-F01	Fountain - Outside Room 306, 2nd Fl. Main Bldg.	Flush180	29-JUN-22	2.210	ug/L
51048	51048-3-HAL-F01	Fountain - Outside Room 306, 2nd Fl. Main Bldg.	Flush180	29-JUN-22	2.200	ug/L
51048	51048-3-HAL-F01	Fountain - Outside Room 306, 2nd Fl. Main Bldg.	Flush180	15-APR-22	5.360	ug/L
51048	51048-3-HAL-F01	Fountain - Outside Room 306, 2nd Fl. Main Bldg.	Flush180	15-APR-22	4.660	ug/L
51048	51048-3-HAL-F01	Fountain - Outside Room 306, 2nd Fl. Main Bldg.	Flush180	15-APR-22	3.750	ug/L
51048	51048-3-HAL-F01	Fountain - Outside Room 306, 2nd Fl. Main Bldg.	Flush180	15-APR-22	3.010	ug/L
51048	51048-3-HAL-F01	Fountain - Outside Room 306, 2nd Fl. Main Bldg.	Initial	27-MAY-16	0.255	ppb
51048	51048-3-HAL-F01	Fountain - Outside Room 306, 2nd Fl. Main Bldg.	Initial	27-MAY-16	0.255	ppb
51048	51048-3-HAL-F01	Fountain - Outside Room 306, 2nd Fl. Main Bldg.	Initial	06-AUG-20	1.690	ug/L
51048	51048-3-HAL-F01	Fountain - Outside Room 306, 2nd Fl. Main Bldg.	Initial	09-MAR-22	57.600	ug/L
51048	51048-3-HAL-F01	Fountain - Outside Room 306, 2nd Fl. Main Bldg.	Initial	29-JUN-22	1.150	ug/L
51048	51048-3-HAL-F01	Fountain - Outside Room 306, 2nd Fl. Main Bldg.	Initial	15-APR-22	3.380	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51048	51048-CAF-F03	Fountain 1 - Basement Lunch Room, Mian Bldg.	Flush180	27-MAY-16	0.439	ppb
51048	51048-CAF-F03	Fountain 1 - Basement Lunch Room, Mian Bldg.	Flush180	27-MAY-16	0.401	ppb
51048	51048-CAF-F03	Fountain 1 - Basement Lunch Room, Mian Bldg.	Flush180	27-MAY-16	0.376	ppb
51048	51048-CAF-F03	Fountain 1 - Basement Lunch Room, Mian Bldg.	Flush180	27-MAY-16	0.528	ppb
51048	51048-B-CAF-F03	Fountain 1 - Basement Lunch Room, Mian Bldg.	Flush180	27-MAY-16	0.528	ppb
51048	51048-B-CAF-F03	Fountain 1 - Basement Lunch Room, Mian Bldg.	Flush180	27-MAY-16	0.376	ppb
51048	51048-B-CAF-F03	Fountain 1 - Basement Lunch Room, Mian Bldg.	Flush180	27-MAY-16	0.439	ppb
51048	51048-B-CAF-F03	Fountain 1 - Basement Lunch Room, Mian Bldg.	Flush180	27-MAY-16	0.401	ppb
51048	51048-B-CAF-F03	Fountain 1 - Basement Lunch Room, Mian Bldg.	Flush180	09-MAR-22	2.420	ug/L
51048	51048-B-CAF-F03	Fountain 1 - Basement Lunch Room, Mian Bldg.	Flush180	09-MAR-22	2.760	ug/L
51048	51048-B-CAF-F03	Fountain 1 - Basement Lunch Room, Mian Bldg.	Flush180	09-MAR-22	3.140	ug/L
51048	51048-B-CAF-F03	Fountain 1 - Basement Lunch Room, Mian Bldg.	Flush180	09-MAR-22	2.510	ug/L
51048	51048-CAF-F03	Fountain 1 - Basement Lunch Room, Mian Bldg.	Initial	27-MAY-16	0.601	ppb
51048	51048-B-CAF-F03	Fountain 1 - Basement Lunch Room, Mian Bldg.	Initial	27-MAY-16	0.601	ppb
51048	51048-B-CAF-F03	Fountain 1 - Basement Lunch Room, Mian Bldg.	Initial	09-MAR-22	2.940	ug/L
51048	51048-B-B6-F05	Fountain 1 - Inside Room B6, Bsmt. Main Bldg.	Flush180	27-MAY-16	1.150	ppb
51048	51048-B-B6-F05	Fountain 1 - Inside Room B6, Bsmt. Main Bldg.	Flush180	27-MAY-16	7.560	ppb
51048	51048-B-B6-F05	Fountain 1 - Inside Room B6, Bsmt. Main Bldg.	Flush180	27-MAY-16	2.870	ppb
51048	51048-B-B6-F05	Fountain 1 - Inside Room B6, Bsmt. Main Bldg.	Flush180	27-MAY-16	2.780	ppb
51048	51048-B-B6-F05	Fountain 1 - Inside Room B6, Bsmt. Main Bldg.	Flush180	27-MAY-16	1.150	ppb
51048	51048-B-B6-F05	Fountain 1 - Inside Room B6, Bsmt. Main Bldg.	Flush180	27-MAY-16	2.780	ppb
51048	51048-B-B6-F05	Fountain 1 - Inside Room B6, Bsmt. Main Bldg.	Flush180	27-MAY-16	2.870	ppb
51048	51048-B-B6-F05	Fountain 1 - Inside Room B6, Bsmt. Main Bldg.	Flush180	27-MAY-16	7.560	ppb
51048	51048-B-B6-F05	Fountain 1 - Inside Room B6, Bsmt. Main Bldg.	Flush180	20-JUL-16	1.460	ppb
51048	51048-B-B6-F05	Fountain 1 - Inside Room B6, Bsmt. Main Bldg.	Flush180	20-JUL-16	0.619	ppb
51048	51048-B-B6-F05	Fountain 1 - Inside Room B6, Bsmt. Main Bldg.	Flush180	20-JUL-16	1.440	ppb
51048	51048-B-B6-F05	Fountain 1 - Inside Room B6, Bsmt. Main Bldg.	Flush180	20-JUL-16	1.250	ppb
51048	51048-B-B6-F05	Fountain 1 - Inside Room B6, Bsmt. Main Bldg.	Flush180	20-JUL-16	0.619	ppb
51048	51048-B-B6-F05	Fountain 1 - Inside Room B6, Bsmt. Main Bldg.	Flush180	20-JUL-16	1.440	ppb
51048	51048-B-B6-F05	Fountain 1 - Inside Room B6, Bsmt. Main Bldg.	Flush180	20-JUL-16	1.460	ppb
51048	51048-B-B6-F05	Fountain 1 - Inside Room B6, Bsmt. Main Bldg.	Flush180	20-JUL-16	1.250	ppb
51048	51048-B-B6-F05	Fountain 1 - Inside Room B6, Bsmt. Main Bldg.	Flush180	28-OCT-16	3.500	ppb
51048	51048-B-B6-F05	Fountain 1 - Inside Room B6, Bsmt. Main Bldg.	Flush180	28-OCT-16	3.700	ppb
51048	51048-B-B6-F05	Fountain 1 - Inside Room B6, Bsmt. Main Bldg.	Flush180	28-OCT-16	2.820	ppb
51048	51048-B-B6-F05	Fountain 1 - Inside Room B6, Bsmt. Main Bldg.	Flush180	28-OCT-16	3.360	ppb
51048	51048-B-B6-F05	Fountain 1 - Inside Room B6, Bsmt. Main Bldg.	Initial	27-MAY-16	19.400	ppb
51048	51048-B-B6-F05	Fountain 1 - Inside Room B6, Bsmt. Main Bldg.	Initial	27-MAY-16	19.400	ppb
51048	51048-B-B6-F05	Fountain 1 - Inside Room B6, Bsmt. Main Bldg.	Initial	20-JUL-16	0.434	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F05	Bsmt. Main Bldg.				
51048	51048-B-B6-F05	Fountain 1 - Inside Room B6, Bsmt. Main Bldg.	Initial	20-JUL-16	0.434	ppb
51048	51048-B-B6-F05	Fountain 1 - Inside Room B6, Bsmt. Main Bldg.	Initial	28-OCT-16	6.680	ppb
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	27-MAY-16	0.569	ppb
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	27-MAY-16	0.551	ppb
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	27-MAY-16	0.768	ppb
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	27-MAY-16	0.569	ppb
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	27-MAY-16	0.653	ppb
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	27-MAY-16	0.768	ppb
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	27-MAY-16	0.653	ppb
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	27-MAY-16	0.551	ppb
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	09-MAR-22	6.140	ug/L
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	09-MAR-22	3.470	ug/L
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	09-MAR-22	1.990	ug/L
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	09-MAR-22	2.860	ug/L
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	19-AUG-22	10.400	ug/L
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	19-AUG-22	6.050	ug/L
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	19-AUG-22	6.000	ug/L
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	19-AUG-22	5.160	ug/L
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	29-JUN-22	5.450	ug/L
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	29-JUN-22	2.260	ug/L
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	29-JUN-22	1.640	ug/L
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	29-JUN-22	1.570	ug/L
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	19-JUL-22	5.580	ug/L
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	19-JUL-22	3.750	ug/L
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	19-JUL-22	3.420	ug/L
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	19-JUL-22	3.060	ug/L
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	15-SEP-22	4.100	ug/L
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	15-SEP-22	1.830	ug/L
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	15-SEP-22	1.510	ug/L
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	15-SEP-22	1.590	ug/L
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	15-APR-22	2.090	ug/L
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	15-APR-22	1.510	ug/L
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	15-APR-22	1.290	ug/L
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	15-APR-22	1.970	ug/L
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	29-SEP-22	2.510	ug/L
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	29-SEP-22	1.420	ug/L
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	29-SEP-22	1.170	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01	1st Fl. Main Bldg.				
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	29-SEP-22	1.000	ug/L
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Initial	27-MAY-16	0.606	ppb
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Initial	27-MAY-16	0.606	ppb
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Initial	09-MAR-22	7.040	ug/L
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Initial	19-AUG-22	29.000	ug/L
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Initial	29-JUN-22	25.000	ug/L
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Initial	19-JUL-22	16.400	ug/L
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Initial	15-SEP-22	6.900	ug/L
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Initial	15-APR-22	5.200	ug/L
51048	51048-1-HAL-F01	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	Initial	29-SEP-22	4.000	ug/L
51048	51048-2-HAL-F02	Fountain 1 - Outside Room 202, 2nd Fl. Main Bldg.	Flush180	27-MAY-16	0.356	ppb
51048	51048-2-HAL-F02	Fountain 1 - Outside Room 202, 2nd Fl. Main Bldg.	Flush180	27-MAY-16	0.362	ppb
51048	51048-2-HAL-F02	Fountain 1 - Outside Room 202, 2nd Fl. Main Bldg.	Flush180	27-MAY-16	0.337	ppb
51048	51048-2-HAL-F02	Fountain 1 - Outside Room 202, 2nd Fl. Main Bldg.	Flush180	27-MAY-16	0.337	ppb
51048	51048-2-HAL-F02	Fountain 1 - Outside Room 202, 2nd Fl. Main Bldg.	Flush180	27-MAY-16	0.353	ppb
51048	51048-2-HAL-F02	Fountain 1 - Outside Room 202, 2nd Fl. Main Bldg.	Flush180	27-MAY-16	0.353	ppb
51048	51048-2-HAL-F02	Fountain 1 - Outside Room 202, 2nd Fl. Main Bldg.	Flush180	27-MAY-16	0.356	ppb
51048	51048-2-HAL-F02	Fountain 1 - Outside Room 202, 2nd Fl. Main Bldg.	Flush180	27-MAY-16	0.362	ppb
51048	51048-2-HAL-F02	Fountain 1 - Outside Room 202, 2nd Fl. Main Bldg.	Initial	27-MAY-16	0.329	ppb
51048	51048-2-HAL-F02	Fountain 1 - Outside Room 202, 2nd Fl. Main Bldg.	Initial	27-MAY-16	0.329	ppb
51048	51048-B-HAL-F08	Fountain 1 - Outside Room B11, Bsmt. Main. Bldg.	Flush180	27-MAY-16	0.904	ppb
51048	51048-B-HAL-F08	Fountain 1 - Outside Room B11, Bsmt. Main. Bldg.	Flush180	27-MAY-16	0.950	ppb
51048	51048-B-HAL-F08	Fountain 1 - Outside Room B11, Bsmt. Main. Bldg.	Flush180	27-MAY-16	0.950	ppb
51048	51048-B-HAL-F08	Fountain 1 - Outside Room B11, Bsmt. Main. Bldg.	Flush180	27-MAY-16	1.260	ppb
51048	51048-B-HAL-F08	Fountain 1 - Outside Room B11, Bsmt. Main. Bldg.	Flush180	27-MAY-16	1.100	ppb
51048	51048-B-HAL-F08	Fountain 1 - Outside Room B11, Bsmt. Main. Bldg.	Flush180	27-MAY-16	1.260	ppb
51048	51048-B-HAL-F08	Fountain 1 - Outside Room B11, Bsmt. Main. Bldg.	Flush180	27-MAY-16	1.100	ppb
51048	51048-B-HAL-F08	Fountain 1 - Outside Room B11, Bsmt. Main. Bldg.	Flush180	27-MAY-16	0.904	ppb
51048	51048-B-HAL-F08	Fountain 1 - Outside Room B11, Bsmt. Main. Bldg.	Flush180	06-AUG-20	3.400	ug/L
51048	51048-B-HAL-F08	Fountain 1 - Outside Room B11, Bsmt. Main. Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-B-HAL-F08	Fountain 1 - Outside Room B11, Bsmt. Main. Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-B-HAL-F08	Fountain 1 - Outside Room B11, Bsmt. Main. Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-B-HAL-F08	Fountain 1 - Outside Room B11, Bsmt. Main. Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-B-HAL-F08	Fountain 1 - Outside Room B11, Bsmt. Main. Bldg.	Flush180	01-OCT-20	1.180	ug/L
51048	51048-B-HAL-F08	Fountain 1 - Outside Room B11, Bsmt. Main. Bldg.	Flush180	01-OCT-20	1.000	ug/L
51048	51048-B-HAL-F08	Fountain 1 - Outside Room B11, Bsmt. Main. Bldg.	Flush180	01-OCT-20	1.390	ug/L
51048	51048-B-HAL-F08	Fountain 1 - Outside Room B11, Bsmt. Main. Bldg.	Flush180	01-OCT-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51048	51048-B-HAL-F08	Fountain 1 - Outside Room B11, Bsmt. Main. Bldg.	Initial	27-MAY-16	1.000	ppb
51048	51048-B-HAL-F08	Fountain 1 - Outside Room B11, Bsmt. Main. Bldg.	Initial	27-MAY-16	1.000	ppb
51048	51048-B-HAL-F08	Fountain 1 - Outside Room B11, Bsmt. Main. Bldg.	Initial	06-AUG-20	7.240	ug/L
51048	51048-B-HAL-F08	Fountain 1 - Outside Room B11, Bsmt. Main. Bldg.	Initial	09-MAR-22	1.350	ug/L
51048	51048-B-HAL-F08	Fountain 1 - Outside Room B11, Bsmt. Main. Bldg.	Initial	01-OCT-20	1.580	ug/L
51048	51048-B-CAF-F04	Fountain 2 - Basement Lunch Room, Main Bldg.	Flush180	27-MAY-16	0.317	ppb
51048	51048-CAF-F04	Fountain 2 - Basement Lunch Room, Main Bldg.	Flush180	27-MAY-16	0.314	ppb
51048	51048-CAF-F04	Fountain 2 - Basement Lunch Room, Main Bldg.	Flush180	27-MAY-16	0.317	ppb
51048	51048-CAF-F04	Fountain 2 - Basement Lunch Room, Main Bldg.	Flush180	27-MAY-16	0.572	ppb
51048	51048-CAF-F04	Fountain 2 - Basement Lunch Room, Main Bldg.	Flush180	27-MAY-16	0.348	ppb
51048	51048-B-CAF-F04	Fountain 2 - Basement Lunch Room, Main Bldg.	Flush180	27-MAY-16	0.572	ppb
51048	51048-B-CAF-F04	Fountain 2 - Basement Lunch Room, Main Bldg.	Flush180	27-MAY-16	0.348	ppb
51048	51048-B-CAF-F04	Fountain 2 - Basement Lunch Room, Main Bldg.	Flush180	27-MAY-16	0.314	ppb
51048	51048-B-CAF-F04	Fountain 2 - Basement Lunch Room, Main Bldg.	Flush180	09-MAR-22	3.440	ug/L
51048	51048-B-CAF-F04	Fountain 2 - Basement Lunch Room, Main Bldg.	Flush180	09-MAR-22	3.890	ug/L
51048	51048-B-CAF-F04	Fountain 2 - Basement Lunch Room, Main Bldg.	Flush180	09-MAR-22	6.660	ug/L
51048	51048-B-CAF-F04	Fountain 2 - Basement Lunch Room, Main Bldg.	Flush180	09-MAR-22	13.400	ug/L
51048	51048-B-CAF-F04	Fountain 2 - Basement Lunch Room, Main Bldg.	Flush180	15-APR-22	1.020	ug/L
51048	51048-B-CAF-F04	Fountain 2 - Basement Lunch Room, Main Bldg.	Flush180	15-APR-22	1.040	ug/L
51048	51048-B-CAF-F04	Fountain 2 - Basement Lunch Room, Main Bldg.	Flush180	15-APR-22	1.080	ug/L
51048	51048-B-CAF-F04	Fountain 2 - Basement Lunch Room, Main Bldg.	Flush180	15-APR-22	1.100	ug/L
51048	51048-CAF-F04	Fountain 2 - Basement Lunch Room, Main Bldg.	Initial	27-MAY-16	0.566	ppb
51048	51048-B-CAF-F04	Fountain 2 - Basement Lunch Room, Main Bldg.	Initial	27-MAY-16	0.566	ppb
51048	51048-B-CAF-F04	Fountain 2 - Basement Lunch Room, Main Bldg.	Initial	09-MAR-22	4.220	ug/L
51048	51048-B-CAF-F04	Fountain 2 - Basement Lunch Room, Main Bldg.	Initial	15-APR-22	1.480	ug/L
51048	51048-1-HAL-F02	Fountain 2 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	27-MAY-16	0.193	ppb
51048	51048-1-HAL-F02	Fountain 2 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	27-MAY-16	0.254	ppb
51048	51048-1-HAL-F02	Fountain 2 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	27-MAY-16	0.548	ppb
51048	51048-1-HAL-F02	Fountain 2 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	27-MAY-16	0.431	ppb
51048	51048-1-HAL-F02	Fountain 2 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	27-MAY-16	0.254	ppb
51048	51048-1-HAL-F02	Fountain 2 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	27-MAY-16	0.431	ppb
51048	51048-1-HAL-F02	Fountain 2 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	27-MAY-16	0.548	ppb
51048	51048-1-HAL-F02	Fountain 2 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	27-MAY-16	0.193	ppb
51048	51048-1-HAL-F02	Fountain 2 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-1-HAL-F02	Fountain 2 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-1-HAL-F02	Fountain 2 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-1-HAL-F02	Fountain 2 - Outside Room 106, 1st Fl. Main Bldg.	Flush180	09-MAR-22	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51048	51048-1-HAL-F02	Fountain 2 - Outside Room 106, 1st Fl. Main Bldg.	Initial	27-MAY-16	0.596	ppb
51048	51048-1-HAL-F02	Fountain 2 - Outside Room 106, 1st Fl. Main Bldg.	Initial	27-MAY-16	0.596	ppb
51048	51048-1-HAL-F02	Fountain 2 - Outside Room 106, 1st Fl. Main Bldg.	Initial	09-MAR-22	3.310	ug/L
51048	51048-2-HAL-F03	Fountain 2 - Outside Room 202, 2nd Fl. Main Bldg.	Flush180	27-MAY-16	0.421	ppb
51048	51048-2-HAL-F03	Fountain 2 - Outside Room 202, 2nd Fl. Main Bldg.	Flush180	27-MAY-16	0.371	ppb
51048	51048-2-HAL-F03	Fountain 2 - Outside Room 202, 2nd Fl. Main Bldg.	Flush180	27-MAY-16	0.381	ppb
51048	51048-2-HAL-F03	Fountain 2 - Outside Room 202, 2nd Fl. Main Bldg.	Flush180	27-MAY-16	0.371	ppb
51048	51048-2-HAL-F03	Fountain 2 - Outside Room 202, 2nd Fl. Main Bldg.	Flush180	27-MAY-16	0.421	ppb
51048	51048-2-HAL-F03	Fountain 2 - Outside Room 202, 2nd Fl. Main Bldg.	Flush180	27-MAY-16	0.376	ppb
51048	51048-2-HAL-F03	Fountain 2 - Outside Room 202, 2nd Fl. Main Bldg.	Flush180	27-MAY-16	0.376	ppb
51048	51048-2-HAL-F03	Fountain 2 - Outside Room 202, 2nd Fl. Main Bldg.	Flush180	27-MAY-16	0.381	ppb
51048	51048-2-HAL-F03	Fountain 2 - Outside Room 202, 2nd Fl. Main Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-2-HAL-F03	Fountain 2 - Outside Room 202, 2nd Fl. Main Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-2-HAL-F03	Fountain 2 - Outside Room 202, 2nd Fl. Main Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-2-HAL-F03	Fountain 2 - Outside Room 202, 2nd Fl. Main Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-2-HAL-F03	Fountain 2 - Outside Room 202, 2nd Fl. Main Bldg.	Initial	27-MAY-16	0.421	ppb
51048	51048-2-HAL-F03	Fountain 2 - Outside Room 202, 2nd Fl. Main Bldg.	Initial	27-MAY-16	0.421	ppb
51048	51048-2-HAL-F03	Fountain 2 - Outside Room 202, 2nd Fl. Main Bldg.	Initial	09-MAR-22	1.000	ug/L
51048	51048-B-HAL-F09	Fountain 2 - Outside Room B11, Bsmt. Main. Bldg.	Flush180	27-MAY-16	0.480	ppb
51048	51048-B-HAL-F09	Fountain 2 - Outside Room B11, Bsmt. Main. Bldg.	Flush180	27-MAY-16	0.817	ppb
51048	51048-B-HAL-F09	Fountain 2 - Outside Room B11, Bsmt. Main. Bldg.	Flush180	27-MAY-16	0.204	ppb
51048	51048-B-HAL-F09	Fountain 2 - Outside Room B11, Bsmt. Main. Bldg.	Flush180	27-MAY-16	0.253	ppb
51048	51048-B-HAL-F09	Fountain 2 - Outside Room B11, Bsmt. Main. Bldg.	Flush180	27-MAY-16	0.817	ppb
51048	51048-B-HAL-F09	Fountain 2 - Outside Room B11, Bsmt. Main. Bldg.	Flush180	27-MAY-16	0.480	ppb
51048	51048-B-HAL-F09	Fountain 2 - Outside Room B11, Bsmt. Main. Bldg.	Flush180	27-MAY-16	0.253	ppb
51048	51048-B-HAL-F09	Fountain 2 - Outside Room B11, Bsmt. Main. Bldg.	Flush180	27-MAY-16	0.204	ppb
51048	51048-B-HAL-F09	Fountain 2 - Outside Room B11, Bsmt. Main. Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-B-HAL-F09	Fountain 2 - Outside Room B11, Bsmt. Main. Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-B-HAL-F09	Fountain 2 - Outside Room B11, Bsmt. Main. Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-B-HAL-F09	Fountain 2 - Outside Room B11, Bsmt. Main. Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-B-HAL-F09	Fountain 2 - Outside Room B11, Bsmt. Main. Bldg.	Initial	27-MAY-16	0.832	ppb
51048	51048-B-HAL-F09	Fountain 2 - Outside Room B11, Bsmt. Main. Bldg.	Initial	27-MAY-16	0.832	ppb
51048	51048-B-HAL-F09	Fountain 2 - Outside Room B11, Bsmt. Main. Bldg.	Initial	09-MAR-22	1.180	ug/L
51048	51048-2-HAL-F04	Fountain, Right - Outside Room 206, 2nd Fl. Main Bldg.	Flush180	09-MAR-22	3.050	ug/L
51048	51048-2-HAL-F04	Fountain, Right - Outside Room 206, 2nd Fl. Main Bldg.	Flush180	09-MAR-22	2.870	ug/L
51048	51048-2-HAL-F04	Fountain, Right - Outside Room 206, 2nd Fl. Main Bldg.	Flush180	09-MAR-22	2.930	ug/L
51048	51048-2-HAL-F04	Fountain, Right - Outside Room 206, 2nd Fl. Main Bldg.	Flush180	09-MAR-22	2.550	ug/L
51048	51048-2-HAL-F04	Fountain, Right - Outside Room 206, 2nd Fl. Main Bldg.	Flush180	15-APR-22	1.110	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F04	206, 2nd Fl. Main Bldg.				
51048	51048-2-HAL-F04	Fountain, Right - Outside Room 206, 2nd Fl. Main Bldg.	Flush180	15-APR-22	1.160	ug/L
51048	51048-2-HAL-F04	Fountain, Right - Outside Room 206, 2nd Fl. Main Bldg.	Flush180	15-APR-22	1.370	ug/L
51048	51048-2-HAL-F04	Fountain, Right - Outside Room 206, 2nd Fl. Main Bldg.	Flush180	15-APR-22	1.030	ug/L
51048	51048-2-HAL-F04	Fountain, Right - Outside Room 206, 2nd Fl. Main Bldg.	Initial	09-MAR-22	6.870	ug/L
51048	51048-2-HAL-F04	Fountain, Right - Outside Room 206, 2nd Fl. Main Bldg.	Initial	15-APR-22	1.940	ug/L
51048	51048-B-HAL-F10	North Fountain - Outside Room B11, Bsmt. Main. Bldg.	Flush180	09-MAR-22	1.040	ug/L
51048	51048-B-HAL-F10	North Fountain - Outside Room B11, Bsmt. Main. Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-B-HAL-F10	North Fountain - Outside Room B11, Bsmt. Main. Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-B-HAL-F10	North Fountain - Outside Room B11, Bsmt. Main. Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-B-HAL-F10	North Fountain - Outside Room B11, Bsmt. Main. Bldg.	Initial	09-MAR-22	1.500	ug/L
51048	51048-B-HAL-RBF01	North Retrofit BF - Outside Room B11, Bsmt. Main. Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-B-HAL-RBF01	North Retrofit BF - Outside Room B11, Bsmt. Main. Bldg.	Flush180	09-MAR-22	1.070	ug/L
51048	51048-B-HAL-RBF01	North Retrofit BF - Outside Room B11, Bsmt. Main. Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-B-HAL-RBF01	North Retrofit BF - Outside Room B11, Bsmt. Main. Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-B-HAL-RBF01	North Retrofit BF - Outside Room B11, Bsmt. Main. Bldg.	Initial	09-MAR-22	1.000	ug/L
51048	51048-2-HAL-RBF01	Retrofit BF - Outside Room 202, 2nd Fl. Main Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-2-HAL-RBF01	Retrofit BF - Outside Room 202, 2nd Fl. Main Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-2-HAL-RBF01	Retrofit BF - Outside Room 202, 2nd Fl. Main Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-2-HAL-RBF01	Retrofit BF - Outside Room 202, 2nd Fl. Main Bldg.	Initial	09-MAR-22	1.000	ug/L
51048	51048-B-B6-S06	Sink - Inside Room B6, Bsmt. Main Bldg.	Flush180	27-MAY-16	0.758	ppb
51048	51048-B-B6-S06	Sink - Inside Room B6, Bsmt. Main Bldg.	Flush180	27-MAY-16	0.644	ppb
51048	51048-B-B6-S06	Sink - Inside Room B6, Bsmt. Main Bldg.	Flush180	27-MAY-16	0.514	ppb
51048	51048-B-B6-S06	Sink - Inside Room B6, Bsmt. Main Bldg.	Flush180	27-MAY-16	0.680	ppb
51048	51048-B-B6-S06	Sink - Inside Room B6, Bsmt. Main Bldg.	Flush180	27-MAY-16	0.644	ppb
51048	51048-B-B6-S06	Sink - Inside Room B6, Bsmt. Main Bldg.	Flush180	27-MAY-16	0.680	ppb
51048	51048-B-B6-S06	Sink - Inside Room B6, Bsmt. Main Bldg.	Flush180	27-MAY-16	0.514	ppb
51048	51048-B-B6-S06	Sink - Inside Room B6, Bsmt. Main Bldg.	Flush180	27-MAY-16	0.758	ppb
51048	51048-B-B6-S06	Sink - Inside Room B6, Bsmt. Main Bldg.	Initial	27-MAY-16	0.873	ppb
51048	51048-B-B6-S06	Sink - Inside Room B6, Bsmt. Main Bldg.	Initial	27-MAY-16	0.873	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	27-MAY-16	4.630	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	27-MAY-16	4.420	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	27-MAY-16	5.280	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	27-MAY-16	4.290	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	27-MAY-16	4.290	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	27-MAY-16	4.630	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	27-MAY-16	4.420	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S07	Bsmt. Main Bldg				
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	01-SEP-16	4.900	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	01-SEP-16	7.400	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	27-MAY-16	5.280	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	20-JUL-16	3.920	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	20-JUL-16	4.100	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	20-JUL-16	17.900	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	20-JUL-16	17.900	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	20-JUL-16	8.580	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	20-JUL-16	4.100	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	20-JUL-16	3.920	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	20-JUL-16	8.580	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	17-AUG-16	11.000	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	17-AUG-16	7.100	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	17-AUG-16	8.300	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	17-AUG-16	8.300	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	17-AUG-16	31.000	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	17-AUG-16	11.000	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	17-AUG-16	7.100	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	17-AUG-16	31.000	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	01-SEP-16	3.400	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	01-SEP-16	3.400	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	01-SEP-16	7.400	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	01-SEP-16	4.900	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	01-SEP-16	4.900	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	01-SEP-16	4.900	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	09-MAR-22	1.380	ug/L
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	09-MAR-22	2.120	ug/L
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	09-MAR-22	1.000	ug/L
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Flush180	09-MAR-22	1.000	ug/L
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Initial	27-MAY-16	20.700	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Initial	27-MAY-16	20.700	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Initial	01-SEP-16	53.000	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Initial	20-JUL-16	14.200	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Initial	20-JUL-16	14.200	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Initial	17-AUG-16	79.000	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Initial	17-AUG-16	79.000	ppb
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Initial	01-SEP-16	53.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51048	51048-B-HAL-S07	Sink - Outside Engineering Office, Bsmt. Main Bldg	Initial	09-MAR-22	1.000	ug/L
51048	51048-B-KIT-KS01	Sink 1 - Basement Kitchen, Main Bldg.	Flush180	27-MAY-16	0.430	ppb
51048	51048-B-KIT-KS01	Sink 1 - Basement Kitchen, Main Bldg.	Flush180	27-MAY-16	0.814	ppb
51048	51048-B-KIT-KS01	Sink 1 - Basement Kitchen, Main Bldg.	Flush180	27-MAY-16	0.430	ppb
51048	51048-B-KIT-KS01	Sink 1 - Basement Kitchen, Main Bldg.	Flush180	27-MAY-16	0.630	ppb
51048	51048-B-KIT-KS01	Sink 1 - Basement Kitchen, Main Bldg.	Flush180	27-MAY-16	0.814	ppb
51048	51048-B-KIT-KS01	Sink 1 - Basement Kitchen, Main Bldg.	Flush180	27-MAY-16	1.400	ppb
51048	51048-B-KIT-KS01	Sink 1 - Basement Kitchen, Main Bldg.	Flush180	27-MAY-16	1.400	ppb
51048	51048-B-KIT-KS01	Sink 1 - Basement Kitchen, Main Bldg.	Flush180	27-MAY-16	0.630	ppb
51048	51048-B-KIT-KS01	Sink 1 - Basement Kitchen, Main Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-B-KIT-KS01	Sink 1 - Basement Kitchen, Main Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-B-KIT-KS01	Sink 1 - Basement Kitchen, Main Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-B-KIT-KS01	Sink 1 - Basement Kitchen, Main Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-B-KIT-KS01	Sink 1 - Basement Kitchen, Main Bldg.	Initial	27-MAY-16	0.714	ppb
51048	51048-B-KIT-KS01	Sink 1 - Basement Kitchen, Main Bldg.	Initial	27-MAY-16	0.714	ppb
51048	51048-B-KIT-KS01	Sink 1 - Basement Kitchen, Main Bldg.	Initial	09-MAR-22	1.000	ug/L
51048	51048-B-KIT-KS02	Sink 2 - Basement Kitchen, Mian Bldg.	Flush180	27-MAY-16	1.830	ppb
51048	51048-B-KIT-KS02	Sink 2 - Basement Kitchen, Mian Bldg.	Flush180	27-MAY-16	2.510	ppb
51048	51048-B-KIT-KS02	Sink 2 - Basement Kitchen, Mian Bldg.	Flush180	27-MAY-16	1.510	ppb
51048	51048-B-KIT-KS02	Sink 2 - Basement Kitchen, Mian Bldg.	Flush180	27-MAY-16	1.830	ppb
51048	51048-B-KIT-KS02	Sink 2 - Basement Kitchen, Mian Bldg.	Flush180	27-MAY-16	0.946	ppb
51048	51048-B-KIT-KS02	Sink 2 - Basement Kitchen, Mian Bldg.	Flush180	27-MAY-16	1.510	ppb
51048	51048-B-KIT-KS02	Sink 2 - Basement Kitchen, Mian Bldg.	Flush180	27-MAY-16	2.510	ppb
51048	51048-B-KIT-KS02	Sink 2 - Basement Kitchen, Mian Bldg.	Flush180	27-MAY-16	0.946	ppb
51048	51048-B-KIT-KS02	Sink 2 - Basement Kitchen, Mian Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-B-KIT-KS02	Sink 2 - Basement Kitchen, Mian Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-B-KIT-KS02	Sink 2 - Basement Kitchen, Mian Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-B-KIT-KS02	Sink 2 - Basement Kitchen, Mian Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-B-KIT-KS02	Sink 2 - Basement Kitchen, Mian Bldg.	Initial	27-MAY-16	0.336	ppb
51048	51048-B-KIT-KS02	Sink 2 - Basement Kitchen, Mian Bldg.	Initial	27-MAY-16	0.336	ppb
51048	51048-B-KIT-KS02	Sink 2 - Basement Kitchen, Mian Bldg.	Initial	09-MAR-22	1.000	ug/L
51048	51048-1-HAL-F03	West Fountain, Left - Outside Room 106, 1st Fl. Main Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-1-HAL-F03	West Fountain, Left - Outside Room 106, 1st Fl. Main Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-1-HAL-F03	West Fountain, Left - Outside Room 106, 1st Fl. Main Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-1-HAL-F03	West Fountain, Left - Outside Room 106, 1st Fl. Main Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-1-HAL-F03	West Fountain, Left - Outside Room 106, 1st Fl. Main Bldg.	Initial	09-MAR-22	1.000	ug/L
51048	51048-1-HAL-RBF01	West Fountain, Right - Outside Room 106, 1st Fl. Main Bldg.	Flush180	09-MAR-22	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51048	51048-1-HAL-RBF01	West Fountain, Right - Outside Room 106, 1st Fl. Main Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-1-HAL-RBF01	West Fountain, Right - Outside Room 106, 1st Fl. Main Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-1-HAL-RBF01	West Fountain, Right - Outside Room 106, 1st Fl. Main Bldg.	Flush180	09-MAR-22	1.000	ug/L
51048	51048-1-HAL-RBF01	West Fountain, Right - Outside Room 106, 1st Fl. Main Bldg.	Initial	09-MAR-22	1.000	ug/L
52394	52394-1-122-F01	Annex Bldg. Inside Room 122, Fountain	Flush180	27-MAY-16	1.260	ppb
52394	52394-1-122-F01	Annex Bldg. Inside Room 122, Fountain	Flush180	27-MAY-16	1.310	ppb
52394	52394-1-122-F01	Annex Bldg. Inside Room 122, Fountain	Flush180	27-MAY-16	1.220	ppb
52394	52394-1-122-F01	Annex Bldg. Inside Room 122, Fountain	Flush180	27-MAY-16	1.060	ppb
52394	52394-1-122-F01	Annex Bldg. Inside Room 122, Fountain	Flush180	06-AUG-20	2.370	ug/L
52394	52394-1-122-F01	Annex Bldg. Inside Room 122, Fountain	Flush180	09-MAR-22	1.170	ug/L
52394	52394-1-122-F01	Annex Bldg. Inside Room 122, Fountain	Flush180	09-MAR-22	1.130	ug/L
52394	52394-1-122-F01	Annex Bldg. Inside Room 122, Fountain	Flush180	09-MAR-22	1.360	ug/L
52394	52394-1-122-F01	Annex Bldg. Inside Room 122, Fountain	Flush180	09-MAR-22	1.280	ug/L
52394	52394-1-122-F01	Annex Bldg. Inside Room 122, Fountain	Initial	27-MAY-16	1.320	ppb
52394	52394-1-122-F01	Annex Bldg. Inside Room 122, Fountain	Initial	06-AUG-20	1.740	ug/L
52394	52394-1-122-F01	Annex Bldg. Inside Room 122, Fountain	Initial	09-MAR-22	1.200	ug/L
52394	52394-1-122-S02	Annex Bldg. Inside Room 122, Sink	Flush180	27-MAY-16	1.110	ppb
52394	52394-1-122-S02	Annex Bldg. Inside Room 122, Sink	Flush180	27-MAY-16	1.040	ppb
52394	52394-1-122-S02	Annex Bldg. Inside Room 122, Sink	Flush180	27-MAY-16	1.260	ppb
52394	52394-1-122-S02	Annex Bldg. Inside Room 122, Sink	Flush180	27-MAY-16	1.000	ppb
52394	52394-1-122-S02	Annex Bldg. Inside Room 122, Sink	Flush180	09-MAR-22	1.560	ug/L
52394	52394-1-122-S02	Annex Bldg. Inside Room 122, Sink	Flush180	09-MAR-22	1.300	ug/L
52394	52394-1-122-S02	Annex Bldg. Inside Room 122, Sink	Flush180	09-MAR-22	1.490	ug/L
52394	52394-1-122-S02	Annex Bldg. Inside Room 122, Sink	Flush180	09-MAR-22	1.320	ug/L
52394	52394-1-122-S02	Annex Bldg. Inside Room 122, Sink	Initial	27-MAY-16	3.890	ppb
52394	52394-1-122-S02	Annex Bldg. Inside Room 122, Sink	Initial	09-MAR-22	2.500	ug/L
52394	52394-1-128-F07	Annex Bldg. Inside Room 128, Fountain	Flush180	27-MAY-16	0.963	ppb
52394	52394-1-128-F07	Annex Bldg. Inside Room 128, Fountain	Flush180	27-MAY-16	0.970	ppb
52394	52394-1-128-F07	Annex Bldg. Inside Room 128, Fountain	Flush180	27-MAY-16	1.030	ppb
52394	52394-1-128-F07	Annex Bldg. Inside Room 128, Fountain	Flush180	27-MAY-16	0.973	ppb
52394	52394-1-128-F07	Annex Bldg. Inside Room 128, Fountain	Flush180	09-MAR-22	3.470	ug/L
52394	52394-1-128-F07	Annex Bldg. Inside Room 128, Fountain	Flush180	09-MAR-22	2.970	ug/L
52394	52394-1-128-F07	Annex Bldg. Inside Room 128, Fountain	Flush180	09-MAR-22	2.810	ug/L
52394	52394-1-128-F07	Annex Bldg. Inside Room 128, Fountain	Flush180	09-MAR-22	2.340	ug/L
52394	52394-1-128-F07	Annex Bldg. Inside Room 128, Fountain	Flush180	29-JUN-22	14.100	ug/L
52394	52394-1-128-F07	Annex Bldg. Inside Room 128, Fountain	Flush180	29-JUN-22	12.100	ug/L
52394	52394-1-128-F07	Annex Bldg. Inside Room 128, Fountain	Flush180	29-JUN-22	8.690	ug/L
52394	52394-1-128-F07	Annex Bldg. Inside Room 128, Fountain	Flush180	29-JUN-22	6.980	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F07	Fountain				
52394	52394-1-128-F07	Annex Bldg. Inside Room 128, Fountain	Flush180	19-JUL-22	1.340	ug/L
52394	52394-1-128-F07	Annex Bldg. Inside Room 128, Fountain	Flush180	19-JUL-22	1.000	ug/L
52394	52394-1-128-F07	Annex Bldg. Inside Room 128, Fountain	Flush180	19-JUL-22	1.000	ug/L
52394	52394-1-128-F07	Annex Bldg. Inside Room 128, Fountain	Flush180	19-JUL-22	1.000	ug/L
52394	52394-1-128-F07	Annex Bldg. Inside Room 128, Fountain	Flush180	15-APR-22	3.320	ug/L
52394	52394-1-128-F07	Annex Bldg. Inside Room 128, Fountain	Flush180	15-APR-22	2.100	ug/L
52394	52394-1-128-F07	Annex Bldg. Inside Room 128, Fountain	Flush180	15-APR-22	1.790	ug/L
52394	52394-1-128-F07	Annex Bldg. Inside Room 128, Fountain	Flush180	15-APR-22	1.520	ug/L
52394	52394-1-128-F07	Annex Bldg. Inside Room 128, Fountain	Initial	27-MAY-16	0.939	ppb
52394	52394-1-128-F07	Annex Bldg. Inside Room 128, Fountain	Initial	09-MAR-22	68.300	ug/L
52394	52394-1-128-F07	Annex Bldg. Inside Room 128, Fountain	Initial	29-JUN-22	12.100	ug/L
52394	52394-1-128-F07	Annex Bldg. Inside Room 128, Fountain	Initial	19-JUL-22	1.000	ug/L
52394	52394-1-128-F07	Annex Bldg. Inside Room 128, Fountain	Initial	15-APR-22	11.900	ug/L
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Flush180	27-MAY-16	1.920	ppb
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Flush180	27-MAY-16	1.680	ppb
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Flush180	27-MAY-16	4.650	ppb
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Flush180	27-MAY-16	1.490	ppb
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Flush180	09-MAR-22	5.630	ug/L
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Flush180	09-MAR-22	7.140	ug/L
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Flush180	09-MAR-22	5.200	ug/L
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Flush180	15-SEP-22	3.310	ug/L
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Flush180	19-AUG-22	1.320	ug/L
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Flush180	19-AUG-22	1.060	ug/L
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Flush180	19-AUG-22	1.040	ug/L
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Flush180	19-AUG-22	2.310	ug/L
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Flush180	29-JUN-22	3.070	ug/L
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Flush180	29-JUN-22	4.950	ug/L
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Flush180	29-JUN-22	9.010	ug/L
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Flush180	29-JUN-22	12.800	ug/L
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Flush180	19-JUL-22	49.000	ug/L
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Flush180	19-JUL-22	58.800	ug/L
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Flush180	19-JUL-22	108.000	ug/L
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Flush180	19-JUL-22	180.000	ug/L
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Flush180	15-SEP-22	1.590	ug/L
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Flush180	15-SEP-22	1.270	ug/L
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Flush180	15-SEP-22	3.660	ug/L
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Flush180	09-MAR-22	4.160	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S06	Sink				
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Flush180	15-APR-22	17.900	ug/L
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Flush180	15-APR-22	20.800	ug/L
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Flush180	15-APR-22	12.500	ug/L
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Flush180	15-APR-22	35.500	ug/L
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Initial	27-MAY-16	4.650	ppb
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Initial	19-AUG-22	14.800	ug/L
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Initial	29-JUN-22	4.060	ug/L
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Initial	19-JUL-22	51.800	ug/L
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Initial	15-SEP-22	4.880	ug/L
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Initial	09-MAR-22	6.380	ug/L
52394	52394-1-128-S06	Annex Bldg. Inside Room 128, Sink	Initial	15-APR-22	11.500	ug/L
52394	52394-1-HAL-S03	Annex Bldg. Outside Boys Bathroom, Sink	Flush180	27-MAY-16	0.501	ppb
52394	52394-1-HAL-S03	Annex Bldg. Outside Boys Bathroom, Sink	Flush180	27-MAY-16	0.608	ppb
52394	52394-1-HAL-S03	Annex Bldg. Outside Boys Bathroom, Sink	Flush180	27-MAY-16	0.322	ppb
52394	52394-1-HAL-S03	Annex Bldg. Outside Boys Bathroom, Sink	Flush180	27-MAY-16	0.527	ppb
52394	52394-1-HAL-S03	Annex Bldg. Outside Boys Bathroom, Sink	Flush180	09-MAR-22	1.000	ug/L
52394	52394-1-HAL-S03	Annex Bldg. Outside Boys Bathroom, Sink	Flush180	09-MAR-22	1.000	ug/L
52394	52394-1-HAL-S03	Annex Bldg. Outside Boys Bathroom, Sink	Flush180	09-MAR-22	1.000	ug/L
52394	52394-1-HAL-S03	Annex Bldg. Outside Boys Bathroom, Sink	Flush180	09-MAR-22	1.000	ug/L
52394	52394-1-HAL-S03	Annex Bldg. Outside Boys Bathroom, Sink	Initial	27-MAY-16	0.716	ppb
52394	52394-1-HAL-S03	Annex Bldg. Outside Boys Bathroom, Sink	Initial	09-MAR-22	1.000	ug/L
52394	52394-1-HAL-F04	Annex Bldg. Outside Girls Bathroom, Fountain 1	Flush180	27-MAY-16	0.213	ppb
52394	52394-1-HAL-F04	Annex Bldg. Outside Girls Bathroom, Fountain 1	Flush180	27-MAY-16	0.216	ppb
52394	52394-1-HAL-F04	Annex Bldg. Outside Girls Bathroom, Fountain 1	Flush180	27-MAY-16	0.281	ppb
52394	52394-1-HAL-F04	Annex Bldg. Outside Girls Bathroom, Fountain 1	Flush180	27-MAY-16	0.209	ppb
52394	52394-1-HAL-F04	Annex Bldg. Outside Girls Bathroom, Fountain 1	Flush180	06-AUG-20	3.040	ug/L
52394	52394-1-HAL-F04	Annex Bldg. Outside Girls Bathroom, Fountain 1	Flush180	09-MAR-22	1.760	ug/L
52394	52394-1-HAL-F04	Annex Bldg. Outside Girls Bathroom, Fountain 1	Flush180	09-MAR-22	2.000	ug/L
52394	52394-1-HAL-F04	Annex Bldg. Outside Girls Bathroom, Fountain 1	Flush180	09-MAR-22	1.840	ug/L
52394	52394-1-HAL-F04	Annex Bldg. Outside Girls Bathroom, Fountain 1	Flush180	09-MAR-22	1.660	ug/L
52394	52394-1-HAL-F04	Annex Bldg. Outside Girls Bathroom, Fountain 1	Initial	27-MAY-16	0.511	ppb
52394	52394-1-HAL-F04	Annex Bldg. Outside Girls Bathroom, Fountain 1	Initial	06-AUG-20	1.470	ug/L
52394	52394-1-HAL-F04	Annex Bldg. Outside Girls Bathroom, Fountain 1	Initial	09-MAR-22	1.000	ug/L
52394	52394-1-HAL-F05	Annex Bldg. Outside Girls Bathroom, Fountain 2	Flush180	27-MAY-16	0.324	ppb
52394	52394-1-HAL-F05	Annex Bldg. Outside Girls Bathroom, Fountain 2	Flush180	27-MAY-16	0.312	ppb
52394	52394-1-HAL-F05	Annex Bldg. Outside Girls Bathroom, Fountain 2	Flush180	27-MAY-16	0.302	ppb
52394	52394-1-HAL-F05	Annex Bldg. Outside Girls Bathroom, Fountain 2	Flush180	27-MAY-16	0.314	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52394	52394-1-HAL-F05	Annex Bldg. Outside Girls Bathroom, Fountain 2	Initial	27-MAY-16	0.145	ppb
52394	52394-1-HAL-RBF01	Annex Bldg. Outside Girls Bathroom,Retrofit Bottle Filler	Flush180	09-MAR-22	1.000	ug/L
52394	52394-1-HAL-RBF01	Annex Bldg. Outside Girls Bathroom,Retrofit Bottle Filler	Flush180	09-MAR-22	1.000	ug/L
52394	52394-1-HAL-RBF01	Annex Bldg. Outside Girls Bathroom,Retrofit Bottle Filler	Flush180	09-MAR-22	1.000	ug/L
52394	52394-1-HAL-RBF01	Annex Bldg. Outside Girls Bathroom,Retrofit Bottle Filler	Flush180	09-MAR-22	1.000	ug/L
52394	52394-1-HAL-RBF01	Annex Bldg. Outside Girls Bathroom,Retrofit Bottle Filler	Initial	09-MAR-22	1.000	ug/L
52394	52394-1-123-BF01	Room 123, Bottle Filler	Flush180	10-AUG-23	1.000	ug/L
52394	52394-1-123-BF01	Room 123, Bottle Filler	Flush180	10-AUG-23	1.000	ug/L
52394	52394-1-123-BF01	Room 123, Bottle Filler	Flush180	10-AUG-23	1.000	ug/L
52394	52394-1-123-BF01	Room 123, Bottle Filler	Flush180	10-AUG-23	1.000	ug/L
52394	52394-1-123-BF01	Room 123, Bottle Filler	Initial	10-AUG-23	1.000	ug/L
52394	52394-1-123-F01	Room 123, Fountain	Flush180	10-AUG-23	1.000	ug/L
52394	52394-1-123-F01	Room 123, Fountain	Flush180	10-AUG-23	1.000	ug/L
52394	52394-1-123-F01	Room 123, Fountain	Flush180	10-AUG-23	1.000	ug/L
52394	52394-1-123-F01	Room 123, Fountain	Initial	10-AUG-23	1.000	ug/L
52394	52394-1-123-S01	Room 123, Left Sink	Flush180	10-AUG-23	1.850	ug/L
52394	52394-1-123-S01	Room 123, Left Sink	Flush180	10-AUG-23	1.350	ug/L
52394	52394-1-123-S01	Room 123, Left Sink	Flush180	10-AUG-23	1.220	ug/L
52394	52394-1-123-S01	Room 123, Left Sink	Flush180	10-AUG-23	1.080	ug/L
52394	52394-1-123-S01	Room 123, Left Sink	Initial	10-AUG-23	3.870	ug/L
52394	52394-1-123-S02	Room 123, Right Sink	Flush180	10-AUG-23	1.340	ug/L
52394	52394-1-123-S02	Room 123, Right Sink	Flush180	10-AUG-23	1.360	ug/L
52394	52394-1-123-S02	Room 123, Right Sink	Flush180	10-AUG-23	1.180	ug/L
52394	52394-1-123-S02	Room 123, Right Sink	Flush180	10-AUG-23	1.160	ug/L
52394	52394-1-123-S02	Room 123, Right Sink	Initial	10-AUG-23	4.570	ug/L