



Sep 10, 2024

BOGAN HS

3939 W 79TH ST, Chicago IL 60652.

Dear **BOGAN HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

BOGAN HS

3939 W 79TH ST, Chicago IL 60652.

Estimadas familias de **BOGAN HS**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51606	51606-1-GYM-F24	Main- Boys Gym, Locker Room, Left Fountain	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-GYM-F24	Main- Boys Gym, Locker Room, Left Fountain	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-GYM-F24	Main- Boys Gym, Locker Room, Left Fountain	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-GYM-F24	Main- Boys Gym, Locker Room, Left Fountain	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-GYM-F24	Main- Boys Gym, Locker Room, Left Fountain	Initial	07-OCT-16	1.000	ppb
51606	51606-1-GYM-F25	Main- Boys Gym, Locker Room, Right Fountain	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-GYM-F25	Main- Boys Gym, Locker Room, Right Fountain	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-GYM-F25	Main- Boys Gym, Locker Room, Right Fountain	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-GYM-F25	Main- Boys Gym, Locker Room, Right Fountain	Initial	07-OCT-16	1.000	ppb
51606	51606-1-GYM-F23	Main- Boys Gym, Southwest Corner, Right Fountain	Flush180	07-OCT-16	2.400	ppb
51606	51606-1-GYM-F23	Main- Boys Gym, Southwest Corner, Right Fountain	Flush180	07-OCT-16	4.300	ppb
51606	51606-1-GYM-F23	Main- Boys Gym, Southwest Corner, Right Fountain	Flush180	07-OCT-16	5.900	ppb
51606	51606-1-GYM-F23	Main- Boys Gym, Southwest Corner, Right Fountain	Flush180	07-OCT-16	4.000	ppb
51606	51606-1-GYM-F23	Main- Boys Gym, Southwest Corner, Right Fountain	Initial	07-OCT-16	3.400	ppb
51606	51606-1-GYM-F27	Main- Girls Gym, Locker Room, Left Fountain	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-GYM-F27	Main- Girls Gym, Locker Room, Left Fountain	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-GYM-F27	Main- Girls Gym, Locker Room, Left Fountain	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-GYM-F27	Main- Girls Gym, Locker Room, Left Fountain	Initial	07-OCT-16	1.000	ppb
51606	51606-1-GYM-F26	Main- Girls Gym, Locker Room, Right Fountain	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-GYM-F26	Main- Girls Gym, Locker Room, Right Fountain	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-GYM-F26	Main- Girls Gym, Locker Room, Right Fountain	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-GYM-F26	Main- Girls Gym, Locker Room, Right Fountain	Initial	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS14	Main- Island Sinks, East Sink	Flush	07-NOV-2023	2.250	ug/L
51606	51606-1-KIT-KS14	Main- Island Sinks, East Sink	Flush	07-NOV-2023	2.680	ug/L
51606	51606-1-KIT-KS14	Main- Island Sinks, East Sink	Flush	07-NOV-2023	2.270	ug/L
51606	51606-1-KIT-KS14	Main- Island Sinks, East Sink	Flush	07-NOV-2023	1.730	ug/L
51606	51606-1-KIT-KS14	Main- Island Sinks, East Sink	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS14	Main- Island Sinks, East Sink	Flush180	07-OCT-16	6.200	ppb
51606	51606-1-KIT-KS14	Main- Island Sinks, East Sink	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS14	Main- Island Sinks, East Sink	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS14	Main- Island Sinks, East Sink	Initial	07-OCT-16	5.800	ppb
51606	51606-1-KIT-KS14	Main- Island Sinks, East Sink	Initial	07-NOV-2023	3.460	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51606	51606-1-KIT-KS13	Main- Island Sinks, West Sink	Flush	30-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS13	Main- Island Sinks, West Sink	Flush	30-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS13	Main- Island Sinks, West Sink	Flush	30-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS13	Main- Island Sinks, West Sink	Flush	30-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS13	Main- Island Sinks, West Sink	Flush	07-NOV-2023	3.530	ug/L
51606	51606-1-KIT-KS13	Main- Island Sinks, West Sink	Flush	07-NOV-2023	2.100	ug/L
51606	51606-1-KIT-KS13	Main- Island Sinks, West Sink	Flush	07-NOV-2023	1.820	ug/L
51606	51606-1-KIT-KS13	Main- Island Sinks, West Sink	Flush	07-NOV-2023	1.580	ug/L
51606	51606-1-KIT-KS13	Main- Island Sinks, West Sink	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS13	Main- Island Sinks, West Sink	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS13	Main- Island Sinks, West Sink	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS13	Main- Island Sinks, West Sink	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS13	Main- Island Sinks, West Sink	Initial	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS13	Main- Island Sinks, West Sink	Initial	30-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS13	Main- Island Sinks, West Sink	Initial	07-NOV-2023	14.500	ug/L
51606	51606-1-KIT-KS02	Main- Kitchen, East Wall, Center Faucet	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS02	Main- Kitchen, East Wall, Center Faucet	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS02	Main- Kitchen, East Wall, Center Faucet	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS02	Main- Kitchen, East Wall, Center Faucet	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS02	Main- Kitchen, East Wall, Center Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS02	Main- Kitchen, East Wall, Center Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS02	Main- Kitchen, East Wall, Center Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS02	Main- Kitchen, East Wall, Center Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS02	Main- Kitchen, East Wall, Center Faucet	Initial	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS02	Main- Kitchen, East Wall, Center Faucet	Initial	07-NOV-2023	4.260	ug/L
51606	51606-1-KIT-KS01	Main- Kitchen, East Wall, Left Faucet	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS01	Main- Kitchen, East Wall, Left Faucet	Flush	07-NOV-2023	1.020	ug/L
51606	51606-1-KIT-KS01	Main- Kitchen, East Wall, Left Faucet	Flush	07-NOV-2023	1.050	ug/L
51606	51606-1-KIT-KS01	Main- Kitchen, East Wall, Left Faucet	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS01	Main- Kitchen, East Wall, Left Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS01	Main- Kitchen, East Wall, Left Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS01	Main- Kitchen, East Wall, Left Faucet	Flush180	07-OCT-16	2.400	ppb
51606	51606-1-KIT-KS01	Main- Kitchen, East Wall, Left Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS01	Main- Kitchen, East Wall, Left Faucet	Initial	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS01	Main- Kitchen, East Wall, Left Faucet	Initial	07-NOV-2023	4.300	ug/L
51606	51606-1-KIT-KS03	Main- Kitchen, East Wall, Right Faucet	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS03	Main- Kitchen, East Wall, Right Faucet	Flush	07-NOV-2023	1.420	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51606	51606-1-KIT-KS03	Main- Kitchen, East Wall, Right Faucet	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS03	Main- Kitchen, East Wall, Right Faucet	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS03	Main- Kitchen, East Wall, Right Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS03	Main- Kitchen, East Wall, Right Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS03	Main- Kitchen, East Wall, Right Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS03	Main- Kitchen, East Wall, Right Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS03	Main- Kitchen, East Wall, Right Faucet	Initial	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS03	Main- Kitchen, East Wall, Right Faucet	Initial	07-NOV-2023	3.000	ug/L
51606	51606-1-KIT-KS05	Main- Kitchen, South Wall, Center Faucet	Flush	30-NOV-2023	1.280	ug/L
51606	51606-1-KIT-KS05	Main- Kitchen, South Wall, Center Faucet	Flush	30-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS05	Main- Kitchen, South Wall, Center Faucet	Flush	30-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS05	Main- Kitchen, South Wall, Center Faucet	Flush	30-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS05	Main- Kitchen, South Wall, Center Faucet	Flush	07-NOV-2023	3.150	ug/L
51606	51606-1-KIT-KS05	Main- Kitchen, South Wall, Center Faucet	Flush	07-NOV-2023	3.650	ug/L
51606	51606-1-KIT-KS05	Main- Kitchen, South Wall, Center Faucet	Flush	07-NOV-2023	2.850	ug/L
51606	51606-1-KIT-KS05	Main- Kitchen, South Wall, Center Faucet	Flush	07-NOV-2023	3.060	ug/L
51606	51606-1-KIT-KS05	Main- Kitchen, South Wall, Center Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS05	Main- Kitchen, South Wall, Center Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS05	Main- Kitchen, South Wall, Center Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS05	Main- Kitchen, South Wall, Center Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS05	Main- Kitchen, South Wall, Center Faucet	Initial	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS05	Main- Kitchen, South Wall, Center Faucet	Initial	30-NOV-2023	1.060	ug/L
51606	51606-1-KIT-KS05	Main- Kitchen, South Wall, Center Faucet	Initial	07-NOV-2023	18.700	ug/L
51606	51606-1-KIT-KS04	Main- Kitchen, South Wall, Left Faucet	Flush	07-NOV-2023	1.320	ug/L
51606	51606-1-KIT-KS04	Main- Kitchen, South Wall, Left Faucet	Flush	30-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS04	Main- Kitchen, South Wall, Left Faucet	Flush	30-NOV-2023	1.690	ug/L
51606	51606-1-KIT-KS04	Main- Kitchen, South Wall, Left Faucet	Flush	30-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS04	Main- Kitchen, South Wall, Left Faucet	Flush	30-NOV-2023	1.130	ug/L
51606	51606-1-KIT-KS04	Main- Kitchen, South Wall, Left Faucet	Flush	07-NOV-2023	1.110	ug/L
51606	51606-1-KIT-KS04	Main- Kitchen, South Wall, Left Faucet	Flush	07-NOV-2023	1.390	ug/L
51606	51606-1-KIT-KS04	Main- Kitchen, South Wall, Left Faucet	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS04	Main- Kitchen, South Wall, Left Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS04	Main- Kitchen, South Wall, Left Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS04	Main- Kitchen, South Wall, Left Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS04	Main- Kitchen, South Wall, Left Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS04	Main- Kitchen, South Wall, Left Faucet	Initial	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS04	Main- Kitchen, South Wall, Left Faucet	Initial	30-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS04	Main- Kitchen, South Wall, Left Faucet	Initial	07-NOV-2023	7.790	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS04	Faucet				
51606	51606-1-KIT-KS06	Main- Kitchen, South Wall, Right Faucet	Flush	07-NOV-2023	2.220	ug/L
51606	51606-1-KIT-KS06	Main- Kitchen, South Wall, Right Faucet	Flush	07-NOV-2023	1.970	ug/L
51606	51606-1-KIT-KS06	Main- Kitchen, South Wall, Right Faucet	Flush	07-NOV-2023	1.800	ug/L
51606	51606-1-KIT-KS06	Main- Kitchen, South Wall, Right Faucet	Flush	07-NOV-2023	1.560	ug/L
51606	51606-1-KIT-KS06	Main- Kitchen, South Wall, Right Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS06	Main- Kitchen, South Wall, Right Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS06	Main- Kitchen, South Wall, Right Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS06	Main- Kitchen, South Wall, Right Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS06	Main- Kitchen, South Wall, Right Faucet	Initial	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS06	Main- Kitchen, South Wall, Right Faucet	Initial	07-NOV-2023	2.410	ug/L
51606	51606-1-KIT-KS07	Main- Kitchen, Southwest Wall, Sink	Flush	07-NOV-2023	1.050	ug/L
51606	51606-1-KIT-KS07	Main- Kitchen, Southwest Wall, Sink	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS07	Main- Kitchen, Southwest Wall, Sink	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS07	Main- Kitchen, Southwest Wall, Sink	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS07	Main- Kitchen, Southwest Wall, Sink	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS07	Main- Kitchen, Southwest Wall, Sink	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS07	Main- Kitchen, Southwest Wall, Sink	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS07	Main- Kitchen, Southwest Wall, Sink	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS07	Main- Kitchen, Southwest Wall, Sink	Initial	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS07	Main- Kitchen, Southwest Wall, Sink	Initial	07-NOV-2023	3.180	ug/L
51606	51606-1-HAL-F15	Main- Outside Room 106, Fountain	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-HAL-F15	Main- Outside Room 106, Fountain	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-HAL-F15	Main- Outside Room 106, Fountain	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-HAL-F15	Main- Outside Room 106, Fountain	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-HAL-F15	Main- Outside Room 106, Fountain	Initial	07-OCT-16	3.000	ppb
51606	51606-1-HAL-BF02	Main- Outside Room 120, Bottle Filler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-HAL-BF02	Main- Outside Room 120, Bottle Filler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-HAL-BF02	Main- Outside Room 120, Bottle Filler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-HAL-BF02	Main- Outside Room 120, Bottle Filler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-HAL-BF02	Main- Outside Room 120, Bottle Filler	Initial	07-NOV-2023	1.000	ug/L
51606	51606-1-HAL-WC16	Main- Outside Room 120, Water Cooler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-HAL-WC16	Main- Outside Room 120, Water Cooler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-HAL-WC16	Main- Outside Room 120, Water Cooler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-HAL-WC16	Main- Outside Room 120, Water Cooler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-HAL-WC16	Main- Outside Room 120, Water Cooler	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-HAL-WC16	Main- Outside Room 120, Water Cooler	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-HAL-WC16	Main- Outside Room 120, Water Cooler	Flush180	07-OCT-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	WC16	Cooler				
51606	51606-1-HAL-WC16	Main- Outside Room 120, Water Cooler	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-HAL-WC16	Main- Outside Room 120, Water Cooler	Flush180	18-DEC-20	1.000	ug/L
51606	51606-1-HAL-WC16	Main- Outside Room 120, Water Cooler	Initial	07-OCT-16	1.000	ppb
51606	51606-1-HAL-WC16	Main- Outside Room 120, Water Cooler	Initial	18-DEC-20	1.000	ug/L
51606	51606-1-HAL-WC16	Main- Outside Room 120, Water Cooler	Initial	07-NOV-2023	1.000	ug/L
51606	51606-1-HAL-BF03	Main- Outside Room 131, Bottle Filler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-HAL-BF03	Main- Outside Room 131, Bottle Filler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-HAL-BF03	Main- Outside Room 131, Bottle Filler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-HAL-BF03	Main- Outside Room 131, Bottle Filler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-HAL-BF03	Main- Outside Room 131, Bottle Filler	Initial	07-NOV-2023	1.000	ug/L
51606	51606-1-HAL-WC18	Main- Outside Room 131, Water Cooler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-HAL-WC18	Main- Outside Room 131, Water Cooler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-HAL-WC18	Main- Outside Room 131, Water Cooler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-HAL-WC18	Main- Outside Room 131, Water Cooler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-HAL-WC18	Main- Outside Room 131, Water Cooler	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-HAL-WC18	Main- Outside Room 131, Water Cooler	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-HAL-WC18	Main- Outside Room 131, Water Cooler	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-HAL-WC18	Main- Outside Room 131, Water Cooler	Initial	07-OCT-16	1.000	ppb
51606	51606-1-HAL-WC18	Main- Outside Room 131, Water Cooler	Initial	07-NOV-2023	1.000	ug/L
51606	51606-1-HAL-BF01	Main- Outside Room 139, Bottle Filler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-HAL-BF01	Main- Outside Room 139, Bottle Filler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-HAL-BF01	Main- Outside Room 139, Bottle Filler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-HAL-BF01	Main- Outside Room 139, Bottle Filler	Initial	07-NOV-2023	1.000	ug/L
51606	51606-1-HAL-F19	Main- Outside Room 139, Fountain	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-HAL-F19	Main- Outside Room 139, Fountain	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-HAL-F19	Main- Outside Room 139, Fountain	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-HAL-F19	Main- Outside Room 139, Fountain	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-HAL-F19	Main- Outside Room 139, Fountain	Flush180	07-OCT-16	6.200	ppb
51606	51606-1-HAL-F19	Main- Outside Room 139, Fountain	Flush180	07-OCT-16	6.100	ppb
51606	51606-1-HAL-F19	Main- Outside Room 139, Fountain	Flush180	07-OCT-16	5.700	ppb
51606	51606-1-HAL-F19	Main- Outside Room 139, Fountain	Flush180	07-OCT-16	4.200	ppb
51606	51606-1-HAL-F19	Main- Outside Room 139, Fountain	Initial	07-OCT-16	3.400	ppb
51606	51606-1-HAL-F19	Main- Outside Room 139, Fountain	Initial	07-NOV-2023	1.000	ug/L
51606	51606-1-HAL-WC17	Main- Outside Room 140, Water Cooler	Flush	30-NOV-2023	20.900	ug/L
51606	51606-1-HAL-WC17	Main- Outside Room 140, Water Cooler	Flush	30-NOV-2023	22.200	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51606	51606-1-HAL-WC17	Main- Outside Room 140, Water Cooler	Flush	07-NOV-2023	8.060	ug/L
51606	51606-1-HAL-WC17	Main- Outside Room 140, Water Cooler	Flush	07-NOV-2023	17.900	ug/L
51606	51606-1-HAL-WC17	Main- Outside Room 140, Water Cooler	Flush	07-NOV-2023	19.800	ug/L
51606	51606-1-HAL-WC17	Main- Outside Room 140, Water Cooler	Flush	07-NOV-2023	19.100	ug/L
51606	51606-1-HAL-WC17	Main- Outside Room 140, Water Cooler	Flush	30-NOV-2023	13.600	ug/L
51606	51606-1-HAL-WC17	Main- Outside Room 140, Water Cooler	Flush	30-NOV-2023	20.600	ug/L
51606	51606-1-HAL-WC17	Main- Outside Room 140, Water Cooler	Flush	27-DEC-2023	5.560	ug/L
51606	51606-1-HAL-WC17	Main- Outside Room 140, Water Cooler	Flush	27-DEC-2023	8.660	ug/L
51606	51606-1-HAL-WC17	Main- Outside Room 140, Water Cooler	Flush	27-DEC-2023	11.000	ug/L
51606	51606-1-HAL-WC17	Main- Outside Room 140, Water Cooler	Flush	27-DEC-2023	11.200	ug/L
51606	51606-1-HAL-WC17	Main- Outside Room 140, Water Cooler	Flush	17-JAN-2024	2.040	ug/L
51606	51606-1-HAL-WC17	Main- Outside Room 140, Water Cooler	Flush	17-JAN-2024	3.910	ug/L
51606	51606-1-HAL-WC17	Main- Outside Room 140, Water Cooler	Flush	17-JAN-2024	5.500	ug/L
51606	51606-1-HAL-WC17	Main- Outside Room 140, Water Cooler	Flush	17-JAN-2024	6.170	ug/L
51606	51606-1-HAL-WC17	Main- Outside Room 140, Water Cooler	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-HAL-WC17	Main- Outside Room 140, Water Cooler	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-HAL-WC17	Main- Outside Room 140, Water Cooler	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-HAL-WC17	Main- Outside Room 140, Water Cooler	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-HAL-WC17	Main- Outside Room 140, Water Cooler	Initial	07-OCT-16	1.000	ppb
51606	51606-1-HAL-WC17	Main- Outside Room 140, Water Cooler	Initial	30-NOV-2023	12.500	ug/L
51606	51606-1-HAL-WC17	Main- Outside Room 140, Water Cooler	Initial	07-NOV-2023	6.170	ug/L
51606	51606-1-HAL-WC17	Main- Outside Room 140, Water Cooler	Initial	27-DEC-2023	4.210	ug/L
51606	51606-1-HAL-WC17	Main- Outside Room 140, Water Cooler	Initial	17-JAN-2024	2.160	ug/L
51606	51606-2-HAL-BF01	Main- Outside Room 212, Bottle Filler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-2-HAL-BF01	Main- Outside Room 212, Bottle Filler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-2-HAL-BF01	Main- Outside Room 212, Bottle Filler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-2-HAL-BF01	Main- Outside Room 212, Bottle Filler	Initial	07-NOV-2023	1.000	ug/L
51606	51606-2-HAL-WC01	Main- Outside Room 212, Water Cooler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-2-HAL-WC01	Main- Outside Room 212, Water Cooler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-2-HAL-WC01	Main- Outside Room 212, Water Cooler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-2-HAL-WC01	Main- Outside Room 212, Water Cooler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-2-HAL-WC01	Main- Outside Room 212, Water Cooler	Flush180	07-OCT-16	1.000	ppb
51606	51606-2-HAL-WC01	Main- Outside Room 212, Water Cooler	Flush180	07-OCT-16	1.000	ppb
51606	51606-2-HAL-WC01	Main- Outside Room 212, Water Cooler	Flush180	07-OCT-16	1.000	ppb
51606	51606-2-HAL-WC01	Main- Outside Room 212, Water Cooler	Flush180	07-OCT-16	1.000	ppb
51606	51606-2-HAL-WC01	Main- Outside Room 212, Water Cooler	Initial	07-OCT-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51606	51606-2-HAL-WC01	Main- Outside Room 212, Water Cooler	Initial	07-NOV-2023	1.000	ug/L
51606	51606-2-HAL-F02	Main- Outside Room 218, Fountain	Flush180	07-OCT-16	1.000	ppb
51606	51606-2-HAL-F02	Main- Outside Room 218, Fountain	Flush180	07-OCT-16	1.000	ppb
51606	51606-2-HAL-F02	Main- Outside Room 218, Fountain	Flush180	07-OCT-16	1.000	ppb
51606	51606-2-HAL-F02	Main- Outside Room 218, Fountain	Flush180	07-OCT-16	1.000	ppb
51606	51606-2-HAL-F02	Main- Outside Room 218, Fountain	Initial	07-OCT-16	1.000	ppb
51606	51606-2-HAL-BF03	Main- Outside Room 231, Bottle Filler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-2-HAL-BF03	Main- Outside Room 231, Bottle Filler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-2-HAL-BF03	Main- Outside Room 231, Bottle Filler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-2-HAL-BF03	Main- Outside Room 231, Bottle Filler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-2-HAL-BF03	Main- Outside Room 231, Bottle Filler	Initial	07-NOV-2023	1.000	ug/L
51606	51606-2-HAL-WC04	Main- Outside Room 231, Water Cooler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-2-HAL-WC04	Main- Outside Room 231, Water Cooler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-2-HAL-WC04	Main- Outside Room 231, Water Cooler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-2-HAL-WC04	Main- Outside Room 231, Water Cooler	Flush	07-NOV-2023	1.000	ug/L
51606	51606-2-HAL-WC04	Main- Outside Room 231, Water Cooler	Flush180	07-OCT-16	1.000	ppb
51606	51606-2-HAL-WC04	Main- Outside Room 231, Water Cooler	Flush180	07-OCT-16	1.000	ppb
51606	51606-2-HAL-WC04	Main- Outside Room 231, Water Cooler	Flush180	07-OCT-16	1.000	ppb
51606	51606-2-HAL-WC04	Main- Outside Room 231, Water Cooler	Flush180	07-OCT-16	1.000	ppb
51606	51606-2-HAL-WC04	Main- Outside Room 231, Water Cooler	Initial	07-OCT-16	1.000	ppb
51606	51606-2-HAL-WC04	Main- Outside Room 231, Water Cooler	Initial	07-NOV-2023	1.000	ug/L
51606	51606-2-HAL-BF02	Main- Outside Room 238, Bottle Filler	Flush	07-NOV-2023	1.190	ug/L
51606	51606-2-HAL-BF02	Main- Outside Room 238, Bottle Filler	Flush	07-NOV-2023	1.110	ug/L
51606	51606-2-HAL-BF02	Main- Outside Room 238, Bottle Filler	Flush	07-NOV-2023	1.090	ug/L
51606	51606-2-HAL-BF02	Main- Outside Room 238, Bottle Filler	Flush	07-NOV-2023	1.010	ug/L
51606	51606-2-HAL-BF02	Main- Outside Room 238, Bottle Filler	Initial	07-NOV-2023	1.220	ug/L
51606	51606-2-HAL-WC03	Main- Outside Room 238, Water Cooler	Flush	07-NOV-2023	1.040	ug/L
51606	51606-2-HAL-WC03	Main- Outside Room 238, Water Cooler	Flush	07-NOV-2023	1.150	ug/L
51606	51606-2-HAL-WC03	Main- Outside Room 238, Water Cooler	Flush	07-NOV-2023	1.210	ug/L
51606	51606-2-HAL-WC03	Main- Outside Room 238, Water Cooler	Flush	07-NOV-2023	1.180	ug/L
51606	51606-2-HAL-WC03	Main- Outside Room 238, Water Cooler	Flush180	07-OCT-16	1.000	ppb
51606	51606-2-HAL-WC03	Main- Outside Room 238, Water Cooler	Flush180	07-OCT-16	1.000	ppb
51606	51606-2-HAL-WC03	Main- Outside Room 238, Water Cooler	Flush180	07-OCT-16	1.000	ppb
51606	51606-2-HAL-WC03	Main- Outside Room 238, Water Cooler	Flush180	07-OCT-16	1.000	ppb
51606	51606-2-HAL-WC03	Main- Outside Room 238, Water Cooler	Flush180	18-DEC-20	2.020	ug/L
51606	51606-2-HAL-WC03	Main- Outside Room 238, Water Cooler	Initial	07-OCT-16	1.000	ppb
51606	51606-2-HAL-WC03	Main- Outside Room 238, Water Cooler	Initial	18-DEC-20	1.780	ug/L
51606	51606-2-HAL-	Main- Outside Room 238, Water	Initial	07-NOV-2023	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	WC03	Cooler				
51606	51606-1-POOL-F28	Main- Swimming Pool, North Wall, Left Fountain	Flush180	07-OCT-16	4.400	ppb
51606	51606-1-POOL-F28	Main- Swimming Pool, North Wall, Left Fountain	Flush180	07-OCT-16	3.700	ppb
51606	51606-1-POOL-F28	Main- Swimming Pool, North Wall, Left Fountain	Flush180	07-OCT-16	2.400	ppb
51606	51606-1-POOL-F28	Main- Swimming Pool, North Wall, Left Fountain	Flush180	07-OCT-16	2.800	ppb
51606	51606-1-POOL-F28	Main- Swimming Pool, North Wall, Left Fountain	Initial	07-OCT-16	3.900	ppb
51606	51606-1-POOL-F29	Main- Swimming Pool, North Wall, Right Fountain	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-POOL-F29	Main- Swimming Pool, North Wall, Right Fountain	Flush180	07-OCT-16	6.300	ppb
51606	51606-1-POOL-F29	Main- Swimming Pool, North Wall, Right Fountain	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-POOL-F29	Main- Swimming Pool, North Wall, Right Fountain	Flush180	07-OCT-16	4.900	ppb
51606	51606-1-POOL-F29	Main- Swimming Pool, North Wall, Right Fountain	Initial	07-OCT-16	3.300	ppb
51606	51606-1-KIT-KS11	Main- West Wall, 2-Basin, Left Faucet	Flush	07-NOV-2023	4.390	ug/L
51606	51606-1-KIT-KS11	Main- West Wall, 2-Basin, Left Faucet	Flush	07-NOV-2023	2.280	ug/L
51606	51606-1-KIT-KS11	Main- West Wall, 2-Basin, Left Faucet	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS11	Main- West Wall, 2-Basin, Left Faucet	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS11	Main- West Wall, 2-Basin, Left Faucet	Flush180	07-OCT-16	120.000	ppb
51606	51606-1-KIT-KS11	Main- West Wall, 2-Basin, Left Faucet	Flush180	07-OCT-16	2.100	ppb
51606	51606-1-KIT-KS11	Main- West Wall, 2-Basin, Left Faucet	Flush180	07-OCT-16	5.300	ppb
51606	51606-1-KIT-KS11	Main- West Wall, 2-Basin, Left Faucet	Flush180	07-OCT-16	16.000	ppb
51606	51606-1-KIT-KS11	Main- West Wall, 2-Basin, Left Faucet	Flush180	08-NOV-16	98.000	ppb
51606	51606-1-KIT-KS11	Main- West Wall, 2-Basin, Left Faucet	Flush180	08-NOV-16	49.000	ppb
51606	51606-1-KIT-KS11	Main- West Wall, 2-Basin, Left Faucet	Flush180	08-NOV-16	34.000	ppb
51606	51606-1-KIT-KS11	Main- West Wall, 2-Basin, Left Faucet	Flush180	08-NOV-16	59.000	ppb
51606	51606-1-KIT-KS11	Main- West Wall, 2-Basin, Left Faucet	Flush180	08-SEP-17	13.700	ppb
51606	51606-1-KIT-KS11	Main- West Wall, 2-Basin, Left Faucet	Flush180	08-SEP-17	11.700	ppb
51606	51606-1-KIT-KS11	Main- West Wall, 2-Basin, Left Faucet	Flush180	08-SEP-17	10.100	ppb
51606	51606-1-KIT-KS11	Main- West Wall, 2-Basin, Left Faucet	Flush180	08-SEP-17	23.100	ppb
51606	51606-1-KIT-KS11	Main- West Wall, 2-Basin, Left Faucet	Flush180	06-OCT-17	4.760	ppb
51606	51606-1-KIT-KS11	Main- West Wall, 2-Basin, Left Faucet	Flush180	06-OCT-17	2.480	ppb
51606	51606-1-KIT-KS11	Main- West Wall, 2-Basin, Left Faucet	Flush180	06-OCT-17	2.170	ppb
51606	51606-1-KIT-KS11	Main- West Wall, 2-Basin, Left Faucet	Flush180	06-OCT-17	2.560	ppb
51606	51606-1-KIT-KS11	Main- West Wall, 2-Basin, Left Faucet	Initial	07-OCT-16	100.000	ppb
51606	51606-1-KIT-KS11	Main- West Wall, 2-Basin, Left Faucet	Initial	08-NOV-16	6.800	ppb
51606	51606-1-KIT-KS11	Main- West Wall, 2-Basin, Left Faucet	Initial	06-OCT-17	1.640	ppb
51606	51606-1-KIT-KS11	Main- West Wall, 2-Basin, Left Faucet	Initial	08-SEP-17	79.200	ppb
51606	51606-1-KIT-KS11	Main- West Wall, 2-Basin, Left Faucet	Initial	07-NOV-2023	2.900	ug/L
51606	51606-1-KIT-KS12	Main- West Wall, 2-Basin, Right Faucet	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-KIT-	Main- West Wall, 2-Basin, Right	Flush	07-NOV-2023	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS12	Faucet				
51606	51606-1-KIT-KS12	Main- West Wall, 2-Basin, Right Faucet	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS12	Main- West Wall, 2-Basin, Right Faucet	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS12	Main- West Wall, 2-Basin, Right Faucet	Flush180	08-NOV-16	23.000	ppb
51606	51606-1-KIT-KS12	Main- West Wall, 2-Basin, Right Faucet	Flush180	08-NOV-16	37.000	ppb
51606	51606-1-KIT-KS12	Main- West Wall, 2-Basin, Right Faucet	Flush180	08-NOV-16	54.000	ppb
51606	51606-1-KIT-KS12	Main- West Wall, 2-Basin, Right Faucet	Flush180	08-SEP-17	65.100	ppb
51606	51606-1-KIT-KS12	Main- West Wall, 2-Basin, Right Faucet	Flush180	08-SEP-17	22.900	ppb
51606	51606-1-KIT-KS12	Main- West Wall, 2-Basin, Right Faucet	Flush180	08-SEP-17	18.400	ppb
51606	51606-1-KIT-KS12	Main- West Wall, 2-Basin, Right Faucet	Flush180	08-SEP-17	21.200	ppb
51606	51606-1-KIT-KS12	Main- West Wall, 2-Basin, Right Faucet	Flush180	07-OCT-16	4.800	ppb
51606	51606-1-KIT-KS12	Main- West Wall, 2-Basin, Right Faucet	Flush180	08-NOV-16	160.000	ppb
51606	51606-1-KIT-KS12	Main- West Wall, 2-Basin, Right Faucet	Flush180	07-OCT-16	2.200	ppb
51606	51606-1-KIT-KS12	Main- West Wall, 2-Basin, Right Faucet	Flush180	07-OCT-16	49.000	ppb
51606	51606-1-KIT-KS12	Main- West Wall, 2-Basin, Right Faucet	Flush180	07-OCT-16	9.700	ppb
51606	51606-1-KIT-KS12	Main- West Wall, 2-Basin, Right Faucet	Flush180	06-OCT-17	3.390	ppb
51606	51606-1-KIT-KS12	Main- West Wall, 2-Basin, Right Faucet	Flush180	06-OCT-17	2.850	ppb
51606	51606-1-KIT-KS12	Main- West Wall, 2-Basin, Right Faucet	Flush180	06-OCT-17	2.210	ppb
51606	51606-1-KIT-KS12	Main- West Wall, 2-Basin, Right Faucet	Flush180	06-OCT-17	3.080	ppb
51606	51606-1-KIT-KS12	Main- West Wall, 2-Basin, Right Faucet	Initial	08-SEP-17	89.500	ppb
51606	51606-1-KIT-KS12	Main- West Wall, 2-Basin, Right Faucet	Initial	06-OCT-17	3.320	ppb
51606	51606-1-KIT-KS12	Main- West Wall, 2-Basin, Right Faucet	Initial	08-NOV-16	360.000	ppb
51606	51606-1-KIT-KS12	Main- West Wall, 2-Basin, Right Faucet	Initial	07-OCT-16	37.000	ppb
51606	51606-1-KIT-KS12	Main- West Wall, 2-Basin, Right Faucet	Initial	07-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS09	Main- West Wall, 3-Basin, Center Faucet	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS09	Main- West Wall, 3-Basin, Center Faucet	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS09	Main- West Wall, 3-Basin, Center Faucet	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS09	Main- West Wall, 3-Basin, Center Faucet	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS09	Main- West Wall, 3-Basin, Center Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS09	Main- West Wall, 3-Basin, Center Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS09	Main- West Wall, 3-Basin, Center Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS09	Main- West Wall, 3-Basin, Center Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS09	Main- West Wall, 3-Basin, Center Faucet	Flush180	27-OCT-17	0.777	ppb
51606	51606-1-KIT-KS09	Main- West Wall, 3-Basin, Center Faucet	Flush180	27-OCT-17	0.868	ppb
51606	51606-1-KIT-KS09	Main- West Wall, 3-Basin, Center Faucet	Flush180	27-OCT-17	0.899	ppb
51606	51606-1-KIT-KS09	Main- West Wall, 3-Basin, Center Faucet	Flush180	27-OCT-17	0.898	ppb
51606	51606-1-KIT-KS09	Main- West Wall, 3-Basin, Center Faucet	Initial	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS09	Main- West Wall, 3-Basin, Center Faucet	Initial	27-OCT-17	2.030	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51606	51606-1-KIT-KS09	Main- West Wall, 3-Basin, Center Faucet	Initial	07-NOV-2023	1.690	ug/L
51606	51606-1-KIT-KS08	Main- West Wall, 3-Basin, Left Faucet	Flush	07-NOV-2023	1.090	ug/L
51606	51606-1-KIT-KS08	Main- West Wall, 3-Basin, Left Faucet	Flush	07-NOV-2023	1.160	ug/L
51606	51606-1-KIT-KS08	Main- West Wall, 3-Basin, Left Faucet	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS08	Main- West Wall, 3-Basin, Left Faucet	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS08	Main- West Wall, 3-Basin, Left Faucet	Flush180	27-OCT-17	0.973	ppb
51606	51606-1-KIT-KS08	Main- West Wall, 3-Basin, Left Faucet	Flush180	27-OCT-17	0.880	ppb
51606	51606-1-KIT-KS08	Main- West Wall, 3-Basin, Left Faucet	Flush180	27-OCT-17	0.962	ppb
51606	51606-1-KIT-KS08	Main- West Wall, 3-Basin, Left Faucet	Flush180	27-OCT-17	0.958	ppb
51606	51606-1-KIT-KS08	Main- West Wall, 3-Basin, Left Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS08	Main- West Wall, 3-Basin, Left Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS08	Main- West Wall, 3-Basin, Left Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS08	Main- West Wall, 3-Basin, Left Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS08	Main- West Wall, 3-Basin, Left Faucet	Initial	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS08	Main- West Wall, 3-Basin, Left Faucet	Initial	27-OCT-17	1.240	ppb
51606	51606-1-KIT-KS08	Main- West Wall, 3-Basin, Left Faucet	Initial	07-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS10	Main- West Wall, 3-Basin, Right Faucet	Flush	07-NOV-2023	1.040	ug/L
51606	51606-1-KIT-KS10	Main- West Wall, 3-Basin, Right Faucet	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS10	Main- West Wall, 3-Basin, Right Faucet	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS10	Main- West Wall, 3-Basin, Right Faucet	Flush	07-NOV-2023	1.000	ug/L
51606	51606-1-KIT-KS10	Main- West Wall, 3-Basin, Right Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS10	Main- West Wall, 3-Basin, Right Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS10	Main- West Wall, 3-Basin, Right Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS10	Main- West Wall, 3-Basin, Right Faucet	Flush180	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS10	Main- West Wall, 3-Basin, Right Faucet	Flush180	27-OCT-17	1.160	ppb
51606	51606-1-KIT-KS10	Main- West Wall, 3-Basin, Right Faucet	Flush180	27-OCT-17	1.020	ppb
51606	51606-1-KIT-KS10	Main- West Wall, 3-Basin, Right Faucet	Flush180	27-OCT-17	0.874	ppb
51606	51606-1-KIT-KS10	Main- West Wall, 3-Basin, Right Faucet	Flush180	27-OCT-17	0.747	ppb
51606	51606-1-KIT-KS10	Main- West Wall, 3-Basin, Right Faucet	Initial	07-OCT-16	1.000	ppb
51606	51606-1-KIT-KS10	Main- West Wall, 3-Basin, Right Faucet	Initial	27-OCT-17	3.390	ppb
51606	51606-1-KIT-KS10	Main- West Wall, 3-Basin, Right Faucet	Initial	07-NOV-2023	2.600	ug/L