



Sep 10, 2024

**BOND**

**7050 S MAY ST, Chicago IL 60621.**

Dear **BOND** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**BOND**

**7050 S MAY ST, Chicago IL 60621.**

Estimadas familias de **BOND**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51387	51387-1-120-F01	Inside Room 120, Fountain	Flush180	01-DEC-21	3.650	ug/L
51387	51387-1-120-F01	Inside Room 120, Fountain	Flush180	01-DEC-21	3.370	ug/L
51387	51387-1-120-F01	Inside Room 120, Fountain	Flush180	01-DEC-21	2.050	ug/L
51387	51387-1-120-F01	Inside Room 120, Fountain	Flush180	01-DEC-21	1.400	ug/L
51387	51387-1-120-F01	Inside Room 120, Fountain	Initial	01-DEC-21	3.730	ug/L
51387	51387-1-121-F01	Inside Room 121, Fountain	Flush180	01-DEC-21	1.000	ug/L
51387	51387-1-121-F01	Inside Room 121, Fountain	Flush180	01-DEC-21	1.000	ug/L
51387	51387-1-121-F01	Inside Room 121, Fountain	Flush180	01-DEC-21	1.000	ug/L
51387	51387-1-121-F01	Inside Room 121, Fountain	Flush180	01-DEC-21	1.000	ug/L
51387	51387-1-121-F01	Inside Room 121, Fountain	Initial	01-DEC-21	1.870	ug/L
51387	51387-1-123-F01	Inside Room 123, Fountain	Flush180	01-DEC-21	1.000	ug/L
51387	51387-1-123-F01	Inside Room 123, Fountain	Flush180	01-DEC-21	1.000	ug/L
51387	51387-1-123-F01	Inside Room 123, Fountain	Flush180	01-DEC-21	1.000	ug/L
51387	51387-1-123-F01	Inside Room 123, Fountain	Flush180	01-DEC-21	1.000	ug/L
51387	51387-1-123-F01	Inside Room 123, Fountain	Initial	01-DEC-21	1.000	ug/L
51387	51387-1-HAL-F02	Main - Across Room 100 Hallway, Fountain 1	Flush180	10-JUN-16	1.000	ppb
51387	51387-1-HAL-F02	Main - Across Room 100 Hallway, Fountain 1	Flush180	10-JUN-16	1.000	ppb
51387	51387-1-HAL-F02	Main - Across Room 100 Hallway, Fountain 1	Flush180	10-JUN-16	1.000	ppb
51387	51387-1-HAL-F02	Main - Across Room 100 Hallway, Fountain 1	Flush180	10-JUN-16	1.000	ppb
51387	51387-1-HAL-F02	Main - Across Room 100 Hallway, Fountain 1	Flush180	10-JUN-16	1.000	ppb
51387	51387-1-HAL-F02	Main - Across Room 100 Hallway, Fountain 1	Flush180	10-JUN-16	1.000	ppb
51387	51387-1-HAL-F02	Main - Across Room 100 Hallway, Fountain 1	Flush180	10-JUN-16	1.000	ppb
51387	51387-1-HAL-F02	Main - Across Room 100 Hallway, Fountain 1	Initial	10-JUN-16	1.000	ppb
51387	51387-1-HAL-F02	Main - Across Room 100 Hallway, Fountain 1	Initial	10-JUN-16	1.000	ppb
51387	51387-1-HAL-F03	Main - Across Room 100 Hallway, Fountain 2	Flush180	10-JUN-16	1.000	ppb
51387	51387-1-HAL-F03	Main - Across Room 100 Hallway, Fountain 2	Flush180	10-JUN-16	1.000	ppb
51387	51387-1-HAL-F03	Main - Across Room 100 Hallway, Fountain 2	Flush180	10-JUN-16	1.000	ppb
51387	51387-1-HAL-F03	Main - Across Room 100 Hallway, Fountain 2	Flush180	10-JUN-16	1.000	ppb
51387	51387-1-HAL-F03	Main - Across Room 100 Hallway, Fountain 2	Flush180	10-JUN-16	1.000	ppb
51387	51387-1-HAL-F03	Main - Across Room 100 Hallway, Fountain 2	Flush180	10-JUN-16	1.000	ppb
51387	51387-1-HAL-F03	Main - Across Room 100 Hallway, Fountain 2	Flush180	10-JUN-16	1.000	ppb
51387	51387-1-HAL-F03	Main - Across Room 100 Hallway, Fountain 2	Flush180	10-JUN-16	1.000	ppb
51387	51387-1-HAL-F03	Main - Across Room 100 Hallway, Fountain 2	Flush180	09-OCT-20	1.000	ug/L
51387	51387-1-HAL-F03	Main - Across Room 100 Hallway, Fountain 2	Initial	10-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51387	51387-1-HAL-F03	Main - Across Room 100 Hallway, Fountain 2	Initial	10-JUN-16	1.000	ppb
51387	51387-1-HAL-F03	Main - Across Room 100 Hallway, Fountain 2	Initial	09-OCT-20	1.000	ug/L
51387	51387-1-HAL-F01	Main - Across Room 102 Hallway, Fountain	Flush180	10-JUN-16	1.000	ppb
51387	51387-1-HAL-F01	Main - Across Room 102 Hallway, Fountain	Flush180	10-JUN-16	1.000	ppb
51387	51387-1-HAL-F01	Main - Across Room 102 Hallway, Fountain	Flush180	10-JUN-16	1.000	ppb
51387	51387-1-HAL-F01	Main - Across Room 102 Hallway, Fountain	Flush180	10-JUN-16	1.000	ppb
51387	51387-1-HAL-F01	Main - Across Room 102 Hallway, Fountain	Flush180	10-JUN-16	1.000	ppb
51387	51387-1-HAL-F01	Main - Across Room 102 Hallway, Fountain	Flush180	10-JUN-16	1.000	ppb
51387	51387-1-HAL-F01	Main - Across Room 102 Hallway, Fountain	Flush180	10-JUN-16	1.000	ppb
51387	51387-1-HAL-F01	Main - Across Room 102 Hallway, Fountain	Flush180	10-JUN-16	1.000	ppb
51387	51387-1-HAL-F01	Main - Across Room 102 Hallway, Fountain	Flush180	09-OCT-20	1.000	ug/L
51387	51387-1-HAL-F01	Main - Across Room 102 Hallway, Fountain	Initial	10-JUN-16	0.127	ppb
51387	51387-1-HAL-F01	Main - Across Room 102 Hallway, Fountain	Initial	10-JUN-16	0.127	ppb
51387	51387-1-HAL-F01	Main - Across Room 102 Hallway, Fountain	Initial	09-OCT-20	1.000	ug/L
51387	51387-2-HAL-F01	Main - Across Room 204 Hallway, Fountain 1	Flush180	10-JUN-16	1.000	ppb
51387	51387-2-HAL-F01	Main - Across Room 204 Hallway, Fountain 1	Flush180	10-JUN-16	0.126	ppb
51387	51387-2-HAL-F01	Main - Across Room 204 Hallway, Fountain 1	Flush180	10-JUN-16	1.000	ppb
51387	51387-2-HAL-F01	Main - Across Room 204 Hallway, Fountain 1	Flush180	10-JUN-16	0.152	ppb
51387	51387-2-HAL-F01	Main - Across Room 204 Hallway, Fountain 1	Flush180	10-JUN-16	0.152	ppb
51387	51387-2-HAL-F01	Main - Across Room 204 Hallway, Fountain 1	Flush180	10-JUN-16	1.000	ppb
51387	51387-2-HAL-F01	Main - Across Room 204 Hallway, Fountain 1	Flush180	10-JUN-16	0.126	ppb
51387	51387-2-HAL-F01	Main - Across Room 204 Hallway, Fountain 1	Flush180	10-JUN-16	1.000	ppb
51387	51387-2-HAL-F01	Main - Across Room 204 Hallway, Fountain 1	Initial	10-JUN-16	1.000	ppb
51387	51387-2-HAL-F01	Main - Across Room 204 Hallway, Fountain 1	Initial	10-JUN-16	1.000	ppb
51387	51387-2-HAL-F02	Main - Across Room 204 Hallway, Fountain 2	Flush180	10-JUN-16	0.129	ppb
51387	51387-2-HAL-F02	Main - Across Room 204 Hallway, Fountain 2	Flush180	10-JUN-16	0.150	ppb
51387	51387-2-HAL-F02	Main - Across Room 204 Hallway, Fountain 2	Flush180	10-JUN-16	0.124	ppb
51387	51387-2-HAL-F02	Main - Across Room 204 Hallway, Fountain 2	Flush180	10-JUN-16	0.139	ppb
51387	51387-2-HAL-F02	Main - Across Room 204 Hallway, Fountain 2	Flush180	10-JUN-16	0.124	ppb
51387	51387-2-HAL-F02	Main - Across Room 204 Hallway, Fountain 2	Flush180	10-JUN-16	0.129	ppb
51387	51387-2-HAL-F02	Main - Across Room 204 Hallway, Fountain 2	Flush180	10-JUN-16	0.150	ppb
51387	51387-2-HAL-F02	Main - Across Room 204 Hallway, Fountain 2	Flush180	10-JUN-16	0.139	ppb
51387	51387-2-HAL-F02	Main - Across Room 204 Hallway, Fountain 2	Initial	10-JUN-16	0.194	ppb
51387	51387-2-HAL-F02	Main - Across Room 204 Hallway, Fountain 2	Initial	10-JUN-16	0.194	ppb
51387	51387-G-KIT-KS01	Main - Kitchen Sink (1)	Flush180	10-JUN-16	0.548	ppb
51387	51387-G-KIT-KS01	Main - Kitchen Sink (1)	Flush180	10-JUN-16	0.448	ppb
51387	51387-G-KIT-KS01	Main - Kitchen Sink (1)	Flush180	10-JUN-16	0.520	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51387	51387-G-KIT-KS01	Main - Kitchen Sink (1)	Flush180	10-JUN-16	0.448	ppb
51387	51387-G-KIT-KS01	Main - Kitchen Sink (1)	Flush180	10-JUN-16	0.520	ppb
51387	51387-G-KIT-KS01	Main - Kitchen Sink (1)	Flush180	10-JUN-16	0.503	ppb
51387	51387-G-KIT-KS01	Main - Kitchen Sink (1)	Flush180	10-JUN-16	0.548	ppb
51387	51387-G-KIT-KS01	Main - Kitchen Sink (1)	Flush180	10-JUN-16	0.503	ppb
51387	51387-G-KIT-KS01	Main - Kitchen Sink (1)	Initial	10-JUN-16	0.577	ppb
51387	51387-G-KIT-KS01	Main - Kitchen Sink (1)	Initial	10-JUN-16	0.577	ppb
51387	51387-G-KIT-KS02	Main - Kitchen Sink (2)	Flush180	10-JUN-16	0.420	ppb
51387	51387-G-KIT-KS02	Main - Kitchen Sink (2)	Flush180	10-JUN-16	0.420	ppb
51387	51387-G-KIT-KS02	Main - Kitchen Sink (2)	Flush180	10-JUN-16	0.460	ppb
51387	51387-G-KIT-KS02	Main - Kitchen Sink (2)	Flush180	10-JUN-16	0.459	ppb
51387	51387-G-KIT-KS02	Main - Kitchen Sink (2)	Flush180	10-JUN-16	0.459	ppb
51387	51387-G-KIT-KS02	Main - Kitchen Sink (2)	Flush180	10-JUN-16	0.386	ppb
51387	51387-G-KIT-KS02	Main - Kitchen Sink (2)	Flush180	10-JUN-16	0.460	ppb
51387	51387-G-KIT-KS02	Main - Kitchen Sink (2)	Flush180	10-JUN-16	0.386	ppb
51387	51387-G-KIT-KS02	Main - Kitchen Sink (2)	Initial	10-JUN-16	0.604	ppb
51387	51387-G-KIT-KS02	Main - Kitchen Sink (2)	Initial	10-JUN-16	0.604	ppb
51387	51387-G-KIT-KS03	Main - Kitchen Sink (3)	Flush180	10-JUN-16	0.428	ppb
51387	51387-G-KIT-KS03	Main - Kitchen Sink (3)	Flush180	10-JUN-16	0.445	ppb
51387	51387-G-KIT-KS03	Main - Kitchen Sink (3)	Flush180	10-JUN-16	0.421	ppb
51387	51387-G-KIT-KS03	Main - Kitchen Sink (3)	Flush180	10-JUN-16	0.459	ppb
51387	51387-G-KIT-KS03	Main - Kitchen Sink (3)	Flush180	10-JUN-16	0.445	ppb
51387	51387-G-KIT-KS03	Main - Kitchen Sink (3)	Flush180	10-JUN-16	0.421	ppb
51387	51387-G-KIT-KS03	Main - Kitchen Sink (3)	Flush180	10-JUN-16	0.459	ppb
51387	51387-G-KIT-KS03	Main - Kitchen Sink (3)	Flush180	10-JUN-16	0.428	ppb
51387	51387-G-KIT-KS03	Main - Kitchen Sink (3)	Initial	10-JUN-16	0.352	ppb
51387	51387-G-KIT-KS03	Main - Kitchen Sink (3)	Initial	10-JUN-16	0.352	ppb
51387	51387-G-KIT-KS04	Main - Kitchen Sink (4)	Flush180	10-JUN-16	0.935	ppb
51387	51387-G-KIT-KS04	Main - Kitchen Sink (4)	Flush180	10-JUN-16	1.450	ppb
51387	51387-G-KIT-KS04	Main - Kitchen Sink (4)	Flush180	10-JUN-16	0.935	ppb
51387	51387-G-KIT-KS04	Main - Kitchen Sink (4)	Flush180	10-JUN-16	1.380	ppb
51387	51387-G-KIT-KS04	Main - Kitchen Sink (4)	Flush180	10-JUN-16	1.810	ppb
51387	51387-G-KIT-KS04	Main - Kitchen Sink (4)	Flush180	10-JUN-16	1.810	ppb
51387	51387-G-KIT-KS04	Main - Kitchen Sink (4)	Flush180	10-JUN-16	1.450	ppb
51387	51387-G-KIT-KS04	Main - Kitchen Sink (4)	Flush180	10-JUN-16	1.380	ppb
51387	51387-G-KIT-KS04	Main - Kitchen Sink (4)	Initial	10-JUN-16	2.550	ppb
51387	51387-G-KIT-KS04	Main - Kitchen Sink (4)	Initial	10-JUN-16	2.550	ppb
57831	57831-1-HAL-	Annex - Across Room 120	Flush180	10-JUN-16	1.270	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02	Hallway, Fountain 2				
57831	57831-1-HAL-F02	Annex - Across Room 129 Hallway, Fountain 2	Initial	10-JUN-16	2.710	ppb
57831	57831-1-HAL-F02	Annex - Across Room 129 Hallway, Fountain 2	Initial	10-JUN-16	2.710	ppb
57831	57831-1-HAL-F03	Annex - Across Room 145 Hallway, Fountain 1	Flush180	10-JUN-16	0.346	ppb
57831	57831-1-HAL-F03	Annex - Across Room 145 Hallway, Fountain 1	Flush180	10-JUN-16	0.278	ppb
57831	57831-1-HAL-F03	Annex - Across Room 145 Hallway, Fountain 1	Flush180	10-JUN-16	0.291	ppb
57831	57831-1-HAL-F03	Annex - Across Room 145 Hallway, Fountain 1	Flush180	10-JUN-16	0.346	ppb
57831	57831-1-HAL-F03	Annex - Across Room 145 Hallway, Fountain 1	Flush180	10-JUN-16	0.278	ppb
57831	57831-1-HAL-F03	Annex - Across Room 145 Hallway, Fountain 1	Flush180	10-JUN-16	0.291	ppb
57831	57831-1-HAL-F03	Annex - Across Room 145 Hallway, Fountain 1	Flush180	10-JUN-16	0.299	ppb
57831	57831-1-HAL-F03	Annex - Across Room 145 Hallway, Fountain 1	Flush180	10-JUN-16	0.299	ppb
57831	57831-1-HAL-F03	Annex - Across Room 145 Hallway, Fountain 1	Initial	10-JUN-16	0.463	ppb
57831	57831-1-HAL-F03	Annex - Across Room 145 Hallway, Fountain 1	Initial	10-JUN-16	0.463	ppb
57831	57831-1-HAL-F04	Annex - Across Room 145 Hallway, Fountain 2	Flush180	10-JUN-16	1.000	ppb
57831	57831-1-HAL-F04	Annex - Across Room 145 Hallway, Fountain 2	Flush180	10-JUN-16	1.000	ppb
57831	57831-1-HAL-F04	Annex - Across Room 145 Hallway, Fountain 2	Flush180	10-JUN-16	1.000	ppb
57831	57831-1-HAL-F04	Annex - Across Room 145 Hallway, Fountain 2	Flush180	10-JUN-16	1.000	ppb
57831	57831-1-HAL-F04	Annex - Across Room 145 Hallway, Fountain 2	Flush180	10-JUN-16	1.000	ppb
57831	57831-1-HAL-F04	Annex - Across Room 145 Hallway, Fountain 2	Flush180	10-JUN-16	1.000	ppb
57831	57831-1-HAL-F04	Annex - Across Room 145 Hallway, Fountain 2	Flush180	10-JUN-16	1.000	ppb
57831	57831-1-HAL-F04	Annex - Across Room 145 Hallway, Fountain 2	Flush180	10-JUN-16	1.000	ppb
57831	57831-1-HAL-F04	Annex - Across Room 145 Hallway, Fountain 2	Flush180	09-OCT-20	1.280	ug/L
57831	57831-1-HAL-F04	Annex - Across Room 145 Hallway, Fountain 2	Initial	10-JUN-16	1.000	ppb
57831	57831-1-HAL-F04	Annex - Across Room 145 Hallway, Fountain 2	Initial	10-JUN-16	1.000	ppb
57831	57831-1-HAL-F04	Annex - Across Room 145 Hallway, Fountain 2	Initial	09-OCT-20	1.400	ug/L
57831	57831-2-HAL-F03	Annex - Across Room 222 Hallway, Fountain 1	Flush180	10-JUN-16	0.587	ppb
57831	57831-2-HAL-F03	Annex - Across Room 222 Hallway, Fountain 1	Flush180	10-JUN-16	0.540	ppb
57831	57831-2-HAL-F03	Annex - Across Room 222 Hallway, Fountain 1	Flush180	10-JUN-16	0.499	ppb
57831	57831-2-HAL-F03	Annex - Across Room 222 Hallway, Fountain 1	Flush180	10-JUN-16	0.587	ppb
57831	57831-2-HAL-F03	Annex - Across Room 222 Hallway, Fountain 1	Flush180	10-JUN-16	0.499	ppb
57831	57831-2-HAL-F03	Annex - Across Room 222 Hallway, Fountain 1	Flush180	10-JUN-16	0.456	ppb
57831	57831-2-HAL-F03	Annex - Across Room 222 Hallway, Fountain 1	Flush180	10-JUN-16	0.456	ppb
57831	57831-2-HAL-F03	Annex - Across Room 222 Hallway, Fountain 1	Flush180	10-JUN-16	0.540	ppb
57831	57831-2-HAL-F03	Annex - Across Room 222 Hallway, Fountain 1	Initial	10-JUN-16	0.394	ppb
57831	57831-2-HAL-F03	Annex - Across Room 222 Hallway, Fountain 1	Initial	10-JUN-16	0.394	ppb
57831	57831-2-HAL-F04	Annex - Across Room 222 Hallway, Fountain 2	Flush180	10-JUN-16	0.422	ppb
57831	57831-2-HAL-F04	Annex - Across Room 222 Hallway, Fountain 2	Flush180	10-JUN-16	0.339	ppb
57831	57831-2-HAL-F04	Annex - Across Room 222 Hallway, Fountain 2	Flush180	10-JUN-16	0.340	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
57831	57831-2-HAL-F04	Annex - Across Room 222 Hallway, Fountain 2	Flush180	10-JUN-16	0.342	ppb
57831	57831-2-HAL-F04	Annex - Across Room 222 Hallway, Fountain 2	Flush180	10-JUN-16	0.342	ppb
57831	57831-2-HAL-F04	Annex - Across Room 222 Hallway, Fountain 2	Flush180	10-JUN-16	0.422	ppb
57831	57831-2-HAL-F04	Annex - Across Room 222 Hallway, Fountain 2	Flush180	10-JUN-16	0.340	ppb
57831	57831-2-HAL-F04	Annex - Across Room 222 Hallway, Fountain 2	Flush180	10-JUN-16	0.339	ppb
57831	57831-2-HAL-F04	Annex - Across Room 222 Hallway, Fountain 2	Initial	10-JUN-16	0.495	ppb
57831	57831-2-HAL-F04	Annex - Across Room 222 Hallway, Fountain 2	Initial	10-JUN-16	0.495	ppb
57831	57831-2-HAL-F01	Annex - Across Room 227 Hallway, Fountain 1	Flush180	10-JUN-16	4.620	ppb
57831	57831-2-HAL-F01	Annex - Across Room 227 Hallway, Fountain 1	Flush180	10-JUN-16	4.980	ppb
57831	57831-2-HAL-F01	Annex - Across Room 227 Hallway, Fountain 1	Flush180	10-JUN-16	4.930	ppb
57831	57831-2-HAL-F01	Annex - Across Room 227 Hallway, Fountain 1	Flush180	10-JUN-16	4.620	ppb
57831	57831-2-HAL-F01	Annex - Across Room 227 Hallway, Fountain 1	Flush180	10-JUN-16	4.980	ppb
57831	57831-2-HAL-F01	Annex - Across Room 227 Hallway, Fountain 1	Flush180	10-JUN-16	4.930	ppb
57831	57831-2-HAL-F01	Annex - Across Room 227 Hallway, Fountain 1	Flush180	10-JUN-16	4.710	ppb
57831	57831-2-HAL-F01	Annex - Across Room 227 Hallway, Fountain 1	Flush180	10-JUN-16	4.710	ppb
57831	57831-2-HAL-F01	Annex - Across Room 227 Hallway, Fountain 1	Flush180	09-OCT-20	2.430	ug/L
57831	57831-2-HAL-F01	Annex - Across Room 227 Hallway, Fountain 1	Initial	10-JUN-16	4.080	ppb
57831	57831-2-HAL-F01	Annex - Across Room 227 Hallway, Fountain 1	Initial	10-JUN-16	4.080	ppb
57831	57831-2-HAL-F01	Annex - Across Room 227 Hallway, Fountain 1	Initial	09-OCT-20	2.860	ug/L
57831	57831-2-HAL-F02	Annex - Across Room 227 Hallway, Fountain 2	Flush180	10-JUN-16	3.770	ppb
57831	57831-2-HAL-F02	Annex - Across Room 227 Hallway, Fountain 2	Flush180	10-JUN-16	3.760	ppb
57831	57831-2-HAL-F02	Annex - Across Room 227 Hallway, Fountain 2	Flush180	10-JUN-16	3.790	ppb
57831	57831-2-HAL-F02	Annex - Across Room 227 Hallway, Fountain 2	Flush180	10-JUN-16	3.770	ppb
57831	57831-2-HAL-F02	Annex - Across Room 227 Hallway, Fountain 2	Flush180	10-JUN-16	3.760	ppb
57831	57831-2-HAL-F02	Annex - Across Room 227 Hallway, Fountain 2	Flush180	10-JUN-16	3.790	ppb
57831	57831-2-HAL-F02	Annex - Across Room 227 Hallway, Fountain 2	Flush180	10-JUN-16	3.640	ppb
57831	57831-2-HAL-F02	Annex - Across Room 227 Hallway, Fountain 2	Flush180	10-JUN-16	3.640	ppb
57831	57831-2-HAL-F02	Annex - Across Room 227 Hallway, Fountain 2	Initial	10-JUN-16	3.660	ppb
57831	57831-2-HAL-F02	Annex - Across Room 227 Hallway, Fountain 2	Initial	10-JUN-16	3.660	ppb
57831	57831-1-120-S07	Annex - Inside of Room 120, Sink	Flush180	10-JUN-16	0.331	ppb
57831	57831-1-120-S07	Annex - Inside of Room 120, Sink	Flush180	10-JUN-16	0.322	ppb
57831	57831-1-120-S07	Annex - Inside of Room 120, Sink	Flush180	10-JUN-16	0.280	ppb
57831	57831-1-120-S07	Annex - Inside of Room 120, Sink	Flush180	10-JUN-16	0.357	ppb
57831	57831-1-120-S07	Annex - Inside of Room 120, Sink	Flush180	10-JUN-16	0.331	ppb
57831	57831-1-120-S07	Annex - Inside of Room 120, Sink	Flush180	10-JUN-16	0.322	ppb
57831	57831-1-120-S07	Annex - Inside of Room 120, Sink	Flush180	10-JUN-16	0.357	ppb
57831	57831-1-120-S07	Annex - Inside of Room 120, Sink	Flush180	10-JUN-16	0.280	ppb



**Water Quality Assessment  
Carrie Jacobs Bond Elementary School**

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
57831	57831-1-120-S07	Annex - Inside of Room 120, Sink	Initial	10-JUN-16	1.000	ppb
57831	57831-1-120-S07	Annex - Inside of Room 120, Sink	Initial	10-JUN-16	1.000	ppb
57831	57831-1-121-S08	Annex - Inside of Room 121, Sink	Flush180	10-JUN-16	0.289	ppb
57831	57831-1-121-S08	Annex - Inside of Room 121, Sink	Flush180	10-JUN-16	1.000	ppb
57831	57831-1-121-S08	Annex - Inside of Room 121, Sink	Flush180	10-JUN-16	0.137	ppb
57831	57831-1-121-S08	Annex - Inside of Room 121, Sink	Flush180	10-JUN-16	0.289	ppb
57831	57831-1-121-S08	Annex - Inside of Room 121, Sink	Flush180	10-JUN-16	1.000	ppb
57831	57831-1-121-S08	Annex - Inside of Room 121, Sink	Flush180	10-JUN-16	0.181	ppb
57831	57831-1-121-S08	Annex - Inside of Room 121, Sink	Flush180	10-JUN-16	0.137	ppb
57831	57831-1-121-S08	Annex - Inside of Room 121, Sink	Flush180	10-JUN-16	0.181	ppb
57831	57831-1-121-S08	Annex - Inside of Room 121, Sink	Initial	10-JUN-16	0.286	ppb
57831	57831-1-121-S08	Annex - Inside of Room 121, Sink	Initial	10-JUN-16	0.286	ppb