



Sep 10, 2024

BOWEN HS

2710 E 89TH ST, Chicago IL 60617.

Dear **BOWEN HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

BOWEN HS

2710 E 89TH ST, Chicago IL 60617.

Estimadas familias de **BOWEN HS**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51627	51627-1-HAL-F06	Across 138	Flush180	21-OCT-16	0.360	ppb
51627	51627-1-HAL-F06	Across 138	Flush180	21-OCT-16	0.500	ppb
51627	51627-1-HAL-F06	Across 138	Flush180	21-OCT-16	0.450	ppb
51627	51627-1-HAL-F06	Across 138	Flush180	21-OCT-16	0.500	ppb
51627	51627-1-HAL-F06	Across 138	Initial	21-OCT-16	0.280	ppb
51627	51627-2-HAL-F06	Across from 238	Flush	08-DEC-2023	1.000	ug/L
51627	51627-2-HAL-F06	Across from 238	Flush	08-DEC-2023	1.000	ug/L
51627	51627-2-HAL-F06	Across from 238	Flush	08-DEC-2023	1.000	ug/L
51627	51627-2-HAL-F06	Across from 238	Flush	08-DEC-2023	1.000	ug/L
51627	51627-2-HAL-F06	Across from 238	Initial	08-DEC-2023	1.000	ug/L
51627	51627-2-HAL-F05	Across from 239	Flush	08-DEC-2023	1.000	ug/L
51627	51627-2-HAL-F05	Across from 239	Flush	08-DEC-2023	1.000	ug/L
51627	51627-2-HAL-F05	Across from 239	Flush	08-DEC-2023	1.000	ug/L
51627	51627-2-HAL-F05	Across from 239	Flush	08-DEC-2023	1.000	ug/L
51627	51627-2-HAL-F05	Across from 239	Initial	08-DEC-2023	1.000	ug/L
51627	51627-3-HAL-F03	Across from room 314	Flush	08-DEC-2023	1.000	ug/L
51627	51627-3-HAL-F03	Across from room 314	Flush	08-DEC-2023	1.000	ug/L
51627	51627-3-HAL-F03	Across from room 314	Flush	08-DEC-2023	1.000	ug/L
51627	51627-3-HAL-F03	Across from room 314	Flush	08-DEC-2023	1.000	ug/L
51627	51627-3-HAL-F03	Across from room 314	Initial	08-DEC-2023	1.000	ug/L
51627	51627-4-HAL-F01	Across from room 400	Flush	08-DEC-2023	1.240	ug/L
51627	51627-4-HAL-F01	Across from room 400	Flush	08-DEC-2023	1.070	ug/L
51627	51627-4-HAL-F01	Across from room 400	Flush	08-DEC-2023	1.290	ug/L
51627	51627-4-HAL-F01	Across from room 400	Flush	08-DEC-2023	1.950	ug/L
51627	51627-4-HAL-F01	Across from room 400	Initial	08-DEC-2023	1.260	ug/L
51627	51627-2-GYM-BF01	BF in Gym	Flush	08-DEC-2023	4.080	ug/L
51627	51627-2-GYM-BF01	BF in Gym	Flush	08-DEC-2023	2.650	ug/L
51627	51627-2-GYM-BF01	BF in Gym	Flush	08-DEC-2023	2.540	ug/L
51627	51627-2-GYM-BF01	BF in Gym	Flush	08-DEC-2023	2.420	ug/L
51627	51627-2-GYM-BF01	BF in Gym	Initial	08-DEC-2023	1.630	ug/L
51627	51627-1-GYM-F01	Fountain in GYM	Flush180	21-OCT-16	0.700	ppb
51627	51627-1-GYM-F01	Fountain in GYM	Flush180	21-OCT-16	0.820	ppb
51627	51627-1-GYM-F01	Fountain in GYM	Flush180	21-OCT-16	0.700	ppb
51627	51627-1-GYM-F01	Fountain in GYM	Flush180	21-OCT-16	0.710	ppb
51627	51627-1-GYM-F01	Fountain in GYM	Initial	21-OCT-16	1.100	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51627	51627-2-GYM-F01	GYM	Flush180	21-OCT-16	0.920	ppb
51627	51627-2-GYM-F01	GYM	Flush180	21-OCT-16	1.200	ppb
51627	51627-2-GYM-F01	GYM	Flush180	21-OCT-16	0.970	ppb
51627	51627-2-GYM-F01	GYM	Flush180	21-OCT-16	0.990	ppb
51627	51627-2-GYM-F01	GYM	Initial	21-OCT-16	0.990	ppb
51627	51627-2-GYM-F01	GYMNASIUM	Flush	08-DEC-2023	1.000	ug/L
51627	51627-2-GYM-F01	GYMNASIUM	Flush	08-DEC-2023	1.000	ug/L
51627	51627-2-GYM-F01	GYMNASIUM	Flush	08-DEC-2023	1.000	ug/L
51627	51627-2-GYM-F01	GYMNASIUM	Flush	08-DEC-2023	1.000	ug/L
51627	51627-2-GYM-F01	GYMNASIUM	Initial	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS01	Kitchen NE Wall Left Sink	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS01	Kitchen NE Wall Left Sink	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS01	Kitchen NE Wall Left Sink	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS01	Kitchen NE Wall Left Sink	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS01	Kitchen NE Wall Left Sink	Flush180	21-OCT-16	0.280	ppb
51627	51627-1-KIT-KS01	Kitchen NE Wall Left Sink	Flush180	21-OCT-16	0.250	ppb
51627	51627-1-KIT-KS01	Kitchen NE Wall Left Sink	Flush180	21-OCT-16	0.200	ppb
51627	51627-1-KIT-KS01	Kitchen NE Wall Left Sink	Flush180	21-OCT-16	0.390	ppb
51627	51627-1-KIT-KS01	Kitchen NE Wall Left Sink	Initial	21-OCT-16	2.400	ppb
51627	51627-1-KIT-KS01	Kitchen NE Wall Left Sink	Initial	08-DEC-2023	1.000	ug/L
51627	51627-1-HAL-F09	Left Fountain	Flush180	21-OCT-16	0.320	ppb
51627	51627-1-HAL-F09	Left Fountain	Flush180	21-OCT-16	0.370	ppb
51627	51627-1-HAL-F09	Left Fountain	Flush180	21-OCT-16	0.560	ppb
51627	51627-1-HAL-F09	Left Fountain	Flush180	21-OCT-16	0.510	ppb
51627	51627-1-HAL-F09	Left Fountain	Initial	21-OCT-16	0.250	ppb
51627	51627-1-HAL-F03	Left Fountain Across 184A	Flush	08-DEC-2023	1.220	ug/L
51627	51627-1-HAL-F03	Left Fountain Across 184A	Flush	08-DEC-2023	1.190	ug/L
51627	51627-1-HAL-F03	Left Fountain Across 184A	Flush	08-DEC-2023	1.070	ug/L
51627	51627-1-HAL-F03	Left Fountain Across 184A	Flush	08-DEC-2023	1.610	ug/L
51627	51627-1-HAL-F03	Left Fountain Across 184A	Flush180	21-OCT-16	1.100	ppb
51627	51627-1-HAL-F03	Left Fountain Across 184A	Flush180	21-OCT-16	1.700	ppb
51627	51627-1-HAL-F03	Left Fountain Across 184A	Flush180	21-OCT-16	2.100	ppb
51627	51627-1-HAL-F03	Left Fountain Across 184A	Flush180	21-OCT-16	3.000	ppb
51627	51627-1-HAL-F03	Left Fountain Across 184A	Initial	21-OCT-16	1.800	ppb
51627	51627-1-HAL-F03	Left Fountain Across 184A	Initial	08-DEC-2023	1.180	ug/L
51627	51627-4-HAL-F01	Left Fountain Across 400	Flush180	21-OCT-16	6.700	ppb
51627	51627-4-HAL-F01	Left Fountain Across 400	Flush180	21-OCT-16	8.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51627	51627-4-HAL-F01	Left Fountain Across 400	Flush180	21-OCT-16	5.300	ppb
51627	51627-4-HAL-F01	Left Fountain Across 400	Flush180	21-OCT-16	4.000	ppb
51627	51627-4-HAL-F01	Left Fountain Across 400	Initial	21-OCT-16	3.200	ppb
51627	51627-3-HAL-F01	Left Fountain Next to 304	Flush180	21-OCT-16	1.600	ppb
51627	51627-3-HAL-F01	Left Fountain Next to 304	Flush180	21-OCT-16	1.400	ppb
51627	51627-3-HAL-F01	Left Fountain Next to 304	Flush180	21-OCT-16	1.800	ppb
51627	51627-3-HAL-F01	Left Fountain Next to 304	Flush180	21-OCT-16	1.800	ppb
51627	51627-3-HAL-F01	Left Fountain Next to 304	Initial	21-OCT-16	1.900	ppb
51627	51627-2-HAL-F05	Left Fountain across 239	Flush180	21-OCT-16	0.660	ppb
51627	51627-2-HAL-F05	Left Fountain across 239	Flush180	21-OCT-16	0.610	ppb
51627	51627-2-HAL-F05	Left Fountain across 239	Flush180	21-OCT-16	0.640	ppb
51627	51627-2-HAL-F05	Left Fountain across 239	Flush180	21-OCT-16	0.610	ppb
51627	51627-2-HAL-F05	Left Fountain across 239	Initial	21-OCT-16	0.430	ppb
51627	51627-3-HAL-F03	Left Fountain across 314	Flush180	21-OCT-16	0.063	ppb
51627	51627-3-HAL-F03	Left Fountain across 314	Flush180	21-OCT-16	1.000	ppb
51627	51627-3-HAL-F03	Left Fountain across 314	Flush180	21-OCT-16	1.000	ppb
51627	51627-3-HAL-F03	Left Fountain across 314	Flush180	21-OCT-16	0.065	ppb
51627	51627-3-HAL-F03	Left Fountain across 314	Initial	21-OCT-16	0.072	ppb
51627	51627-1-CAF-F01	Left Fountain in Lunchroom	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-CAF-F01	Left Fountain in Lunchroom	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-CAF-F01	Left Fountain in Lunchroom	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-CAF-F01	Left Fountain in Lunchroom	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-CAF-F01	Left Fountain in Lunchroom	Flush180	21-OCT-16	4.700	ppb
51627	51627-1-CAF-F01	Left Fountain in Lunchroom	Flush180	21-OCT-16	6.400	ppb
51627	51627-1-CAF-F01	Left Fountain in Lunchroom	Flush180	21-OCT-16	5.300	ppb
51627	51627-1-CAF-F01	Left Fountain in Lunchroom	Flush180	21-OCT-16	5.300	ppb
51627	51627-1-CAF-F01	Left Fountain in Lunchroom	Initial	21-OCT-16	7.300	ppb
51627	51627-1-CAF-F01	Left Fountain in Lunchroom	Initial	08-DEC-2023	1.000	ug/L
51627	51627-2-HAL-F03	Left Fountain near 213	Flush180	21-OCT-16	1.000	ppb
51627	51627-2-HAL-F03	Left Fountain near 213	Flush180	21-OCT-16	1.000	ppb
51627	51627-2-HAL-F03	Left Fountain near 213	Flush180	21-OCT-16	1.000	ppb
51627	51627-2-HAL-F03	Left Fountain near 213	Flush180	21-OCT-16	1.000	ppb
51627	51627-2-HAL-F03	Left Fountain near 213	Initial	21-OCT-16	0.690	ppb
51627	51627-2-HAL-F07	Left Fountain near 229	Flush	08-DEC-2023	1.000	ug/L
51627	51627-2-HAL-F07	Left Fountain near 229	Flush	08-DEC-2023	1.000	ug/L
51627	51627-2-HAL-F07	Left Fountain near 229	Flush	08-DEC-2023	1.000	ug/L
51627	51627-2-HAL-F07	Left Fountain near 229	Flush	08-DEC-2023	1.000	ug/L
51627	51627-2-HAL-F07	Left Fountain near 229	Flush180	21-OCT-16	0.420	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F07					
51627	51627-2-HAL-F07	Left Fountain near 229	Flush180	21-OCT-16	0.500	ppb
51627	51627-2-HAL-F07	Left Fountain near 229	Flush180	21-OCT-16	0.330	ppb
51627	51627-2-HAL-F07	Left Fountain near 229	Flush180	21-OCT-16	0.450	ppb
51627	51627-2-HAL-F07	Left Fountain near 229	Initial	21-OCT-16	0.180	ppb
51627	51627-2-HAL-F07	Left Fountain near 229	Initial	08-DEC-2023	1.000	ug/L
51627	51627-1-HAL-F01	Left Fountain near RM 111	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-HAL-F01	Left Fountain near RM 111	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-HAL-F01	Left Fountain near RM 111	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-HAL-F01	Left Fountain near RM 111	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-HAL-F01	Left Fountain near RM 111	Flush180	21-OCT-16	0.340	ppb
51627	51627-1-HAL-F01	Left Fountain near RM 111	Flush180	21-OCT-16	0.360	ppb
51627	51627-1-HAL-F01	Left Fountain near RM 111	Flush180	21-OCT-16	0.350	ppb
51627	51627-1-HAL-F01	Left Fountain near RM 111	Flush180	21-OCT-16	0.360	ppb
51627	51627-1-HAL-F01	Left Fountain near RM 111	Flush180	18-DEC-20	1.000	ug/L
51627	51627-1-HAL-F01	Left Fountain near RM 111	Initial	21-OCT-16	0.170	ppb
51627	51627-1-HAL-F01	Left Fountain near RM 111	Initial	18-DEC-20	1.000	ug/L
51627	51627-1-HAL-F01	Left Fountain near RM 111	Initial	08-DEC-2023	1.000	ug/L
51627	51627-4-HAL-F03	Left Fountain next to 490	Flush180	21-OCT-16	0.220	ppb
51627	51627-4-HAL-F03	Left Fountain next to 490	Flush180	21-OCT-16	0.190	ppb
51627	51627-4-HAL-F03	Left Fountain next to 490	Flush180	21-OCT-16	0.200	ppb
51627	51627-4-HAL-F03	Left Fountain next to 490	Flush180	21-OCT-16	0.200	ppb
51627	51627-4-HAL-F03	Left Fountain next to 490	Flush180	18-DEC-20	2.340	ug/L
51627	51627-4-HAL-F03	Left Fountain next to 490	Initial	21-OCT-16	0.180	ppb
51627	51627-4-HAL-F03	Left Fountain next to 490	Initial	18-DEC-20	2.060	ug/L
51627	51627-2-HAL-F01	Left Fountains near 204	Flush180	21-OCT-16	1.100	ppb
51627	51627-2-HAL-F01	Left Fountains near 204	Flush180	21-OCT-16	1.300	ppb
51627	51627-2-HAL-F01	Left Fountains near 204	Flush180	21-OCT-16	0.890	ppb
51627	51627-2-HAL-F01	Left Fountains near 204	Flush180	21-OCT-16	0.920	ppb
51627	51627-2-HAL-F01	Left Fountains near 204	Initial	21-OCT-16	1.700	ppb
51627	51627-1-HAL-F07	Left of 144	Flush180	21-OCT-16	1.600	ppb
51627	51627-1-HAL-F07	Left of 144	Flush180	21-OCT-16	0.980	ppb
51627	51627-1-HAL-F07	Left of 144	Flush180	21-OCT-16	1.600	ppb
51627	51627-1-HAL-F07	Left of 144	Flush180	21-OCT-16	0.910	ppb
51627	51627-1-HAL-F07	Left of 144	Initial	21-OCT-16	1.300	ppb
51627	51627-1-KIT-KS08	Middle Kitchen Sink	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS08	Middle Kitchen Sink	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-	Middle Kitchen Sink	Flush	08-DEC-2023	1.120	ug/L

Water Quality Assessment Bowen High School

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS08					
51627	51627-1-KIT-KS08	Middle Kitchen Sink	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS08	Middle Kitchen Sink	Flush180	21-OCT-16	0.300	ppb
51627	51627-1-KIT-KS08	Middle Kitchen Sink	Flush180	21-OCT-16	0.270	ppb
51627	51627-1-KIT-KS08	Middle Kitchen Sink	Flush180	21-OCT-16	1.000	ppb
51627	51627-1-KIT-KS08	Middle Kitchen Sink	Flush180	21-OCT-16	0.400	ppb
51627	51627-1-KIT-KS08	Middle Kitchen Sink	Initial	21-OCT-16	0.620	ppb
51627	51627-1-KIT-KS08	Middle Kitchen Sink	Initial	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS02	NE Wall Right Sink	Flush180	21-OCT-16	11.000	ppb
51627	51627-1-KIT-KS02	NE Wall Right Sink	Flush180	21-OCT-16	0.200	ppb
51627	51627-1-KIT-KS02	NE Wall Right Sink	Flush180	21-OCT-16	0.650	ppb
51627	51627-1-KIT-KS02	NE Wall Right Sink	Flush180	21-OCT-16	0.420	ppb
51627	51627-1-KIT-KS02	NE Wall Right Sink	Initial	21-OCT-16	7.300	ppb
51627	51627-2-HAL-BF02	Near room 229 BF	Flush	08-DEC-2023	1.000	ug/L
51627	51627-2-HAL-BF02	Near room 229 BF	Flush	08-DEC-2023	1.000	ug/L
51627	51627-2-HAL-BF02	Near room 229 BF	Flush	08-DEC-2023	1.000	ug/L
51627	51627-2-HAL-BF02	Near room 229 BF	Flush	08-DEC-2023	1.000	ug/L
51627	51627-2-HAL-BF02	Near room 229 BF	Initial	08-DEC-2023	1.000	ug/L
51627	51627-4-HAL-F03	Next to room 490, Fountain	Flush	08-DEC-2023	1.000	ug/L
51627	51627-4-HAL-F03	Next to room 490, Fountain	Flush	08-DEC-2023	1.000	ug/L
51627	51627-4-HAL-F03	Next to room 490, Fountain	Flush	08-DEC-2023	1.000	ug/L
51627	51627-4-HAL-F03	Next to room 490, Fountain	Flush	08-DEC-2023	1.000	ug/L
51627	51627-4-HAL-F03	Next to room 490, Fountain	Initial	08-DEC-2023	1.000	ug/L
51627	51627-4-HAL-RBF02	Next to room 490, Retrofit BF	Flush	08-DEC-2023	1.350	ug/L
51627	51627-4-HAL-RBF02	Next to room 490, Retrofit BF	Flush	08-DEC-2023	1.000	ug/L
51627	51627-4-HAL-RBF02	Next to room 490, Retrofit BF	Flush	08-DEC-2023	1.000	ug/L
51627	51627-4-HAL-RBF02	Next to room 490, Retrofit BF	Initial	08-DEC-2023	3.270	ug/L
51627	51627-2-HAL-F01	Outside Room 204. Left Fountain	Flush	08-DEC-2023	2.570	ug/L
51627	51627-2-HAL-F01	Outside Room 204. Left Fountain	Flush	08-DEC-2023	3.960	ug/L
51627	51627-2-HAL-F01	Outside Room 204. Left Fountain	Flush	08-DEC-2023	2.600	ug/L
51627	51627-2-HAL-F01	Outside Room 204. Left Fountain	Flush	08-DEC-2023	2.120	ug/L
51627	51627-2-HAL-F01	Outside Room 204. Left Fountain	Initial	08-DEC-2023	1.690	ug/L
51627	51627-2-HAL-F02	Outside Room 204. Right Fountain	Flush	08-DEC-2023	4.500	ug/L
51627	51627-2-HAL-F02	Outside Room 204. Right Fountain	Flush	08-DEC-2023	2.350	ug/L
51627	51627-2-HAL-F02	Outside Room 204. Right Fountain	Flush	08-DEC-2023	1.850	ug/L
51627	51627-2-HAL-F02	Outside Room 204. Right Fountain	Flush	08-DEC-2023	1.970	ug/L
51627	51627-2-HAL-F02	Outside Room 204. Right Fountain	Initial	08-DEC-2023	2.900	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51627	51627-2-HAL-F03	Outside room 213, Fountain	Flush	08-DEC-2023	1.000	ug/L
51627	51627-2-HAL-F03	Outside room 213, Fountain	Flush	08-DEC-2023	1.000	ug/L
51627	51627-2-HAL-F03	Outside room 213, Fountain	Flush	08-DEC-2023	1.000	ug/L
51627	51627-2-HAL-F03	Outside room 213, Fountain	Flush	08-DEC-2023	1.000	ug/L
51627	51627-2-HAL-F03	Outside room 213, Fountain	Initial	08-DEC-2023	1.000	ug/L
51627	51627-1-HAL-F10	Right Fountain	Flush180	21-OCT-16	0.490	ppb
51627	51627-1-HAL-F10	Right Fountain	Flush180	21-OCT-16	0.630	ppb
51627	51627-1-HAL-F10	Right Fountain	Flush180	21-OCT-16	0.470	ppb
51627	51627-1-HAL-F10	Right Fountain	Flush180	21-OCT-16	0.450	ppb
51627	51627-1-HAL-F10	Right Fountain	Initial	21-OCT-16	0.800	ppb
51627	51627-1-HAL-F04	Right Fountain Across 184A	Flush	08-DEC-2023	1.510	ug/L
51627	51627-1-HAL-F04	Right Fountain Across 184A	Flush	08-DEC-2023	1.260	ug/L
51627	51627-1-HAL-F04	Right Fountain Across 184A	Flush	08-DEC-2023	1.620	ug/L
51627	51627-1-HAL-F04	Right Fountain Across 184A	Flush	08-DEC-2023	1.050	ug/L
51627	51627-1-HAL-F04	Right Fountain Across 184A	Flush180	21-OCT-16	3.100	ppb
51627	51627-1-HAL-F04	Right Fountain Across 184A	Flush180	21-OCT-16	1.600	ppb
51627	51627-1-HAL-F04	Right Fountain Across 184A	Flush180	21-OCT-16	3.300	ppb
51627	51627-1-HAL-F04	Right Fountain Across 184A	Flush180	21-OCT-16	1.700	ppb
51627	51627-1-HAL-F04	Right Fountain Across 184A	Initial	21-OCT-16	6.200	ppb
51627	51627-1-HAL-F04	Right Fountain Across 184A	Initial	08-DEC-2023	1.590	ug/L
51627	51627-4-HAL-F02	Right Fountain Across 400	Flush180	21-OCT-16	1.600	ppb
51627	51627-4-HAL-F02	Right Fountain Across 400	Flush180	21-OCT-16	3.700	ppb
51627	51627-4-HAL-F02	Right Fountain Across 400	Flush180	21-OCT-16	5.900	ppb
51627	51627-4-HAL-F02	Right Fountain Across 400	Flush180	21-OCT-16	8.400	ppb
51627	51627-4-HAL-F02	Right Fountain Across 400	Initial	21-OCT-16	2.100	ppb
51627	51627-3-HAL-F04	Right Fountain across 314	Flush180	21-OCT-16	1.000	ppb
51627	51627-3-HAL-F04	Right Fountain across 314	Flush180	21-OCT-16	1.000	ppb
51627	51627-3-HAL-F04	Right Fountain across 314	Flush180	21-OCT-16	1.000	ppb
51627	51627-3-HAL-F04	Right Fountain across 314	Flush180	21-OCT-16	1.000	ppb
51627	51627-3-HAL-F04	Right Fountain across 314	Initial	21-OCT-16	1.000	ppb
51627	51627-1-CAF-F02	Right Fountain in Lunchroom	Flush	12-JAN-2024	4.900	ug/L
51627	51627-1-CAF-F02	Right Fountain in Lunchroom	Flush	12-JAN-2024	4.790	ug/L
51627	51627-1-CAF-F02	Right Fountain in Lunchroom	Flush	12-JAN-2024	4.590	ug/L
51627	51627-1-CAF-F02	Right Fountain in Lunchroom	Flush	12-JAN-2024	3.700	ug/L
51627	51627-1-CAF-F02	Right Fountain in Lunchroom	Flush	08-DEC-2023	2.560	ug/L
51627	51627-1-CAF-F02	Right Fountain in Lunchroom	Flush	08-DEC-2023	2.580	ug/L
51627	51627-1-CAF-F02	Right Fountain in Lunchroom	Flush	08-DEC-2023	4.640	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51627	51627-1-CAF-F02	Right Fountain in Lunchroom	Flush	08-DEC-2023	2.980	ug/L
51627	51627-1-CAF-F02	Right Fountain in Lunchroom	Flush180	21-OCT-16	4.700	ppb
51627	51627-1-CAF-F02	Right Fountain in Lunchroom	Flush180	21-OCT-16	4.800	ppb
51627	51627-1-CAF-F02	Right Fountain in Lunchroom	Flush180	21-OCT-16	8.300	ppb
51627	51627-1-CAF-F02	Right Fountain in Lunchroom	Flush180	21-OCT-16	4.400	ppb
51627	51627-1-CAF-F02	Right Fountain in Lunchroom	Initial	21-OCT-16	7.200	ppb
51627	51627-1-CAF-F02	Right Fountain in Lunchroom	Initial	12-JAN-2024	4.200	ug/L
51627	51627-1-CAF-F02	Right Fountain in Lunchroom	Initial	08-DEC-2023	5.040	ug/L
51627	51627-2-HAL-F02	Right Fountain near 204	Flush180	21-OCT-16	1.300	ppb
51627	51627-2-HAL-F02	Right Fountain near 204	Flush180	21-OCT-16	2.800	ppb
51627	51627-2-HAL-F02	Right Fountain near 204	Flush180	21-OCT-16	1.700	ppb
51627	51627-2-HAL-F02	Right Fountain near 204	Flush180	21-OCT-16	1.000	ppb
51627	51627-2-HAL-F02	Right Fountain near 204	Initial	21-OCT-16	2.900	ppb
51627	51627-2-HAL-F08	Right Fountain near 229	Flush	08-DEC-2023	1.000	ug/L
51627	51627-2-HAL-F08	Right Fountain near 229	Flush	08-DEC-2023	1.000	ug/L
51627	51627-2-HAL-F08	Right Fountain near 229	Flush	08-DEC-2023	1.000	ug/L
51627	51627-2-HAL-F08	Right Fountain near 229	Flush180	21-OCT-16	0.440	ppb
51627	51627-2-HAL-F08	Right Fountain near 229	Flush180	21-OCT-16	0.560	ppb
51627	51627-2-HAL-F08	Right Fountain near 229	Flush180	21-OCT-16	0.380	ppb
51627	51627-2-HAL-F08	Right Fountain near 229	Flush180	21-OCT-16	0.470	ppb
51627	51627-2-HAL-F08	Right Fountain near 229	Initial	21-OCT-16	0.400	ppb
51627	51627-2-HAL-F08	Right Fountain near 229	Initial	08-DEC-2023	1.000	ug/L
51627	51627-1-HAL-F02	Right Fountain near RM 111	Flush180	21-OCT-16	0.390	ppb
51627	51627-1-HAL-F02	Right Fountain near RM 111	Flush180	21-OCT-16	0.400	ppb
51627	51627-1-HAL-F02	Right Fountain near RM 111	Flush180	21-OCT-16	0.390	ppb
51627	51627-1-HAL-F02	Right Fountain near RM 111	Flush180	21-OCT-16	0.330	ppb
51627	51627-1-HAL-F02	Right Fountain near RM 111	Initial	21-OCT-16	0.240	ppb
51627	51627-2-HAL-F06	Right across 238	Flush180	21-OCT-16	0.680	ppb
51627	51627-2-HAL-F06	Right across 238	Flush180	21-OCT-16	0.650	ppb
51627	51627-2-HAL-F06	Right across 238	Flush180	21-OCT-16	0.670	ppb
51627	51627-2-HAL-F06	Right across 238	Flush180	21-OCT-16	0.720	ppb
51627	51627-2-HAL-F06	Right across 238	Initial	21-OCT-16	0.550	ppb
51627	51627-3-HAL-F02	Right fountain next to 304	Flush180	21-OCT-16	2.100	ppb
51627	51627-3-HAL-F02	Right fountain next to 304	Flush180	21-OCT-16	2.100	ppb
51627	51627-3-HAL-F02	Right fountain next to 304	Flush180	21-OCT-16	1.900	ppb
51627	51627-3-HAL-F02	Right fountain next to 304	Flush180	21-OCT-16	1.800	ppb
51627	51627-3-HAL-F02	Right fountain next to 304	Initial	21-OCT-16	2.400	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02					
51627	51627-1-KIT-KS05	SW Wall Left Sink	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS05	SW Wall Left Sink	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS05	SW Wall Left Sink	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS05	SW Wall Left Sink	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS05	SW Wall Left Sink	Flush180	21-OCT-16	1.000	ppb
51627	51627-1-KIT-KS05	SW Wall Left Sink	Flush180	21-OCT-16	0.083	ppb
51627	51627-1-KIT-KS05	SW Wall Left Sink	Flush180	21-OCT-16	1.000	ppb
51627	51627-1-KIT-KS05	SW Wall Left Sink	Flush180	21-OCT-16	1.000	ppb
51627	51627-1-KIT-KS05	SW Wall Left Sink	Initial	21-OCT-16	0.180	ppb
51627	51627-1-KIT-KS05	SW Wall Left Sink	Initial	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS06	SW Wall Middle Sink	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS06	SW Wall Middle Sink	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS06	SW Wall Middle Sink	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS06	SW Wall Middle Sink	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS06	SW Wall Middle Sink	Flush180	21-OCT-16	1.000	ppb
51627	51627-1-KIT-KS06	SW Wall Middle Sink	Flush180	21-OCT-16	1.000	ppb
51627	51627-1-KIT-KS06	SW Wall Middle Sink	Flush180	21-OCT-16	0.220	ppb
51627	51627-1-KIT-KS06	SW Wall Middle Sink	Flush180	21-OCT-16	1.000	ppb
51627	51627-1-KIT-KS06	SW Wall Middle Sink	Initial	21-OCT-16	1.000	ppb
51627	51627-1-KIT-KS06	SW Wall Middle Sink	Initial	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS07	SW Wall Right Sink	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS07	SW Wall Right Sink	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS07	SW Wall Right Sink	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS07	SW Wall Right Sink	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS07	SW Wall Right Sink	Flush180	21-OCT-16	1.000	ppb
51627	51627-1-KIT-KS07	SW Wall Right Sink	Flush180	21-OCT-16	1.000	ppb
51627	51627-1-KIT-KS07	SW Wall Right Sink	Flush180	21-OCT-16	1.000	ppb
51627	51627-1-KIT-KS07	SW Wall Right Sink	Flush180	21-OCT-16	1.000	ppb
51627	51627-1-KIT-KS07	SW Wall Right Sink	Initial	21-OCT-16	0.170	ppb
51627	51627-1-KIT-KS07	SW Wall Right Sink	Initial	08-DEC-2023	1.000	ug/L
51627	51627-2-230-S01	Sink in Lunchroom	Flush180	21-OCT-16	1.000	ppb
51627	51627-2-230-S01	Sink in Lunchroom	Flush180	21-OCT-16	1.000	ppb
51627	51627-2-230-S01	Sink in Lunchroom	Flush180	21-OCT-16	1.000	ppb
51627	51627-2-230-S01	Sink in Lunchroom	Flush180	21-OCT-16	1.000	ppb
51627	51627-2-230-S01	Sink in Lunchroom	Initial	21-OCT-16	0.630	ppb
51627	51627-3-300-S01	Sink in Teachers Lounge	Flush	08-DEC-2023	1.000	ug/L
51627	51627-3-300-	Sink in Teachers Lounge	Flush	08-DEC-2023	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S01					
51627	51627-3-300-S01	Sink in Teachers Lounge	Flush	08-DEC-2023	1.000	ug/L
51627	51627-3-300-S01	Sink in Teachers Lounge	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-140E-S01	Sink in Teachers Lounge	Flush180	21-OCT-16	0.920	ppb
51627	51627-1-140E-S01	Sink in Teachers Lounge	Flush180	21-OCT-16	1.300	ppb
51627	51627-1-140E-S01	Sink in Teachers Lounge	Flush180	21-OCT-16	0.560	ppb
51627	51627-1-140E-S01	Sink in Teachers Lounge	Flush180	21-OCT-16	0.580	ppb
51627	51627-3-300-S01	Sink in Teachers Lounge	Flush180	21-OCT-16	1.700	ppb
51627	51627-3-300-S01	Sink in Teachers Lounge	Flush180	21-OCT-16	2.300	ppb
51627	51627-3-300-S01	Sink in Teachers Lounge	Flush180	21-OCT-16	1.200	ppb
51627	51627-3-300-S01	Sink in Teachers Lounge	Flush180	21-OCT-16	1.900	ppb
51627	51627-1-140E-S01	Sink in Teachers Lounge	Initial	21-OCT-16	0.650	ppb
51627	51627-3-300-S01	Sink in Teachers Lounge	Initial	21-OCT-16	1.600	ppb
51627	51627-3-300-S01	Sink in Teachers Lounge	Initial	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS03	W Wall Left Sink	Flush180	21-OCT-16	0.120	ppb
51627	51627-1-KIT-KS03	W Wall Left Sink	Flush180	21-OCT-16	0.076	ppb
51627	51627-1-KIT-KS03	W Wall Left Sink	Flush180	21-OCT-16	0.076	ppb
51627	51627-1-KIT-KS03	W Wall Left Sink	Flush180	21-OCT-16	0.091	ppb
51627	51627-1-KIT-KS03	W Wall Left Sink	Initial	21-OCT-16	3.300	ppb
51627	51627-1-KIT-KS04	W Wall Right Sink	Flush180	21-OCT-16	1.000	ppb
51627	51627-1-KIT-KS04	W Wall Right Sink	Flush180	21-OCT-16	1.000	ppb
51627	51627-1-KIT-KS04	W Wall Right Sink	Flush180	21-OCT-16	1.000	ppb
51627	51627-1-KIT-KS04	W Wall Right Sink	Flush180	21-OCT-16	1.000	ppb
51627	51627-1-KIT-KS04	W Wall Right Sink	Initial	21-OCT-16	1.300	ppb
51627	51627-1-KIT-KS03	West Wall Left Sink	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS03	West Wall Left Sink	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS03	West Wall Left Sink	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS03	West Wall Left Sink	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS03	West Wall Left Sink	Initial	08-DEC-2023	2.110	ug/L
51627	51627-1-KIT-KS04	West Wall Right Sink	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS04	West Wall Right Sink	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS04	West Wall Right Sink	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS04	West Wall Right Sink	Initial	08-DEC-2023	4.270	ug/L
51627	51627-3-HAL-F01	across from room 304 left fountain	Flush	08-DEC-2023	3.410	ug/L
51627	51627-3-HAL-F01	across from room 304 left fountain	Flush	08-DEC-2023	3.210	ug/L
51627	51627-3-HAL-F01	across from room 304 left fountain	Flush	08-DEC-2023	1.720	ug/L
51627	51627-3-HAL-F01	across from room 304 left fountain	Flush	08-DEC-2023	1.400	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51627	51627-3-HAL-F01	across from room 304 left fountain	Initial	08-DEC-2023	1.230	ug/L
51627	51627-3-HAL-F02	across from room 304 right fountain	Flush	08-DEC-2023	2.120	ug/L
51627	51627-3-HAL-F02	across from room 304 right fountain	Flush	08-DEC-2023	1.750	ug/L
51627	51627-3-HAL-F02	across from room 304 right fountain	Flush	08-DEC-2023	1.910	ug/L
51627	51627-3-HAL-F02	across from room 304 right fountain	Flush	08-DEC-2023	1.920	ug/L
51627	51627-3-HAL-F02	across from room 304 right fountain	Initial	08-DEC-2023	3.150	ug/L
51627	51627-1-KIT-KS02	north wall right sink	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS02	north wall right sink	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS02	north wall right sink	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS02	north wall right sink	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-KIT-KS02	north wall right sink	Initial	08-DEC-2023	1.000	ug/L
51627	51627-1-HAL-F02	right fountain near room 116	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-HAL-F02	right fountain near room 116	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-HAL-F02	right fountain near room 116	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-HAL-F02	right fountain near room 116	Flush	08-DEC-2023	1.000	ug/L
51627	51627-1-HAL-F02	right fountain near room 116	Initial	08-DEC-2023	1.000	ug/L