



Sep 10, 2024

**BRENNEMANN**

**4251 N CLARENDON AVE, Chicago IL 60613.**

Dear **BRENNEMANN** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**BRENNEMANN**

**4251 N CLARENDON AVE, Chicago IL 60613.**

Estimadas familias de **BRENNEMANN**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarle y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51078	51078-1-N-HAL-F06		Flush180	15-MAR-19	1.000	ug/L
51078	51078-1-N-HAL-F06		Flush180	15-MAR-19	1.000	ug/L
51078	51078-1-N-HAL-F06		Flush180	15-MAR-19	1.000	ug/L
51078	51078-1-N-HAL-F06		Flush180	15-MAR-19	1.000	ug/L
51078	51078-1-E-KIT-KS02		Flush180	15-MAR-19	1.000	ug/L
51078	51078-1-E-KIT-KS02		Flush180	15-MAR-19	1.000	ug/L
51078	51078-1-E-KIT-KS02		Flush180	15-MAR-19	1.000	ug/L
51078	51078-1-E-KIT-KS02		Flush180	15-MAR-19	1.000	ug/L
51078	51078-1-E-Kit-KS03		Flush180	15-MAR-19	1.000	ug/L
51078	51078-1-E-Kit-KS03		Flush180	15-MAR-19	1.000	ug/L
51078	51078-1-E-Kit-KS03		Flush180	15-MAR-19	1.000	ug/L
51078	51078-1-E-Kit-KS03		Flush180	15-MAR-19	1.000	ug/L
51078	51078-1-N-HAL-F06		Initial	15-MAR-19	1.000	ug/L
51078	51078-1-E-KIT-KS02		Initial	15-MAR-19	1.000	ug/L
51078	51078-1-E-Kit-KS03		Initial	15-MAR-19	1.000	ug/L
51078	51078-1-125-F10	Main - Inside Kindergarten Room 125, Fountain	Flush180	17-JUN-16	0.460	ppb
51078	51078-1-125-F10	Main - Inside Kindergarten Room 125, Fountain	Flush180	17-JUN-16	0.331	ppb
51078	51078-1-125-F10	Main - Inside Kindergarten Room 125, Fountain	Flush180	17-JUN-16	0.331	ppb
51078	51078-1-125-F10	Main - Inside Kindergarten Room 125, Fountain	Flush180	17-JUN-16	1.080	ppb
51078	51078-1-125-F10	Main - Inside Kindergarten Room 125, Fountain	Flush180	17-JUN-16	0.757	ppb
51078	51078-1-125-F10	Main - Inside Kindergarten Room 125, Fountain	Flush180	17-JUN-16	0.460	ppb
51078	51078-1-125-F10	Main - Inside Kindergarten Room 125, Fountain	Flush180	17-JUN-16	0.757	ppb
51078	51078-1-125-F10	Main - Inside Kindergarten Room 125, Fountain	Flush180	17-JUN-16	1.080	ppb
51078	51078-1-125-F10	Main - Inside Kindergarten Room 125, Fountain	Initial	17-JUN-16	1.010	ppb
51078	51078-1-125-F10	Main - Inside Kindergarten Room 125, Fountain	Initial	17-JUN-16	1.010	ppb
51078	51078-1-N-125-S01	Main - Inside Kindergarten Room 125, Sink	Flush180	17-JUN-16	1.080	ppb
51078	51078-1-N-125-S01	Main - Inside Kindergarten Room 125, Sink	Flush180	17-JUN-16	0.496	ppb
51078	51078-1-N-125-S01	Main - Inside Kindergarten Room 125, Sink	Flush180	17-JUN-16	0.336	ppb
51078	51078-1-N-125-S01	Main - Inside Kindergarten Room 125, Sink	Flush180	17-JUN-16	1.080	ppb
51078	51078-1-N-125-S01	Main - Inside Kindergarten Room 125, Sink	Flush180	17-JUN-16	1.640	ppb
51078	51078-1-N-125-S01	Main - Inside Kindergarten Room 125, Sink	Flush180	17-JUN-16	1.640	ppb
51078	51078-1-N-125-S01	Main - Inside Kindergarten Room 125, Sink	Flush180	17-JUN-16	0.496	ppb
51078	51078-1-N-125-S01	Main - Inside Kindergarten Room 125, Sink	Flush180	17-JUN-16	0.336	ppb
51078	51078-1-N-125-S01	Main - Inside Kindergarten Room 125, Sink	Flush180	15-MAR-19	1.220	ug/L
51078	51078-1-N-125-S01	Main - Inside Kindergarten Room 125, Sink	Flush180	15-MAR-19	1.210	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51078	51078-1-N-125-S01	Main - Inside Kindergarten Room 125, Sink	Flush180	15-MAR-19	1.750	ug/L
51078	51078-1-N-125-S01	Main - Inside Kindergarten Room 125, Sink	Flush180	15-MAR-19	2.360	ug/L
51078	51078-1-N-125-S01	Main - Inside Kindergarten Room 125, Sink	Initial	17-JUN-16	1.110	ppb
51078	51078-1-N-125-S01	Main - Inside Kindergarten Room 125, Sink	Initial	17-JUN-16	1.110	ppb
51078	51078-1-N-125-S01	Main - Inside Kindergarten Room 125, Sink	Initial	15-MAR-19	2.050	ug/L
51078	51078-1-126-S12	Main - Inside Kindergarten Room 126, Sink	Flush180	17-JUN-16	18.700	ppb
51078	51078-1-126-S12	Main - Inside Kindergarten Room 126, Sink	Flush180	17-JUN-16	17.300	ppb
51078	51078-1-126-S12	Main - Inside Kindergarten Room 126, Sink	Flush180	17-JUN-16	15.600	ppb
51078	51078-1-126-S12	Main - Inside Kindergarten Room 126, Sink	Flush180	17-JUN-16	7.270	ppb
51078	51078-1-126-S12	Main - Inside Kindergarten Room 126, Sink	Flush180	17-JUN-16	15.600	ppb
51078	51078-1-126-S12	Main - Inside Kindergarten Room 126, Sink	Flush180	17-JUN-16	17.300	ppb
51078	51078-1-126-S12	Main - Inside Kindergarten Room 126, Sink	Flush180	17-JUN-16	18.700	ppb
51078	51078-1-126-S12	Main - Inside Kindergarten Room 126, Sink	Flush180	17-JUN-16	7.270	ppb
51078	51078-1-126-S12	Main - Inside Kindergarten Room 126, Sink	Flush180	19-AUG-16	11.000	ppb
51078	51078-1-126-S12	Main - Inside Kindergarten Room 126, Sink	Flush180	19-AUG-16	6.300	ppb
51078	51078-1-126-S12	Main - Inside Kindergarten Room 126, Sink	Flush180	19-AUG-16	8.600	ppb
51078	51078-1-126-S12	Main - Inside Kindergarten Room 126, Sink	Flush180	16-SEP-16	2.100	ppb
51078	51078-1-126-S12	Main - Inside Kindergarten Room 126, Sink	Flush180	16-SEP-16	1.000	ppb
51078	51078-1-126-S12	Main - Inside Kindergarten Room 126, Sink	Flush180	16-SEP-16	2.100	ppb
51078	51078-1-126-S12	Main - Inside Kindergarten Room 126, Sink	Flush180	16-SEP-16	2.000	ppb
51078	51078-1-126-S12	Main - Inside Kindergarten Room 126, Sink	Flush180	19-AUG-16	8.600	ppb
51078	51078-1-126-S12	Main - Inside Kindergarten Room 126, Sink	Flush180	19-AUG-16	7.800	ppb
51078	51078-1-126-S12	Main - Inside Kindergarten Room 126, Sink	Flush180	19-AUG-16	6.300	ppb
51078	51078-1-126-S12	Main - Inside Kindergarten Room 126, Sink	Flush180	19-AUG-16	11.000	ppb
51078	51078-1-126-S12	Main - Inside Kindergarten Room 126, Sink	Flush180	19-AUG-16	7.800	ppb
51078	51078-1-126-S12	Main - Inside Kindergarten Room 126, Sink	Flush180	16-SEP-16	2.100	ppb
51078	51078-1-126-S12	Main - Inside Kindergarten Room 126, Sink	Flush180	16-SEP-16	1.000	ppb
51078	51078-1-126-S12	Main - Inside Kindergarten Room 126, Sink	Flush180	16-SEP-16	2.100	ppb
51078	51078-1-126-S12	Main - Inside Kindergarten Room 126, Sink	Flush180	16-SEP-16	2.000	ppb
51078	51078-1-126-S12	Main - Inside Kindergarten Room 126, Sink	Initial	17-JUN-16	4.310	ppb
51078	51078-1-126-S12	Main - Inside Kindergarten Room 126, Sink	Initial	17-JUN-16	4.310	ppb
51078	51078-1-126-S12	Main - Inside Kindergarten Room 126, Sink	Initial	19-AUG-16	18.000	ppb
51078	51078-1-126-S12	Main - Inside Kindergarten Room 126, Sink	Initial	19-AUG-16	18.000	ppb
51078	51078-1-126-S12	Main - Inside Kindergarten Room 126, Sink	Initial	16-SEP-16	2.700	ppb
51078	51078-1-126-S12	Main - Inside Kindergarten Room 126, Sink	Initial	16-SEP-16	2.700	ppb
51078	51078-1-117-S06	Main - Inside Room 117, Sink	Flush180	19-AUG-16	7.700	ppb
51078	51078-1-117-S06	Main - Inside Room 117, Sink	Flush180	19-AUG-16	12.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51078	51078-1-117-S06	Main - Inside Room 117, Sink	Flush180	19-AUG-16	10.000	ppb
51078	51078-1-117-S06	Main - Inside Room 117, Sink	Flush180	19-AUG-16	7.700	ppb
51078	51078-1-117-S06	Main - Inside Room 117, Sink	Flush180	19-AUG-16	10.000	ppb
51078	51078-1-117-S06	Main - Inside Room 117, Sink	Flush180	19-AUG-16	7.700	ppb
51078	51078-1-117-S06	Main - Inside Room 117, Sink	Flush180	16-SEP-16	1.000	ppb
51078	51078-1-117-S06	Main - Inside Room 117, Sink	Flush180	16-SEP-16	1.000	ppb
51078	51078-1-117-S06	Main - Inside Room 117, Sink	Flush180	16-SEP-16	1.000	ppb
51078	51078-1-117-S06	Main - Inside Room 117, Sink	Flush180	16-SEP-16	1.000	ppb
51078	51078-1-117-S06	Main - Inside Room 117, Sink	Flush180	16-SEP-16	1.000	ppb
51078	51078-1-117-S06	Main - Inside Room 117, Sink	Flush180	16-SEP-16	1.000	ppb
51078	51078-1-117-S06	Main - Inside Room 117, Sink	Flush180	16-SEP-16	1.000	ppb
51078	51078-1-117-S06	Main - Inside Room 117, Sink	Flush180	16-SEP-16	1.000	ppb
51078	51078-1-117-S06	Main - Inside Room 117, Sink	Flush180	16-SEP-16	1.000	ppb
51078	51078-1-117-S06	Main - Inside Room 117, Sink	Flush180	19-AUG-16	7.700	ppb
51078	51078-1-117-S06	Main - Inside Room 117, Sink	Flush180	19-AUG-16	12.000	ppb
51078	51078-1-117-S06	Main - Inside Room 117, Sink	Initial	19-AUG-16	17.000	ppb
51078	51078-1-117-S06	Main - Inside Room 117, Sink	Initial	19-AUG-16	17.000	ppb
51078	51078-1-117-S06	Main - Inside Room 117, Sink	Initial	16-SEP-16	1.000	ppb
51078	51078-1-117-S06	Main - Inside Room 117, Sink	Initial	16-SEP-16	1.000	ppb
51078	51078-1-E-KIT-KS01	Main - Kitchen, Sink	Flush180	17-JUN-16	0.627	ppb
51078	51078-1-E-KIT-KS01	Main - Kitchen, Sink	Flush180	17-JUN-16	0.714	ppb
51078	51078-1-E-KIT-KS01	Main - Kitchen, Sink	Flush180	17-JUN-16	0.714	ppb
51078	51078-1-E-KIT-KS01	Main - Kitchen, Sink	Flush180	17-JUN-16	0.258	ppb
51078	51078-1-E-KIT-KS01	Main - Kitchen, Sink	Flush180	17-JUN-16	0.258	ppb
51078	51078-1-E-KIT-KS01	Main - Kitchen, Sink	Flush180	17-JUN-16	1.820	ppb
51078	51078-1-E-KIT-KS01	Main - Kitchen, Sink	Flush180	17-JUN-16	1.820	ppb
51078	51078-1-E-KIT-KS01	Main - Kitchen, Sink	Flush180	17-JUN-16	0.627	ppb
51078	51078-1-E-KIT-KS01	Main - Kitchen, Sink	Flush180	15-MAR-19	1.000	ug/L
51078	51078-1-E-KIT-KS01	Main - Kitchen, Sink	Flush180	15-MAR-19	1.000	ug/L
51078	51078-1-E-KIT-KS01	Main - Kitchen, Sink	Flush180	15-MAR-19	1.000	ug/L
51078	51078-1-E-KIT-KS01	Main - Kitchen, Sink	Initial	17-JUN-16	1.040	ppb
51078	51078-1-E-KIT-KS01	Main - Kitchen, Sink	Initial	17-JUN-16	1.040	ppb
51078	51078-1-E-KIT-KS01	Main - Kitchen, Sink	Initial	15-MAR-19	1.000	ug/L
51078	51078-1-HAL-F07	Main - Outside Boys Toilet (East), Fountain 1	Flush180	17-JUN-16	0.277	ppb
51078	51078-1-HAL-F07	Main - Outside Boys Toilet (East), Fountain 1	Flush180	17-JUN-16	0.259	ppb
51078	51078-1-S-HAL-F02	Main - Outside Boys Toilet (East), Fountain 1	Flush180	17-JUN-16	0.147	ppb
51078	51078-1-HAL-F07	Main - Outside Boys Toilet (East), Fountain 1	Flush180	17-JUN-16	0.267	ppb
51078	51078-1-S-	Main - Outside Boys Toilet (East),	Flush180	17-JUN-16	0.203	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F02	Fountain 1				
51078	51078-1-S-HAL-F02	Main - Outside Boys Toilet (East), Fountain 1	Flush180	17-JUN-16	0.203	ppb
51078	51078-1-S-HAL-F02	Main - Outside Boys Toilet (East), Fountain 1	Flush180	17-JUN-16	0.147	ppb
51078	51078-1-S-HAL-F02	Main - Outside Boys Toilet (East), Fountain 1	Flush180	17-JUN-16	0.179	ppb
51078	51078-1-S-HAL-F02	Main - Outside Boys Toilet (East), Fountain 1	Flush180	17-JUN-16	0.367	ppb
51078	51078-1-S-HAL-F02	Main - Outside Boys Toilet (East), Fountain 1	Flush180	17-JUN-16	0.367	ppb
51078	51078-1-HAL-F07	Main - Outside Boys Toilet (East), Fountain 1	Flush180	17-JUN-16	0.277	ppb
51078	51078-1-HAL-F07	Main - Outside Boys Toilet (East), Fountain 1	Flush180	17-JUN-16	0.259	ppb
51078	51078-1-HAL-F07	Main - Outside Boys Toilet (East), Fountain 1	Flush180	17-JUN-16	0.267	ppb
51078	51078-1-HAL-F07	Main - Outside Boys Toilet (East), Fountain 1	Flush180	17-JUN-16	0.267	ppb
51078	51078-1-S-HAL-F02	Main - Outside Boys Toilet (East), Fountain 1	Flush180	17-JUN-16	0.179	ppb
51078	51078-1-HAL-F07	Main - Outside Boys Toilet (East), Fountain 1	Flush180	17-JUN-16	0.267	ppb
51078	51078-1-S-HAL-F02	Main - Outside Boys Toilet (East), Fountain 1	Flush180	15-MAR-19	1.000	ug/L
51078	51078-1-S-HAL-F02	Main - Outside Boys Toilet (East), Fountain 1	Flush180	15-MAR-19	1.000	ug/L
51078	51078-1-S-HAL-F02	Main - Outside Boys Toilet (East), Fountain 1	Flush180	15-MAR-19	1.000	ug/L
51078	51078-1-S-HAL-F02	Main - Outside Boys Toilet (East), Fountain 1	Flush180	15-MAR-19	1.000	ug/L
51078	51078-1-HAL-F07	Main - Outside Boys Toilet (East), Fountain 1	Initial	17-JUN-16	0.535	ppb
51078	51078-1-S-HAL-F02	Main - Outside Boys Toilet (East), Fountain 1	Initial	17-JUN-16	0.277	ppb
51078	51078-1-S-HAL-F02	Main - Outside Boys Toilet (East), Fountain 1	Initial	17-JUN-16	0.277	ppb
51078	51078-1-HAL-F07	Main - Outside Boys Toilet (East), Fountain 1	Initial	17-JUN-16	0.535	ppb
51078	51078-1-S-HAL-F02	Main - Outside Boys Toilet (East), Fountain 1	Initial	15-MAR-19	1.000	ug/L
51078	51078-1-S-HAL-F03	Main - Outside Boys Toilet (West), Fountain 2	Flush180	17-JUN-16	0.130	ppb
51078	51078-1-S-HAL-F03	Main - Outside Boys Toilet (West), Fountain 2	Flush180	17-JUN-16	0.134	ppb
51078	51078-1-S-HAL-F03	Main - Outside Boys Toilet (West), Fountain 2	Flush180	17-JUN-16	0.122	ppb
51078	51078-1-S-HAL-F03	Main - Outside Boys Toilet (West), Fountain 2	Flush180	17-JUN-16	0.130	ppb
51078	51078-1-S-HAL-F03	Main - Outside Boys Toilet (West), Fountain 2	Flush180	17-JUN-16	0.130	ppb
51078	51078-1-S-HAL-F03	Main - Outside Boys Toilet (West), Fountain 2	Flush180	17-JUN-16	0.134	ppb
51078	51078-1-S-HAL-F03	Main - Outside Boys Toilet (West), Fountain 2	Flush180	17-JUN-16	0.122	ppb
51078	51078-1-HAL-F08	Main - Outside Boys Toilet (West), Fountain 2	Flush180	17-JUN-16	0.258	ppb
51078	51078-1-HAL-F08	Main - Outside Boys Toilet (West), Fountain 2	Flush180	17-JUN-16	0.258	ppb
51078	51078-1-HAL-F08	Main - Outside Boys Toilet (West), Fountain 2	Flush180	17-JUN-16	0.266	ppb
51078	51078-1-HAL-F08	Main - Outside Boys Toilet (West), Fountain 2	Flush180	17-JUN-16	0.266	ppb
51078	51078-1-HAL-F08	Main - Outside Boys Toilet (West), Fountain 2	Flush180	17-JUN-16	0.261	ppb
51078	51078-1-HAL-F08	Main - Outside Boys Toilet (West), Fountain 2	Flush180	17-JUN-16	0.261	ppb
51078	51078-1-HAL-F08	Main - Outside Boys Toilet (West), Fountain 2	Flush180	17-JUN-16	0.258	ppb
51078	51078-1-HAL-F08	Main - Outside Boys Toilet (West), Fountain 2	Flush180	17-JUN-16	0.258	ppb
51078	51078-1-S-HAL-F03	Main - Outside Boys Toilet (West), Fountain 2	Flush180	17-JUN-16	0.130	ppb
51078	51078-1-S-	Main - Outside Boys Toilet (West),	Flush180	15-MAR-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F03	Fountain 2				
51078	51078-1-S-HAL-F03	Main - Outside Boys Toilet (West), Fountain 2	Flush180	15-MAR-19	1.000	ug/L
51078	51078-1-S-HAL-F03	Main - Outside Boys Toilet (West), Fountain 2	Flush180	15-MAR-19	1.000	ug/L
51078	51078-1-S-HAL-F03	Main - Outside Boys Toilet (West), Fountain 2	Flush180	15-MAR-19	1.000	ug/L
51078	51078-1-S-HAL-F03	Main - Outside Boys Toilet (West), Fountain 2	Initial	17-JUN-16	0.135	ppb
51078	51078-1-S-HAL-F03	Main - Outside Boys Toilet (West), Fountain 2	Initial	17-JUN-16	0.135	ppb
51078	51078-1-HAL-F08	Main - Outside Boys Toilet (West), Fountain 2	Initial	17-JUN-16	0.263	ppb
51078	51078-1-HAL-F08	Main - Outside Boys Toilet (West), Fountain 2	Initial	17-JUN-16	0.263	ppb
51078	51078-1-S-HAL-F03	Main - Outside Boys Toilet (West), Fountain 2	Initial	15-MAR-19	1.000	ug/L
51078	51078-B-W-HAL-F01	Main - Outside Gym (North), Fountain 1	Flush180	17-JUN-16	0.667	ppb
51078	51078-B-W-HAL-F01	Main - Outside Gym (North), Fountain 1	Flush180	17-JUN-16	0.587	ppb
51078	51078-B-W-HAL-F01	Main - Outside Gym (North), Fountain 1	Flush180	17-JUN-16	0.620	ppb
51078	51078-B-W-HAL-F01	Main - Outside Gym (North), Fountain 1	Flush180	17-JUN-16	0.587	ppb
51078	51078-B-W-HAL-F01	Main - Outside Gym (North), Fountain 1	Flush180	17-JUN-16	0.646	ppb
51078	51078-B-W-HAL-F01	Main - Outside Gym (North), Fountain 1	Flush180	17-JUN-16	0.646	ppb
51078	51078-B-W-HAL-F01	Main - Outside Gym (North), Fountain 1	Flush180	17-JUN-16	0.620	ppb
51078	51078-B-W-HAL-F01	Main - Outside Gym (North), Fountain 1	Flush180	17-JUN-16	0.667	ppb
51078	51078-B-W-HAL-F01	Main - Outside Gym (North), Fountain 1	Flush180	15-MAR-19	1.000	ug/L
51078	51078-B-W-HAL-F01	Main - Outside Gym (North), Fountain 1	Flush180	15-MAR-19	1.000	ug/L
51078	51078-B-W-HAL-F01	Main - Outside Gym (North), Fountain 1	Flush180	15-MAR-19	1.000	ug/L
51078	51078-B-W-HAL-F01	Main - Outside Gym (North), Fountain 1	Initial	17-JUN-16	0.995	ppb
51078	51078-B-W-HAL-F01	Main - Outside Gym (North), Fountain 1	Initial	17-JUN-16	0.995	ppb
51078	51078-B-W-HAL-F01	Main - Outside Gym (North), Fountain 1	Initial	15-MAR-19	1.000	ug/L
51078	51078-B-W-HAL-F02	Main - Outside Gym (South), Fountain 2	Flush180	17-JUN-16	0.497	ppb
51078	51078-B-W-HAL-F02	Main - Outside Gym (South), Fountain 2	Flush180	17-JUN-16	0.534	ppb
51078	51078-B-W-HAL-F02	Main - Outside Gym (South), Fountain 2	Flush180	17-JUN-16	0.391	ppb
51078	51078-B-W-HAL-F02	Main - Outside Gym (South), Fountain 2	Flush180	17-JUN-16	0.308	ppb
51078	51078-B-W-HAL-F02	Main - Outside Gym (South), Fountain 2	Flush180	17-JUN-16	0.534	ppb
51078	51078-B-W-HAL-F02	Main - Outside Gym (South), Fountain 2	Flush180	17-JUN-16	0.308	ppb
51078	51078-B-W-HAL-F02	Main - Outside Gym (South), Fountain 2	Flush180	17-JUN-16	0.391	ppb
51078	51078-B-W-HAL-F02	Main - Outside Gym (South), Fountain 2	Flush180	17-JUN-16	0.497	ppb
51078	51078-B-W-HAL-F02	Main - Outside Gym (South), Fountain 2	Flush180	15-MAR-19	1.000	ug/L
51078	51078-B-W-HAL-F02	Main - Outside Gym (South), Fountain 2	Flush180	15-MAR-19	1.000	ug/L
51078	51078-B-W-HAL-F02	Main - Outside Gym (South), Fountain 2	Flush180	15-MAR-19	1.000	ug/L
51078	51078-B-W-HAL-F02	Main - Outside Gym (South), Fountain 2	Flush180	15-MAR-19	1.000	ug/L
51078	51078-B-W-HAL-F02	Main - Outside Gym (South), Fountain 2	Initial	17-JUN-16	0.543	ppb
51078	51078-B-W-HAL-F02	Main - Outside Gym (South), Fountain 2	Initial	17-JUN-16	0.543	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51078	51078-B-W-HAL-F02	Main - Outside Gym (South), Fountain 2	Initial	15-MAR-19	1.000	ug/L
51078	51078-1-S-HAL-F04	Main - Outside Main Office (East), Fountain 1	Flush180	17-JUN-16	0.710	ppb
51078	51078-1-S-HAL-F04	Main - Outside Main Office (East), Fountain 1	Flush180	17-JUN-16	0.687	ppb
51078	51078-1-S-HAL-F04	Main - Outside Main Office (East), Fountain 1	Flush180	17-JUN-16	0.682	ppb
51078	51078-1-S-HAL-F04	Main - Outside Main Office (East), Fountain 1	Flush180	17-JUN-16	0.710	ppb
51078	51078-1-S-HAL-F04	Main - Outside Main Office (East), Fountain 1	Flush180	17-JUN-16	0.687	ppb
51078	51078-1-S-HAL-F04	Main - Outside Main Office (East), Fountain 1	Flush180	17-JUN-16	0.658	ppb
51078	51078-1-S-HAL-F04	Main - Outside Main Office (East), Fountain 1	Flush180	17-JUN-16	0.682	ppb
51078	51078-1-S-HAL-F04	Main - Outside Main Office (East), Fountain 1	Flush180	17-JUN-16	0.658	ppb
51078	51078-1-S-HAL-F04	Main - Outside Main Office (East), Fountain 1	Flush180	15-MAR-19	1.000	ug/L
51078	51078-1-S-HAL-F04	Main - Outside Main Office (East), Fountain 1	Flush180	15-MAR-19	1.000	ug/L
51078	51078-1-S-HAL-F04	Main - Outside Main Office (East), Fountain 1	Flush180	15-MAR-19	1.000	ug/L
51078	51078-1-S-HAL-F04	Main - Outside Main Office (East), Fountain 1	Flush180	15-MAR-19	1.000	ug/L
51078	51078-1-S-HAL-F04	Main - Outside Main Office (East), Fountain 1	Initial	17-JUN-16	0.786	ppb
51078	51078-1-S-HAL-F04	Main - Outside Main Office (East), Fountain 1	Initial	17-JUN-16	0.786	ppb
51078	51078-1-S-HAL-F04	Main - Outside Main Office (East), Fountain 1	Initial	15-MAR-19	1.000	ug/L
51078	51078-1-N-HAL-F05	Main - Outside Main Office (West), Fountain 2	Flush180	17-JUN-16	0.280	ppb
51078	51078-1-N-HAL-F05	Main - Outside Main Office (West), Fountain 2	Flush180	17-JUN-16	0.188	ppb
51078	51078-1-N-HAL-F05	Main - Outside Main Office (West), Fountain 2	Flush180	17-JUN-16	0.280	ppb
51078	51078-1-N-HAL-F05	Main - Outside Main Office (West), Fountain 2	Flush180	17-JUN-16	0.313	ppb
51078	51078-1-N-HAL-F05	Main - Outside Main Office (West), Fountain 2	Flush180	17-JUN-16	0.188	ppb
51078	51078-1-N-HAL-F05	Main - Outside Main Office (West), Fountain 2	Flush180	17-JUN-16	0.313	ppb
51078	51078-1-N-HAL-F05	Main - Outside Main Office (West), Fountain 2	Flush180	17-JUN-16	0.433	ppb
51078	51078-1-N-HAL-F05	Main - Outside Main Office (West), Fountain 2	Flush180	17-JUN-16	0.433	ppb
51078	51078-1-N-HAL-F05	Main - Outside Main Office (West), Fountain 2	Flush180	15-MAR-19	1.000	ug/L
51078	51078-1-N-HAL-F05	Main - Outside Main Office (West), Fountain 2	Flush180	15-MAR-19	1.000	ug/L
51078	51078-1-N-HAL-F05	Main - Outside Main Office (West), Fountain 2	Flush180	15-MAR-19	1.000	ug/L
51078	51078-1-N-HAL-F05	Main - Outside Main Office (West), Fountain 2	Initial	17-JUN-16	0.581	ppb
51078	51078-1-N-HAL-F05	Main - Outside Main Office (West), Fountain 2	Initial	17-JUN-16	0.581	ppb
51078	51078-1-N-HAL-F05	Main - Outside Main Office (West), Fountain 2	Initial	15-MAR-19	1.000	ug/L
51078	51078-1-126-F11	Main- Inside Room 126, Fountain	Flush180	19-AUG-16	3.300	ppb
51078	51078-1-126-F11	Main- Inside Room 126, Fountain	Flush180	19-AUG-16	3.800	ppb
51078	51078-1-126-F11	Main- Inside Room 126, Fountain	Flush180	19-AUG-16	4.600	ppb
51078	51078-1-126-F11	Main- Inside Room 126, Fountain	Flush180	19-AUG-16	3.800	ppb
51078	51078-1-126-F11	Main- Inside Room 126, Fountain	Flush180	16-SEP-16	1.000	ppb
51078	51078-1-126-F11	Main- Inside Room 126, Fountain	Flush180	16-SEP-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51078	51078-1-126-F11	Main- Inside Room 126, Fountain	Flush180	16-SEP-16	1.000	ppb
51078	51078-1-126-F11	Main- Inside Room 126, Fountain	Flush180	16-SEP-16	1.000	ppb
51078	51078-1-126-F11	Main- Inside Room 126, Fountain	Flush180	19-AUG-16	4.600	ppb
51078	51078-1-126-F11	Main- Inside Room 126, Fountain	Flush180	19-AUG-16	3.600	ppb
51078	51078-1-126-F11	Main- Inside Room 126, Fountain	Flush180	19-AUG-16	3.300	ppb
51078	51078-1-126-F11	Main- Inside Room 126, Fountain	Flush180	19-AUG-16	3.600	ppb
51078	51078-1-126-F11	Main- Inside Room 126, Fountain	Initial	16-SEP-16	1.000	ppb
51078	51078-1-126-F11	Main- Inside Room 126, Fountain	Initial	19-AUG-16	5.100	ppb
51078	51078-1-126-F11	Main- Inside Room 126, Fountain	Initial	19-AUG-16	5.100	ppb
52599	52599-1-S-HAL-F01	Addition - Next to Boy's Toilet (North) Left Fountain	Flush180	08-AUG-23	1.000	ug/L
52599	52599-1-S-HAL-F01	Addition - Next to Boy's Toilet (North) Left Fountain	Flush180	08-AUG-23	1.000	ug/L
52599	52599-1-S-HAL-F01	Addition - Next to Boy's Toilet (North) Left Fountain	Flush180	08-AUG-23	1.000	ug/L
52599	52599-1-S-HAL-F01	Addition - Next to Boy's Toilet (North) Left Fountain	Flush180	08-AUG-23	1.000	ug/L
52599	52599-1-S-HAL-F01	Addition - Next to Boy's Toilet (North) Left Fountain	Flush180	06-JUL-23	6.220	ug/L
52599	52599-1-S-HAL-F01	Addition - Next to Boy's Toilet (North) Left Fountain	Flush180	06-JUL-23	4.400	ug/L
52599	52599-1-S-HAL-F01	Addition - Next to Boy's Toilet (North) Left Fountain	Flush180	06-JUL-23	4.740	ug/L
52599	52599-1-S-HAL-F01	Addition - Next to Boy's Toilet (North) Left Fountain	Flush180	06-JUL-23	6.390	ug/L
52599	52599-1-S-HAL-F01	Addition - Next to Boy's Toilet (North) Left Fountain	Flush180	05-OCT-16	17.000	ppb
52599	52599-1-S-HAL-F01	Addition - Next to Boy's Toilet (North) Left Fountain	Flush180	16-SEP-16	19.000	ppb
52599	52599-1-S-HAL-F01	Addition - Next to Boy's Toilet (North) Left Fountain	Flush180	16-SEP-16	19.000	ppb
52599	52599-1-S-HAL-F01	Addition - Next to Boy's Toilet (North) Left Fountain	Flush180	16-SEP-16	33.000	ppb
52599	52599-1-S-HAL-F01	Addition - Next to Boy's Toilet (North) Left Fountain	Flush180	16-SEP-16	33.000	ppb
52599	52599-1-S-HAL-F01	Addition - Next to Boy's Toilet (North) Left Fountain	Flush180	05-OCT-16	20.000	ppb
52599	52599-1-S-HAL-F01	Addition - Next to Boy's Toilet (North) Left Fountain	Flush180	19-AUG-16	31.000	ppb
52599	52599-1-S-HAL-F01	Addition - Next to Boy's Toilet (North) Left Fountain	Flush180	19-AUG-16	58.000	ppb
52599	52599-1-S-HAL-F01	Addition - Next to Boy's Toilet (North) Left Fountain	Flush180	19-AUG-16	33.000	ppb
52599	52599-1-S-HAL-F01	Addition - Next to Boy's Toilet (North) Left Fountain	Flush180	19-AUG-16	58.000	ppb
52599	52599-1-S-HAL-F01	Addition - Next to Boy's Toilet (North) Left Fountain	Flush180	16-SEP-16	27.000	ppb
52599	52599-1-S-HAL-F01	Addition - Next to Boy's Toilet (North) Left Fountain	Flush180	16-SEP-16	27.000	ppb
52599	52599-1-S-HAL-F01	Addition - Next to Boy's Toilet (North) Left Fountain	Flush180	16-SEP-16	24.000	ppb
52599	52599-1-S-HAL-F01	Addition - Next to Boy's Toilet (North) Left Fountain	Flush180	16-SEP-16	24.000	ppb
52599	52599-1-S-HAL-F01	Addition - Next to Boy's Toilet (North) Left Fountain	Flush180	17-JUN-16	20.700	ppb
52599	52599-1-S-HAL-F01	Addition - Next to Boy's Toilet (North) Left Fountain	Flush180	17-JUN-16	20.900	ppb
52599	52599-1-S-HAL-F01	Addition - Next to Boy's Toilet (North) Left Fountain	Flush180	05-OCT-16	20.000	ppb
52599	52599-1-S-HAL-F01	Addition - Next to Boy's Toilet (North) Left Fountain	Flush180	17-JUN-16	19.800	ppb
52599	52599-1-S-HAL-F01	Addition - Next to Boy's Toilet (North) Left Fountain	Flush180	17-JUN-16	20.900	ppb
52599	52599-1-S-HAL-F01	Addition - Next to Boy's Toilet (North) Left Fountain	Flush180	17-JUN-16	20.700	ppb
52599	52599-1-S-	Addition - Next to Boy's Toilet	Flush180	17-JUN-16	20.100	ppb



**Water Quality Assessment  
Joseph Brennemann Elementary School**

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F01	(North) Left Fountain				
52599	52599-1-S-HAL-F01	Addition - Next to Boy's Toilet (North) Left Fountain	Initial	19-AUG-16	47.000	ppb
52599	52599-1-S-HAL-F01	Addition - Next to Boy's Toilet (North) Left Fountain	Initial	19-AUG-16	47.000	ppb
52599	52599-1-S-HAL-F01	Addition - Next to Boy's Toilet (North) Left Fountain	Initial	05-OCT-16	11.000	ppb
52599	52599-1-S-HAL-F01	Addition - Next to Boy's Toilet (North) Left Fountain	Initial	15-MAR-19	1.000	ug/L
52599	52599-1-S-HAL-F02	Addition - Next to Boy's Toilet (North) Right Fountain	Flush180	08-AUG-23	2.090	ug/L
52599	52599-1-S-HAL-F02	Addition - Next to Boy's Toilet (North) Right Fountain	Flush180	08-AUG-23	1.930	ug/L
52599	52599-1-S-HAL-F02	Addition - Next to Boy's Toilet (North) Right Fountain	Flush180	08-AUG-23	1.580	ug/L
52599	52599-1-S-HAL-F02	Addition - Next to Boy's Toilet (North) Right Fountain	Flush180	08-AUG-23	1.530	ug/L
52599	52599-1-S-HAL-F02	Addition - Next to Boy's Toilet (North) Right Fountain	Flush180	06-JUL-23	13.100	ug/L
52599	52599-1-S-HAL-F02	Addition - Next to Boy's Toilet (North) Right Fountain	Flush180	06-JUL-23	30.400	ug/L
52599	52599-1-S-HAL-F02	Addition - Next to Boy's Toilet (North) Right Fountain	Flush180	06-JUL-23	26.500	ug/L
52599	52599-1-S-HAL-F02	Addition - Next to Boy's Toilet (North) Right Fountain	Flush180	06-JUL-23	18.300	ug/L
52599	52599-1-S-HAL-F02	Addition - Next to Boy's Toilet (North) Right Fountain	Initial	08-AUG-23	2.610	ug/L
52599	52599-1-S-HAL-F02	Addition - Next to Boy's Toilet (North) Right Fountain	Initial	06-JUL-23	16.400	ug/L