



Sep 10, 2024

BRIDGE

3800 N NEW ENGLAND AVE, Chicago IL 60634.

Dear **BRIDGE** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

BRIDGE

3800 N NEW ENGLAND AVE, Chicago IL 60634.

Estimadas familias de **BRIDGE**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

| Facility ID | Fixture Code | Fixture Location | Draw Type | Collected On | Result | UOM |
|-------------|-------------------|--|-----------|--------------|--------|------|
| 51004 | 51004-1-HAL-F05 | Main- 1st FI Corridor Across from Rm 107, Left Sink | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-1-HAL-F05 | Main- 1st FI Corridor Across from Rm 107, Left Sink | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-1-HAL-F05 | Main- 1st FI Corridor Across from Rm 107, Left Sink | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-1-HAL-F05 | Main- 1st FI Corridor Across from Rm 107, Left Sink | Flush180 | 18-MAY-23 | 1.110 | ug/L |
| 51004 | 51004-1-HAL-F05 | Main- 1st FI Corridor Across from Rm 107, Left Sink | Initial | 18-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-1-HAL-F06 | Main- 1st FI Corridor Across from Rm 107, Right Sink | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-1-HAL-F06 | Main- 1st FI Corridor Across from Rm 107, Right Sink | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-1-HAL-F06 | Main- 1st FI Corridor Across from Rm 107, Right Sink | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-1-HAL-F06 | Main- 1st FI Corridor Across from Rm 107, Right Sink | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-1-HAL-F06 | Main- 1st FI Corridor Across from Rm 107, Right Sink | Initial | 18-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-1-W-HAL-F02 | Main- 1st FI Corridor Outside Kitchen, Fountain | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-1-W-HAL-F02 | Main- 1st FI Corridor Outside Kitchen, Fountain | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-1-W-HAL-F02 | Main- 1st FI Corridor Outside Kitchen, Fountain | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-1-W-HAL-F02 | Main- 1st FI Corridor Outside Kitchen, Fountain | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-1-W-HAL-F02 | Main- 1st FI Corridor Outside Kitchen, Fountain | Flush180 | 02-JUN-16 | 0.141 | ppb |
| 51004 | 51004-1-W-HAL-F02 | Main- 1st FI Corridor Outside Kitchen, Fountain | Flush180 | 02-JUN-16 | 0.155 | ppb |
| 51004 | 51004-1-W-HAL-F02 | Main- 1st FI Corridor Outside Kitchen, Fountain | Flush180 | 02-JUN-16 | 1.000 | ppb |
| 51004 | 51004-1-W-HAL-F02 | Main- 1st FI Corridor Outside Kitchen, Fountain | Flush180 | 02-JUN-16 | 1.000 | ppb |
| 51004 | 51004-1-W-HAL-F02 | Main- 1st FI Corridor Outside Kitchen, Fountain | Flush180 | 02-JUN-16 | 1.390 | ppb |
| 51004 | 51004-1-W-HAL-F02 | Main- 1st FI Corridor Outside Kitchen, Fountain | Flush180 | 02-JUN-16 | 0.141 | ppb |
| 51004 | 51004-1-W-HAL-F02 | Main- 1st FI Corridor Outside Kitchen, Fountain | Flush180 | 02-JUN-16 | 1.390 | ppb |
| 51004 | 51004-1-W-HAL-F02 | Main- 1st FI Corridor Outside Kitchen, Fountain | Flush180 | 02-JUN-16 | 0.155 | ppb |
| 51004 | 51004-1-W-HAL-F02 | Main- 1st FI Corridor Outside Kitchen, Fountain | Flush180 | 23-JUL-20 | 1.000 | ug/L |
| 51004 | 51004-1-W-HAL-F02 | Main- 1st FI Corridor Outside Kitchen, Fountain | Initial | 19-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-1-W-HAL-F02 | Main- 1st FI Corridor Outside Kitchen, Fountain | Initial | 02-JUN-16 | 1.200 | ppb |
| 51004 | 51004-1-W-HAL-F02 | Main- 1st FI Corridor Outside Kitchen, Fountain | Initial | 02-JUN-16 | 1.200 | ppb |
| 51004 | 51004-1-W-HAL-F02 | Main- 1st FI Corridor Outside Kitchen, Fountain | Initial | 23-JUL-20 | 1.000 | ug/L |
| 51004 | 51004-1-HAL-F03 | Main- 1st FI Corridor Outside Main Office Fountain | Flush180 | 02-JUN-16 | 0.792 | ppb |
| 51004 | 51004-1-HAL-F03 | Main- 1st FI Corridor Outside Main Office Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-1-HAL-F03 | Main- 1st FI Corridor Outside Main Office Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-1-HAL-F03 | Main- 1st FI Corridor Outside Main Office Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-1-HAL-F03 | Main- 1st FI Corridor Outside Main Office Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-1-HAL-F03 | Main- 1st FI Corridor Outside Main Office Fountain | Flush180 | 02-JUN-16 | 0.792 | ppb |
| 51004 | 51004-1-HAL-F03 | Main- 1st FI Corridor Outside Main Office Fountain | Flush180 | 02-JUN-16 | 0.240 | ppb |
| 51004 | 51004-1-HAL-F03 | Main- 1st FI Corridor Outside Main Office Fountain | Flush180 | 02-JUN-16 | 0.240 | ppb |



| Facility ID | Fixture Code | Fixture Location | Draw Type | Collected On | Result | UOM |
|-------------|-----------------|--|-----------|--------------|--------|------|
| 51004 | 51004-1-HAL-F03 | Main- 1st FI Corridor Outside Main Office Fountain | Flush180 | 02-JUN-16 | 0.185 | ppb |
| 51004 | 51004-1-HAL-F03 | Main- 1st FI Corridor Outside Main Office Fountain | Flush180 | 02-JUN-16 | 0.185 | ppb |
| 51004 | 51004-1-HAL-F03 | Main- 1st FI Corridor Outside Main Office Fountain | Flush180 | 02-JUN-16 | 0.436 | ppb |
| 51004 | 51004-1-HAL-F03 | Main- 1st FI Corridor Outside Main Office Fountain | Flush180 | 02-JUN-16 | 0.436 | ppb |
| 51004 | 51004-1-HAL-F03 | Main- 1st FI Corridor Outside Main Office Fountain | Initial | 18-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-1-HAL-F03 | Main- 1st FI Corridor Outside Main Office Fountain | Initial | 02-JUN-16 | 1.040 | ppb |
| 51004 | 51004-1-HAL-F03 | Main- 1st FI Corridor Outside Main Office Fountain | Initial | 02-JUN-16 | 1.040 | ppb |
| 51004 | 51004-1-HAL-F04 | Main- 1st FI Corridor Outside Room 103, Fountain | Flush180 | 02-JUN-16 | 0.784 | ppb |
| 51004 | 51004-1-HAL-F04 | Main- 1st FI Corridor Outside Room 103, Fountain | Flush180 | 02-JUN-16 | 0.872 | ppb |
| 51004 | 51004-1-HAL-F04 | Main- 1st FI Corridor Outside Room 103, Fountain | Flush180 | 02-JUN-16 | 0.871 | ppb |
| 51004 | 51004-1-HAL-F04 | Main- 1st FI Corridor Outside Room 103, Fountain | Flush180 | 02-JUN-16 | 0.872 | ppb |
| 51004 | 51004-1-HAL-F04 | Main- 1st FI Corridor Outside Room 103, Fountain | Flush180 | 02-JUN-16 | 0.784 | ppb |
| 51004 | 51004-1-HAL-F04 | Main- 1st FI Corridor Outside Room 103, Fountain | Flush180 | 02-JUN-16 | 0.871 | ppb |
| 51004 | 51004-1-HAL-F04 | Main- 1st FI Corridor Outside Room 103, Fountain | Flush180 | 02-JUN-16 | 0.749 | ppb |
| 51004 | 51004-1-HAL-F04 | Main- 1st FI Corridor Outside Room 103, Fountain | Flush180 | 02-JUN-16 | 0.749 | ppb |
| 51004 | 51004-1-HAL-F04 | Main- 1st FI Corridor Outside Room 103, Fountain | Flush180 | 18-MAY-23 | 2.020 | ug/L |
| 51004 | 51004-1-HAL-F04 | Main- 1st FI Corridor Outside Room 103, Fountain | Flush180 | 18-MAY-23 | 2.120 | ug/L |
| 51004 | 51004-1-HAL-F04 | Main- 1st FI Corridor Outside Room 103, Fountain | Flush180 | 18-MAY-23 | 1.850 | ug/L |
| 51004 | 51004-1-HAL-F04 | Main- 1st FI Corridor Outside Room 103, Fountain | Flush180 | 18-MAY-23 | 1.800 | ug/L |
| 51004 | 51004-1-HAL-F04 | Main- 1st FI Corridor Outside Room 103, Fountain | Initial | 02-JUN-16 | 1.110 | ppb |
| 51004 | 51004-1-HAL-F04 | Main- 1st FI Corridor Outside Room 103, Fountain | Initial | 02-JUN-16 | 1.110 | ppb |
| 51004 | 51004-1-HAL-F04 | Main- 1st FI Corridor Outside Room 103, Fountain | Initial | 18-MAY-23 | 1.680 | ug/L |
| 51004 | 51004-2-HAL-F03 | Main- 2nd FI Outside Room 203, Fountain | Flush180 | 02-JUN-16 | 0.986 | ppb |
| 51004 | 51004-2-HAL-F03 | Main- 2nd FI Outside Room 203, Fountain | Flush180 | 02-JUN-16 | 1.730 | ppb |
| 51004 | 51004-2-HAL-F03 | Main- 2nd FI Outside Room 203, Fountain | Flush180 | 02-JUN-16 | 0.973 | ppb |
| 51004 | 51004-2-HAL-F03 | Main- 2nd FI Outside Room 203, Fountain | Flush180 | 02-JUN-16 | 1.080 | ppb |
| 51004 | 51004-2-HAL-F03 | Main- 2nd FI Outside Room 203, Fountain | Flush180 | 02-JUN-16 | 0.986 | ppb |
| 51004 | 51004-2-HAL-F03 | Main- 2nd FI Outside Room 203, Fountain | Flush180 | 02-JUN-16 | 1.730 | ppb |
| 51004 | 51004-2-HAL-F03 | Main- 2nd FI Outside Room 203, Fountain | Flush180 | 02-JUN-16 | 0.973 | ppb |
| 51004 | 51004-2-HAL-F03 | Main- 2nd FI Outside Room 203, Fountain | Flush180 | 02-JUN-16 | 1.080 | ppb |
| 51004 | 51004-2-HAL-F03 | Main- 2nd FI Outside Room 203, Fountain | Flush180 | 18-MAY-23 | 1.770 | ug/L |
| 51004 | 51004-2-HAL-F03 | Main- 2nd FI Outside Room 203, Fountain | Flush180 | 18-MAY-23 | 1.630 | ug/L |
| 51004 | 51004-2-HAL-F03 | Main- 2nd FI Outside Room 203, Fountain | Flush180 | 18-MAY-23 | 1.520 | ug/L |
| 51004 | 51004-2-HAL-F03 | Main- 2nd FI Outside Room 203, Fountain | Flush180 | 18-MAY-23 | 1.440 | ug/L |
| 51004 | 51004-2-HAL-F03 | Main- 2nd FI Outside Room 203, Fountain | Initial | 02-JUN-16 | 1.360 | ppb |
| 51004 | 51004-2-HAL-F03 | Main- 2nd FI Outside Room 203, Fountain | Initial | 02-JUN-16 | 1.360 | ppb |
| 51004 | 51004-2-HAL-F03 | Main- 2nd FI Outside Room 203, Fountain | Initial | 18-MAY-23 | 1.830 | ug/L |

Water Quality Assessment Norman A Bridge Elementary School

| Facility ID | Fixture Code | Fixture Location | Draw Type | Collected On | Result | UOM |
|-------------|-------------------|---|-----------|--------------|--------|------|
| 51004 | 51004-2-HAL-F02 | Main- 2nd FI Outside Room 204, Fountain | Flush180 | 02-JUN-16 | 0.708 | ppb |
| 51004 | 51004-2-HAL-F02 | Main- 2nd FI Outside Room 204, Fountain | Flush180 | 02-JUN-16 | 0.702 | ppb |
| 51004 | 51004-2-HAL-F02 | Main- 2nd FI Outside Room 204, Fountain | Flush180 | 02-JUN-16 | 0.897 | ppb |
| 51004 | 51004-2-HAL-F02 | Main- 2nd FI Outside Room 204, Fountain | Flush180 | 02-JUN-16 | 0.708 | ppb |
| 51004 | 51004-2-HAL-F02 | Main- 2nd FI Outside Room 204, Fountain | Flush180 | 02-JUN-16 | 0.914 | ppb |
| 51004 | 51004-2-HAL-F02 | Main- 2nd FI Outside Room 204, Fountain | Flush180 | 02-JUN-16 | 0.897 | ppb |
| 51004 | 51004-2-HAL-F02 | Main- 2nd FI Outside Room 204, Fountain | Flush180 | 02-JUN-16 | 0.914 | ppb |
| 51004 | 51004-2-HAL-F02 | Main- 2nd FI Outside Room 204, Fountain | Flush180 | 02-JUN-16 | 0.702 | ppb |
| 51004 | 51004-2-HAL-F02 | Main- 2nd FI Outside Room 204, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-2-HAL-F02 | Main- 2nd FI Outside Room 204, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-2-HAL-F02 | Main- 2nd FI Outside Room 204, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-2-HAL-F02 | Main- 2nd FI Outside Room 204, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-2-HAL-F02 | Main- 2nd FI Outside Room 204, Fountain | Initial | 02-JUN-16 | 1.090 | ppb |
| 51004 | 51004-2-HAL-F02 | Main- 2nd FI Outside Room 204, Fountain | Initial | 02-JUN-16 | 1.090 | ppb |
| 51004 | 51004-2-HAL-F02 | Main- 2nd FI Outside Room 204, Fountain | Initial | 18-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-2-W-HAL-F01 | Main- 2nd FI Outside Room 212, Fountain | Flush180 | 02-JUN-16 | 0.625 | ppb |
| 51004 | 51004-2-W-HAL-F01 | Main- 2nd FI Outside Room 212, Fountain | Flush180 | 02-JUN-16 | 0.625 | ppb |
| 51004 | 51004-2-W-HAL-F01 | Main- 2nd FI Outside Room 212, Fountain | Flush180 | 02-JUN-16 | 0.754 | ppb |
| 51004 | 51004-2-W-HAL-F01 | Main- 2nd FI Outside Room 212, Fountain | Flush180 | 02-JUN-16 | 0.859 | ppb |
| 51004 | 51004-2-W-HAL-F01 | Main- 2nd FI Outside Room 212, Fountain | Flush180 | 02-JUN-16 | 0.859 | ppb |
| 51004 | 51004-2-W-HAL-F01 | Main- 2nd FI Outside Room 212, Fountain | Flush180 | 02-JUN-16 | 0.754 | ppb |
| 51004 | 51004-2-W-HAL-F01 | Main- 2nd FI Outside Room 212, Fountain | Flush180 | 02-JUN-16 | 0.794 | ppb |
| 51004 | 51004-2-W-HAL-F01 | Main- 2nd FI Outside Room 212, Fountain | Flush180 | 02-JUN-16 | 0.794 | ppb |
| 51004 | 51004-2-W-HAL-F01 | Main- 2nd FI Outside Room 212, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-2-W-HAL-F01 | Main- 2nd FI Outside Room 212, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-2-W-HAL-F01 | Main- 2nd FI Outside Room 212, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-2-W-HAL-F01 | Main- 2nd FI Outside Room 212, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-2-W-HAL-F01 | Main- 2nd FI Outside Room 212, Fountain | Flush180 | 23-JUL-20 | 5.540 | ug/L |
| 51004 | 51004-2-W-HAL-F01 | Main- 2nd FI Outside Room 212, Fountain | Flush180 | 10-SEP-20 | 1.510 | ug/L |
| 51004 | 51004-2-W-HAL-F01 | Main- 2nd FI Outside Room 212, Fountain | Flush180 | 10-SEP-20 | 1.400 | ug/L |
| 51004 | 51004-2-W-HAL-F01 | Main- 2nd FI Outside Room 212, Fountain | Flush180 | 10-SEP-20 | 1.300 | ug/L |
| 51004 | 51004-2-W-HAL-F01 | Main- 2nd FI Outside Room 212, Fountain | Flush180 | 10-SEP-20 | 2.090 | ug/L |
| 51004 | 51004-2-W-HAL-F01 | Main- 2nd FI Outside Room 212, Fountain | Initial | 02-JUN-16 | 0.761 | ppb |
| 51004 | 51004-2-W-HAL-F01 | Main- 2nd FI Outside Room 212, Fountain | Initial | 02-JUN-16 | 0.761 | ppb |
| 51004 | 51004-2-W-HAL-F01 | Main- 2nd FI Outside Room 212, Fountain | Initial | 18-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-2-W-HAL-F01 | Main- 2nd FI Outside Room 212, Fountain | Initial | 23-JUL-20 | 1.770 | ug/L |
| 51004 | 51004-2-W-HAL-F01 | Main- 2nd FI Outside Room 212, Fountain | Initial | 10-SEP-20 | 1.280 | ug/L |
| 51004 | 51004-1-KIT- | Main- North Kitchen Sink | Flush180 | 02-JUN-16 | 0.397 | ppb |



| Facility ID | Fixture Code | Fixture Location | Draw Type | Collected On | Result | UOM |
|-------------|--------------------|--|-----------|--------------|--------|------|
| | KS01 | | | | | |
| 51004 | 51004-1-KIT-KS01 | Main- North Kitchen Sink | Flush180 | 02-JUN-16 | 0.301 | ppb |
| 51004 | 51004-1-KIT-KS01 | Main- North Kitchen Sink | Flush180 | 02-JUN-16 | 0.397 | ppb |
| 51004 | 51004-1-KIT-KS01 | Main- North Kitchen Sink | Flush180 | 02-JUN-16 | 0.325 | ppb |
| 51004 | 51004-1-KIT-KS01 | Main- North Kitchen Sink | Flush180 | 02-JUN-16 | 0.309 | ppb |
| 51004 | 51004-1-KIT-KS01 | Main- North Kitchen Sink | Flush180 | 02-JUN-16 | 0.301 | ppb |
| 51004 | 51004-1-KIT-KS01 | Main- North Kitchen Sink | Flush180 | 02-JUN-16 | 0.309 | ppb |
| 51004 | 51004-1-KIT-KS01 | Main- North Kitchen Sink | Flush180 | 02-JUN-16 | 0.325 | ppb |
| 51004 | 51004-1-KIT-KS01 | Main- North Kitchen Sink | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-1-KIT-KS01 | Main- North Kitchen Sink | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-1-KIT-KS01 | Main- North Kitchen Sink | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-1-KIT-KS01 | Main- North Kitchen Sink | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-1-KIT-KS01 | Main- North Kitchen Sink | Initial | 02-JUN-16 | 0.673 | ppb |
| 51004 | 51004-1-KIT-KS01 | Main- North Kitchen Sink | Initial | 02-JUN-16 | 0.673 | ppb |
| 51004 | 51004-1-KIT-KS01 | Main- North Kitchen Sink | Initial | 19-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-2-W-HAL-F04 | Main-2nd FI Outside Room 212, Fountain on left | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-2-W-HAL-F04 | Main-2nd FI Outside Room 212, Fountain on left | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-2-W-HAL-F04 | Main-2nd FI Outside Room 212, Fountain on left | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-2-W-HAL-F04 | Main-2nd FI Outside Room 212, Fountain on left | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-2-W-HAL-F04 | Main-2nd FI Outside Room 212, Fountain on left | Initial | 18-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-1-W-HAL-BF01 | Main-Inside lunchroom, bottle filler | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-1-W-HAL-BF01 | Main-Inside lunchroom, bottle filler | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-1-W-HAL-BF01 | Main-Inside lunchroom, bottle filler | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-1-W-HAL-BF01 | Main-Inside lunchroom, bottle filler | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-1-W-HAL-BF01 | Main-Inside lunchroom, bottle filler | Initial | 19-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-1-KIT-KS02 | Main-North Kitchen, Right Sink | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-1-KIT-KS02 | Main-North Kitchen, Right Sink | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-1-KIT-KS02 | Main-North Kitchen, Right Sink | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-1-KIT-KS02 | Main-North Kitchen, Right Sink | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 51004 | 51004-1-KIT-KS02 | Main-North Kitchen, Right Sink | Initial | 18-MAY-23 | 1.000 | ug/L |
| 53763 | 53763-1-HAL-RBF01 | Modular- Outside Girls Toilets, Fountain 1 | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 53763 | 53763-1-HAL-RBF01 | Modular- Outside Girls Toilets, Fountain 1 | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 53763 | 53763-1-HAL-RBF01 | Modular- Outside Girls Toilets, Fountain 1 | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 53763 | 53763-1-HAL-RBF01 | Modular- Outside Girls Toilets, Fountain 1 | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 53763 | 53763-1-HAL-RBF01 | Modular- Outside Girls Toilets, Fountain 1 | Initial | 18-MAY-23 | 1.000 | ug/L |
| 53763 | 53763-1-HAL-F01 | Modular- Outside Girls Toilets, Fountain 1 | Flush180 | 02-JUN-16 | 1.000 | ppb |
| 53763 | 53763-1-HAL-F01 | Modular- Outside Girls Toilets, Fountain 1 | Flush180 | 02-JUN-16 | 1.000 | ppb |
| 53763 | 53763-1-HAL-F01 | Modular- Outside Girls Toilets, Fountain 1 | Flush180 | 02-JUN-16 | 1.000 | ppb |

| Facility ID | Fixture Code | Fixture Location | Draw Type | Collected On | Result | UOM |
|-------------|--------------------|---|-----------|--------------|--------|------|
| | F01 | Fountain 1 | | | | |
| 53763 | 53763-1-HAL-F01 | Modular- Outside Girls Toilets, Fountain 1 | Flush180 | 02-JUN-16 | 1.000 | ppb |
| 53763 | 53763-1-HAL-F01 | Modular- Outside Girls Toilets, Fountain 1 | Initial | 02-JUN-16 | 1.000 | ppb |
| 53763 | 53763-1-HAL-F02 | Modular- Outside Girls Toilets, Fountain 2 | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 53763 | 53763-1-HAL-F02 | Modular- Outside Girls Toilets, Fountain 2 | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 53763 | 53763-1-HAL-F02 | Modular- Outside Girls Toilets, Fountain 2 | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 53763 | 53763-1-HAL-F02 | Modular- Outside Girls Toilets, Fountain 2 | Flush180 | 02-JUN-16 | 1.000 | ppb |
| 53763 | 53763-1-HAL-F02 | Modular- Outside Girls Toilets, Fountain 2 | Flush180 | 02-JUN-16 | 1.000 | ppb |
| 53763 | 53763-1-HAL-F02 | Modular- Outside Girls Toilets, Fountain 2 | Flush180 | 02-JUN-16 | 1.000 | ppb |
| 53763 | 53763-1-HAL-F02 | Modular- Outside Girls Toilets, Fountain 2 | Initial | 18-MAY-23 | 1.000 | ug/L |
| 53763 | 53763-1-HAL-F02 | Modular- Outside Girls Toilets, Fountain 2 | Initial | 02-JUN-16 | 0.131 | ppb |
| 54722 | 54722-1-E-HAL-WC05 | Branch - 1st FL Outside Boys Toilet, Fountain on left | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-1-E-HAL-WC05 | Branch - 1st FL Outside Boys Toilet, Fountain on left | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-1-E-HAL-WC05 | Branch - 1st FL Outside Boys Toilet, Fountain on left | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-1-E-HAL-WC05 | Branch - 1st FL Outside Boys Toilet, Fountain on left | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-1-E-HAL-WC05 | Branch - 1st FL Outside Boys Toilet, Fountain on left | Initial | 18-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-2-HAL-WC02 | Branch, 2nd FL Outside Boys Toilets, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-2-HAL-WC02 | Branch, 2nd FL Outside Boys Toilets, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-2-HAL-WC02 | Branch, 2nd FL Outside Boys Toilets, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-2-HAL-WC02 | Branch, 2nd FL Outside Boys Toilets, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-2-HAL-WC02 | Branch, 2nd FL Outside Boys Toilets, Fountain | Flush180 | 02-JUN-16 | 0.215 | ppb |
| 54722 | 54722-2-HAL-WC02 | Branch, 2nd FL Outside Boys Toilets, Fountain | Flush180 | 02-JUN-16 | 0.540 | ppb |
| 54722 | 54722-2-HAL-WC02 | Branch, 2nd FL Outside Boys Toilets, Fountain | Flush180 | 02-JUN-16 | 0.268 | ppb |
| 54722 | 54722-2-HAL-WC02 | Branch, 2nd FL Outside Boys Toilets, Fountain | Flush180 | 02-JUN-16 | 1.420 | ppb |
| 54722 | 54722-2-HAL-WC02 | Branch, 2nd FL Outside Boys Toilets, Fountain | Initial | 18-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-2-HAL-WC02 | Branch, 2nd FL Outside Boys Toilets, Fountain | Initial | 02-JUN-16 | 1.240 | ppb |
| 54722 | 54722-3-HAL-WC01 | Branch, 3rd FL Outside Boys Toilets, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-3-HAL-WC01 | Branch, 3rd FL Outside Boys Toilets, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-3-HAL-WC01 | Branch, 3rd FL Outside Boys Toilets, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-3-HAL-WC01 | Branch, 3rd FL Outside Boys Toilets, Fountain | Flush180 | 02-JUN-16 | 1.650 | ppb |
| 54722 | 54722-3-HAL-WC01 | Branch, 3rd FL Outside Boys Toilets, Fountain | Flush180 | 02-JUN-16 | 1.980 | ppb |
| 54722 | 54722-3-HAL-WC01 | Branch, 3rd FL Outside Boys Toilets, Fountain | Flush180 | 02-JUN-16 | 1.350 | ppb |
| 54722 | 54722-3-HAL-WC01 | Branch, 3rd FL Outside Boys Toilets, Fountain | Flush180 | 02-JUN-16 | 1.690 | ppb |
| 54722 | 54722-3-HAL-WC01 | Branch, 3rd FL Outside Boys Toilets, Fountain | Initial | 18-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-3-HAL-WC01 | Branch, 3rd FL Outside Boys Toilets, Fountain | Initial | 02-JUN-16 | 1.940 | ppb |



| Facility ID | Fixture Code | Fixture Location | Draw Type | Collected On | Result | UOM |
|-------------|--------------------|--|-----------|--------------|--------|------|
| 54722 | 54722-3-S-HAL-WC02 | Branch, 3rd FL Outside Girls Toilets, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-3-S-HAL-WC02 | Branch, 3rd FL Outside Girls Toilets, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-3-S-HAL-WC02 | Branch, 3rd FL Outside Girls Toilets, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-3-S-HAL-WC02 | Branch, 3rd FL Outside Girls Toilets, Fountain | Flush180 | 02-JUN-16 | 0.649 | ppb |
| 54722 | 54722-3-S-HAL-WC02 | Branch, 3rd FL Outside Girls Toilets, Fountain | Flush180 | 02-JUN-16 | 0.516 | ppb |
| 54722 | 54722-3-S-HAL-WC02 | Branch, 3rd FL Outside Girls Toilets, Fountain | Flush180 | 02-JUN-16 | 1.320 | ppb |
| 54722 | 54722-3-S-HAL-WC02 | Branch, 3rd FL Outside Girls Toilets, Fountain | Flush180 | 02-JUN-16 | 1.770 | ppb |
| 54722 | 54722-3-S-HAL-WC02 | Branch, 3rd FL Outside Girls Toilets, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-3-S-HAL-WC02 | Branch, 3rd FL Outside Girls Toilets, Fountain | Flush180 | 23-JUL-20 | 1.000 | ug/L |
| 54722 | 54722-3-S-HAL-WC02 | Branch, 3rd FL Outside Girls Toilets, Fountain | Initial | 18-MAY-23 | 1.440 | ug/L |
| 54722 | 54722-3-S-HAL-WC02 | Branch, 3rd FL Outside Girls Toilets, Fountain | Initial | 02-JUN-16 | 0.925 | ppb |
| 54722 | 54722-3-S-HAL-WC02 | Branch, 3rd FL Outside Girls Toilets, Fountain | Initial | 23-JUL-20 | 1.640 | ug/L |
| 54722 | 54722-1-E-HAL-WC01 | Branch- 1st FL Outside Boys Toilet, Fountain | Flush180 | 02-JUN-16 | 0.346 | ppb |
| 54722 | 54722-1-E-HAL-WC01 | Branch- 1st FL Outside Boys Toilet, Fountain | Flush180 | 02-JUN-16 | 0.319 | ppb |
| 54722 | 54722-1-E-HAL-WC01 | Branch- 1st FL Outside Boys Toilet, Fountain | Flush180 | 02-JUN-16 | 0.540 | ppb |
| 54722 | 54722-1-E-HAL-WC01 | Branch- 1st FL Outside Boys Toilet, Fountain | Flush180 | 02-JUN-16 | 0.294 | ppb |
| 54722 | 54722-1-E-HAL-WC01 | Branch- 1st FL Outside Boys Toilet, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-1-E-HAL-WC01 | Branch- 1st FL Outside Boys Toilet, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-1-E-HAL-WC01 | Branch- 1st FL Outside Boys Toilet, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-1-E-HAL-WC01 | Branch- 1st FL Outside Boys Toilet, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-1-E-HAL-WC01 | Branch- 1st FL Outside Boys Toilet, Fountain | Flush180 | 23-JUL-20 | 1.000 | ug/L |
| 54722 | 54722-1-E-HAL-WC01 | Branch- 1st FL Outside Boys Toilet, Fountain | Initial | 02-JUN-16 | 0.931 | ppb |
| 54722 | 54722-1-E-HAL-WC01 | Branch- 1st FL Outside Boys Toilet, Fountain | Initial | 18-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-1-E-HAL-WC01 | Branch- 1st FL Outside Boys Toilet, Fountain | Initial | 23-JUL-20 | 1.000 | ug/L |
| 54722 | 54722-1-HAL-WC04 | Branch- 1st FL Outside Girls Toilet, Fountain | Flush180 | 18-MAY-23 | 1.720 | ug/L |
| 54722 | 54722-1-HAL-WC04 | Branch- 1st FL Outside Girls Toilet, Fountain | Flush180 | 18-MAY-23 | 1.240 | ug/L |
| 54722 | 54722-1-HAL-WC04 | Branch- 1st FL Outside Girls Toilet, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-1-HAL-WC04 | Branch- 1st FL Outside Girls Toilet, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-1-HAL-WC04 | Branch- 1st FL Outside Girls Toilet, Fountain | Flush180 | 02-JUN-16 | 0.326 | ppb |
| 54722 | 54722-1-HAL-WC04 | Branch- 1st FL Outside Girls Toilet, Fountain | Flush180 | 02-JUN-16 | 0.263 | ppb |
| 54722 | 54722-1-HAL-WC04 | Branch- 1st FL Outside Girls Toilet, Fountain | Flush180 | 02-JUN-16 | 0.698 | ppb |
| 54722 | 54722-1-HAL-WC04 | Branch- 1st FL Outside Girls Toilet, Fountain | Flush180 | 02-JUN-16 | 1.710 | ppb |
| 54722 | 54722-1-HAL-WC04 | Branch- 1st FL Outside Girls Toilet, Fountain | Initial | 18-MAY-23 | 1.160 | ug/L |
| 54722 | 54722-1-HAL-WC04 | Branch- 1st FL Outside Girls Toilet, Fountain | Initial | 02-JUN-16 | 1.400 | ppb |
| 54722 | 54722-2-HAL-WC03 | Branch- 2nd FL Outside Girls Toilets, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-2-HAL-WC03 | Branch- 2nd FL Outside Girls Toilets, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-2-HAL-WC03 | Branch- 2nd FL Outside Girls Toilets, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |

| Facility ID | Fixture Code | Fixture Location | Draw Type | Collected On | Result | UOM |
|-------------|------------------|--|-----------|--------------|--------|------|
| 54722 | 54722-2-HAL-WC03 | Branch- 2nd FL Outside Girls Toilets, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-2-HAL-WC03 | Branch- 2nd FL Outside Girls Toilets, Fountain | Flush180 | 02-JUN-16 | 1.410 | ppb |
| 54722 | 54722-2-HAL-WC03 | Branch- 2nd FL Outside Girls Toilets, Fountain | Flush180 | 02-JUN-16 | 0.797 | ppb |
| 54722 | 54722-2-HAL-WC03 | Branch- 2nd FL Outside Girls Toilets, Fountain | Flush180 | 02-JUN-16 | 0.942 | ppb |
| 54722 | 54722-2-HAL-WC03 | Branch- 2nd FL Outside Girls Toilets, Fountain | Flush180 | 02-JUN-16 | 0.743 | ppb |
| 54722 | 54722-2-HAL-WC03 | Branch- 2nd FL Outside Girls Toilets, Fountain | Initial | 18-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-2-HAL-WC03 | Branch- 2nd FL Outside Girls Toilets, Fountain | Initial | 02-JUN-16 | 0.734 | ppb |
| 54722 | 54722-2-KIT-KS01 | Branch- Kitchen West Wall, Sink | Flush180 | 02-JUN-16 | 0.837 | ppb |
| 54722 | 54722-2-KIT-KS01 | Branch- Kitchen West Wall, Sink | Flush180 | 02-JUN-16 | 0.444 | ppb |
| 54722 | 54722-2-KIT-KS01 | Branch- Kitchen West Wall, Sink | Flush180 | 02-JUN-16 | 0.563 | ppb |
| 54722 | 54722-2-KIT-KS01 | Branch- Kitchen West Wall, Sink | Flush180 | 02-JUN-16 | 0.326 | ppb |
| 54722 | 54722-2-KIT-KS01 | Branch- Kitchen West Wall, Sink | Initial | 02-JUN-16 | 0.265 | ppb |
| 54722 | 54722-1-KIT-KS03 | Branch-Left spigot, basin sink in kitchen | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-1-KIT-KS03 | Branch-Left spigot, basin sink in kitchen | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-1-KIT-KS03 | Branch-Left spigot, basin sink in kitchen | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-1-KIT-KS03 | Branch-Left spigot, basin sink in kitchen | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-1-KIT-KS03 | Branch-Left spigot, basin sink in kitchen | Initial | 19-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-1-KIT-KS02 | Branch-Right spigot, basin sink in kitchen | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-1-KIT-KS02 | Branch-Right spigot, basin sink in kitchen | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-1-KIT-KS02 | Branch-Right spigot, basin sink in kitchen | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-1-KIT-KS02 | Branch-Right spigot, basin sink in kitchen | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-1-KIT-KS02 | Branch-Right spigot, basin sink in kitchen | Initial | 19-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-1-CAF-S01 | Branch-sink in cafeteria | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-1-CAF-S01 | Branch-sink in cafeteria | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-1-CAF-S01 | Branch-sink in cafeteria | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-1-CAF-S01 | Branch-sink in cafeteria | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-1-CAF-S01 | Branch-sink in cafeteria | Initial | 19-MAY-23 | 1.000 | ug/L |
| 54722 | 54722-1-KIT-KS01 | Branch-stand alone sink, kitchen | Flush180 | 20-JUN-23 | 1.000 | ug/L |
| 54722 | 54722-1-KIT-KS01 | Branch-stand alone sink, kitchen | Flush180 | 20-JUN-23 | 1.430 | ug/L |
| 54722 | 54722-1-KIT-KS01 | Branch-stand alone sink, kitchen | Flush180 | 20-JUN-23 | 1.140 | ug/L |
| 54722 | 54722-1-KIT-KS01 | Branch-stand alone sink, kitchen | Flush180 | 20-JUN-23 | 1.160 | ug/L |
| 54722 | 54722-1-KIT-KS01 | Branch-stand alone sink, kitchen | Flush180 | 19-MAY-23 | 12.100 | ug/L |
| 54722 | 54722-1-KIT-KS01 | Branch-stand alone sink, kitchen | Flush180 | 19-MAY-23 | 54.700 | ug/L |
| 54722 | 54722-1-KIT-KS01 | Branch-stand alone sink, kitchen | Flush180 | 19-MAY-23 | 19.400 | ug/L |
| 54722 | 54722-1-KIT-KS01 | Branch-stand alone sink, kitchen | Flush180 | 19-MAY-23 | 17.100 | ug/L |
| 54722 | 54722-1-KIT-KS01 | Branch-stand alone sink, kitchen | Initial | 20-JUN-23 | 1.000 | ug/L |
| 54722 | 54722-1-KIT-KS01 | Branch-stand alone sink, kitchen | Initial | 19-MAY-23 | 3.640 | ug/L |
| 58494 | 58494-1-HAL- | Corridor East End Left Fountain | Flush180 | 01-SEP-17 | 4.660 | ppb |



| Facility ID | Fixture Code | Fixture Location | Draw Type | Collected On | Result | UOM |
|-------------|-------------------|-----------------------------------|-----------|--------------|--------|------|
| | F19 | | | | | |
| 58494 | 58494-1-HAL-F19 | Corridor East End Left Fountain | Flush180 | 01-SEP-17 | 6.930 | ppb |
| 58494 | 58494-1-HAL-F19 | Corridor East End Left Fountain | Flush180 | 01-SEP-17 | 6.620 | ppb |
| 58494 | 58494-1-HAL-F19 | Corridor East End Left Fountain | Flush180 | 01-SEP-17 | 6.870 | ppb |
| 58494 | 58494-1-HAL-F19 | Corridor East End Left Fountain | Initial | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-HAL-F20 | Corridor East End Right Fountain | Flush180 | 01-SEP-17 | 7.300 | ppb |
| 58494 | 58494-1-HAL-F20 | Corridor East End Right Fountain | Flush180 | 01-SEP-17 | 7.790 | ppb |
| 58494 | 58494-1-HAL-F20 | Corridor East End Right Fountain | Flush180 | 01-SEP-17 | 7.830 | ppb |
| 58494 | 58494-1-HAL-F20 | Corridor East End Right Fountain | Flush180 | 01-SEP-17 | 6.950 | ppb |
| 58494 | 58494-1-HAL-F20 | Corridor East End Right Fountain | Initial | 01-SEP-17 | 4.580 | ppb |
| 58494 | 58494-1-S-HAL-F19 | Corridor East End, Left Fountain | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-S-HAL-F19 | Corridor East End, Left Fountain | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-S-HAL-F19 | Corridor East End, Left Fountain | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-S-HAL-F19 | Corridor East End, Left Fountain | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-S-HAL-F19 | Corridor East End, Left Fountain | Initial | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-S-HAL-F20 | Corridor East End, Right Fountain | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-S-HAL-F20 | Corridor East End, Right Fountain | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-S-HAL-F20 | Corridor East End, Right Fountain | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-S-HAL-F20 | Corridor East End, Right Fountain | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-S-HAL-F20 | Corridor East End, Right Fountain | Initial | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-S-HAL-F17 | Corridor West End Left Fountain | Flush180 | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-S-HAL-F17 | Corridor West End Left Fountain | Flush180 | 01-SEP-17 | 2.170 | ppb |
| 58494 | 58494-1-S-HAL-F17 | Corridor West End Left Fountain | Flush180 | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-S-HAL-F17 | Corridor West End Left Fountain | Flush180 | 01-SEP-17 | 2.220 | ppb |
| 58494 | 58494-1-S-HAL-F17 | Corridor West End Left Fountain | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-S-HAL-F17 | Corridor West End Left Fountain | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-S-HAL-F17 | Corridor West End Left Fountain | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-S-HAL-F17 | Corridor West End Left Fountain | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-S-HAL-F17 | Corridor West End Left Fountain | Flush180 | 23-JUL-20 | 1.000 | ug/L |
| 58494 | 58494-1-S-HAL-F17 | Corridor West End Left Fountain | Initial | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-S-HAL-F17 | Corridor West End Left Fountain | Initial | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-S-HAL-F17 | Corridor West End Left Fountain | Initial | 23-JUL-20 | 1.000 | ug/L |
| 58494 | 58494-1-S-HAL-F18 | Corridor West End, Right Fountain | Flush180 | 01-SEP-17 | 2.630 | ppb |
| 58494 | 58494-1-S-HAL-F18 | Corridor West End, Right Fountain | Flush180 | 01-SEP-17 | 2.210 | ppb |
| 58494 | 58494-1-S-HAL-F18 | Corridor West End, Right Fountain | Flush180 | 01-SEP-17 | 2.400 | ppb |
| 58494 | 58494-1-S-HAL-F18 | Corridor West End, Right Fountain | Flush180 | 01-SEP-17 | 2.600 | ppb |
| 58494 | 58494-1-S-HAL-F18 | Corridor West End, Right Fountain | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-S- | Corridor West End, Right Fountain | Flush180 | 19-MAY-23 | 1.000 | ug/L |

| Facility ID | Fixture Code | Fixture Location | Draw Type | Collected On | Result | UOM |
|-------------|-------------------|-----------------------------------|-----------|--------------|--------|------|
| | HAL-F18 | | | | | |
| 58494 | 58494-1-S-HAL-F18 | Corridor West End, Right Fountain | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-S-HAL-F18 | Corridor West End, Right Fountain | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-S-HAL-F18 | Corridor West End, Right Fountain | Flush180 | 23-JUL-20 | 1.000 | ug/L |
| 58494 | 58494-1-S-HAL-F18 | Corridor West End, Right Fountain | Initial | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-S-HAL-F18 | Corridor West End, Right Fountain | Initial | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-S-HAL-F18 | Corridor West End, Right Fountain | Initial | 23-JUL-20 | 1.000 | ug/L |
| 58494 | 58494-1-005-F01 | Room 005, Fountain | Flush180 | 01-SEP-17 | 2.390 | ppb |
| 58494 | 58494-1-005-F01 | Room 005, Fountain | Flush180 | 01-SEP-17 | 2.280 | ppb |
| 58494 | 58494-1-005-F01 | Room 005, Fountain | Flush180 | 01-SEP-17 | 2.100 | ppb |
| 58494 | 58494-1-005-F01 | Room 005, Fountain | Flush180 | 01-SEP-17 | 2.110 | ppb |
| 58494 | 58494-1-005-F01 | Room 005, Fountain | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-005-F01 | Room 005, Fountain | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-005-F01 | Room 005, Fountain | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-005-F01 | Room 005, Fountain | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-005-F01 | Room 005, Fountain | Initial | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-005-F01 | Room 005, Fountain | Initial | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-005-S02 | Room 005, Sink | Flush180 | 01-SEP-17 | 2.430 | ppb |
| 58494 | 58494-1-005-S02 | Room 005, Sink | Flush180 | 01-SEP-17 | 2.560 | ppb |
| 58494 | 58494-1-005-S02 | Room 005, Sink | Flush180 | 01-SEP-17 | 7.130 | ppb |
| 58494 | 58494-1-005-S02 | Room 005, Sink | Flush180 | 01-SEP-17 | 5.310 | ppb |
| 58494 | 58494-1-005-S02 | Room 005, Sink | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-005-S02 | Room 005, Sink | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-005-S02 | Room 005, Sink | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-005-S02 | Room 005, Sink | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-005-S02 | Room 005, Sink | Initial | 01-SEP-17 | 5.720 | ppb |
| 58494 | 58494-1-005-S02 | Room 005, Sink | Initial | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-006-F03 | Room 006, Fountain | Flush180 | 01-SEP-17 | 3.490 | ppb |
| 58494 | 58494-1-006-F03 | Room 006, Fountain | Flush180 | 01-SEP-17 | 4.380 | ppb |
| 58494 | 58494-1-006-F03 | Room 006, Fountain | Flush180 | 01-SEP-17 | 2.200 | ppb |
| 58494 | 58494-1-006-F03 | Room 006, Fountain | Flush180 | 01-SEP-17 | 3.310 | ppb |
| 58494 | 58494-1-006-F03 | Room 006, Fountain | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-006-F03 | Room 006, Fountain | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-006-F03 | Room 006, Fountain | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-006-F03 | Room 006, Fountain | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-006-F03 | Room 006, Fountain | Initial | 01-SEP-17 | 2.050 | ppb |
| 58494 | 58494-1-006-F03 | Room 006, Fountain | Initial | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-006-S04 | Room 006, Sink | Flush180 | 01-SEP-17 | 3.380 | ppb |



| Facility ID | Fixture Code | Fixture Location | Draw Type | Collected On | Result | UOM |
|-------------|-----------------|--------------------|-----------|--------------|--------|------|
| 58494 | 58494-1-006-S04 | Room 006, Sink | Flush180 | 01-SEP-17 | 2.880 | ppb |
| 58494 | 58494-1-006-S04 | Room 006, Sink | Flush180 | 01-SEP-17 | 3.570 | ppb |
| 58494 | 58494-1-006-S04 | Room 006, Sink | Flush180 | 01-SEP-17 | 3.770 | ppb |
| 58494 | 58494-1-006-S04 | Room 006, Sink | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-006-S04 | Room 006, Sink | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-006-S04 | Room 006, Sink | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-006-S04 | Room 006, Sink | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-006-S04 | Room 006, Sink | Initial | 01-SEP-17 | 3.570 | ppb |
| 58494 | 58494-1-006-S04 | Room 006, Sink | Initial | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-007-F05 | Room 007, Fountain | Flush180 | 01-SEP-17 | 2.370 | ppb |
| 58494 | 58494-1-007-F05 | Room 007, Fountain | Flush180 | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-007-F05 | Room 007, Fountain | Flush180 | 01-SEP-17 | 2.320 | ppb |
| 58494 | 58494-1-007-F05 | Room 007, Fountain | Flush180 | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-007-F05 | Room 007, Fountain | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-007-F05 | Room 007, Fountain | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-007-F05 | Room 007, Fountain | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-007-F05 | Room 007, Fountain | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-007-F05 | Room 007, Fountain | Initial | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-007-F05 | Room 007, Fountain | Initial | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-007-S06 | Room 007, Sink | Flush180 | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-007-S06 | Room 007, Sink | Flush180 | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-007-S06 | Room 007, Sink | Flush180 | 01-SEP-17 | 2.630 | ppb |
| 58494 | 58494-1-007-S06 | Room 007, Sink | Flush180 | 01-SEP-17 | 2.470 | ppb |
| 58494 | 58494-1-007-S06 | Room 007, Sink | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-007-S06 | Room 007, Sink | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-007-S06 | Room 007, Sink | Flush180 | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-007-S06 | Room 007, Sink | Initial | 01-SEP-17 | 3.560 | ppb |
| 58494 | 58494-1-007-S06 | Room 007, Sink | Initial | 19-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-008-F07 | Room 008, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-008-F07 | Room 008, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-008-F07 | Room 008, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-008-F07 | Room 008, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-008-F07 | Room 008, Fountain | Flush180 | 01-SEP-17 | 3.640 | ppb |
| 58494 | 58494-1-008-F07 | Room 008, Fountain | Flush180 | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-008-F07 | Room 008, Fountain | Flush180 | 01-SEP-17 | 2.310 | ppb |
| 58494 | 58494-1-008-F07 | Room 008, Fountain | Flush180 | 01-SEP-17 | 1.000 | ppb |

| Facility ID | Fixture Code | Fixture Location | Draw Type | Collected On | Result | UOM |
|-------------|-----------------|--------------------|-----------|--------------|--------|------|
| 58494 | 58494-1-008-F07 | Room 008, Fountain | Initial | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-008-F07 | Room 008, Fountain | Initial | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-008-S08 | Room 008, Sink | Flush180 | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-008-S08 | Room 008, Sink | Flush180 | 01-SEP-17 | 2.850 | ppb |
| 58494 | 58494-1-008-S08 | Room 008, Sink | Flush180 | 01-SEP-17 | 2.190 | ppb |
| 58494 | 58494-1-008-S08 | Room 008, Sink | Flush180 | 01-SEP-17 | 2.220 | ppb |
| 58494 | 58494-1-008-S08 | Room 008, Sink | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-008-S08 | Room 008, Sink | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-008-S08 | Room 008, Sink | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-008-S08 | Room 008, Sink | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-008-S08 | Room 008, Sink | Initial | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-008-S08 | Room 008, Sink | Initial | 01-SEP-17 | 3.410 | ppb |
| 58494 | 58494-1-009-F09 | Room 009, Fountain | Flush180 | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-009-F09 | Room 009, Fountain | Flush180 | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-009-F09 | Room 009, Fountain | Flush180 | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-009-F09 | Room 009, Fountain | Flush180 | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-009-F09 | Room 009, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-009-F09 | Room 009, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-009-F09 | Room 009, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-009-F09 | Room 009, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-009-F09 | Room 009, Fountain | Initial | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-009-F09 | Room 009, Fountain | Initial | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-009-S10 | Room 009, Sink | Flush180 | 01-SEP-17 | 2.190 | ppb |
| 58494 | 58494-1-009-S10 | Room 009, Sink | Flush180 | 01-SEP-17 | 2.040 | ppb |
| 58494 | 58494-1-009-S10 | Room 009, Sink | Flush180 | 01-SEP-17 | 3.460 | ppb |
| 58494 | 58494-1-009-S10 | Room 009, Sink | Flush180 | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-009-S10 | Room 009, Sink | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-009-S10 | Room 009, Sink | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-009-S10 | Room 009, Sink | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-009-S10 | Room 009, Sink | Initial | 01-SEP-17 | 5.520 | ppb |
| 58494 | 58494-1-009-S10 | Room 009, Sink | Initial | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-010-F11 | Room 010, Fountain | Flush180 | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-010-F11 | Room 010, Fountain | Flush180 | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-010-F11 | Room 010, Fountain | Flush180 | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-010-F11 | Room 010, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-010-F11 | Room 010, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |



| Facility ID | Fixture Code | Fixture Location | Draw Type | Collected On | Result | UOM |
|-------------|-----------------|--------------------|-----------|--------------|--------|------|
| | F11 | | | | | |
| 58494 | 58494-1-010-F11 | Room 010, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-010-F11 | Room 010, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-010-F11 | Room 010, Fountain | Initial | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-010-F11 | Room 010, Fountain | Initial | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-010-S12 | Room 010, Sink | Flush180 | 01-SEP-17 | 6.240 | ppb |
| 58494 | 58494-1-010-S12 | Room 010, Sink | Flush180 | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-010-S12 | Room 010, Sink | Flush180 | 01-SEP-17 | 3.760 | ppb |
| 58494 | 58494-1-010-S12 | Room 010, Sink | Flush180 | 01-SEP-17 | 6.140 | ppb |
| 58494 | 58494-1-010-S12 | Room 010, Sink | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-010-S12 | Room 010, Sink | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-010-S12 | Room 010, Sink | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-010-S12 | Room 010, Sink | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-010-S12 | Room 010, Sink | Initial | 01-SEP-17 | 5.560 | ppb |
| 58494 | 58494-1-010-S12 | Room 010, Sink | Initial | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-011-F13 | Room 011, Fountain | Flush180 | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-011-F13 | Room 011, Fountain | Flush180 | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-011-F13 | Room 011, Fountain | Flush180 | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-011-F13 | Room 011, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-011-F13 | Room 011, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-011-F13 | Room 011, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-011-F13 | Room 011, Fountain | Initial | 01-SEP-17 | 2.360 | ppb |
| 58494 | 58494-1-011-F13 | Room 011, Fountain | Initial | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-011-S14 | Room 011, Sink | Flush180 | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-011-S14 | Room 011, Sink | Flush180 | 01-SEP-17 | 6.720 | ppb |
| 58494 | 58494-1-011-S14 | Room 011, Sink | Flush180 | 01-SEP-17 | 4.330 | ppb |
| 58494 | 58494-1-011-S14 | Room 011, Sink | Flush180 | 01-SEP-17 | 2.450 | ppb |
| 58494 | 58494-1-011-S14 | Room 011, Sink | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-011-S14 | Room 011, Sink | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-011-S14 | Room 011, Sink | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-011-S14 | Room 011, Sink | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-011-S14 | Room 011, Sink | Initial | 01-SEP-17 | 3.250 | ppb |
| 58494 | 58494-1-011-S14 | Room 011, Sink | Initial | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-012-F15 | Room 012, Fountain | Flush180 | 01-SEP-17 | 2.020 | ppb |
| 58494 | 58494-1-012-F15 | Room 012, Fountain | Flush180 | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-012-F15 | Room 012, Fountain | Flush180 | 01-SEP-17 | 2.800 | ppb |

**Water Quality Assessment
Norman A Bridge Elementary School**

| Facility ID | Fixture Code | Fixture Location | Draw Type | Collected On | Result | UOM |
|-------------|-----------------|--------------------|-----------|--------------|--------|------|
| | F15 | | | | | |
| 58494 | 58494-1-012-F15 | Room 012, Fountain | Flush180 | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-012-F15 | Room 012, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-012-F15 | Room 012, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-012-F15 | Room 012, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-012-F15 | Room 012, Fountain | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-012-F15 | Room 012, Fountain | Initial | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-012-F15 | Room 012, Fountain | Initial | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-012-S16 | Room 012, Sink | Flush180 | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-012-S16 | Room 012, Sink | Flush180 | 01-SEP-17 | 2.050 | ppb |
| 58494 | 58494-1-012-S16 | Room 012, Sink | Flush180 | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-012-S16 | Room 012, Sink | Flush180 | 01-SEP-17 | 1.000 | ppb |
| 58494 | 58494-1-012-S16 | Room 012, Sink | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-012-S16 | Room 012, Sink | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-012-S16 | Room 012, Sink | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-012-S16 | Room 012, Sink | Flush180 | 18-MAY-23 | 1.000 | ug/L |
| 58494 | 58494-1-012-S16 | Room 012, Sink | Initial | 01-SEP-17 | 3.110 | ppb |
| 58494 | 58494-1-012-S16 | Room 012, Sink | Initial | 18-MAY-23 | 1.000 | ug/L |