



Sep 10, 2024

BRIGHTON PARK

3825 S WASHTENAW AVE, Chicago IL 60632.

Dear **BRIGHTON PARK** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

BRIGHTON PARK

3825 S WASHTENAW AVE, Chicago IL 60632.

Estimadas familias de **BRIGHTON PARK**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51285	51285-ADD-1-KIT-KS04	Addition- Kitchen Near Dishwasher, Sink 4	Flush180	15-JUN-16	0.638	ppb
51285	51285-ADD-1-KIT-KS04	Addition- Kitchen Near Dishwasher, Sink 4	Flush180	15-JUN-16	0.638	ppb
51285	51285-ADD-1-KIT-KS04	Addition- Kitchen Near Dishwasher, Sink 4	Flush180	15-JUN-16	0.518	ppb
51285	51285-ADD-1-KIT-KS04	Addition- Kitchen Near Dishwasher, Sink 4	Flush180	15-JUN-16	0.518	ppb
51285	51285-ADD-1-KIT-KS04	Addition- Kitchen Near Dishwasher, Sink 4	Flush180	15-JUN-16	0.388	ppb
51285	51285-ADD-1-KIT-KS04	Addition- Kitchen Near Dishwasher, Sink 4	Flush180	15-JUN-16	0.312	ppb
51285	51285-ADD-1-KIT-KS04	Addition- Kitchen Near Dishwasher, Sink 4	Flush180	15-JUN-16	0.388	ppb
51285	51285-ADD-1-KIT-KS04	Addition- Kitchen Near Dishwasher, Sink 4	Flush180	15-JUN-16	0.312	ppb
51285	51285-ADD-1-KIT-KS04	Addition- Kitchen Near Dishwasher, Sink 4	Initial	15-JUN-16	0.405	ppb
51285	51285-ADD-1-KIT-KS04	Addition- Kitchen Near Dishwasher, Sink 4	Initial	15-JUN-16	0.405	ppb
51285	51285-ADD-1-KIT-KS02	Addition- Kitchen, Island Sink 3	Flush180	15-JUN-16	0.327	ppb
51285	51285-ADD-1-KIT-KS02	Addition- Kitchen, Island Sink 3	Flush180	15-JUN-16	0.329	ppb
51285	51285-ADD-1-KIT-KS02	Addition- Kitchen, Island Sink 3	Flush180	15-JUN-16	0.484	ppb
51285	51285-ADD-1-KIT-KS02	Addition- Kitchen, Island Sink 3	Flush180	15-JUN-16	0.327	ppb
51285	51285-ADD-1-KIT-KS02	Addition- Kitchen, Island Sink 3	Flush180	15-JUN-16	0.312	ppb
51285	51285-ADD-1-KIT-KS02	Addition- Kitchen, Island Sink 3	Flush180	15-JUN-16	0.312	ppb
51285	51285-ADD-1-KIT-KS02	Addition- Kitchen, Island Sink 3	Flush180	15-JUN-16	0.329	ppb
51285	51285-ADD-1-KIT-KS02	Addition- Kitchen, Island Sink 3	Flush180	15-JUN-16	0.484	ppb
51285	51285-ADD-1-KIT-KS02	Addition- Kitchen, Island Sink 3	Initial	15-JUN-16	0.838	ppb
51285	51285-ADD-1-KIT-KS02	Addition- Kitchen, Island Sink 3	Initial	15-JUN-16	0.838	ppb
51285	51285-ADD-1-KIT-KS01	Addition- Kitchen, Sink 1	Flush180	15-JUN-16	0.655	ppb
51285	51285-ADD-1-KIT-KS01	Addition- Kitchen, Sink 1	Flush180	15-JUN-16	1.830	ppb
51285	51285-ADD-1-KIT-KS01	Addition- Kitchen, Sink 1	Flush180	15-JUN-16	1.830	ppb
51285	51285-ADD-1-KIT-KS01	Addition- Kitchen, Sink 1	Flush180	15-JUN-16	0.720	ppb
51285	51285-ADD-1-KIT-KS01	Addition- Kitchen, Sink 1	Flush180	15-JUN-16	0.585	ppb
51285	51285-ADD-1-KIT-KS01	Addition- Kitchen, Sink 1	Flush180	15-JUN-16	0.720	ppb
51285	51285-ADD-1-KIT-KS01	Addition- Kitchen, Sink 1	Flush180	15-JUN-16	0.585	ppb
51285	51285-ADD-1-KIT-KS01	Addition- Kitchen, Sink 1	Flush180	15-JUN-16	0.655	ppb
51285	51285-ADD-1-KIT-KS01	Addition- Kitchen, Sink 1	Initial	15-JUN-16	1.170	ppb
51285	51285-ADD-1-KIT-KS01	Addition- Kitchen, Sink 1	Initial	15-JUN-16	1.170	ppb
51285	51285-ADD-1-KIT-KS03	Addition- Kitchen, Sink 2	Flush180	15-JUN-16	0.189	ppb
51285	51285-ADD-1-KIT-KS03	Addition- Kitchen, Sink 2	Flush180	15-JUN-16	0.141	ppb
51285	51285-ADD-1-KIT-KS03	Addition- Kitchen, Sink 2	Flush180	15-JUN-16	0.141	ppb
51285	51285-ADD-1-KIT-KS03	Addition- Kitchen, Sink 2	Flush180	15-JUN-16	0.168	ppb
51285	51285-ADD-1-KIT-KS03	Addition- Kitchen, Sink 2	Flush180	15-JUN-16	0.136	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51285	51285-ADD-1-KIT-KS03	Addition- Kitchen, Sink 2	Flush180	15-JUN-16	0.189	ppb
51285	51285-ADD-1-KIT-KS03	Addition- Kitchen, Sink 2	Flush180	15-JUN-16	0.136	ppb
51285	51285-ADD-1-KIT-KS03	Addition- Kitchen, Sink 2	Flush180	15-JUN-16	0.168	ppb
51285	51285-ADD-1-KIT-KS03	Addition- Kitchen, Sink 2	Initial	15-JUN-16	0.237	ppb
51285	51285-ADD-1-KIT-KS03	Addition- Kitchen, Sink 2	Initial	15-JUN-16	0.237	ppb
51285	51285-ADD-2-HAL-F01	Addition- Outside Gym, North Fountain 1	Flush180	15-JUN-16	0.526	ppb
51285	51285-ADD-2-HAL-F01	Addition- Outside Gym, North Fountain 1	Flush180	15-JUN-16	0.528	ppb
51285	51285-ADD-2-HAL-F01	Addition- Outside Gym, North Fountain 1	Flush180	15-JUN-16	0.562	ppb
51285	51285-ADD-2-HAL-F01	Addition- Outside Gym, North Fountain 1	Flush180	15-JUN-16	0.501	ppb
51285	51285-ADD-2-HAL-F01	Addition- Outside Gym, North Fountain 1	Flush180	15-JUN-16	0.528	ppb
51285	51285-ADD-2-HAL-F01	Addition- Outside Gym, North Fountain 1	Flush180	15-JUN-16	0.501	ppb
51285	51285-ADD-2-HAL-F01	Addition- Outside Gym, North Fountain 1	Flush180	15-JUN-16	0.526	ppb
51285	51285-ADD-2-HAL-F01	Addition- Outside Gym, North Fountain 1	Flush180	15-JUN-16	0.562	ppb
51285	51285-ADD-2-HAL-F01	Addition- Outside Gym, North Fountain 1	Initial	15-JUN-16	0.161	ppb
51285	51285-ADD-2-HAL-F01	Addition- Outside Gym, North Fountain 1	Initial	15-JUN-16	0.161	ppb
51285	51285-ADD-2-HAL-F02	Addition- Outside Gym, South Fountain 2	Flush180	15-JUN-16	0.554	ppb
51285	51285-ADD-2-HAL-F02	Addition- Outside Gym, South Fountain 2	Flush180	15-JUN-16	0.548	ppb
51285	51285-ADD-2-HAL-F02	Addition- Outside Gym, South Fountain 2	Flush180	15-JUN-16	0.554	ppb
51285	51285-ADD-2-HAL-F02	Addition- Outside Gym, South Fountain 2	Flush180	15-JUN-16	0.548	ppb
51285	51285-ADD-2-HAL-F02	Addition- Outside Gym, South Fountain 2	Flush180	15-JUN-16	0.541	ppb
51285	51285-ADD-2-HAL-F02	Addition- Outside Gym, South Fountain 2	Flush180	15-JUN-16	0.556	ppb
51285	51285-ADD-2-HAL-F02	Addition- Outside Gym, South Fountain 2	Flush180	15-JUN-16	0.556	ppb
51285	51285-ADD-2-HAL-F02	Addition- Outside Gym, South Fountain 2	Flush180	15-JUN-16	0.541	ppb
51285	51285-ADD-2-HAL-F02	Addition- Outside Gym, South Fountain 2	Initial	15-JUN-16	0.213	ppb
51285	51285-ADD-2-HAL-F02	Addition- Outside Gym, South Fountain 2	Initial	15-JUN-16	0.213	ppb
51285	51285-ADD-3-HAL-F01	Addition- Outside Restroom, North Fountain 1	Flush180	15-JUN-16	1.000	ppb
51285	51285-ADD-3-HAL-F01	Addition- Outside Restroom, North Fountain 1	Flush180	15-JUN-16	1.000	ppb
51285	51285-ADD-3-HAL-F01	Addition- Outside Restroom, North Fountain 1	Flush180	15-JUN-16	1.000	ppb
51285	51285-ADD-3-HAL-F01	Addition- Outside Restroom, North Fountain 1	Flush180	15-JUN-16	0.137	ppb
51285	51285-ADD-3-HAL-F01	Addition- Outside Restroom, North Fountain 1	Flush180	15-JUN-16	1.000	ppb
51285	51285-ADD-3-HAL-F01	Addition- Outside Restroom, North Fountain 1	Flush180	15-JUN-16	1.000	ppb
51285	51285-ADD-3-HAL-F01	Addition- Outside Restroom, North Fountain 1	Flush180	15-JUN-16	1.000	ppb
51285	51285-ADD-3-HAL-F01	Addition- Outside Restroom, North Fountain 1	Flush180	15-JUN-16	0.137	ppb
51285	51285-ADD-3-HAL-F01	Addition- Outside Restroom, North Fountain 1	Flush180	20-AUG-20	1.000	ug/L
51285	51285-ADD-3-HAL-F01	Addition- Outside Restroom, North Fountain 1	Initial	15-JUN-16	1.000	ppb
51285	51285-ADD-3-HAL-F01	Addition- Outside Restroom, North Fountain 1	Initial	15-JUN-16	1.000	ppb
51285	51285-ADD-3-HAL-F01	Addition- Outside Restroom, North Fountain 1	Initial	20-AUG-20	1.710	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51285	51285-ADD-3-HAL-F02	Addition- Outside Restroom, South Fountain 2	Flush180	15-JUN-16	0.234	ppb
51285	51285-ADD-3-HAL-F02	Addition- Outside Restroom, South Fountain 2	Flush180	15-JUN-16	0.391	ppb
51285	51285-ADD-3-HAL-F02	Addition- Outside Restroom, South Fountain 2	Flush180	15-JUN-16	0.301	ppb
51285	51285-ADD-3-HAL-F02	Addition- Outside Restroom, South Fountain 2	Flush180	15-JUN-16	0.448	ppb
51285	51285-ADD-3-HAL-F02	Addition- Outside Restroom, South Fountain 2	Flush180	15-JUN-16	0.448	ppb
51285	51285-ADD-3-HAL-F02	Addition- Outside Restroom, South Fountain 2	Flush180	15-JUN-16	0.391	ppb
51285	51285-ADD-3-HAL-F02	Addition- Outside Restroom, South Fountain 2	Flush180	15-JUN-16	0.301	ppb
51285	51285-ADD-3-HAL-F02	Addition- Outside Restroom, South Fountain 2	Flush180	15-JUN-16	0.234	ppb
51285	51285-ADD-3-HAL-F02	Addition- Outside Restroom, South Fountain 2	Initial	15-JUN-16	0.154	ppb
51285	51285-ADD-3-HAL-F02	Addition- Outside Restroom, South Fountain 2	Initial	15-JUN-16	0.154	ppb
51285	51285-ADD-1-HAL-F05	Addition- Outside Room 114, North Fountain 1	Flush180	15-JUN-16	0.315	ppb
51285	51285-ADD-1-HAL-F05	Addition- Outside Room 114, North Fountain 1	Flush180	15-JUN-16	0.315	ppb
51285	51285-ADD-1-HAL-F05	Addition- Outside Room 114, North Fountain 1	Flush180	15-JUN-16	0.127	ppb
51285	51285-ADD-1-HAL-F05	Addition- Outside Room 114, North Fountain 1	Flush180	15-JUN-16	0.319	ppb
51285	51285-ADD-1-HAL-F05	Addition- Outside Room 114, North Fountain 1	Flush180	15-JUN-16	0.277	ppb
51285	51285-ADD-1-HAL-F05	Addition- Outside Room 114, North Fountain 1	Flush180	15-JUN-16	0.127	ppb
51285	51285-ADD-1-HAL-F05	Addition- Outside Room 114, North Fountain 1	Flush180	15-JUN-16	0.319	ppb
51285	51285-ADD-1-HAL-F05	Addition- Outside Room 114, North Fountain 1	Flush180	15-JUN-16	0.277	ppb
51285	51285-ADD-1-HAL-F05	Addition- Outside Room 114, North Fountain 1	Flush180	20-AUG-20	1.000	ug/L
51285	51285-ADD-1-HAL-F05	Addition- Outside Room 114, North Fountain 1	Initial	15-JUN-16	0.175	ppb
51285	51285-ADD-1-HAL-F05	Addition- Outside Room 114, North Fountain 1	Initial	15-JUN-16	0.175	ppb
51285	51285-ADD-1-HAL-F05	Addition- Outside Room 114, North Fountain 1	Initial	20-AUG-20	1.370	ug/L
51285	51285-ADD-1-HAL-F06	Addition- Outside Room 114, South Fountain 2	Flush180	15-JUN-16	0.308	ppb
51285	51285-ADD-1-HAL-F06	Addition- Outside Room 114, South Fountain 2	Flush180	15-JUN-16	0.292	ppb
51285	51285-ADD-1-HAL-F06	Addition- Outside Room 114, South Fountain 2	Flush180	15-JUN-16	0.295	ppb
51285	51285-ADD-1-HAL-F06	Addition- Outside Room 114, South Fountain 2	Flush180	15-JUN-16	0.304	ppb
51285	51285-ADD-1-HAL-F06	Addition- Outside Room 114, South Fountain 2	Flush180	15-JUN-16	0.292	ppb
51285	51285-ADD-1-HAL-F06	Addition- Outside Room 114, South Fountain 2	Flush180	15-JUN-16	0.295	ppb
51285	51285-ADD-1-HAL-F06	Addition- Outside Room 114, South Fountain 2	Flush180	15-JUN-16	0.304	ppb
51285	51285-ADD-1-HAL-F06	Addition- Outside Room 114, South Fountain 2	Flush180	15-JUN-16	0.308	ppb
51285	51285-ADD-1-HAL-F06	Addition- Outside Room 114, South Fountain 2	Initial	15-JUN-16	0.234	ppb
51285	51285-ADD-1-HAL-F06	Addition- Outside Room 114, South Fountain 2	Initial	15-JUN-16	0.234	ppb
51285	51285-1-BAT-S01	Bathroom in Pre-K Addition	Flush180	20-AUG-20	1.000	ug/L
51285	51285-1-BAT-S01	Bathroom in Pre-K Addition	Initial	20-AUG-20	1.490	ug/L
51285	51285-1-CAF-F03	Main- Additional Lunchroom, Fountain	Flush180	15-JUN-16	1.000	ppb
51285	51285-1-CAF-F03	Main- Additional Lunchroom, Fountain	Flush180	15-JUN-16	1.000	ppb
51285	51285-1-CAF-F03	Main- Additional Lunchroom, Fountain	Flush180	15-JUN-16	1.000	ppb
51285	51285-1-CAF-F03	Main- Additional Lunchroom, Fountain	Flush180	15-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F03	Fountain				
51285	51285-1-CAF-F03	Main- Additional Lunchroom, Fountain	Flush180	15-JUN-16	1.000	ppb
51285	51285-1-CAF-F03	Main- Additional Lunchroom, Fountain	Flush180	15-JUN-16	1.000	ppb
51285	51285-1-CAF-F03	Main- Additional Lunchroom, Fountain	Flush180	15-JUN-16	1.000	ppb
51285	51285-1-CAF-F03	Main- Additional Lunchroom, Fountain	Flush180	15-JUN-16	1.000	ppb
51285	51285-1-CAF-F03	Main- Additional Lunchroom, Fountain	Flush180	20-AUG-20	1.000	ug/L
51285	51285-1-CAF-F03	Main- Additional Lunchroom, Fountain	Initial	15-JUN-16	1.000	ppb
51285	51285-1-CAF-F03	Main- Additional Lunchroom, Fountain	Initial	15-JUN-16	1.000	ppb
51285	51285-1-CAF-F03	Main- Additional Lunchroom, Fountain	Initial	20-AUG-20	1.000	ug/L
51285	51285-1-HAL-F02	Main- Outside Room 101, Fountain	Flush180	15-JUN-16	0.552	ppb
51285	51285-1-HAL-F02	Main- Outside Room 101, Fountain	Flush180	15-JUN-16	0.552	ppb
51285	51285-1-HAL-F02	Main- Outside Room 101, Fountain	Flush180	15-JUN-16	0.669	ppb
51285	51285-1-HAL-F02	Main- Outside Room 101, Fountain	Flush180	15-JUN-16	0.748	ppb
51285	51285-1-HAL-F02	Main- Outside Room 101, Fountain	Flush180	15-JUN-16	0.748	ppb
51285	51285-1-HAL-F02	Main- Outside Room 101, Fountain	Flush180	15-JUN-16	0.881	ppb
51285	51285-1-HAL-F02	Main- Outside Room 101, Fountain	Flush180	15-JUN-16	0.669	ppb
51285	51285-1-HAL-F02	Main- Outside Room 101, Fountain	Flush180	15-JUN-16	0.881	ppb
51285	51285-1-HAL-F02	Main- Outside Room 101, Fountain	Initial	15-JUN-16	1.080	ppb
51285	51285-1-HAL-F02	Main- Outside Room 101, Fountain	Initial	15-JUN-16	1.080	ppb
51285	51285-1-HAL-F01	Main- Outside Room 130, Fountain	Flush180	15-JUN-16	2.210	ppb
51285	51285-1-HAL-F01	Main- Outside Room 130, Fountain	Flush180	15-JUN-16	3.010	ppb
51285	51285-1-HAL-F01	Main- Outside Room 130, Fountain	Flush180	15-JUN-16	2.640	ppb
51285	51285-1-HAL-F01	Main- Outside Room 130, Fountain	Flush180	15-JUN-16	2.210	ppb
51285	51285-1-HAL-F01	Main- Outside Room 130, Fountain	Flush180	15-JUN-16	3.000	ppb
51285	51285-1-HAL-F01	Main- Outside Room 130, Fountain	Flush180	15-JUN-16	3.000	ppb
51285	51285-1-HAL-F01	Main- Outside Room 130, Fountain	Flush180	15-JUN-16	3.010	ppb
51285	51285-1-HAL-F01	Main- Outside Room 130, Fountain	Flush180	15-JUN-16	2.640	ppb
51285	51285-1-HAL-F01	Main- Outside Room 130, Fountain	Initial	15-JUN-16	0.347	ppb
51285	51285-1-HAL-F01	Main- Outside Room 130, Fountain	Initial	15-JUN-16	0.347	ppb
51285	51285-2-HAL-F01	Main- Outside Room 225 Fountain	Flush180	15-JUN-16	8.020	ppb
51285	51285-2-HAL-F01	Main- Outside Room 225 Fountain	Flush180	15-JUN-16	8.020	ppb
51285	51285-2-HAL-F01	Main- Outside Room 225 Fountain	Flush180	15-JUN-16	7.250	ppb
51285	51285-2-HAL-F01	Main- Outside Room 225 Fountain	Flush180	15-JUN-16	6.010	ppb
51285	51285-2-HAL-F01	Main- Outside Room 225 Fountain	Flush180	15-JUN-16	7.250	ppb
51285	51285-2-HAL-F01	Main- Outside Room 225 Fountain	Flush180	15-JUN-16	6.970	ppb
51285	51285-2-HAL-F01	Main- Outside Room 225 Fountain	Flush180	15-JUN-16	6.970	ppb
51285	51285-2-HAL-F01	Main- Outside Room 225 Fountain	Flush180	15-JUN-16	6.010	ppb
51285	51285-2-HAL-F01	Main- Outside Room 225 Fountain	Flush180	29-DEC-20	2.280	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01					
51285	51285-2-HAL-F01	Main- Outside Room 225 Fountain	Flush180	29-DEC-20	1.560	ug/L
51285	51285-2-HAL-F01	Main- Outside Room 225 Fountain	Flush180	29-DEC-20	1.550	ug/L
51285	51285-2-HAL-F01	Main- Outside Room 225 Fountain	Flush180	29-DEC-20	1.660	ug/L
51285	51285-2-HAL-F01	Main- Outside Room 225 Fountain	Flush180	04-DEC-20	6.610	ug/L
51285	51285-2-HAL-F01	Main- Outside Room 225 Fountain	Flush180	04-DEC-20	3.740	ug/L
51285	51285-2-HAL-F01	Main- Outside Room 225 Fountain	Flush180	04-DEC-20	5.300	ug/L
51285	51285-2-HAL-F01	Main- Outside Room 225 Fountain	Flush180	04-DEC-20	6.090	ug/L
51285	51285-2-HAL-F01	Main- Outside Room 225 Fountain	Flush180	20-AUG-20	5.910	ug/L
51285	51285-2-HAL-F01	Main- Outside Room 225 Fountain	Flush180	02-OCT-20	22.100	ug/L
51285	51285-2-HAL-F01	Main- Outside Room 225 Fountain	Flush180	02-OCT-20	23.200	ug/L
51285	51285-2-HAL-F01	Main- Outside Room 225 Fountain	Flush180	02-OCT-20	23.600	ug/L
51285	51285-2-HAL-F01	Main- Outside Room 225 Fountain	Flush180	02-OCT-20	23.400	ug/L
51285	51285-2-HAL-F01	Main- Outside Room 225 Fountain	Initial	15-JUN-16	7.800	ppb
51285	51285-2-HAL-F01	Main- Outside Room 225 Fountain	Initial	15-JUN-16	7.800	ppb
51285	51285-2-HAL-F01	Main- Outside Room 225 Fountain	Initial	29-DEC-20	3.000	ug/L
51285	51285-2-HAL-F01	Main- Outside Room 225 Fountain	Initial	04-DEC-20	6.200	ug/L
51285	51285-2-HAL-F01	Main- Outside Room 225 Fountain	Initial	20-AUG-20	5.620	ug/L
51285	51285-2-HAL-F01	Main- Outside Room 225 Fountain	Initial	02-OCT-20	21.800	ug/L
51285	51285-2-HAL-F02	Main- Outside Room 235, Fountain	Flush180	15-JUN-16	2.700	ppb
51285	51285-2-HAL-F02	Main- Outside Room 235, Fountain	Flush180	15-JUN-16	2.330	ppb
51285	51285-2-HAL-F02	Main- Outside Room 235, Fountain	Flush180	15-JUN-16	1.380	ppb
51285	51285-2-HAL-F02	Main- Outside Room 235, Fountain	Flush180	15-JUN-16	1.630	ppb
51285	51285-2-HAL-F02	Main- Outside Room 235, Fountain	Flush180	15-JUN-16	2.330	ppb
51285	51285-2-HAL-F02	Main- Outside Room 235, Fountain	Flush180	15-JUN-16	1.630	ppb
51285	51285-2-HAL-F02	Main- Outside Room 235, Fountain	Flush180	15-JUN-16	2.700	ppb
51285	51285-2-HAL-F02	Main- Outside Room 235, Fountain	Flush180	15-JUN-16	1.380	ppb
51285	51285-2-HAL-F02	Main- Outside Room 235, Fountain	Initial	15-JUN-16	2.940	ppb
51285	51285-2-HAL-F02	Main- Outside Room 235, Fountain	Initial	15-JUN-16	2.940	ppb
51285	51285-1-E-148-F01	Room 148	Flush180	04-SEP-19	1.120	ug/L
51285	51285-1-E-148-F01	Room 148	Flush180	04-SEP-19	1.000	ug/L
51285	51285-1-E-148-F01	Room 148	Flush180	04-SEP-19	1.000	ug/L
51285	51285-1-E-148-F01	Room 148	Flush180	04-SEP-19	1.000	ug/L
51285	51285-1-E-148-S01	Room 148	Flush180	04-SEP-19	1.000	ug/L
51285	51285-1-E-148-S01	Room 148	Flush180	04-SEP-19	1.290	ug/L
51285	51285-1-E-148-S01	Room 148	Flush180	04-SEP-19	1.000	ug/L
51285	51285-1-E-148-S01	Room 148	Flush180	04-SEP-19	1.000	ug/L
51285	51285-1-E-148-S01	Room 148	Flush180	04-SEP-19	1.000	ug/L
51285	51285-1-E-148-F01	Room 148	Flush180	20-AUG-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51285	51285-1-E-148-F01	Room 148	Initial	04-SEP-19	1.130	ug/L
51285	51285-1-E-148-S01	Room 148	Initial	04-SEP-19	1.250	ug/L
51285	51285-1-E-148-F01	Room 148	Initial	20-AUG-20	1.000	ug/L