



**Sep 10, 2024**

**BROWNELL**

**6741 S MICHIGAN AVE, Chicago IL 60637.**

Dear **BROWNELL** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**BROWNELL**

**6741 S MICHIGAN AVE, Chicago IL 60637.**

Estimadas familias de **BROWNELL**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51376	51376-2-HAL-F02	Across From Room 210, Fountain	Flush180	15-JUN-16	1.230	ppb
51376	51376-2-HAL-F02	Across From Room 210, Fountain	Flush180	15-JUN-16	0.739	ppb
51376	51376-2-HAL-F02	Across From Room 210, Fountain	Flush180	15-JUN-16	1.100	ppb
51376	51376-2-HAL-F02	Across From Room 210, Fountain	Flush180	15-JUN-16	1.180	ppb
51376	51376-2-HAL-F02	Across From Room 210, Fountain	Flush180	15-JUN-16	1.100	ppb
51376	51376-2-HAL-F02	Across From Room 210, Fountain	Flush180	15-JUN-16	0.739	ppb
51376	51376-2-HAL-F02	Across From Room 210, Fountain	Flush180	15-JUN-16	1.230	ppb
51376	51376-2-HAL-F02	Across From Room 210, Fountain	Flush180	15-JUN-16	1.180	ppb
51376	51376-2-HAL-F02	Across From Room 210, Fountain	Flush180	02-NOV-21	1.000	ug/L
51376	51376-2-HAL-F02	Across From Room 210, Fountain	Flush180	02-NOV-21	1.000	ug/L
51376	51376-2-HAL-F02	Across From Room 210, Fountain	Flush180	02-NOV-21	1.150	ug/L
51376	51376-2-HAL-F02	Across From Room 210, Fountain	Flush180	02-NOV-21	1.000	ug/L
51376	51376-2-HAL-F02	Across From Room 210, Fountain	Initial	15-JUN-16	1.160	ppb
51376	51376-2-HAL-F02	Across From Room 210, Fountain	Initial	15-JUN-16	1.160	ppb
51376	51376-2-HAL-F02	Across From Room 210, Fountain	Initial	02-NOV-21	1.240	ug/L
51376	51376-1-HAL-RBF01	Across from room 104, Bottle Filler	Flush180	02-NOV-21	1.000	ug/L
51376	51376-1-HAL-RBF01	Across from room 104, Bottle Filler	Flush180	02-NOV-21	1.000	ug/L
51376	51376-1-HAL-RBF01	Across from room 104, Bottle Filler	Flush180	02-NOV-21	1.000	ug/L
51376	51376-1-HAL-RBF01	Across from room 104, Bottle Filler	Flush180	02-NOV-21	1.000	ug/L
51376	51376-1-HAL-RBF01	Across from room 104, Bottle Filler	Initial	02-NOV-21	1.330	ug/L
51376	51376-1-HAL-F04	Across from room 104, Fountain	Flush180	02-NOV-21	1.000	ug/L
51376	51376-1-HAL-F04	Across from room 104, Fountain	Flush180	02-NOV-21	1.000	ug/L
51376	51376-1-HAL-F04	Across from room 104, Fountain	Flush180	02-NOV-21	1.000	ug/L
51376	51376-1-HAL-F04	Across from room 104, Fountain	Flush180	15-JUN-16	0.409	ppb
51376	51376-1-HAL-F04	Across from room 104, Fountain	Flush180	15-JUN-16	0.305	ppb
51376	51376-1-HAL-F04	Across from room 104, Fountain	Flush180	15-JUN-16	0.310	ppb
51376	51376-1-HAL-F04	Across from room 104, Fountain	Flush180	15-JUN-16	0.298	ppb
51376	51376-1-HAL-F04	Across from room 104, Fountain	Flush180	15-JUN-16	0.310	ppb
51376	51376-1-HAL-F04	Across from room 104, Fountain	Flush180	15-JUN-16	0.305	ppb
51376	51376-1-HAL-F04	Across from room 104, Fountain	Flush180	15-JUN-16	0.409	ppb
51376	51376-1-HAL-F04	Across from room 104, Fountain	Flush180	15-JUN-16	0.298	ppb
51376	51376-1-HAL-F04	Across from room 104, Fountain	Initial	02-NOV-21	1.020	ug/L
51376	51376-1-HAL-F04	Across from room 104, Fountain	Initial	15-JUN-16	0.703	ppb
51376	51376-1-HAL-F04	Across from room 104, Fountain	Initial	15-JUN-16	0.703	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51376	51376-1-HAL-F06	Across from room 108, Fountain Left Side	Flush180	02-NOV-21	1.000	ug/L
51376	51376-1-HAL-F06	Across from room 108, Fountain Left Side	Flush180	02-NOV-21	1.000	ug/L
51376	51376-1-HAL-F06	Across from room 108, Fountain Left Side	Flush180	02-NOV-21	1.000	ug/L
51376	51376-1-HAL-F06	Across from room 108, Fountain Left Side	Flush180	02-NOV-21	1.000	ug/L
51376	51376-1-HAL-F06	Across from room 108, Fountain Left Side	Initial	02-NOV-21	1.000	ug/L
51376	51376-2-HAL-F03	Across from room 204, Fountain Left Side	Flush180	02-NOV-21	1.000	ug/L
51376	51376-2-HAL-F03	Across from room 204, Fountain Left Side	Flush180	02-NOV-21	1.000	ug/L
51376	51376-2-HAL-F03	Across from room 204, Fountain Left Side	Flush180	02-NOV-21	1.000	ug/L
51376	51376-2-HAL-F03	Across from room 204, Fountain Left Side	Flush180	02-NOV-21	1.000	ug/L
51376	51376-2-HAL-F03	Across from room 204, Fountain Left Side	Initial	02-NOV-21	1.200	ug/L
51376	51376-2-HAL-F01	Across from room 204, Fountain Right Side	Flush180	15-JUN-16	0.754	ppb
51376	51376-2-HAL-F01	Across from room 204, Fountain Right Side	Flush180	15-JUN-16	0.628	ppb
51376	51376-2-HAL-F01	Across from room 204, Fountain Right Side	Flush180	15-JUN-16	0.754	ppb
51376	51376-2-HAL-F01	Across from room 204, Fountain Right Side	Flush180	15-JUN-16	0.489	ppb
51376	51376-2-HAL-F01	Across from room 204, Fountain Right Side	Flush180	15-JUN-16	0.628	ppb
51376	51376-2-HAL-F01	Across from room 204, Fountain Right Side	Flush180	20-AUG-20	3.230	ug/L
51376	51376-2-HAL-F01	Across from room 204, Fountain Right Side	Flush180	02-NOV-21	1.000	ug/L
51376	51376-2-HAL-F01	Across from room 204, Fountain Right Side	Flush180	02-NOV-21	1.000	ug/L
51376	51376-2-HAL-F01	Across from room 204, Fountain Right Side	Flush180	02-NOV-21	1.000	ug/L
51376	51376-2-HAL-F01	Across from room 204, Fountain Right Side	Flush180	02-NOV-21	1.000	ug/L
51376	51376-2-HAL-F01	Across from room 204, Fountain Right Side	Flush180	15-JUN-16	0.782	ppb
51376	51376-2-HAL-F01	Across from room 204, Fountain Right Side	Flush180	15-JUN-16	0.489	ppb
51376	51376-2-HAL-F01	Across from room 204, Fountain Right Side	Flush180	15-JUN-16	0.782	ppb
51376	51376-2-HAL-F01	Across from room 204, Fountain Right Side	Initial	15-JUN-16	0.923	ppb
51376	51376-2-HAL-F01	Across from room 204, Fountain Right Side	Initial	15-JUN-16	0.923	ppb
51376	51376-2-HAL-F01	Across from room 204, Fountain Right Side	Initial	20-AUG-20	2.110	ug/L
51376	51376-2-HAL-	Across from room 204, Fountain	Initial	02-NOV-21	1.060	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01	Right Side				
51376	51376-2-HAL-RBF02	Across from room 210, Bottle Filler	Flush180	02-NOV-21	1.000	ug/L
51376	51376-2-HAL-RBF02	Across from room 210, Bottle Filler	Flush180	02-NOV-21	1.000	ug/L
51376	51376-2-HAL-RBF02	Across from room 210, Bottle Filler	Flush180	02-NOV-21	1.000	ug/L
51376	51376-2-HAL-RBF02	Across from room 210, Bottle Filler	Flush180	02-NOV-21	1.000	ug/L
51376	51376-2-HAL-RBF02	Across from room 210, Bottle Filler	Initial	02-NOV-21	1.000	ug/L
51376	51376-1-108-S06	Inside Room 108, Sink	Flush180	15-JUN-16	2.240	ppb
51376	51376-1-108-S06	Inside Room 108, Sink	Flush180	15-JUN-16	2.240	ppb
51376	51376-1-108-S06	Inside Room 108, Sink	Flush180	15-JUN-16	1.580	ppb
51376	51376-1-108-S06	Inside Room 108, Sink	Flush180	15-JUN-16	4.120	ppb
51376	51376-1-108-S06	Inside Room 108, Sink	Flush180	15-JUN-16	3.730	ppb
51376	51376-1-108-S06	Inside Room 108, Sink	Flush180	15-JUN-16	3.730	ppb
51376	51376-1-108-S06	Inside Room 108, Sink	Flush180	15-JUN-16	1.580	ppb
51376	51376-1-108-S06	Inside Room 108, Sink	Flush180	15-JUN-16	4.120	ppb
51376	51376-1-108-S06	Inside Room 108, Sink	Initial	15-JUN-16	5.460	ppb
51376	51376-1-108-S06	Inside Room 108, Sink	Initial	15-JUN-16	5.460	ppb
51376	51376-1-110-BF01	Inside Room 110, Bottle Filler	Flush180	23-SEP-22	5.700	ug/L
51376	51376-1-110-BF01	Inside Room 110, Bottle Filler	Flush180	23-SEP-22	3.800	ug/L
51376	51376-1-110-BF01	Inside Room 110, Bottle Filler	Flush180	23-SEP-22	3.790	ug/L
51376	51376-1-110-BF01	Inside Room 110, Bottle Filler	Flush180	23-SEP-22	3.280	ug/L
51376	51376-1-110-BF01	Inside Room 110, Bottle Filler	Flush180	13-OCT-22	1.230	ug/L
51376	51376-1-110-BF01	Inside Room 110, Bottle Filler	Flush180	13-OCT-22	1.420	ug/L
51376	51376-1-110-BF01	Inside Room 110, Bottle Filler	Flush180	13-OCT-22	1.100	ug/L
51376	51376-1-110-BF01	Inside Room 110, Bottle Filler	Flush180	13-OCT-22	1.320	ug/L
51376	51376-1-110-BF01	Inside Room 110, Bottle Filler	Initial	23-SEP-22	8.100	ug/L
51376	51376-1-110-BF01	Inside Room 110, Bottle Filler	Initial	13-OCT-22	1.760	ug/L
51376	51376-1-110-F01	Inside Room 110, Fountain	Flush180	23-SEP-22	1.000	ug/L
51376	51376-1-110-F01	Inside Room 110, Fountain	Flush180	23-SEP-22	1.000	ug/L
51376	51376-1-110-F01	Inside Room 110, Fountain	Flush180	23-SEP-22	1.000	ug/L
51376	51376-1-110-F01	Inside Room 110, Fountain	Initial	23-SEP-22	1.090	ug/L
51376	51376-1-110-S07	Inside Room 110, Sink	Flush180	15-JUN-16	0.774	ppb
51376	51376-1-110-S07	Inside Room 110, Sink	Flush180	15-JUN-16	0.932	ppb
51376	51376-1-110-S07	Inside Room 110, Sink	Flush180	15-JUN-16	0.730	ppb
51376	51376-1-110-S07	Inside Room 110, Sink	Flush180	15-JUN-16	0.454	ppb
51376	51376-1-110-S07	Inside Room 110, Sink	Flush180	15-JUN-16	0.730	ppb
51376	51376-1-110-S07	Inside Room 110, Sink	Flush180	15-JUN-16	0.932	ppb
51376	51376-1-110-	Inside Room 110, Sink	Flush180	02-NOV-21	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S07					
51376	51376-1-110-S07	Inside Room 110, Sink	Flush180	02-NOV-21	1.000	ug/L
51376	51376-1-110-S07	Inside Room 110, Sink	Flush180	02-NOV-21	1.000	ug/L
51376	51376-1-110-S07	Inside Room 110, Sink	Flush180	02-NOV-21	1.000	ug/L
51376	51376-1-110-S07	Inside Room 110, Sink	Flush180	15-JUN-16	0.774	ppb
51376	51376-1-110-S07	Inside Room 110, Sink	Flush180	15-JUN-16	0.454	ppb
51376	51376-1-110-S07	Inside Room 110, Sink	Initial	15-JUN-16	0.599	ppb
51376	51376-1-110-S07	Inside Room 110, Sink	Initial	15-JUN-16	0.599	ppb
51376	51376-1-110-S07	Inside Room 110, Sink	Initial	02-NOV-21	1.040	ug/L
51376	51376-1-110-S01	Inside Room 110, Sink	Flush180	23-SEP-22	1.000	ug/L
51376	51376-1-110-S01	Inside Room 110, Sink	Flush180	23-SEP-22	2.010	ug/L
51376	51376-1-110-S01	Inside Room 110, Sink	Flush180	23-SEP-22	1.060	ug/L
51376	51376-1-110-S01	Inside Room 110, Sink	Flush180	23-SEP-22	1.000	ug/L
51376	51376-1-110-S01	Inside Room 110, Sink	Initial	23-SEP-22	1.000	ug/L
51376	51376-1-KIT-KS02	Kitchen, Center Sink	Flush180	02-NOV-21	8.630	ug/L
51376	51376-1-KIT-KS02	Kitchen, Center Sink	Flush180	02-NOV-21	1.270	ug/L
51376	51376-1-KIT-KS02	Kitchen, Center Sink	Flush180	02-NOV-21	1.000	ug/L
51376	51376-1-KIT-KS02	Kitchen, Center Sink	Flush180	02-NOV-21	1.000	ug/L
51376	51376-1-KIT-KS02	Kitchen, Center Sink	Flush180	16-SEP-22	1.000	ug/L
51376	51376-1-KIT-KS02	Kitchen, Center Sink	Flush180	16-SEP-22	1.000	ug/L
51376	51376-1-KIT-KS02	Kitchen, Center Sink	Flush180	16-SEP-22	1.000	ug/L
51376	51376-1-KIT-KS02	Kitchen, Center Sink	Flush180	16-SEP-22	1.000	ug/L
51376	51376-1-KIT-KS02	Kitchen, Center Sink	Flush180	15-JUN-16	0.834	ppb
51376	51376-1-KIT-KS02	Kitchen, Center Sink	Flush180	15-JUN-16	1.010	ppb
51376	51376-1-KIT-KS02	Kitchen, Center Sink	Flush180	15-JUN-16	1.010	ppb
51376	51376-1-KIT-KS02	Kitchen, Center Sink	Flush180	15-JUN-16	0.834	ppb
51376	51376-1-KIT-KS02	Kitchen, Center Sink	Flush180	15-JUN-16	1.340	ppb
51376	51376-1-KIT-KS02	Kitchen, Center Sink	Flush180	15-JUN-16	1.340	ppb
51376	51376-1-KIT-KS02	Kitchen, Center Sink	Flush180	15-JUN-16	1.150	ppb
51376	51376-1-KIT-KS02	Kitchen, Center Sink	Flush180	15-JUN-16	1.150	ppb
51376	51376-1-KIT-KS02	Kitchen, Center Sink	Initial	02-NOV-21	1.000	ug/L
51376	51376-1-KIT-KS02	Kitchen, Center Sink	Initial	16-SEP-22	2.030	ug/L
51376	51376-1-KIT-KS02	Kitchen, Center Sink	Initial	15-JUN-16	0.935	ppb
51376	51376-1-KIT-KS02	Kitchen, Center Sink	Initial	15-JUN-16	0.935	ppb
51376	51376-1-KIT-KS01	Kitchen, East Sink	Flush180	02-NOV-21	1.000	ug/L
51376	51376-1-KIT-KS01	Kitchen, East Sink	Flush180	02-NOV-21	1.000	ug/L
51376	51376-1-KIT-KS01	Kitchen, East Sink	Flush180	02-NOV-21	1.000	ug/L
51376	51376-1-KIT-	Kitchen, East Sink	Flush180	02-NOV-21	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS01					
51376	51376-1-KIT-KS01	Kitchen, East Sink	Flush180	15-JUN-16	0.436	ppb
51376	51376-1-KIT-KS01	Kitchen, East Sink	Flush180	15-JUN-16	0.424	ppb
51376	51376-1-KIT-KS01	Kitchen, East Sink	Flush180	15-JUN-16	1.150	ppb
51376	51376-1-KIT-KS01	Kitchen, East Sink	Flush180	15-JUN-16	1.580	ppb
51376	51376-1-KIT-KS01	Kitchen, East Sink	Flush180	15-JUN-16	0.436	ppb
51376	51376-1-KIT-KS01	Kitchen, East Sink	Flush180	15-JUN-16	0.424	ppb
51376	51376-1-KIT-KS01	Kitchen, East Sink	Flush180	15-JUN-16	1.150	ppb
51376	51376-1-KIT-KS01	Kitchen, East Sink	Flush180	15-JUN-16	1.580	ppb
51376	51376-1-KIT-KS01	Kitchen, East Sink	Initial	02-NOV-21	1.480	ug/L
51376	51376-1-KIT-KS01	Kitchen, East Sink	Initial	15-JUN-16	0.825	ppb
51376	51376-1-KIT-KS01	Kitchen, East Sink	Initial	15-JUN-16	0.825	ppb
51376	51376-1-KIT-KS03	Kitchen, West Sink	Flush180	02-NOV-21	1.000	ug/L
51376	51376-1-KIT-KS03	Kitchen, West Sink	Flush180	02-NOV-21	1.000	ug/L
51376	51376-1-KIT-KS03	Kitchen, West Sink	Flush180	02-NOV-21	1.000	ug/L
51376	51376-1-KIT-KS03	Kitchen, West Sink	Flush180	02-NOV-21	1.000	ug/L
51376	51376-1-KIT-KS03	Kitchen, West Sink	Flush180	15-JUN-16	0.429	ppb
51376	51376-1-KIT-KS03	Kitchen, West Sink	Flush180	15-JUN-16	0.284	ppb
51376	51376-1-KIT-KS03	Kitchen, West Sink	Flush180	15-JUN-16	0.283	ppb
51376	51376-1-KIT-KS03	Kitchen, West Sink	Flush180	15-JUN-16	0.308	ppb
51376	51376-1-KIT-KS03	Kitchen, West Sink	Flush180	15-JUN-16	0.308	ppb
51376	51376-1-KIT-KS03	Kitchen, West Sink	Flush180	15-JUN-16	0.284	ppb
51376	51376-1-KIT-KS03	Kitchen, West Sink	Flush180	15-JUN-16	0.283	ppb
51376	51376-1-KIT-KS03	Kitchen, West Sink	Flush180	15-JUN-16	0.429	ppb
51376	51376-1-KIT-KS03	Kitchen, West Sink	Initial	02-NOV-21	1.000	ug/L
51376	51376-1-KIT-KS03	Kitchen, West Sink	Initial	15-JUN-16	0.976	ppb
51376	51376-1-KIT-KS03	Kitchen, West Sink	Initial	15-JUN-16	0.976	ppb
51376	51376-1-HAL-F05	Across from room 108, Fountain Right Side	Flush180	02-NOV-21	1.000	ug/L
51376	51376-1-HAL-F05	Across from room 108, Fountain Right Side	Flush180	02-NOV-21	1.000	ug/L
51376	51376-1-HAL-F05	Across from room 108, Fountain Right Side	Flush180	02-NOV-21	1.000	ug/L
51376	51376-1-HAL-F05	Across from room 108, Fountain Right Side	Flush180	02-NOV-21	1.000	ug/L
51376	51376-1-HAL-F05	Across from room 108, Fountain Right Side	Flush180	20-AUG-20	1.000	ug/L
51376	51376-1-HAL-F05	Across from room 108, Fountain Right Side	Flush180	15-JUN-16	0.619	ppb
51376	51376-1-HAL-F05	Across from room 108, Fountain Right Side	Flush180	15-JUN-16	1.180	ppb
51376	51376-1-HAL-		Flush180	15-JUN-16	0.985	ppb





Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F05	Across from room 108, Fountain Right Side				
51376	51376-1-HAL-F05	Across from room 108, Fountain Right Side	Flush180	15-JUN-16	0.619	ppb
51376	51376-1-HAL-F05	Across from room 108, Fountain Right Side	Flush180	15-JUN-16	0.350	ppb
51376	51376-1-HAL-F05	Across from room 108, Fountain Right Side	Flush180	15-JUN-16	0.985	ppb
51376	51376-1-HAL-F05	Across from room 108, Fountain Right Side	Flush180	15-JUN-16	0.350	ppb
51376	51376-1-HAL-F05	Across from room 108, Fountain Right Side	Flush180	15-JUN-16	1.180	ppb
51376	51376-1-HAL-F05	Across from room 108, Fountain Right Side	Initial	02-NOV-21	1.070	ug/L
51376	51376-1-HAL-F05	Across from room 108, Fountain Right Side	Initial	20-AUG-20	2.730	ug/L
51376	51376-1-HAL-F05	Across from room 108, Fountain Right Side	Initial	15-JUN-16	0.812	ppb
51376	51376-1-HAL-F05	Across from room 108, Fountain Right Side	Initial	15-JUN-16	0.812	ppb