



Sep 10, 2024

BRUNSON

932 N CENTRAL AVE, Chicago IL 60651.

Dear **BRUNSON** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

BRUNSON

932 N CENTRAL AVE, Chicago IL 60651.

Estimadas familias de **BRUNSON**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarle y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51088	51088-1-HAL-F18	Main- 1st Floor Outside Restroom, East Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-HAL-F18	Main- 1st Floor Outside Restroom, East Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-HAL-F18	Main- 1st Floor Outside Restroom, East Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-HAL-F18	Main- 1st Floor Outside Restroom, East Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-HAL-F18	Main- 1st Floor Outside Restroom, East Fountain	Flush180	22-JUL-20	1.000	ug/L
51088	51088-1-HAL-F18	Main- 1st Floor Outside Restroom, East Fountain	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-HAL-F18	Main- 1st Floor Outside Restroom, East Fountain	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-HAL-F18	Main- 1st Floor Outside Restroom, East Fountain	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-HAL-F18	Main- 1st Floor Outside Restroom, East Fountain	Initial	27-SEP-16	1.000	ppb
51088	51088-1-HAL-F18	Main- 1st Floor Outside Restroom, East Fountain	Initial	22-JUL-20	1.000	ug/L
51088	51088-1-HAL-F18	Main- 1st Floor Outside Restroom, East Fountain	Initial	21-OCT-21	1.000	ug/L
51088	51088-1-HAL-F19	Main- 1st Floor Outside Restroom, West Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-HAL-F19	Main- 1st Floor Outside Restroom, West Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-HAL-F19	Main- 1st Floor Outside Restroom, West Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-HAL-F19	Main- 1st Floor Outside Restroom, West Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-HAL-F19	Main- 1st Floor Outside Restroom, West Fountain	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-HAL-F19	Main- 1st Floor Outside Restroom, West Fountain	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-HAL-F19	Main- 1st Floor Outside Restroom, West Fountain	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-HAL-F19	Main- 1st Floor Outside Restroom, West Fountain	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-HAL-F19	Main- 1st Floor Outside Restroom, West Fountain	Initial	27-SEP-16	1.000	ppb
51088	51088-1-HAL-F19	Main- 1st Floor Outside Restroom, West Fountain	Initial	21-OCT-21	1.000	ug/L
51088	51088-2-HAL-F02	Main- 2nd Floor Outside Restroom, East Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-2-HAL-F02	Main- 2nd Floor Outside Restroom, East Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-2-HAL-F02	Main- 2nd Floor Outside Restroom, East Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-2-HAL-F02	Main- 2nd Floor Outside Restroom, East Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-2-HAL-F02	Main- 2nd Floor Outside Restroom, East Fountain	Flush180	21-OCT-21	1.000	ug/L
51088	51088-2-HAL-F02	Main- 2nd Floor Outside Restroom, East Fountain	Flush180	21-OCT-21	1.000	ug/L
51088	51088-2-HAL-F02	Main- 2nd Floor Outside Restroom, East Fountain	Flush180	21-OCT-21	1.000	ug/L
51088	51088-2-HAL-F02	Main- 2nd Floor Outside Restroom, East Fountain	Initial	27-SEP-16	1.000	ppb
51088	51088-2-HAL-F02	Main- 2nd Floor Outside Restroom, East Fountain	Initial	21-OCT-21	1.000	ug/L
51088	51088-2-HAL-F03	Main- 2nd Floor Outside Restroom, West Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-2-HAL-F03	Main- 2nd Floor Outside Restroom, West Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-2-HAL-F03	Main- 2nd Floor Outside Restroom, West Fountain	Flush180	27-SEP-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51088	51088-2-HAL-F03	Main- 2nd Floor Outside Restroom, West Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-2-HAL-F03	Main- 2nd Floor Outside Restroom, West Fountain	Flush180	16-OCT-20	1.000	ug/L
51088	51088-2-HAL-F03	Main- 2nd Floor Outside Restroom, West Fountain	Flush180	16-OCT-20	1.000	ug/L
51088	51088-2-HAL-F03	Main- 2nd Floor Outside Restroom, West Fountain	Flush180	16-OCT-20	1.000	ug/L
51088	51088-2-HAL-F03	Main- 2nd Floor Outside Restroom, West Fountain	Flush180	16-OCT-20	1.000	ug/L
51088	51088-2-HAL-F03	Main- 2nd Floor Outside Restroom, West Fountain	Initial	27-SEP-16	1.000	ppb
51088	51088-2-HAL-F03	Main- 2nd Floor Outside Restroom, West Fountain	Initial	16-OCT-20	1.000	ug/L
51088	51088-2-HAL-F01	Main- 2nd Floor Outside Room 200, Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-2-HAL-F01	Main- 2nd Floor Outside Room 200, Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-2-HAL-F01	Main- 2nd Floor Outside Room 200, Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-2-HAL-F01	Main- 2nd Floor Outside Room 200, Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-2-HAL-F01	Main- 2nd Floor Outside Room 200, Fountain	Flush180	21-OCT-21	1.000	ug/L
51088	51088-2-HAL-F01	Main- 2nd Floor Outside Room 200, Fountain	Flush180	21-OCT-21	1.000	ug/L
51088	51088-2-HAL-F01	Main- 2nd Floor Outside Room 200, Fountain	Flush180	21-OCT-21	1.000	ug/L
51088	51088-2-HAL-F01	Main- 2nd Floor Outside Room 200, Fountain	Initial	27-SEP-16	1.000	ppb
51088	51088-2-HAL-F01	Main- 2nd Floor Outside Room 200, Fountain	Initial	21-OCT-21	1.000	ug/L
51088	51088-3-HAL-F02	Main- 3rd Floor Outside Restroom, East Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-3-HAL-F02	Main- 3rd Floor Outside Restroom, East Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-3-HAL-F02	Main- 3rd Floor Outside Restroom, East Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-3-HAL-F02	Main- 3rd Floor Outside Restroom, East Fountain	Flush180	21-OCT-21	1.000	ug/L
51088	51088-3-HAL-F02	Main- 3rd Floor Outside Restroom, East Fountain	Flush180	21-OCT-21	1.000	ug/L
51088	51088-3-HAL-F02	Main- 3rd Floor Outside Restroom, East Fountain	Flush180	21-OCT-21	1.000	ug/L
51088	51088-3-HAL-F02	Main- 3rd Floor Outside Restroom, East Fountain	Initial	27-SEP-16	1.000	ppb
51088	51088-3-HAL-F02	Main- 3rd Floor Outside Restroom, East Fountain	Initial	21-OCT-21	1.000	ug/L
51088	51088-3-HAL-F03	Main- 3rd Floor Outside Restroom, West Fountain	Flush	02-MAY-2024	1.000	ug/L
51088	51088-3-HAL-F03	Main- 3rd Floor Outside Restroom, West Fountain	Flush	02-MAY-2024	1.000	ug/L
51088	51088-3-HAL-F03	Main- 3rd Floor Outside Restroom, West Fountain	Flush	02-MAY-2024	1.000	ug/L
51088	51088-3-HAL-F03	Main- 3rd Floor Outside Restroom, West Fountain	Flush	02-MAY-2024	1.000	ug/L
51088	51088-3-HAL-F03	Main- 3rd Floor Outside Restroom, West Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-3-HAL-F03	Main- 3rd Floor Outside Restroom, West Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-3-HAL-F03	Main- 3rd Floor Outside Restroom, West Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-3-HAL-F03	Main- 3rd Floor Outside Restroom, West Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-3-HAL-F03	Main- 3rd Floor Outside Restroom, West Fountain	Flush180	22-JUL-20	1.000	ug/L
51088	51088-3-HAL-F03	Main- 3rd Floor Outside Restroom, West Fountain	Initial	27-SEP-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51088	51088-3-HAL-F03	Main- 3rd Floor Outside Restroom, West Fountain	Initial	22-JUL-20	6.660	ug/L
51088	51088-3-HAL-F03	Main- 3rd Floor Outside Restroom, West Fountain	Initial	02-MAY-2024	1.000	ug/L
51088	51088-3-HAL-F01	Main- 3rd Floor Outside Room 300, Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-3-HAL-F01	Main- 3rd Floor Outside Room 300, Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-3-HAL-F01	Main- 3rd Floor Outside Room 300, Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-3-HAL-F01	Main- 3rd Floor Outside Room 300, Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-3-HAL-F01	Main- 3rd Floor Outside Room 300, Fountain	Flush180	21-OCT-21	1.000	ug/L
51088	51088-3-HAL-F01	Main- 3rd Floor Outside Room 300, Fountain	Flush180	21-OCT-21	1.000	ug/L
51088	51088-3-HAL-F01	Main- 3rd Floor Outside Room 300, Fountain	Flush180	21-OCT-21	1.000	ug/L
51088	51088-3-HAL-F01	Main- 3rd Floor Outside Room 300, Fountain	Initial	27-SEP-16	1.000	ppb
51088	51088-3-HAL-F01	Main- 3rd Floor Outside Room 300, Fountain	Initial	21-OCT-21	1.000	ug/L
51088	51088-1-109-S07	Main- Inside Room 109, Center, North Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-109-S07	Main- Inside Room 109, Center, North Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-109-S07	Main- Inside Room 109, Center, North Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-109-S07	Main- Inside Room 109, Center, North Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-109-S07	Main- Inside Room 109, Center, North Sink	Initial	27-SEP-16	1.000	ppb
51088	51088-1-109-S08	Main- Inside Room 109, Center, South Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-109-S08	Main- Inside Room 109, Center, South Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-109-S08	Main- Inside Room 109, Center, South Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-109-S08	Main- Inside Room 109, Center, South Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-109-S08	Main- Inside Room 109, Center, South Sink	Initial	27-SEP-16	8.900	ppb
51088	51088-1-109-F06	Main- Inside Room 109, West Wall Fountain	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-109-F06	Main- Inside Room 109, West Wall Fountain	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-109-F06	Main- Inside Room 109, West Wall Fountain	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-109-F06	Main- Inside Room 109, West Wall Fountain	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-109-F06	Main- Inside Room 109, West Wall Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-109-F06	Main- Inside Room 109, West Wall Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-109-F06	Main- Inside Room 109, West Wall Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-109-F06	Main- Inside Room 109, West Wall Fountain	Initial	21-OCT-21	1.000	ug/L
51088	51088-1-109-F06	Main- Inside Room 109, West Wall Fountain	Initial	27-SEP-16	1.000	ppb
51088	51088-1-111-S10	Main- Inside Room 111, Center, North Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-111-S10	Main- Inside Room 111, Center, North Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-111-S10	Main- Inside Room 111, Center, North Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-111-S10	Main- Inside Room 111, Center, North Sink	Initial	27-SEP-16	1.000	ppb
51088	51088-1-111-	Main- Inside Room 111, Center,	Flush180	27-SEP-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S11	South Sink				
51088	51088-1-111-S11	Main- Inside Room 111, Center, South Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-111-S11	Main- Inside Room 111, Center, South Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-111-S11	Main- Inside Room 111, Center, South Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-111-S11	Main- Inside Room 111, Center, South Sink	Initial	27-SEP-16	6.300	ppb
51088	51088-1-111-F09	Main- Inside Room 111, West Wall Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-111-F09	Main- Inside Room 111, West Wall Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-111-F09	Main- Inside Room 111, West Wall Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-111-F09	Main- Inside Room 111, West Wall Fountain	Flush180	09-SEP-22	1.000	ug/L
51088	51088-1-111-F09	Main- Inside Room 111, West Wall Fountain	Flush180	09-SEP-22	1.000	ug/L
51088	51088-1-111-F09	Main- Inside Room 111, West Wall Fountain	Flush180	09-SEP-22	1.000	ug/L
51088	51088-1-111-F09	Main- Inside Room 111, West Wall Fountain	Flush180	09-SEP-22	1.000	ug/L
51088	51088-1-111-F09	Main- Inside Room 111, West Wall Fountain	Flush180	21-OCT-21	2.200	ug/L
51088	51088-1-111-F09	Main- Inside Room 111, West Wall Fountain	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-111-F09	Main- Inside Room 111, West Wall Fountain	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-111-F09	Main- Inside Room 111, West Wall Fountain	Flush180	21-OCT-21	3.570	ug/L
51088	51088-1-111-F09	Main- Inside Room 111, West Wall Fountain	Flush180	11-AUG-22	23.000	ug/L
51088	51088-1-111-F09	Main- Inside Room 111, West Wall Fountain	Flush180	11-AUG-22	11.000	ug/L
51088	51088-1-111-F09	Main- Inside Room 111, West Wall Fountain	Flush180	11-AUG-22	4.800	ug/L
51088	51088-1-111-F09	Main- Inside Room 111, West Wall Fountain	Flush180	11-AUG-22	3.000	ug/L
51088	51088-1-111-F09	Main- Inside Room 111, West Wall Fountain	Initial	27-SEP-16	1.000	ppb
51088	51088-1-111-F09	Main- Inside Room 111, West Wall Fountain	Initial	09-SEP-22	1.000	ug/L
51088	51088-1-111-F09	Main- Inside Room 111, West Wall Fountain	Initial	21-OCT-21	38.700	ug/L
51088	51088-1-111-F09	Main- Inside Room 111, West Wall Fountain	Initial	11-AUG-22	5.400	ug/L
51088	51088-1-113-S13	Main- Inside Room 113, Center, North Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-113-S13	Main- Inside Room 113, Center, North Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-113-S13	Main- Inside Room 113, Center, North Sink	Flush180	27-SEP-16	2.100	ppb
51088	51088-1-113-S13	Main- Inside Room 113, Center, North Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-113-S13	Main- Inside Room 113, Center, North Sink	Initial	27-SEP-16	2.300	ppb
51088	51088-1-113-S14	Main- Inside Room 113, Center, South Sink	Flush180	08-DEC-16	2.100	ppb
51088	51088-1-113-S14	Main- Inside Room 113, Center, South Sink	Flush180	08-DEC-16	1.000	ppb
51088	51088-1-113-S14	Main- Inside Room 113, Center, South Sink	Flush180	08-DEC-16	1.000	ppb
51088	51088-1-113-S14	Main- Inside Room 113, Center, South Sink	Flush180	08-DEC-16	1.000	ppb
51088	51088-1-113-S14	Main- Inside Room 113, Center, South Sink	Flush180	08-DEC-16	2.100	ppb
51088	51088-1-113-S14	Main- Inside Room 113, Center, South Sink	Flush180	08-DEC-16	1.000	ppb
51088	51088-1-113-S14	Main- Inside Room 113, Center, South Sink	Flush180	08-DEC-16	1.000	ppb
51088	51088-1-113-S14	Main- Inside Room 113, Center, South Sink	Flush180	08-DEC-16	2.100	ppb
51088	51088-1-113-S14	Main- Inside Room 113, Center, South Sink	Flush180	08-DEC-16	1.000	ppb
51088	51088-1-113-S14	Main- Inside Room 113, Center, South Sink	Flush180	08-DEC-16	1.000	ppb
51088	51088-1-113-S14	Main- Inside Room 113, Center, South Sink	Flush180	08-DEC-16	1.000	ppb
51088	51088-1-113-S14	Main- Inside Room 113, Center, South Sink	Flush180	08-DEC-16	1.000	ppb

Water Quality Assessment Milton Brunson Math & Science Specialty ES

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S14	South Sink				
51088	51088-1-113-S14	Main- Inside Room 113, Center, South Sink	Flush180	27-SEP-16	2.000	ppb
51088	51088-1-113-S14	Main- Inside Room 113, Center, South Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-113-S14	Main- Inside Room 113, Center, South Sink	Flush180	27-SEP-16	5.400	ppb
51088	51088-1-113-S14	Main- Inside Room 113, Center, South Sink	Flush180	27-SEP-16	3.100	ppb
51088	51088-1-113-S14	Main- Inside Room 113, Center, South Sink	Initial	08-DEC-16	2.400	ppb
51088	51088-1-113-S14	Main- Inside Room 113, Center, South Sink	Initial	27-SEP-16	19.000	ppb
51088	51088-1-113-S14	Main- Inside Room 113, Center, South Sink	Initial	08-DEC-16	2.400	ppb
51088	51088-1-113-F12	Main- Inside Room 113, West Wall Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-113-F12	Main- Inside Room 113, West Wall Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-113-F12	Main- Inside Room 113, West Wall Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-113-F12	Main- Inside Room 113, West Wall Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-113-F12	Main- Inside Room 113, West Wall Fountain	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-113-F12	Main- Inside Room 113, West Wall Fountain	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-113-F12	Main- Inside Room 113, West Wall Fountain	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-113-F12	Main- Inside Room 113, West Wall Fountain	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-113-F12	Main- Inside Room 113, West Wall Fountain	Initial	27-SEP-16	1.000	ppb
51088	51088-1-113-F12	Main- Inside Room 113, West Wall Fountain	Initial	21-OCT-21	1.000	ug/L
51088	51088-1-115-S16	Main- Inside Room 115, Center, North Sink	Flush180	27-SEP-16	3.200	ppb
51088	51088-1-115-S16	Main- Inside Room 115, Center, North Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-115-S16	Main- Inside Room 115, Center, North Sink	Flush180	27-SEP-16	2.900	ppb
51088	51088-1-115-S16	Main- Inside Room 115, Center, North Sink	Flush180	27-SEP-16	2.400	ppb
51088	51088-1-115-S16	Main- Inside Room 115, Center, North Sink	Initial	27-SEP-16	7.200	ppb
51088	51088-1-115-S17	Main- Inside Room 115, Center, South Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-115-S17	Main- Inside Room 115, Center, South Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-115-S17	Main- Inside Room 115, Center, South Sink	Flush180	27-SEP-16	2.900	ppb
51088	51088-1-115-S17	Main- Inside Room 115, Center, South Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-115-S17	Main- Inside Room 115, Center, South Sink	Initial	27-SEP-16	8.900	ppb
51088	51088-1-115-F15	Main- Inside Room 115, West Wall Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-115-F15	Main- Inside Room 115, West Wall Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-115-F15	Main- Inside Room 115, West Wall Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-115-F15	Main- Inside Room 115, West Wall Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-115-F15	Main- Inside Room 115, West Wall Fountain	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-115-F15	Main- Inside Room 115, West Wall Fountain	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-115-F15	Main- Inside Room 115, West Wall Fountain	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-115-F15	Main- Inside Room 115, West Wall Fountain	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-115-F15	Main- Inside Room 115, West Wall Fountain	Initial	27-SEP-16	1.000	ppb
51088	51088-1-115-F15	Main- Inside Room 115, West Wall Fountain	Initial	21-OCT-21	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51088	51088-1-KIT-KS01	Main- Kitchen, East Wall Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-KIT-KS01	Main- Kitchen, East Wall Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-KIT-KS01	Main- Kitchen, East Wall Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-KIT-KS01	Main- Kitchen, East Wall Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-KIT-KS01	Main- Kitchen, East Wall Sink	Initial	27-SEP-16	1.000	ppb
51088	51088-1-KIT-KS03	Main- Kitchen, Island Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-KIT-KS03	Main- Kitchen, Island Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-KIT-KS03	Main- Kitchen, Island Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-KIT-KS03	Main- Kitchen, Island Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-KIT-KS03	Main- Kitchen, Island Sink	Initial	27-SEP-16	1.000	ppb
51088	51088-1-KIT-KS02	Main- Kitchen, West Wall Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-KIT-KS02	Main- Kitchen, West Wall Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-KIT-KS02	Main- Kitchen, West Wall Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-KIT-KS02	Main- Kitchen, West Wall Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-KIT-KS02	Main- Kitchen, West Wall Sink	Initial	27-SEP-16	1.000	ppb
51088	51088-1-HAL-F04	Main- Outside Lunchroom, Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-HAL-F04	Main- Outside Lunchroom, Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-HAL-F04	Main- Outside Lunchroom, Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-HAL-F04	Main- Outside Lunchroom, Fountain	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-HAL-F04	Main- Outside Lunchroom, Fountain	Initial	27-SEP-16	1.000	ppb
51088	51088-1-102-S05	Main- Teachers Lounge 102, Sink	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-102-S05	Main- Teachers Lounge 102, Sink	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-102-S05	Main- Teachers Lounge 102, Sink	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-102-S05	Main- Teachers Lounge 102, Sink	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-102-S05	Main- Teachers Lounge 102, Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-102-S05	Main- Teachers Lounge 102, Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-102-S05	Main- Teachers Lounge 102, Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-102-S05	Main- Teachers Lounge 102, Sink	Flush180	27-SEP-16	1.000	ppb
51088	51088-1-102-S05	Main- Teachers Lounge 102, Sink	Initial	21-OCT-21	1.000	ug/L
51088	51088-1-102-S05	Main- Teachers Lounge 102, Sink	Initial	27-SEP-16	1.000	ppb
51088	51088-1-HAL-RBF01	Retrofitted Bottle Filler, Outside Lunchroom	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-HAL-RBF01	Retrofitted Bottle Filler, Outside Lunchroom	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-HAL-RBF01	Retrofitted Bottle Filler, Outside Lunchroom	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-HAL-RBF01	Retrofitted Bottle Filler, Outside Lunchroom	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-HAL-RBF01	Retrofitted Bottle Filler, Outside Lunchroom	Initial	21-OCT-21	1.000	ug/L
51088	51088-2-HAL-RBF01	Retrofitted Bottle Filler, Outside Room 200	Flush180	21-OCT-21	1.000	ug/L
51088	51088-2-HAL-RBF01	Retrofitted Bottle Filler, Outside Room 200	Flush180	21-OCT-21	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51088	51088-2-HAL-RBF01	Retrofitted Bottle Filler, Outside Room 200	Flush180	21-OCT-21	1.000	ug/L
51088	51088-2-HAL-RBF01	Retrofitted Bottle Filler, Outside Room 200	Flush180	21-OCT-21	1.000	ug/L
51088	51088-2-HAL-RBF01	Retrofitted Bottle Filler, Outside Room 200	Initial	21-OCT-21	1.000	ug/L
51088	51088-3-HAL-RBF01	Retrofitted Bottle Filler, Outside Room 300	Flush180	21-OCT-21	1.000	ug/L
51088	51088-3-HAL-RBF01	Retrofitted Bottle Filler, Outside Room 300	Flush180	21-OCT-21	1.000	ug/L
51088	51088-3-HAL-RBF01	Retrofitted Bottle Filler, Outside Room 300	Flush180	21-OCT-21	1.000	ug/L
51088	51088-3-HAL-RBF01	Retrofitted Bottle Filler, Outside Room 300	Flush180	21-OCT-21	1.000	ug/L
51088	51088-3-HAL-RBF01	Retrofitted Bottle Filler, Outside Room 300	Initial	21-OCT-21	1.000	ug/L
51088	51088-1-109-S01	Room 109, Left Sink	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-109-S01	Room 109, Left Sink	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-109-S01	Room 109, Left Sink	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-109-S01	Room 109, Left Sink	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-109-S01	Room 109, Left Sink	Initial	21-OCT-21	1.390	ug/L
51088	51088-1-109-S02	Room 109, Right Sink	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-109-S02	Room 109, Right Sink	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-109-S02	Room 109, Right Sink	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-109-S02	Room 109, Right Sink	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-109-S02	Room 109, Right Sink	Initial	21-OCT-21	1.000	ug/L
51088	51088-1-111-S01	Room 111, Left Sink	Flush180	11-AUG-22	2.300	ug/L
51088	51088-1-111-S01	Room 111, Left Sink	Flush180	09-SEP-22	1.000	ug/L
51088	51088-1-111-S01	Room 111, Left Sink	Flush180	09-SEP-22	1.000	ug/L
51088	51088-1-111-S01	Room 111, Left Sink	Flush180	09-SEP-22	1.000	ug/L
51088	51088-1-111-S01	Room 111, Left Sink	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-111-S01	Room 111, Left Sink	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-111-S01	Room 111, Left Sink	Flush180	21-OCT-21	3.210	ug/L
51088	51088-1-111-S01	Room 111, Left Sink	Flush180	21-OCT-21	5.770	ug/L
51088	51088-1-111-S01	Room 111, Left Sink	Flush180	09-SEP-22	1.000	ug/L
51088	51088-1-111-S01	Room 111, Left Sink	Flush180	11-AUG-22	4.600	ug/L
51088	51088-1-111-S01	Room 111, Left Sink	Flush180	11-AUG-22	8.800	ug/L
51088	51088-1-111-S01	Room 111, Left Sink	Flush180	11-AUG-22	3.600	ug/L
51088	51088-1-111-S01	Room 111, Left Sink	Initial	11-AUG-22	2.500	ug/L
51088	51088-1-111-S01	Room 111, Left Sink	Initial	21-OCT-21	12.500	ug/L
51088	51088-1-111-S01	Room 111, Left Sink	Initial	09-SEP-22	1.000	ug/L
51088	51088-1-111-S02	Room 111, Right Sink	Flush180	21-OCT-21	5.610	ug/L
51088	51088-1-111-S02	Room 111, Right Sink	Flush180	21-OCT-21	2.520	ug/L
51088	51088-1-111-S02	Room 111, Right Sink	Flush180	21-OCT-21	2.420	ug/L
51088	51088-1-111-S02	Room 111, Right Sink	Flush180	21-OCT-21	1.620	ug/L
51088	51088-1-111-S02	Room 111, Right Sink	Flush180	11-AUG-22	2.200	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S02					
51088	51088-1-111-S02	Room 111, Right Sink	Flush180	11-AUG-22	1.000	ug/L
51088	51088-1-111-S02	Room 111, Right Sink	Flush180	11-AUG-22	1.000	ug/L
51088	51088-1-111-S02	Room 111, Right Sink	Flush180	11-AUG-22	1.000	ug/L
51088	51088-1-111-S02	Room 111, Right Sink	Initial	21-OCT-21	1.000	ug/L
51088	51088-1-111-S02	Room 111, Right Sink	Initial	11-AUG-22	4.700	ug/L
51088	51088-1-113-S01	Room 113, Left Sink	Flush180	11-AUG-22	4.600	ug/L
51088	51088-1-113-S01	Room 113, Left Sink	Flush180	11-AUG-22	1.000	ug/L
51088	51088-1-113-S01	Room 113, Left Sink	Flush180	11-AUG-22	1.000	ug/L
51088	51088-1-113-S01	Room 113, Left Sink	Flush180	11-AUG-22	1.000	ug/L
51088	51088-1-113-S01	Room 113, Left Sink	Flush180	21-OCT-21	4.930	ug/L
51088	51088-1-113-S01	Room 113, Left Sink	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-113-S01	Room 113, Left Sink	Flush180	21-OCT-21	2.660	ug/L
51088	51088-1-113-S01	Room 113, Left Sink	Flush180	21-OCT-21	1.130	ug/L
51088	51088-1-113-S01	Room 113, Left Sink	Initial	11-AUG-22	2.000	ug/L
51088	51088-1-113-S01	Room 113, Left Sink	Initial	21-OCT-21	1.090	ug/L
51088	51088-1-113-S02	Room 113, Right Sink	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-113-S02	Room 113, Right Sink	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-113-S02	Room 113, Right Sink	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-113-S02	Room 113, Right Sink	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-113-S02	Room 113, Right Sink	Initial	21-OCT-21	1.000	ug/L
51088	51088-1-115-S01	Room 115, Left Sink	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-115-S01	Room 115, Left Sink	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-115-S01	Room 115, Left Sink	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-115-S01	Room 115, Left Sink	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-115-S01	Room 115, Left Sink	Initial	21-OCT-21	1.000	ug/L
51088	51088-1-115-S02	Room 115, Right Sink	Flush180	21-OCT-21	1.060	ug/L
51088	51088-1-115-S02	Room 115, Right Sink	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-115-S02	Room 115, Right Sink	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-115-S02	Room 115, Right Sink	Flush180	21-OCT-21	1.000	ug/L
51088	51088-1-115-S02	Room 115, Right Sink	Initial	21-OCT-21	1.460	ug/L