



Sep 10, 2024

BUDLONG

2701 W FOSTER AVE, Chicago IL 60625.

Dear **BUDLONG** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

BUDLONG

2701 W FOSTER AVE, Chicago IL 60625.

Estimadas familias de **BUDLONG**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
50501	51050-1-HAL-RBF01	1st Floor Across from Main Office, West Fountain	Flush	31-JAN-2024	1.000	ug/L
50501	51050-1-HAL-RBF01	1st Floor Across from Main Office, West Fountain	Flush	31-JAN-2024	1.000	ug/L
50501	51050-1-HAL-RBF01	1st Floor Across from Main Office, West Fountain	Flush	31-JAN-2024	1.000	ug/L
50501	51050-1-HAL-RBF01	1st Floor Across from Main Office, West Fountain	Flush	31-JAN-2024	1.000	ug/L
50501	51050-1-HAL-RBF01	1st Floor Across from Main Office, West Fountain	Initial	31-JAN-2024	1.000	ug/L
50501	51050-2-HAL-RBF01	2nd Floor Across from Room 207, Left Fountain	Flush	31-JAN-2024	1.000	ug/L
50501	51050-2-HAL-RBF01	2nd Floor Across from Room 207, Left Fountain	Flush	31-JAN-2024	1.000	ug/L
50501	51050-2-HAL-RBF01	2nd Floor Across from Room 207, Left Fountain	Flush	31-JAN-2024	1.000	ug/L
50501	51050-2-HAL-RBF01	2nd Floor Across from Room 207, Left Fountain	Flush	31-JAN-2024	1.000	ug/L
50501	51050-2-HAL-RBF01	2nd Floor Across from Room 207, Left Fountain	Initial	31-JAN-2024	1.000	ug/L
50501	51050-3-HAL-BF01	3rd Floor Across from Room 307, Right Fountain	Flush	31-JAN-2024	1.000	ug/L
50501	51050-3-HAL-BF01	3rd Floor Across from Room 307, Right Fountain	Flush	31-JAN-2024	1.000	ug/L
50501	51050-3-HAL-BF01	3rd Floor Across from Room 307, Right Fountain	Flush	31-JAN-2024	1.000	ug/L
50501	51050-3-HAL-BF01	3rd Floor Across from Room 307, Right Fountain	Flush	31-JAN-2024	1.000	ug/L
50501	51050-3-HAL-BF01	3rd Floor Across from Room 307, Right Fountain	Initial	31-JAN-2024	1.000	ug/L
51050	51050-1-108-S05		Flush180	29-JUL-16	1.000	ppb
51050	51050-1-108-S05		Flush180	29-JUL-16	1.000	ppb
51050	51050-1-108-S05		Flush180	29-JUL-16	13.000	ppb
51050	51050-1-108-S05		Flush180	29-JUL-16	17.000	ppb
51050	51050-1-108-S05		Flush180	05-AUG-16	1.000	ppb
51050	51050-1-108-S05		Flush180	05-AUG-16	1.000	ppb
51050	51050-1-108-S05		Flush180	05-AUG-16	1.000	ppb
51050	51050-1-108-S05		Flush180	05-AUG-16	1.000	ppb
51050	51050-1-108-S05		Initial	29-JUL-16	15.000	ppb
51050	51050-1-108-S05		Initial	05-AUG-16	1.000	ppb
51050	51050-1-HAL-BF03	1st Floor Across from Main Office, East Bottle Filler	Flush	31-JAN-2024	1.000	ug/L
51050	51050-1-HAL-BF03	1st Floor Across from Main Office, East Bottle Filler	Flush	31-JAN-2024	1.000	ug/L
51050	51050-1-HAL-BF03	1st Floor Across from Main Office, East Bottle Filler	Flush	31-JAN-2024	1.000	ug/L
51050	51050-1-HAL-BF03	1st Floor Across from Main Office, East Bottle Filler	Flush	31-JAN-2024	1.000	ug/L
51050	51050-1-HAL-BF03	1st Floor Across from Main Office, East Bottle Filler	Initial	31-JAN-2024	1.000	ug/L
51050	51050-1-HAL-F02	1st Floor Across from Main Office, East Fountain	Flush	31-JAN-2024	1.000	ug/L
51050	51050-1-HAL-F02	1st Floor Across from Main Office, East Fountain	Flush	31-JAN-2024	1.000	ug/L
51050	51050-1-HAL-F02	1st Floor Across from Main Office, East Fountain	Flush	31-JAN-2024	1.000	ug/L
51050	51050-1-HAL-F02	1st Floor Across from Main Office, East Fountain	Flush	31-JAN-2024	1.000	ug/L
51050	51050-1-HAL-F02	1st Floor Across from Main Office, East Fountain	Flush180	26-MAY-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51050	51050-1-HAL-F02	1st Floor Across from Main Office, East Fountain	Flush180	26-MAY-16	1.000	ppb
51050	51050-1-HAL-F02	1st Floor Across from Main Office, East Fountain	Flush180	26-MAY-16	1.000	ppb
51050	51050-1-HAL-F02	1st Floor Across from Main Office, East Fountain	Flush180	26-MAY-16	1.000	ppb
51050	51050-1-HAL-F02	1st Floor Across from Main Office, East Fountain	Flush180	22-OCT-20	11.100	ug/L
51050	51050-1-HAL-F02	1st Floor Across from Main Office, East Fountain	Flush180	13-NOV-20	1.000	ug/L
51050	51050-1-HAL-F02	1st Floor Across from Main Office, East Fountain	Flush180	13-NOV-20	1.000	ug/L
51050	51050-1-HAL-F02	1st Floor Across from Main Office, East Fountain	Flush180	13-NOV-20	1.000	ug/L
51050	51050-1-HAL-F02	1st Floor Across from Main Office, East Fountain	Flush180	13-NOV-20	1.000	ug/L
51050	51050-1-HAL-F02	1st Floor Across from Main Office, East Fountain	Initial	26-MAY-16	1.000	ppb
51050	51050-1-HAL-F02	1st Floor Across from Main Office, East Fountain	Initial	22-OCT-20	10.900	ug/L
51050	51050-1-HAL-F02	1st Floor Across from Main Office, East Fountain	Initial	13-NOV-20	1.000	ug/L
51050	51050-1-HAL-F02	1st Floor Across from Main Office, East Fountain	Initial	31-JAN-2024	1.000	ug/L
51050	51050-1-HAL-F01	1st Floor Across from Main Office, West Fountain	Flush180	26-MAY-16	0.133	ppb
51050	51050-1-HAL-F01	1st Floor Across from Main Office, West Fountain	Flush180	26-MAY-16	0.162	ppb
51050	51050-1-HAL-F01	1st Floor Across from Main Office, West Fountain	Flush180	26-MAY-16	1.000	ppb
51050	51050-1-HAL-F01	1st Floor Across from Main Office, West Fountain	Flush180	26-MAY-16	1.000	ppb
51050	51050-1-HAL-F01	1st Floor Across from Main Office, West Fountain	Initial	26-MAY-16	1.000	ppb
51050	51050-1-101-S06	1st Floor Room 101, Sink	Flush180	26-MAY-16	0.730	ppb
51050	51050-1-101-S06	1st Floor Room 101, Sink	Flush180	26-MAY-16	0.754	ppb
51050	51050-1-101-S06	1st Floor Room 101, Sink	Flush180	26-MAY-16	0.613	ppb
51050	51050-1-101-S06	1st Floor Room 101, Sink	Flush180	26-MAY-16	1.160	ppb
51050	51050-1-101-S06	1st Floor Room 101, Sink	Initial	26-MAY-16	1.030	ppb
51050	51050-1-102-S04	1st Floor Room 102 / 103, East Sink	Initial	26-MAY-16	0.345	ppb
51050	51050-1-102-S07	1st Floor Room 102, Sink	Flush180	26-MAY-16	6.230	ppb
51050	51050-1-102-S07	1st Floor Room 102, Sink	Flush180	26-MAY-16	8.100	ppb
51050	51050-1-102-S07	1st Floor Room 102, Sink	Flush180	26-MAY-16	6.210	ppb
51050	51050-1-102-S07	1st Floor Room 102, Sink	Flush180	26-MAY-16	4.630	ppb
51050	51050-1-102-S07	1st Floor Room 102, Sink	Initial	26-MAY-16	7.040	ppb
51050	51050-1-105-S03	1st Floor Room 105 / 106, West Sink	Initial	26-MAY-16	0.210	ppb
51050	51050-1-HAL-108	1st Floor Room 108, Sink	Flush180	26-MAY-16	4.220	ppb
51050	51050-1-HAL-108	1st Floor Room 108, Sink	Flush180	26-MAY-16	17.400	ppb
51050	51050-1-HAL-108	1st Floor Room 108, Sink	Flush180	26-MAY-16	3.440	ppb
51050	51050-1-HAL-108	1st Floor Room 108, Sink	Flush180	26-MAY-16	4.010	ppb
51050	51050-1-HAL-108	1st Floor Room 108, Sink	Initial	26-MAY-16	4.860	ppb
51050	51050-2-HAL-F02	2nd Floor Across from Room 207, Right Fountain	Flush	31-JAN-2024	1.000	ug/L
51050	51050-2-HAL-F02	2nd Floor Across from Room 207, Right Fountain	Flush	31-JAN-2024	1.000	ug/L
51050	51050-2-HAL-F02	2nd Floor Across from Room 207, Right Fountain	Flush	31-JAN-2024	1.000	ug/L

Water Quality Assessment Lyman A Budlong Elementary School

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51050	51050-2-HAL-F02	2nd Floor Across from Room 207, Right Fountain	Flush	31-JAN-2024	1.000	ug/L
51050	51050-2-HAL-F02	2nd Floor Across from Room 207, Right Fountain	Initial	31-JAN-2024	1.000	ug/L
51050	51050-2-HAL-F01	2nd Floor Across from Room 207, West Fountain	Initial	26-MAY-16	0.171	ppb
51050	51050-3-HAL-F02	3rd Floor Across from Room 307, Right Fountain	Flush	31-JAN-2024	1.000	ug/L
51050	51050-3-HAL-F02	3rd Floor Across from Room 307, Right Fountain	Flush	31-JAN-2024	1.000	ug/L
51050	51050-3-HAL-F02	3rd Floor Across from Room 307, Right Fountain	Flush	31-JAN-2024	1.000	ug/L
51050	51050-3-HAL-F02	3rd Floor Across from Room 307, Right Fountain	Flush	31-JAN-2024	1.000	ug/L
51050	51050-3-HAL-F02	3rd Floor Across from Room 307, Right Fountain	Initial	31-JAN-2024	1.000	ug/L
51050	51050-3-HAL-F01	3rd Floor Across from Room 307, West Fountain	Flush	31-JAN-2024	1.000	ug/L
51050	51050-3-HAL-F01	3rd Floor Across from Room 307, West Fountain	Flush	31-JAN-2024	1.000	ug/L
51050	51050-3-HAL-F01	3rd Floor Across from Room 307, West Fountain	Flush	31-JAN-2024	1.000	ug/L
51050	51050-3-HAL-F01	3rd Floor Across from Room 307, West Fountain	Flush	31-JAN-2024	1.000	ug/L
51050	51050-3-HAL-F01	3rd Floor Across from Room 307, West Fountain	Initial	26-MAY-16	0.141	ppb
51050	51050-3-HAL-F01	3rd Floor Across from Room 307, West Fountain	Initial	31-JAN-2024	1.000	ug/L
51050	51050-2-HAL-F02	7th Floor Across from Room 207, East Fountain	Initial	26-MAY-16	1.000	ppb
51050	51050-3-HAL-F02	9th Floor Across from Room 307, East Fountain	Flush180	26-MAY-16	0.469	ppb
51050	51050-3-HAL-F02	9th Floor Across from Room 307, East Fountain	Flush180	22-OCT-20	4.040	ug/L
51050	51050-3-HAL-F02	9th Floor Across from Room 307, East Fountain	Initial	22-OCT-20	3.970	ug/L
51050	51050-G-HAL-F08	Annex Ground Level By Multi Purpose Rm, East Fount	Flush180	26-MAY-16	1.000	ppb
51050	51050-G-HAL-F08	Annex Ground Level By Multi Purpose Rm, East Fount	Flush180	26-MAY-16	1.000	ppb
51050	51050-G-HAL-F08	Annex Ground Level By Multi Purpose Rm, East Fount	Flush180	26-MAY-16	1.000	ppb
51050	51050-G-HAL-F08	Annex Ground Level By Multi Purpose Rm, East Fount	Flush180	26-MAY-16	1.000	ppb
51050	51050-G-HAL-F09	Annex Ground Level By Multi Purpose Rm, East Fount	Flush180	26-MAY-16	1.000	ppb
51050	51050-G-HAL-F09	Annex Ground Level By Multi Purpose Rm, East Fount	Flush180	26-MAY-16	1.000	ppb
51050	51050-G-HAL-F09	Annex Ground Level By Multi Purpose Rm, East Fount	Flush180	26-MAY-16	1.000	ppb
51050	51050-G-HAL-F09	Annex Ground Level By Multi Purpose Rm, East Fount	Flush180	26-MAY-16	1.000	ppb
51050	51050-G-HAL-F08	Annex Ground Level By Multi Purpose Rm, East Fount	Initial	26-MAY-16	1.000	ppb
51050	51050-G-HAL-F09	Annex Ground Level By Multi Purpose Rm, East Fount	Initial	26-MAY-16	1.000	ppb
51050	51050-1-FH-F01	Field House By Mechanical Rm, East Fountain	Flush180	26-MAY-16	1.000	ppb
51050	51050-1-FH-F01	Field House By Mechanical Rm, East Fountain	Flush180	26-MAY-16	1.000	ppb
51050	51050-1-FH-F01	Field House By Mechanical Rm, East Fountain	Flush180	26-MAY-16	1.000	ppb
51050	51050-1-FH-F01	Field House By Mechanical Rm, East Fountain	Flush180	26-MAY-16	1.000	ppb
51050	51050-1-FH-F01	Field House By Mechanical Rm, East Fountain	Initial	26-MAY-16	1.000	ppb
51050	51050-1-FH-F02	Field House By Mechanical Rm, West Fountain	Flush180	26-MAY-16	1.000	ppb
51050	51050-1-FH-F02	Field House By Mechanical Rm, West Fountain	Flush180	26-MAY-16	1.000	ppb
51050	51050-1-FH-F02	Field House By Mechanical Rm, West Fountain	Flush180	26-MAY-16	1.000	ppb
51050	51050-1-FH-F02	Field House By Mechanical Rm, West Fountain	Flush180	26-MAY-16	1.000	ppb
51050	51050-1-FH-F02	Field House By Mechanical Rm, West Fountain	Initial	26-MAY-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02	West Fountain				
51050	51050-1-FH-S03	Field House, Sink	Flush180	26-MAY-16	1.000	ppb
51050	51050-1-FH-S03	Field House, Sink	Flush180	26-MAY-16	1.000	ppb
51050	51050-1-FH-S03	Field House, Sink	Flush180	26-MAY-16	1.000	ppb
51050	51050-1-FH-S03	Field House, Sink	Flush180	26-MAY-16	1.000	ppb
51050	51050-1-FH-S03	Field House, Sink	Initial	26-MAY-16	0.338	ppb
51050	51050-G-HAL-F03	Ground Level Across Boys TR, Center Fountain	Flush	31-JAN-2024	1.000	ug/L
51050	51050-G-HAL-F03	Ground Level Across Boys TR, Center Fountain	Flush	31-JAN-2024	1.000	ug/L
51050	51050-G-HAL-F03	Ground Level Across Boys TR, Center Fountain	Flush	31-JAN-2024	1.000	ug/L
51050	51050-G-HAL-F03	Ground Level Across Boys TR, Center Fountain	Flush	31-JAN-2024	1.000	ug/L
51050	51050-G-HAL-F03	Ground Level Across Boys TR, Center Fountain	Initial	31-JAN-2024	1.000	ug/L
51050	51050-G-HAL-RBF02	Ground Level Across Boys TR, Left Fountain	Flush	31-JAN-2024	1.000	ug/L
51050	51050-G-HAL-RBF02	Ground Level Across Boys TR, Left Fountain	Flush	31-JAN-2024	1.000	ug/L
51050	51050-G-HAL-RBF02	Ground Level Across Boys TR, Left Fountain	Flush	31-JAN-2024	1.000	ug/L
51050	51050-G-HAL-RBF02	Ground Level Across Boys TR, Left Fountain	Flush	31-JAN-2024	1.000	ug/L
51050	51050-G-HAL-RBF02	Ground Level Across Boys TR, Left Fountain	Initial	31-JAN-2024	1.000	ug/L
51050	51050-G-HAL-F04	Ground Level Across Boys TR, Right Fountain	Flush	31-JAN-2024	1.000	ug/L
51050	51050-G-HAL-F04	Ground Level Across Boys TR, Right Fountain	Flush	31-JAN-2024	1.000	ug/L
51050	51050-G-HAL-F04	Ground Level Across Boys TR, Right Fountain	Flush	31-JAN-2024	1.000	ug/L
51050	51050-G-HAL-F04	Ground Level Across Boys TR, Right Fountain	Flush	31-JAN-2024	1.000	ug/L
51050	51050-G-HAL-F04	Ground Level Across Boys TR, Right Fountain	Initial	31-JAN-2024	1.000	ug/L
51050	51050-G-HAL-F03	Ground Level Across Room 120, Center Fountain	Flush180	26-MAY-16	2.220	ppb
51050	51050-G-HAL-F03	Ground Level Across Room 120, Center Fountain	Flush180	26-MAY-16	4.640	ppb
51050	51050-G-HAL-F03	Ground Level Across Room 120, Center Fountain	Flush180	26-MAY-16	1.400	ppb
51050	51050-G-HAL-F03	Ground Level Across Room 120, Center Fountain	Flush180	26-MAY-16	1.390	ppb
51050	51050-G-HAL-F03	Ground Level Across Room 120, Center Fountain	Initial	26-MAY-16	2.980	ppb
51050	51050-G-HAL-F02	Ground Level Across Room 120, Left Fountain	Flush180	26-MAY-16	1.690	ppb
51050	51050-G-HAL-F02	Ground Level Across Room 120, Left Fountain	Flush180	26-MAY-16	2.020	ppb
51050	51050-G-HAL-F02	Ground Level Across Room 120, Left Fountain	Flush180	26-MAY-16	1.160	ppb
51050	51050-G-HAL-F02	Ground Level Across Room 120, Left Fountain	Flush180	26-MAY-16	1.480	ppb
51050	51050-G-HAL-F02	Ground Level Across Room 120, Left Fountain	Initial	26-MAY-16	3.030	ppb
51050	51050-G-HAL-F04	Ground Level Across Room 120, Right Fountain	Flush180	26-MAY-16	0.881	ppb
51050	51050-G-HAL-F04	Ground Level Across Room 120, Right Fountain	Flush180	26-MAY-16	1.090	ppb
51050	51050-G-HAL-F04	Ground Level Across Room 120, Right Fountain	Flush180	26-MAY-16	1.050	ppb
51050	51050-G-HAL-F04	Ground Level Across Room 120, Right Fountain	Flush180	26-MAY-16	0.882	ppb
51050	51050-G-HAL-F04	Ground Level Across Room 120, Right Fountain	Initial	26-MAY-16	1.630	ppb
51050	51050-G-KIT-KS01	Ground Level Kitchen, Sink	Flush180	26-MAY-16	1.000	ppb
51050	51050-G-KIT-	Ground Level Kitchen, Sink	Flush180	26-MAY-16	1.000	ppb

**Water Quality Assessment
Lyman A Budlong Elementary School**

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS01					
51050	51050-G-KIT-KS01	Ground Level Kitchen, Sink	Flush180	26-MAY-16	1.000	ppb
51050	51050-G-KIT-KS01	Ground Level Kitchen, Sink	Flush180	26-MAY-16	1.000	ppb
51050	51050-G-KIT-KS01	Ground Level Kitchen, Sink	Initial	26-MAY-16	1.000	ppb
51050	51050-G-HAL-F06	Ground Level by Entrance 9, Center Fountain	Flush180	26-MAY-16	0.173	ppb
51050	51050-G-HAL-F06	Ground Level by Entrance 9, Center Fountain	Flush180	26-MAY-16	0.236	ppb
51050	51050-G-HAL-F06	Ground Level by Entrance 9, Center Fountain	Flush180	26-MAY-16	0.127	ppb
51050	51050-G-HAL-F06	Ground Level by Entrance 9, Center Fountain	Flush180	26-MAY-16	0.297	ppb
51050	51050-G-HAL-F06	Ground Level by Entrance 9, Center Fountain	Initial	26-MAY-16	1.000	ppb
51050	51050-G-HAL-F05	Ground Level by Entrance 9, Left Fountain	Flush180	26-MAY-16	1.000	ppb
51050	51050-G-HAL-F05	Ground Level by Entrance 9, Left Fountain	Flush180	26-MAY-16	1.000	ppb
51050	51050-G-HAL-F05	Ground Level by Entrance 9, Left Fountain	Flush180	26-MAY-16	1.000	ppb
51050	51050-G-HAL-F05	Ground Level by Entrance 9, Left Fountain	Flush180	26-MAY-16	1.840	ppb
51050	51050-G-HAL-F05	Ground Level by Entrance 9, Left Fountain	Initial	26-MAY-16	1.000	ppb
51050	51050-G-HAL-F07	Ground Level by Entrance 9, Right Fountain	Flush180	26-MAY-16	0.359	ppb
51050	51050-G-HAL-F07	Ground Level by Entrance 9, Right Fountain	Flush180	26-MAY-16	0.398	ppb
51050	51050-G-HAL-F07	Ground Level by Entrance 9, Right Fountain	Flush180	26-MAY-16	0.410	ppb
51050	51050-G-HAL-F07	Ground Level by Entrance 9, Right Fountain	Flush180	26-MAY-16	0.382	ppb
51050	51050-G-HAL-F07	Ground Level by Entrance 9, Right Fountain	Initial	26-MAY-16	0.233	ppb
52405	52405-1-S-003-S02		Flush180	18-JUN-19	1.000	ug/L
52405	52405-1-S-003-S02		Flush180	18-JUN-19	1.000	ug/L
52405	52405-1-S-003-S02		Flush180	18-JUN-19	1.000	ug/L
52405	52405-1-S-003-S02		Flush180	18-JUN-19	1.000	ug/L
52405	52405-1-S-003-S02		Initial	18-JUN-19	1.000	ug/L