



Sep 10, 2024

BURKE

5356 S KING DR, Chicago IL 60615.

Dear **BURKE** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

BURKE

5356 S KING DR, Chicago IL 60615.

Estimadas familias de **BURKE**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51347	51347-1-HAL-F01	Between Room 102 and 103	Flush180	20-JUL-23	1.910	ug/L
51347	51347-1-HAL-F01	Between Room 102 and 103	Flush180	20-JUL-23	3.060	ug/L
51347	51347-1-HAL-F01	Between Room 102 and 103	Flush180	20-JUL-23	1.550	ug/L
51347	51347-1-HAL-F01	Between Room 102 and 103	Flush180	20-JUL-23	2.280	ug/L
51347	51347-1-HAL-F05	Between Room 102 and 103	Flush180	20-JUL-23	9.340	ug/L
51347	51347-1-HAL-F05	Between Room 102 and 103	Flush180	20-JUL-23	4.950	ug/L
51347	51347-1-HAL-F05	Between Room 102 and 103	Flush180	20-JUL-23	3.900	ug/L
51347	51347-1-HAL-F05	Between Room 102 and 103	Flush180	20-JUL-23	4.150	ug/L
51347	51347-1-HAL-F01	Between Room 102 and 103	Flush180	21-JUN-23	5.690	ug/L
51347	51347-1-HAL-F01	Between Room 102 and 103	Flush180	21-JUN-23	4.720	ug/L
51347	51347-1-HAL-F01	Between Room 102 and 103	Flush180	21-JUN-23	3.890	ug/L
51347	51347-1-HAL-F01	Between Room 102 and 103	Flush180	21-JUN-23	3.630	ug/L
51347	51347-1-HAL-F03	Between Room 102 and 103	Flush180	21-JUN-23	1.780	ug/L
51347	51347-1-HAL-F05	Between Room 102 and 103	Flush180	08-AUG-23	11.600	ug/L
51347	51347-1-HAL-F05	Between Room 102 and 103	Flush180	08-AUG-23	9.650	ug/L
51347	51347-1-HAL-F05	Between Room 102 and 103	Flush180	08-AUG-23	10.700	ug/L
51347	51347-1-HAL-F05	Between Room 102 and 103	Flush180	08-AUG-23	11.200	ug/L
51347	51347-1-HAL-F04	Between Room 102 and 103	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F05	Between Room 102 and 103	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F05	Between Room 102 and 103	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F05	Between Room 102 and 103	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F05	Between Room 102 and 103	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F05	Between Room 102 and 103	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F05	Between Room 102 and 103	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F06	Between Room 102 and 103	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F06	Between Room 102 and 103	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F06	Between Room 102 and 103	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F06	Between Room 102 and 103	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F01	Between Room 102 and 103	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F01	Between Room 102 and 103	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F01	Between Room 102 and 103	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F03	Between Room 102 and 103	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F03	Between Room 102 and 103	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F03	Between Room 102 and 103	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F01	Between Room 102 and 103	Flush180	04-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51347	51347-1-HAL-F02	Between Room 102 and 103	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F02	Between Room 102 and 103	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F02	Between Room 102 and 103	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F02	Between Room 102 and 103	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F02	Between Room 102 and 103	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F03	Between Room 102 and 103	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F03	Between Room 102 and 103	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F04	Between Room 102 and 103	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F04	Between Room 102 and 103	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F04	Between Room 102 and 103	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F04	Between Room 102 and 103	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F03	Between Room 102 and 103	Flush180	21-JUN-23	1.790	ug/L
51347	51347-1-HAL-F03	Between Room 102 and 103	Flush180	21-JUN-23	3.880	ug/L
51347	51347-1-HAL-F03	Between Room 102 and 103	Flush180	21-JUN-23	1.840	ug/L
51347	51347-1-HAL-F04	Between Room 102 and 103	Flush180	21-JUN-23	1.000	ug/L
51347	51347-1-HAL-F04	Between Room 102 and 103	Flush180	21-JUN-23	1.000	ug/L
51347	51347-1-HAL-F04	Between Room 102 and 103	Flush180	21-JUN-23	1.000	ug/L
51347	51347-1-HAL-F05	Between Room 102 and 103	Flush180	21-JUN-23	5.360	ug/L
51347	51347-1-HAL-F05	Between Room 102 and 103	Flush180	21-JUN-23	5.880	ug/L
51347	51347-1-HAL-F05	Between Room 102 and 103	Flush180	21-JUN-23	3.660	ug/L
51347	51347-1-HAL-F05	Between Room 102 and 103	Flush180	21-JUN-23	2.600	ug/L
51347	51347-1-HAL-F04	Between Room 102 and 103	Flush180	10-MAY-23	3.580	ug/L
51347	51347-1-HAL-F04	Between Room 102 and 103	Flush180	10-MAY-23	2.830	ug/L
51347	51347-1-HAL-F04	Between Room 102 and 103	Flush180	10-MAY-23	2.110	ug/L
51347	51347-1-HAL-F04	Between Room 102 and 103	Flush180	10-MAY-23	1.730	ug/L
51347	51347-1-HAL-F05	Between Room 102 and 103	Flush180	10-MAY-23	6.400	ug/L
51347	51347-1-HAL-F05	Between Room 102 and 103	Flush180	10-MAY-23	4.790	ug/L
51347	51347-1-HAL-F05	Between Room 102 and 103	Flush180	10-MAY-23	3.810	ug/L
51347	51347-1-HAL-F05	Between Room 102 and 103	Flush180	10-MAY-23	3.770	ug/L
51347	51347-1-HAL-F01	Between Room 102 and 103	Flush180	10-MAY-23	31.400	ug/L
51347	51347-1-HAL-F01	Between Room 102 and 103	Flush180	10-MAY-23	5.930	ug/L
51347	51347-1-HAL-F01	Between Room 102 and 103	Flush180	10-MAY-23	5.220	ug/L
51347	51347-1-HAL-F01	Between Room 102 and 103	Flush180	10-MAY-23	5.710	ug/L
51347	51347-1-HAL-F02	Between Room 102 and 103	Flush180	10-MAY-23	2.690	ug/L
51347	51347-1-HAL-F02	Between Room 102 and 103	Flush180	10-MAY-23	2.690	ug/L
51347	51347-1-HAL-F02	Between Room 102 and 103	Flush180	10-MAY-23	2.350	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F04	Restroom				
51347	51347-2-HAL-RBF01	Between Room 206 and Girls Restroom, Retrofitted Bottle Filler	Flush180	10-MAY-23	1.000	ug/L
51347	51347-2-HAL-RBF01	Between Room 206 and Girls Restroom, Retrofitted Bottle Filler	Flush180	10-MAY-23	1.000	ug/L
51347	51347-2-HAL-RBF01	Between Room 206 and Girls Restroom, Retrofitted Bottle Filler	Flush180	10-MAY-23	1.000	ug/L
51347	51347-2-HAL-RBF01	Between Room 206 and Girls Restroom, Retrofitted Bottle Filler	Flush180	10-MAY-23	1.000	ug/L
51347	51347-2-HAL-RBF01	Between Room 206 and Girls Restroom, Retrofitted Bottle Filler	Initial	10-MAY-23	1.000	ug/L
51347	51347-3-HAL-F01	Between Room 302 and 303	Flush180	04-JUN-16	1.000	ppb
51347	51347-3-HAL-F01	Between Room 302 and 303	Flush180	04-JUN-16	1.000	ppb
51347	51347-3-HAL-F01	Between Room 302 and 303	Flush180	04-JUN-16	1.000	ppb
51347	51347-3-HAL-F01	Between Room 302 and 303	Flush180	04-JUN-16	1.000	ppb
51347	51347-3-HAL-F01	Between Room 302 and 303	Flush180	04-JUN-16	1.000	ppb
51347	51347-3-HAL-F01	Between Room 302 and 303	Flush180	04-JUN-16	1.000	ppb
51347	51347-3-HAL-F02	Between Room 302 and 303	Flush180	04-JUN-16	1.000	ppb
51347	51347-3-HAL-F02	Between Room 302 and 303	Flush180	04-JUN-16	1.000	ppb
51347	51347-3-HAL-F02	Between Room 302 and 303	Flush180	04-JUN-16	1.000	ppb
51347	51347-3-HAL-F02	Between Room 302 and 303	Flush180	04-JUN-16	1.000	ppb
51347	51347-3-HAL-F01	Between Room 302 and 303	Flush180	21-AUG-20	1.000	ug/L
51347	51347-3-HAL-F01	Between Room 302 and 303	Flush180	21-OCT-20	1.000	ug/L
51347	51347-3-HAL-F01	Between Room 302 and 303	Flush180	21-OCT-20	1.000	ug/L
51347	51347-3-HAL-F01	Between Room 302 and 303	Flush180	21-OCT-20	1.000	ug/L
51347	51347-3-HAL-F01	Between Room 302 and 303	Flush180	21-OCT-20	1.000	ug/L
51347	51347-3-HAL-F02	Between Room 302 and 303	Flush180	10-MAY-23	1.300	ug/L
51347	51347-3-HAL-F01	Between Room 302 and 303	Flush180	10-MAY-23	1.730	ug/L
51347	51347-3-HAL-F01	Between Room 302 and 303	Flush180	10-MAY-23	1.710	ug/L
51347	51347-3-HAL-F01	Between Room 302 and 303	Flush180	10-MAY-23	1.220	ug/L
51347	51347-3-HAL-F01	Between Room 302 and 303	Flush180	10-MAY-23	1.000	ug/L
51347	51347-3-HAL-F02	Between Room 302 and 303	Flush180	10-MAY-23	1.000	ug/L
51347	51347-3-HAL-F02	Between Room 302 and 303	Flush180	10-MAY-23	1.000	ug/L
51347	51347-3-HAL-F02	Between Room 302 and 303	Flush180	10-MAY-23	1.000	ug/L
51347	51347-3-HAL-F01	Between Room 302 and 303	Initial	21-AUG-20	10.000	ug/L
51347	51347-3-HAL-F01	Between Room 302 and 303	Initial	21-OCT-20	1.000	ug/L
51347	51347-3-HAL-F01	Between Room 302 and 303	Initial	10-MAY-23	1.340	ug/L
51347	51347-3-HAL-F02	Between Room 302 and 303	Initial	10-MAY-23	1.480	ug/L
51347	51347-3-HAL-F05	Boys Restroom	Flush180	04-JUN-16	1.000	ppb
51347	51347-3-HAL-F05	Boys Restroom	Flush180	04-JUN-16	1.000	ppb
51347	51347-3-HAL-F05	Boys Restroom	Flush180	04-JUN-16	1.000	ppb
51347	51347-3-HAL-F05	Boys Restroom	Flush180	04-JUN-16	1.000	ppb
51347	51347-3-HAL-	Boys Restroom	Flush180	04-JUN-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F05					
51347	51347-3-HAL-F05	Boys Restroom	Flush180	10-MAY-23	1.000	ug/L
51347	51347-3-HAL-F05	Boys Restroom	Flush180	10-MAY-23	1.000	ug/L
51347	51347-3-HAL-F05	Boys Restroom	Flush180	10-MAY-23	1.000	ug/L
51347	51347-3-HAL-F05	Boys Restroom	Flush180	10-MAY-23	1.000	ug/L
51347	51347-3-HAL-F05	Boys Restroom	Initial	10-MAY-23	1.000	ug/L
51347	51347-3-HAL-F06	Boys Toilet by Staircase	Flush180	04-JUN-16	1.000	ppb
51347	51347-3-HAL-F06	Boys Toilet by Staircase	Flush180	04-JUN-16	1.000	ppb
51347	51347-3-HAL-F06	Boys Toilet by Staircase	Flush180	04-JUN-16	1.000	ppb
51347	51347-3-HAL-F06	Boys Toilet by Staircase	Flush180	04-JUN-16	1.000	ppb
51347	51347-3-HAL-F06	Boys Toilet by Staircase	Flush180	04-JUN-16	1.000	ppb
51347	51347-3-HAL-F06	Boys Toilet by Staircase	Flush180	10-MAY-23	1.000	ug/L
51347	51347-3-HAL-F06	Boys Toilet by Staircase	Flush180	10-MAY-23	1.000	ug/L
51347	51347-3-HAL-F06	Boys Toilet by Staircase	Flush180	10-MAY-23	1.000	ug/L
51347	51347-3-HAL-F06	Boys Toilet by Staircase	Flush180	10-MAY-23	1.000	ug/L
51347	51347-3-HAL-F06	Boys Toilet by Staircase	Initial	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F11	Engineers Office, Room 106	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F11	Engineers Office, Room 106	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F11	Engineers Office, Room 106	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F11	Engineers Office, Room 106	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F12	Engineers Office, Room 106	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F12	Engineers Office, Room 106	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F12	Engineers Office, Room 106	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F12	Engineers Office, Room 106	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F12	Engineers Office, Room 106	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F12	Engineers Office, Room 106	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F08	Engineers Office, Room 106	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F09	Engineers Office, Room 106	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F09	Engineers Office, Room 106	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F09	Engineers Office, Room 106	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F09	Engineers Office, Room 106	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F10	Engineers Office, Room 106	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F10	Engineers Office, Room 106	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F10	Engineers Office, Room 106	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F10	Engineers Office, Room 106	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F10	Engineers Office, Room 106	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F10	Engineers Office, Room 106	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F10	Engineers Office, Room 106	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F11	Engineers Office, Room 106	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F07	Engineers Office, Room 106	Flush180	04-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51347	51347-1-HAL-F07	Engineers Office, Room 106	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F07	Engineers Office, Room 106	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F07	Engineers Office, Room 106	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F07	Engineers Office, Room 106	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F08	Engineers Office, Room 106	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F08	Engineers Office, Room 106	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F08	Engineers Office, Room 106	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F08	Engineers Office, Room 106	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F09	Engineers Office, Room 106	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F09	Engineers Office, Room 106	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F09	Engineers Office, Room 106	Flush180	10-MAY-23	1.130	ug/L
51347	51347-1-HAL-F09	Engineers Office, Room 106	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F10	Engineers Office, Room 106	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F10	Engineers Office, Room 106	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F10	Engineers Office, Room 106	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F10	Engineers Office, Room 106	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F10	Engineers Office, Room 106	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F11	Engineers Office, Room 106	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F11	Engineers Office, Room 106	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F11	Engineers Office, Room 106	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F11	Engineers Office, Room 106	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F12	Engineers Office, Room 106	Flush180	10-MAY-23	2.860	ug/L
51347	51347-1-HAL-F12	Engineers Office, Room 106	Flush180	10-MAY-23	1.540	ug/L
51347	51347-1-HAL-F12	Engineers Office, Room 106	Flush180	10-MAY-23	1.040	ug/L
51347	51347-1-HAL-F12	Engineers Office, Room 106	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F08	Engineers Office, Room 106	Flush180	10-MAY-23	1.380	ug/L
51347	51347-1-HAL-F08	Engineers Office, Room 106	Flush180	10-MAY-23	1.640	ug/L
51347	51347-1-HAL-F08	Engineers Office, Room 106	Flush180	10-MAY-23	1.130	ug/L
51347	51347-1-HAL-F08	Engineers Office, Room 106	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F09	Engineers Office, Room 106	Initial	10-MAY-23	1.430	ug/L
51347	51347-1-HAL-F10	Engineers Office, Room 106	Initial	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F11	Engineers Office, Room 106	Initial	10-MAY-23	1.210	ug/L
51347	51347-1-HAL-F12	Engineers Office, Room 106	Initial	10-MAY-23	3.190	ug/L
51347	51347-1-HAL-F08	Engineers Office, Room 106	Initial	10-MAY-23	1.350	ug/L
51347	51347-1-HAL-RBF01	Engineers Office, Room 106, Left Fountain, Retrofitted Bottle Filler	Flush180	10-MAY-23	1.050	ug/L
51347	51347-1-HAL-RBF01	Engineers Office, Room 106, Left Fountain, Retrofitted Bottle Filler	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-RBF01	Engineers Office, Room 106, Left Fountain, Retrofitted Bottle Filler	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-RBF01	Engineers Office, Room 106, Left Fountain, Retrofitted Bottle Filler	Flush180	10-MAY-23	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51347	51347-1-HAL-RBF01	Engineers Office, Room 106, Left Fountain, Retrofitted Bottle Filler	Initial	10-MAY-23	1.000	ug/L
51347	51347-3-HAL-F03	Girls Washroom Facing Room 312	Flush180	04-JUN-16	1.000	ppb
51347	51347-3-HAL-F03	Girls Washroom Facing Room 312	Flush180	04-JUN-16	1.000	ppb
51347	51347-3-HAL-F03	Girls Washroom Facing Room 312	Flush180	04-JUN-16	1.000	ppb
51347	51347-3-HAL-F03	Girls Washroom Facing Room 312	Flush180	04-JUN-16	1.000	ppb
51347	51347-3-HAL-F03	Girls Washroom Facing Room 312	Flush180	04-JUN-16	1.000	ppb
51347	51347-3-HAL-F04	Girls Washroom Facing Room 312	Flush180	04-JUN-16	1.000	ppb
51347	51347-3-HAL-F04	Girls Washroom Facing Room 312	Flush180	04-JUN-16	1.000	ppb
51347	51347-3-HAL-F04	Girls Washroom Facing Room 312	Flush180	04-JUN-16	1.000	ppb
51347	51347-3-HAL-F04	Girls Washroom Facing Room 312	Flush180	04-JUN-16	1.000	ppb
51347	51347-3-HAL-F04	Girls Washroom Facing Room 312	Flush180	04-JUN-16	1.000	ppb
51347	51347-3-HAL-F04	Girls Washroom Facing Room 312	Flush180	10-MAY-23	1.000	ug/L
51347	51347-3-HAL-F04	Girls Washroom Facing Room 312	Flush180	10-MAY-23	1.000	ug/L
51347	51347-3-HAL-F04	Girls Washroom Facing Room 312	Flush180	10-MAY-23	1.000	ug/L
51347	51347-3-HAL-F04	Girls Washroom Facing Room 312	Flush180	10-MAY-23	1.000	ug/L
51347	51347-3-HAL-F04	Girls Washroom Facing Room 312	Initial	10-MAY-23	1.000	ug/L
51347	51347-3-HAL-RBF01	Girls Washroom Facing Room 312, Retrofitted Bottle Filler	Flush180	10-MAY-23	1.000	ug/L
51347	51347-3-HAL-RBF01	Girls Washroom Facing Room 312, Retrofitted Bottle Filler	Flush180	10-MAY-23	1.000	ug/L
51347	51347-3-HAL-RBF01	Girls Washroom Facing Room 312, Retrofitted Bottle Filler	Flush180	10-MAY-23	1.000	ug/L
51347	51347-3-HAL-RBF01	Girls Washroom Facing Room 312, Retrofitted Bottle Filler	Flush180	10-MAY-23	1.000	ug/L
51347	51347-3-HAL-RBF01	Girls Washroom Facing Room 312, Retrofitted Bottle Filler	Initial	10-MAY-23	1.000	ug/L
51347	51347-1-KIT-KS01	Kitchen - Big Sink	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-KIT-KS01	Kitchen - Big Sink	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-KIT-KS01	Kitchen - Big Sink	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-KIT-KS01	Kitchen - Big Sink	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-KIT-KS01	Kitchen - Big Sink	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-KIT-KS02	Kitchen - Small Sink	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-KIT-KS02	Kitchen - Small Sink	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-KIT-KS02	Kitchen - Small Sink	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-KIT-KS02	Kitchen - Small Sink	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-KIT-KS02	Kitchen - Small Sink	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F13	Near Boys Bathroom / Main Office	Flush180	03-AUG-16	0.515	ppb
51347	51347-1-HAL-F13	Near Boys Bathroom / Main Office	Flush180	03-AUG-16	0.655	ppb
51347	51347-1-HAL-F13	Near Boys Bathroom / Main Office	Flush180	03-AUG-16	1.000	ppb
51347	51347-1-HAL-F13	Near Boys Bathroom / Main Office	Flush180	10-NOV-16	0.440	ppb
51347	51347-1-HAL-F13	Near Boys Bathroom / Main Office	Flush180	10-NOV-16	0.630	ppb
51347	51347-1-HAL-F13	Near Boys Bathroom / Main Office	Flush180	10-NOV-16	0.520	ppb
51347	51347-1-HAL-	Near Boys Bathroom / Main Office	Flush180	10-NOV-16	0.450	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F13					
51347	51347-1-HAL-F14	Near Boys Bathroom / Main Office	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F15	Near Boys Bathroom / Main Office	Flush180	04-JUN-16	10.000	ppb
51347	51347-1-HAL-F15	Near Boys Bathroom / Main Office	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F15	Near Boys Bathroom / Main Office	Flush180	04-JUN-16	6.010	ppb
51347	51347-1-HAL-F15	Near Boys Bathroom / Main Office	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F15	Near Boys Bathroom / Main Office	Flush180	04-JUN-16	14.200	ppb
51347	51347-1-HAL-F16	Near Boys Bathroom / Main Office	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F16	Near Boys Bathroom / Main Office	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F16	Near Boys Bathroom / Main Office	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F16	Near Boys Bathroom / Main Office	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F16	Near Boys Bathroom / Main Office	Flush180	04-JUN-16	6.380	ppb
51347	51347-1-HAL-F16	Near Boys Bathroom / Main Office	Flush180	04-JUN-16	16.500	ppb
51347	51347-1-HAL-F13	Near Boys Bathroom / Main Office	Flush180	04-JUN-16	15.300	ppb
51347	51347-1-HAL-F13	Near Boys Bathroom / Main Office	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F13	Near Boys Bathroom / Main Office	Flush180	04-JUN-16	8.430	ppb
51347	51347-1-HAL-F13	Near Boys Bathroom / Main Office	Flush180	04-JUN-16	16.000	ppb
51347	51347-1-HAL-F13	Near Boys Bathroom / Main Office	Flush180	03-AUG-16	0.459	ppb
51347	51347-1-HAL-F17	Near Boys Bathroom / Main Office	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F17	Near Boys Bathroom / Main Office	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F17	Near Boys Bathroom / Main Office	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F17	Near Boys Bathroom / Main Office	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F17	Near Boys Bathroom / Main Office	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F18	Near Boys Bathroom / Main Office	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F18	Near Boys Bathroom / Main Office	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F18	Near Boys Bathroom / Main Office	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F18	Near Boys Bathroom / Main Office	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-HAL-F14	Near Boys Bathroom / Main Office	Flush180	04-JUN-16	7.350	ppb
51347	51347-1-HAL-F14	Near Boys Bathroom / Main Office	Flush180	04-JUN-16	10.200	ppb
51347	51347-1-HAL-F14	Near Boys Bathroom / Main Office	Flush180	04-JUN-16	10.900	ppb
51347	51347-1-HAL-F14	Near Boys Bathroom / Main Office	Flush180	04-JUN-16	10.300	ppb
51347	51347-1-HAL-F13	Near Boys Bathroom / Main Office	Flush180	21-OCT-20	1.000	ug/L
51347	51347-1-HAL-F13	Near Boys Bathroom / Main Office	Flush180	21-OCT-20	1.000	ug/L
51347	51347-1-HAL-F13	Near Boys Bathroom / Main Office	Flush180	21-OCT-20	1.000	ug/L
51347	51347-1-HAL-F13	Near Boys Bathroom / Main Office	Flush180	21-AUG-20	4.930	ug/L
51347	51347-1-HAL-F13	Near Boys Bathroom / Main Office	Flush180	21-OCT-20	1.000	ug/L
51347	51347-1-HAL-	Near Boys Bathroom / Main Office	Flush180	10-MAY-23	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F13					
51347	51347-1-HAL-F13	Near Boys Bathroom / Main Office	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F13	Near Boys Bathroom / Main Office	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F13	Near Boys Bathroom / Main Office	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F14	Near Boys Bathroom / Main Office	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F14	Near Boys Bathroom / Main Office	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F14	Near Boys Bathroom / Main Office	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F14	Near Boys Bathroom / Main Office	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F15	Near Boys Bathroom / Main Office	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F15	Near Boys Bathroom / Main Office	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F15	Near Boys Bathroom / Main Office	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F15	Near Boys Bathroom / Main Office	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F16	Near Boys Bathroom / Main Office	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F16	Near Boys Bathroom / Main Office	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F16	Near Boys Bathroom / Main Office	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F16	Near Boys Bathroom / Main Office	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F17	Near Boys Bathroom / Main Office	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F17	Near Boys Bathroom / Main Office	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F17	Near Boys Bathroom / Main Office	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F17	Near Boys Bathroom / Main Office	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F18	Near Boys Bathroom / Main Office	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F18	Near Boys Bathroom / Main Office	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F18	Near Boys Bathroom / Main Office	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F18	Near Boys Bathroom / Main Office	Flush180	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F13	Near Boys Bathroom / Main Office	Initial	03-AUG-16	1.790	ppb
51347	51347-1-HAL-F13	Near Boys Bathroom / Main Office	Initial	10-NOV-16	0.820	ppb
51347	51347-1-HAL-F13	Near Boys Bathroom / Main Office	Initial	21-AUG-20	26.000	ug/L
51347	51347-1-HAL-F13	Near Boys Bathroom / Main Office	Initial	21-OCT-20	1.000	ug/L
51347	51347-1-HAL-F13	Near Boys Bathroom / Main Office	Initial	10-MAY-23	1.180	ug/L
51347	51347-1-HAL-F14	Near Boys Bathroom / Main Office	Initial	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F15	Near Boys Bathroom / Main Office	Initial	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F16	Near Boys Bathroom / Main Office	Initial	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F17	Near Boys Bathroom / Main Office	Initial	10-MAY-23	1.000	ug/L
51347	51347-1-HAL-F18	Near Boys Bathroom / Main Office	Initial	10-MAY-23	1.000	ug/L
51347	51347-2-HAL-F05	Next to Boys Restroom Outside Gym	Flush180	04-JUN-16	1.000	ppb
51347	51347-2-HAL-F05	Next to Boys Restroom Outside Gym	Flush180	04-JUN-16	1.000	ppb
51347	51347-2-HAL-F05	Next to Boys Restroom Outside Gym	Flush180	04-JUN-16	1.000	ppb
51347	51347-2-HAL-F05	Next to Boys Restroom Outside Gym	Flush180	04-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51347	51347-2-HAL-F05	Next to Boys Restroom Outside Gym	Flush180	04-JUN-16	1.000	ppb
51347	51347-2-HAL-F06	Next to Boys Restroom Outside Gym	Flush180	04-JUN-16	1.000	ppb
51347	51347-2-HAL-F06	Next to Boys Restroom Outside Gym	Flush180	04-JUN-16	1.000	ppb
51347	51347-2-HAL-F06	Next to Boys Restroom Outside Gym	Flush180	04-JUN-16	1.000	ppb
51347	51347-2-HAL-F06	Next to Boys Restroom Outside Gym	Flush180	04-JUN-16	1.000	ppb
51347	51347-2-HAL-F06	Next to Boys Restroom Outside Gym	Flush180	04-JUN-16	1.000	ppb
51347	51347-2-HAL-F05	Next to Boys Restroom Outside Gym	Flush180	10-MAY-23	1.000	ug/L
51347	51347-2-HAL-F05	Next to Boys Restroom Outside Gym	Flush180	10-MAY-23	1.000	ug/L
51347	51347-2-HAL-F05	Next to Boys Restroom Outside Gym	Flush180	10-MAY-23	1.000	ug/L
51347	51347-2-HAL-F05	Next to Boys Restroom Outside Gym	Flush180	10-MAY-23	1.000	ug/L
51347	51347-2-HAL-F06	Next to Boys Restroom Outside Gym	Flush180	10-MAY-23	1.000	ug/L
51347	51347-2-HAL-F06	Next to Boys Restroom Outside Gym	Flush180	10-MAY-23	1.000	ug/L
51347	51347-2-HAL-F06	Next to Boys Restroom Outside Gym	Flush180	10-MAY-23	1.000	ug/L
51347	51347-2-HAL-F06	Next to Boys Restroom Outside Gym	Flush180	10-MAY-23	1.000	ug/L
51347	51347-2-HAL-F06	Next to Boys Restroom Outside Gym	Flush180	10-MAY-23	1.000	ug/L
51347	51347-2-HAL-F06	Next to Boys Restroom Outside Gym	Flush180	10-MAY-23	1.000	ug/L
51347	51347-2-HAL-F05	Next to Boys Restroom Outside Gym	Initial	10-MAY-23	1.000	ug/L
51347	51347-2-HAL-F06	Next to Boys Restroom Outside Gym	Initial	10-MAY-23	1.000	ug/L
51347	51347-1-110-F01	Room 110	Flush180	21-JUN-23	1.000	ug/L
51347	51347-1-110-F01	Room 110	Flush180	21-JUN-23	1.000	ug/L
51347	51347-1-110-F01	Room 110	Flush180	21-JUN-23	1.000	ug/L
51347	51347-1-110-F01	Room 110	Flush180	21-JUN-23	1.000	ug/L
51347	51347-1-110-S01	Room 110	Flush180	21-JUN-23	2.000	ug/L
51347	51347-1-110-S01	Room 110	Flush180	21-JUN-23	1.000	ug/L
51347	51347-1-110-S01	Room 110	Flush180	21-JUN-23	1.000	ug/L
51347	51347-1-110-S01	Room 110	Flush180	21-JUN-23	1.000	ug/L
51347	51347-1-110-F01	Room 110	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-110-F01	Room 110	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-110-F01	Room 110	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-110-F01	Room 110	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-110-S01	Room 110	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-110-S01	Room 110	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-110-S01	Room 110	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-110-F01	Room 110	Flush180	04-JUN-16	1.000	ppb
51347	51347-1-110-S01	Room 110	Flush180	10-MAY-23	21.200	ug/L
51347	51347-1-110-S01	Room 110	Flush180	10-MAY-23	12.400	ug/L
51347	51347-1-110-S01	Room 110	Flush180	10-MAY-23	18.800	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51347	51347-1-110-S01	Room 110	Flush180	10-MAY-23	16.600	ug/L
51347	51347-1-110-F01	Room 110	Flush180	10-MAY-23	2.420	ug/L
51347	51347-1-110-F01	Room 110	Flush180	10-MAY-23	1.860	ug/L
51347	51347-1-110-F01	Room 110	Flush180	10-MAY-23	1.610	ug/L
51347	51347-1-110-F01	Room 110	Flush180	10-MAY-23	1.270	ug/L
51347	51347-1-110-F01	Room 110	Initial	21-JUN-23	1.000	ug/L
51347	51347-1-110-S01	Room 110	Initial	21-JUN-23	1.000	ug/L
51347	51347-1-110-S01	Room 110	Initial	10-MAY-23	89.000	ug/L
51347	51347-1-110-F01	Room 110	Initial	10-MAY-23	5.600	ug/L
51347	51347-2-HAL-F02	Room 202 and 203	Flush180	04-JUN-16	1.000	ppb
51347	51347-2-HAL-F02	Room 202 and 203	Flush180	04-JUN-16	1.000	ppb
51347	51347-2-HAL-F02	Room 202 and 203	Flush180	04-JUN-16	1.000	ppb
51347	51347-2-HAL-F02	Room 202 and 203	Flush180	04-JUN-16	1.000	ppb
51347	51347-2-HAL-F02	Room 202 and 203	Flush180	04-JUN-16	1.000	ppb
51347	51347-2-HAL-F02	Room 202 and 203	Flush180	10-MAY-23	1.590	ug/L
51347	51347-2-HAL-F02	Room 202 and 203	Flush180	10-MAY-23	1.000	ug/L
51347	51347-2-HAL-F02	Room 202 and 203	Flush180	10-MAY-23	1.000	ug/L
51347	51347-2-HAL-F02	Room 202 and 203	Flush180	10-MAY-23	1.000	ug/L
51347	51347-2-HAL-F02	Room 202 and 203	Initial	10-MAY-23	1.480	ug/L