



Sep 10, 2024

BYRNE

5329 S OAK PARK AVE, Chicago IL 60638.

Dear **BYRNE** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

BYRNE

5329 S OAK PARK AVE, Chicago IL 60638.

Estimadas familias de **BYRNE**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51289	51289-1-KIT-KS02	Main- Kitchen, North Wall, Center Faucet	Flush180	20-SEP-16	1.020	ppb
51289	51289-1-KIT-KS02	Main- Kitchen, North Wall, Center Faucet	Flush180	20-SEP-16	0.921	ppb
51289	51289-1-KIT-KS02	Main- Kitchen, North Wall, Center Faucet	Flush180	20-SEP-16	0.769	ppb
51289	51289-1-KIT-KS02	Main- Kitchen, North Wall, Center Faucet	Flush180	20-SEP-16	1.420	ppb
51289	51289-1-KIT-KS02	Main- Kitchen, North Wall, Center Faucet	Flush180	26-SEP-19	1.000	ug/L
51289	51289-1-KIT-KS02	Main- Kitchen, North Wall, Center Faucet	Flush180	26-SEP-19	1.000	ug/L
51289	51289-1-KIT-KS02	Main- Kitchen, North Wall, Center Faucet	Flush180	26-SEP-19	1.000	ug/L
51289	51289-1-KIT-KS02	Main- Kitchen, North Wall, Center Faucet	Flush180	26-SEP-19	1.000	ug/L
51289	51289-1-KIT-KS02	Main- Kitchen, North Wall, Center Faucet	Flush180	22-JUL-20	1.000	ug/L
51289	51289-1-KIT-KS02	Main- Kitchen, North Wall, Center Faucet	Initial	20-SEP-16	1.690	ppb
51289	51289-1-KIT-KS02	Main- Kitchen, North Wall, Center Faucet	Initial	26-SEP-19	1.000	ug/L
51289	51289-1-KIT-KS02	Main- Kitchen, North Wall, Center Faucet	Initial	22-JUL-20	1.000	ug/L
51289	51289-1-KIT-KS01	Main- Kitchen, North Wall, Left Faucet	Flush180	20-SEP-16	1.510	ppb
51289	51289-1-KIT-KS01	Main- Kitchen, North Wall, Left Faucet	Flush180	20-SEP-16	2.000	ppb
51289	51289-1-KIT-KS01	Main- Kitchen, North Wall, Left Faucet	Flush180	20-SEP-16	2.010	ppb
51289	51289-1-KIT-KS01	Main- Kitchen, North Wall, Left Faucet	Flush180	20-SEP-16	2.190	ppb
51289	51289-1-KIT-KS01	Main- Kitchen, North Wall, Left Faucet	Flush180	26-SEP-19	1.000	ug/L
51289	51289-1-KIT-KS01	Main- Kitchen, North Wall, Left Faucet	Flush180	26-SEP-19	1.000	ug/L
51289	51289-1-KIT-KS01	Main- Kitchen, North Wall, Left Faucet	Flush180	26-SEP-19	1.000	ug/L
51289	51289-1-KIT-KS01	Main- Kitchen, North Wall, Left Faucet	Flush180	26-SEP-19	1.000	ug/L
51289	51289-1-KIT-KS01	Main- Kitchen, North Wall, Left Faucet	Initial	20-SEP-16	2.330	ppb
51289	51289-1-KIT-KS01	Main- Kitchen, North Wall, Left Faucet	Initial	26-SEP-19	1.000	ug/L
51289	51289-1-KIT-KS03	Main- Kitchen, North Wall,Right Faucet	Flush180	20-SEP-16	1.610	ppb
51289	51289-1-KIT-KS03	Main- Kitchen, North Wall,Right Faucet	Flush180	20-SEP-16	1.830	ppb
51289	51289-1-KIT-KS03	Main- Kitchen, North Wall,Right Faucet	Flush180	20-SEP-16	1.950	ppb
51289	51289-1-KIT-KS03	Main- Kitchen, North Wall,Right Faucet	Flush180	20-SEP-16	1.760	ppb
51289	51289-1-KIT-KS03	Main- Kitchen, North Wall,Right Faucet	Flush180	26-SEP-19	1.000	ug/L
51289	51289-1-KIT-KS03	Main- Kitchen, North Wall,Right Faucet	Flush180	26-SEP-19	1.000	ug/L
51289	51289-1-KIT-KS03	Main- Kitchen, North Wall,Right Faucet	Flush180	26-SEP-19	1.000	ug/L
51289	51289-1-KIT-KS03	Main- Kitchen, North Wall,Right Faucet	Initial	20-SEP-16	2.480	ppb
51289	51289-1-KIT-KS03	Main- Kitchen, North Wall,Right Faucet	Initial	26-SEP-19	1.000	ug/L
51289	51289-1-HAL-F05	Main- Outside Room 105, Left Fountain	Flush180	20-SEP-16	0.309	ppb
51289	51289-1-HAL-F05	Main- Outside Room 105, Left Fountain	Flush180	20-SEP-16	0.284	ppb
51289	51289-1-HAL-F05	Main- Outside Room 105, Left Fountain	Flush180	20-SEP-16	0.285	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51289	51289-1-HAL-F05	Main- Outside Room 105, Left Fountain	Flush180	20-SEP-16	0.310	ppb
51289	51289-1-HAL-F05	Main- Outside Room 105, Left Fountain	Flush180	26-SEP-19	1.000	ug/L
51289	51289-1-HAL-F05	Main- Outside Room 105, Left Fountain	Flush180	26-SEP-19	1.000	ug/L
51289	51289-1-HAL-F05	Main- Outside Room 105, Left Fountain	Flush180	26-SEP-19	1.000	ug/L
51289	51289-1-HAL-F05	Main- Outside Room 105, Left Fountain	Flush180	26-SEP-19	1.000	ug/L
51289	51289-1-HAL-F05	Main- Outside Room 105, Left Fountain	Initial	20-SEP-16	0.322	ppb
51289	51289-1-HAL-F05	Main- Outside Room 105, Left Fountain	Initial	26-SEP-19	1.000	ug/L
51289	51289-1-HAL-F04	Main- Outside Room 105, Right Fountain	Flush180	20-SEP-16	0.331	ppb
51289	51289-1-HAL-F04	Main- Outside Room 105, Right Fountain	Flush180	20-SEP-16	0.360	ppb
51289	51289-1-HAL-F04	Main- Outside Room 105, Right Fountain	Flush180	20-SEP-16	0.315	ppb
51289	51289-1-HAL-F04	Main- Outside Room 105, Right Fountain	Flush180	20-SEP-16	0.359	ppb
51289	51289-1-HAL-F04	Main- Outside Room 105, Right Fountain	Flush180	26-SEP-19	1.000	ug/L
51289	51289-1-HAL-F04	Main- Outside Room 105, Right Fountain	Flush180	26-SEP-19	1.000	ug/L
51289	51289-1-HAL-F04	Main- Outside Room 105, Right Fountain	Flush180	26-SEP-19	1.000	ug/L
51289	51289-1-HAL-F04	Main- Outside Room 105, Right Fountain	Flush180	05-MAY-23	1.000	ug/L
51289	51289-1-HAL-F04	Main- Outside Room 105, Right Fountain	Initial	20-SEP-16	0.313	ppb
51289	51289-1-HAL-F04	Main- Outside Room 105, Right Fountain	Initial	26-SEP-19	1.000	ug/L
51289	51289-1-HAL-F04	Main- Outside Room 105, Right Fountain	Initial	05-MAY-23	1.000	ug/L
51289	51289-1-HAL-F07	Main- Outside Room 113, Left Fountain	Flush180	20-SEP-16	0.871	ppb
51289	51289-1-HAL-F07	Main- Outside Room 113, Left Fountain	Flush180	20-SEP-16	0.883	ppb
51289	51289-1-HAL-F07	Main- Outside Room 113, Left Fountain	Flush180	20-SEP-16	0.888	ppb
51289	51289-1-HAL-F07	Main- Outside Room 113, Left Fountain	Flush180	20-SEP-16	0.862	ppb
51289	51289-1-HAL-F07	Main- Outside Room 113, Left Fountain	Flush180	26-SEP-19	1.000	ug/L
51289	51289-1-HAL-F07	Main- Outside Room 113, Left Fountain	Flush180	26-SEP-19	1.000	ug/L
51289	51289-1-HAL-F07	Main- Outside Room 113, Left Fountain	Flush180	26-SEP-19	1.000	ug/L
51289	51289-1-HAL-F07	Main- Outside Room 113, Left Fountain	Flush180	22-JUL-20	1.000	ug/L
51289	51289-1-HAL-F07	Main- Outside Room 113, Left Fountain	Initial	20-SEP-16	0.618	ppb
51289	51289-1-HAL-F07	Main- Outside Room 113, Left Fountain	Initial	26-SEP-19	1.000	ug/L
51289	51289-1-HAL-F07	Main- Outside Room 113, Left Fountain	Initial	22-JUL-20	1.000	ug/L
51289	51289-1-HAL-F06	Main- Outside Room 113, Right Fountain	Flush180	20-SEP-16	1.130	ppb
51289	51289-1-HAL-F06	Main- Outside Room 113, Right Fountain	Flush180	20-SEP-16	1.050	ppb
51289	51289-1-HAL-F06	Main- Outside Room 113, Right Fountain	Flush180	20-SEP-16	0.975	ppb
51289	51289-1-HAL-F06	Main- Outside Room 113, Right Fountain	Flush180	20-SEP-16	1.100	ppb
51289	51289-1-HAL-F06	Main- Outside Room 113, Right Fountain	Flush180	26-SEP-19	1.000	ug/L
51289	51289-1-HAL-F06	Main- Outside Room 113, Right Fountain	Flush180	26-SEP-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51289	51289-1-HAL-F06	Main- Outside Room 113, Right Fountain	Flush180	26-SEP-19	1.000	ug/L
51289	51289-1-HAL-F06	Main- Outside Room 113, Right Fountain	Flush180	26-SEP-19	1.000	ug/L
51289	51289-1-HAL-F06	Main- Outside Room 113, Right Fountain	Initial	20-SEP-16	0.672	ppb
51289	51289-1-HAL-F06	Main- Outside Room 113, Right Fountain	Initial	26-SEP-19	1.000	ug/L
51289	51289-2-HAL-F02	Main- Outside Room 205, Left Fountain	Flush180	20-SEP-16	0.632	ppb
51289	51289-2-HAL-F02	Main- Outside Room 205, Left Fountain	Flush180	20-SEP-16	0.648	ppb
51289	51289-2-HAL-F02	Main- Outside Room 205, Left Fountain	Flush180	20-SEP-16	0.818	ppb
51289	51289-2-HAL-F02	Main- Outside Room 205, Left Fountain	Flush180	20-SEP-16	0.542	ppb
51289	51289-2-HAL-F02	Main- Outside Room 205, Left Fountain	Flush180	26-SEP-19	1.000	ug/L
51289	51289-2-HAL-F02	Main- Outside Room 205, Left Fountain	Flush180	26-SEP-19	1.000	ug/L
51289	51289-2-HAL-F02	Main- Outside Room 205, Left Fountain	Flush180	26-SEP-19	1.000	ug/L
51289	51289-2-HAL-F02	Main- Outside Room 205, Left Fountain	Flush180	26-SEP-19	1.000	ug/L
51289	51289-2-HAL-F02	Main- Outside Room 205, Left Fountain	Initial	20-SEP-16	0.526	ppb
51289	51289-2-HAL-F02	Main- Outside Room 205, Left Fountain	Initial	26-SEP-19	1.000	ug/L
51289	51289-2-HAL-F01	Main- Outside Room 205, Right Fountain	Flush180	20-SEP-16	1.070	ppb
51289	51289-2-HAL-F01	Main- Outside Room 205, Right Fountain	Flush180	20-SEP-16	0.969	ppb
51289	51289-2-HAL-F01	Main- Outside Room 205, Right Fountain	Flush180	20-SEP-16	1.140	ppb
51289	51289-2-HAL-F01	Main- Outside Room 205, Right Fountain	Flush180	20-SEP-16	1.350	ppb
51289	51289-2-HAL-F01	Main- Outside Room 205, Right Fountain	Flush180	26-SEP-19	1.000	ug/L
51289	51289-2-HAL-F01	Main- Outside Room 205, Right Fountain	Flush180	26-SEP-19	1.000	ug/L
51289	51289-2-HAL-F01	Main- Outside Room 205, Right Fountain	Flush180	26-SEP-19	1.000	ug/L
51289	51289-2-HAL-F01	Main- Outside Room 205, Right Fountain	Flush180	26-SEP-19	1.000	ug/L
51289	51289-2-HAL-F01	Main- Outside Room 205, Right Fountain	Initial	20-SEP-16	0.593	ppb
51289	51289-2-HAL-F01	Main- Outside Room 205, Right Fountain	Initial	26-SEP-19	1.000	ug/L
51289	51289-2-HAL-F04	Main- Outside Room 213, Left Fountain	Flush180	20-SEP-16	1.650	ppb
51289	51289-2-HAL-F04	Main- Outside Room 213, Left Fountain	Flush180	20-SEP-16	1.580	ppb
51289	51289-2-HAL-F04	Main- Outside Room 213, Left Fountain	Flush180	20-SEP-16	1.540	ppb
51289	51289-2-HAL-F04	Main- Outside Room 213, Left Fountain	Flush180	20-SEP-16	1.570	ppb
51289	51289-2-HAL-F04	Main- Outside Room 213, Left Fountain	Flush180	26-SEP-19	1.000	ug/L
51289	51289-2-HAL-F04	Main- Outside Room 213, Left Fountain	Flush180	26-SEP-19	1.000	ug/L
51289	51289-2-HAL-F04	Main- Outside Room 213, Left Fountain	Flush180	26-SEP-19	1.000	ug/L
51289	51289-2-HAL-F04	Main- Outside Room 213, Left Fountain	Flush180	26-SEP-19	1.000	ug/L
51289	51289-2-HAL-F04	Main- Outside Room 213, Left Fountain	Initial	20-SEP-16	1.660	ppb
51289	51289-2-HAL-F04	Main- Outside Room 213, Left Fountain	Initial	26-SEP-19	1.000	ug/L
51289	51289-2-HAL-F04	Main- Outside Room 213, Left Fountain	Initial	05-MAY-23	1.000	ug/L
51289	51289-2-HAL-F03	Main- Outside Room 213, Right Fountain	Flush180	20-SEP-16	1.840	ppb
51289	51289-2-HAL-	Main- Outside Room 213, Right	Flush180	20-SEP-16	1.480	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F03	Fountain				
51289	51289-2-HAL-F03	Main- Outside Room 213, Right Fountain	Flush180	20-SEP-16	1.750	ppb
51289	51289-2-HAL-F03	Main- Outside Room 213, Right Fountain	Flush180	20-SEP-16	1.920	ppb
51289	51289-2-HAL-F03	Main- Outside Room 213, Right Fountain	Flush180	26-SEP-19	1.000	ug/L
51289	51289-2-HAL-F03	Main- Outside Room 213, Right Fountain	Flush180	26-SEP-19	1.000	ug/L
51289	51289-2-HAL-F03	Main- Outside Room 213, Right Fountain	Flush180	26-SEP-19	1.000	ug/L
51289	51289-2-HAL-F03	Main- Outside Room 213, Right Fountain	Flush180	26-SEP-19	1.000	ug/L
51289	51289-2-HAL-F03	Main- Outside Room 213, Right Fountain	Initial	20-SEP-16	1.430	ppb
51289	51289-2-HAL-F03	Main- Outside Room 213, Right Fountain	Initial	26-SEP-19	1.000	ug/L
51289	51289-1-HAL-S08	Main- Teachers Lounge Room 114, Sink	Flush180	20-SEP-16	2.770	ppb
51289	51289-1-HAL-S08	Main- Teachers Lounge Room 114, Sink	Flush180	20-SEP-16	4.360	ppb
51289	51289-1-HAL-S08	Main- Teachers Lounge Room 114, Sink	Flush180	20-SEP-16	2.560	ppb
51289	51289-1-HAL-S08	Main- Teachers Lounge Room 114, Sink	Flush180	20-SEP-16	3.800	ppb
51289	51289-1-HAL-S08	Main- Teachers Lounge Room 114, Sink	Flush180	26-SEP-19	1.340	ug/L
51289	51289-1-HAL-S08	Main- Teachers Lounge Room 114, Sink	Flush180	26-SEP-19	1.150	ug/L
51289	51289-1-HAL-S08	Main- Teachers Lounge Room 114, Sink	Flush180	26-SEP-19	1.160	ug/L
51289	51289-1-HAL-S08	Main- Teachers Lounge Room 114, Sink	Flush180	26-SEP-19	1.150	ug/L
51289	51289-1-HAL-S08	Main- Teachers Lounge Room 114, Sink	Initial	20-SEP-16	1.140	ppb
51289	51289-1-HAL-S08	Main- Teachers Lounge Room 114, Sink	Initial	26-SEP-19	1.000	ug/L