



Sep 10, 2024

CALMECA

3456 W 38th St, Chicago IL 60632.

Dear **CALMECA** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

CALMECA

3456 W 38th St, Chicago IL 60632.

Estimadas familias de **CALMECA**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51286	51286-1-118-S14	Main- Inside Kindergarten Room 118, Sink	Flush180	28-SEP-16	0.262	ppb
51286	51286-1-118-S14	Main- Inside Kindergarten Room 118, Sink	Flush180	28-SEP-16	0.321	ppb
51286	51286-1-118-S14	Main- Inside Kindergarten Room 118, Sink	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-118-S14	Main- Inside Kindergarten Room 118, Sink	Flush180	28-SEP-16	0.258	ppb
51286	51286-1-118-S14	Main- Inside Kindergarten Room 118, Sink	Initial	28-SEP-16	0.495	ppb
51286	51286-1-118-WC15	Main- Inside Kindergarten Room 118, Water Cooler	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-118-WC15	Main- Inside Kindergarten Room 118, Water Cooler	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-118-WC15	Main- Inside Kindergarten Room 118, Water Cooler	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-118-WC15	Main- Inside Kindergarten Room 118, Water Cooler	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-118-WC15	Main- Inside Kindergarten Room 118, Water Cooler	Initial	28-SEP-16	1.000	ppb
51286	51286-1-119-S16	Main- Inside Kindergarten Room 119, Sink	Flush180	28-SEP-16	0.306	ppb
51286	51286-1-119-S16	Main- Inside Kindergarten Room 119, Sink	Flush180	28-SEP-16	3.480	ppb
51286	51286-1-119-S16	Main- Inside Kindergarten Room 119, Sink	Flush180	28-SEP-16	1.050	ppb
51286	51286-1-119-S16	Main- Inside Kindergarten Room 119, Sink	Flush180	28-SEP-16	0.943	ppb
51286	51286-1-119-S16	Main- Inside Kindergarten Room 119, Sink	Initial	28-SEP-16	1.060	ppb
51286	51286-1-119-WC17	Main- Inside Kindergarten Room 119, Water Cooler	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-119-WC17	Main- Inside Kindergarten Room 119, Water Cooler	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-119-WC17	Main- Inside Kindergarten Room 119, Water Cooler	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-119-WC17	Main- Inside Kindergarten Room 119, Water Cooler	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-119-WC17	Main- Inside Kindergarten Room 119, Water Cooler	Initial	28-SEP-16	1.000	ppb
51286	51286-1-120-S10	Main- Inside Kindergarten Room 120, Sink	Flush180	28-SEP-16	0.290	ppb
51286	51286-1-120-S10	Main- Inside Kindergarten Room 120, Sink	Flush180	28-SEP-16	0.414	ppb
51286	51286-1-120-S10	Main- Inside Kindergarten Room 120, Sink	Flush180	28-SEP-16	0.448	ppb
51286	51286-1-120-S10	Main- Inside Kindergarten Room 120, Sink	Flush180	28-SEP-16	0.512	ppb
51286	51286-1-120-S10	Main- Inside Kindergarten Room 120, Sink	Initial	28-SEP-16	0.693	ppb
51286	51286-1-120-WC11	Main- Inside Kindergarten Room 120, Water Cooler	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-120-WC11	Main- Inside Kindergarten Room 120, Water Cooler	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-120-WC11	Main- Inside Kindergarten Room 120, Water Cooler	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-120-WC11	Main- Inside Kindergarten Room 120, Water Cooler	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-120-WC11	Main- Inside Kindergarten Room 120, Water Cooler	Initial	28-SEP-16	1.000	ppb
51286	51286-2-121-S12	Main- Inside Kindergarten Room 121, Sink	Flush180	28-SEP-16	0.316	ppb
51286	51286-2-121-S12	Main- Inside Kindergarten Room 121, Sink	Flush180	28-SEP-16	0.260	ppb
51286	51286-2-121-S12	Main- Inside Kindergarten Room 121, Sink	Flush180	28-SEP-16	0.542	ppb
51286	51286-2-121-S12	Main- Inside Kindergarten Room 121, Sink	Flush180	28-SEP-16	0.608	ppb
51286	51286-2-121-S12	Main- Inside Kindergarten Room 121, Sink	Initial	28-SEP-16	0.539	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51286	51286-1-121-WC13	Main- Inside Kindergarten Room 121, Water Cooler	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-121-WC13	Main- Inside Kindergarten Room 121, Water Cooler	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-121-WC13	Main- Inside Kindergarten Room 121, Water Cooler	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-121-WC13	Main- Inside Kindergarten Room 121, Water Cooler	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-121-WC13	Main- Inside Kindergarten Room 121, Water Cooler	Initial	28-SEP-16	1.000	ppb
51286	51286-1-122-S06	Main- Inside Kindergarten Room 122, Sink	Flush180	28-SEP-16	0.312	ppb
51286	51286-1-122-S06	Main- Inside Kindergarten Room 122, Sink	Flush180	28-SEP-16	0.435	ppb
51286	51286-1-122-S06	Main- Inside Kindergarten Room 122, Sink	Flush180	28-SEP-16	0.231	ppb
51286	51286-1-122-S06	Main- Inside Kindergarten Room 122, Sink	Flush180	28-SEP-16	0.547	ppb
51286	51286-1-122-S06	Main- Inside Kindergarten Room 122, Sink	Initial	28-SEP-16	0.479	ppb
51286	51286-1-122-WC07	Main- Inside Kindergarten Room 122, Water Cooler	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-122-WC07	Main- Inside Kindergarten Room 122, Water Cooler	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-122-WC07	Main- Inside Kindergarten Room 122, Water Cooler	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-122-WC07	Main- Inside Kindergarten Room 122, Water Cooler	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-122-WC07	Main- Inside Kindergarten Room 122, Water Cooler	Initial	28-SEP-16	1.000	ppb
51286	51286-1-123-S08	Main- Inside Kindergarten Room 123, Sink	Flush180	28-SEP-16	0.208	ppb
51286	51286-1-123-S08	Main- Inside Kindergarten Room 123, Sink	Flush180	28-SEP-16	0.197	ppb
51286	51286-1-123-S08	Main- Inside Kindergarten Room 123, Sink	Flush180	28-SEP-16	3.520	ppb
51286	51286-1-123-S08	Main- Inside Kindergarten Room 123, Sink	Flush180	28-SEP-16	0.175	ppb
51286	51286-1-123-S08	Main- Inside Kindergarten Room 123, Sink	Initial	28-SEP-16	0.314	ppb
51286	51286-1-123-WC09	Main- Inside Kindergarten Room 123, Water Cooler	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-123-WC09	Main- Inside Kindergarten Room 123, Water Cooler	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-123-WC09	Main- Inside Kindergarten Room 123, Water Cooler	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-123-WC09	Main- Inside Kindergarten Room 123, Water Cooler	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-123-WC09	Main- Inside Kindergarten Room 123, Water Cooler	Initial	28-SEP-16	1.000	ppb
51286	51286-1-KIT-KS01	Main- KitcheMain- Kitchen East Wall, Left Sink	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-KIT-KS01	Main- KitcheMain- Kitchen East Wall, Left Sink	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-KIT-KS01	Main- KitcheMain- Kitchen East Wall, Left Sink	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-KIT-KS01	Main- KitcheMain- Kitchen East Wall, Left Sink	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-KIT-KS01	Main- KitcheMain- Kitchen East Wall, Left Sink	Initial	28-SEP-16	0.391	ppb
51286	51286-1-KIT-KS02	Main- Kitchen East Wall, Right Sink	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-KIT-KS02	Main- Kitchen East Wall, Right Sink	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-KIT-KS02	Main- Kitchen East Wall, Right Sink	Flush180	28-SEP-16	2.620	ppb
51286	51286-1-KIT-KS02	Main- Kitchen East Wall, Right Sink	Initial	28-SEP-16	0.189	ppb
51286	51286-1-HAL-F19	Main-Outside Luncroom 107, Center Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-HAL-F19	Main-Outside Luncroom 107, Center Fountain	Flush180	28-SEP-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51286	51286-1-HAL-F19	Main-Outside Luncroom 107, Center Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-HAL-F19	Main-Outside Luncroom 107, Center Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-HAL-F19	Main-Outside Luncroom 107, Center Fountain	Flush180	28-JUL-20	1.000	ug/L
51286	51286-1-HAL-F19	Main-Outside Luncroom 107, Center Fountain	Initial	28-SEP-16	1.000	ppb
51286	51286-1-HAL-F19	Main-Outside Luncroom 107, Center Fountain	Initial	28-JUL-20	1.000	ug/L
51286	51286-1-HAL-F18	Main-Outside Luncroom 107, Left Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-HAL-F18	Main-Outside Luncroom 107, Left Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-HAL-F18	Main-Outside Luncroom 107, Left Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-HAL-F18	Main-Outside Luncroom 107, Left Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-HAL-F18	Main-Outside Luncroom 107, Left Fountain	Initial	28-SEP-16	1.000	ppb
51286	51286-1-HAL-F20	Main-Outside Luncroom 107, Right Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-HAL-F20	Main-Outside Luncroom 107, Right Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-HAL-F20	Main-Outside Luncroom 107, Right Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-HAL-F20	Main-Outside Luncroom 107, Right Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-HAL-F20	Main-Outside Luncroom 107, Right Fountain	Initial	28-SEP-16	1.000	ppb
51286	51286-1-HAL-F04	Main-Outside Room 126, Center Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-HAL-F04	Main-Outside Room 126, Center Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-HAL-F04	Main-Outside Room 126, Center Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-HAL-F04	Main-Outside Room 126, Center Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-HAL-F04	Main-Outside Room 126, Center Fountain	Initial	28-SEP-16	1.000	ppb
51286	51286-1-HAL-F03	Main-Outside Room 126, Left Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-HAL-F03	Main-Outside Room 126, Left Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-HAL-F03	Main-Outside Room 126, Left Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-HAL-F03	Main-Outside Room 126, Left Fountain	Initial	28-SEP-16	1.000	ppb
51286	51286-1-HAL-F05	Main-Outside Room 126, Right Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-HAL-F05	Main-Outside Room 126, Right Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-HAL-F05	Main-Outside Room 126, Right Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-1-HAL-F05	Main-Outside Room 126, Right Fountain	Initial	28-SEP-16	1.000	ppb
51286	51286-2-HAL-F05	Main-Outside Room 209, Center Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-2-HAL-F05	Main-Outside Room 209, Center Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-2-HAL-F05	Main-Outside Room 209, Center Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-2-HAL-F05	Main-Outside Room 209, Center Fountain	Initial	28-SEP-16	1.000	ppb
51286	51286-2-HAL-F04	Main-Outside Room 209, Left Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-2-HAL-F04	Main-Outside Room 209, Left Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-2-HAL-F04	Main-Outside Room 209, Left Fountain	Flush180	28-SEP-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F04	Fountain				
51286	51286-2-HAL-F04	Main-Outside Room 209, Left Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-2-HAL-F04	Main-Outside Room 209, Left Fountain	Initial	28-SEP-16	1.000	ppb
51286	51286-2-HAL-F06	Main-Outside Room 209, Right Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-2-HAL-F06	Main-Outside Room 209, Right Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-2-HAL-F06	Main-Outside Room 209, Right Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-2-HAL-F06	Main-Outside Room 209, Right Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-2-HAL-F06	Main-Outside Room 209, Right Fountain	Initial	28-SEP-16	1.000	ppb
51286	51286-2-HAL-F02	Main-Outside Room 228, Center Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-2-HAL-F02	Main-Outside Room 228, Center Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-2-HAL-F02	Main-Outside Room 228, Center Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-2-HAL-F02	Main-Outside Room 228, Center Fountain	Initial	28-SEP-16	1.000	ppb
51286	51286-2-HAL-F01	Main-Outside Room 228, Left Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-2-HAL-F01	Main-Outside Room 228, Left Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-2-HAL-F01	Main-Outside Room 228, Left Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-2-HAL-F01	Main-Outside Room 228, Left Fountain	Initial	28-SEP-16	1.000	ppb
51286	51286-3-HAL-F05	Main-Outside Room 309, Center Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-3-HAL-F05	Main-Outside Room 309, Center Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-3-HAL-F05	Main-Outside Room 309, Center Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-3-HAL-F05	Main-Outside Room 309, Center Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-3-HAL-F05	Main-Outside Room 309, Center Fountain	Initial	28-SEP-16	1.000	ppb
51286	51286-3-HAL-F04	Main-Outside Room 309, Left Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-3-HAL-F04	Main-Outside Room 309, Left Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-3-HAL-F04	Main-Outside Room 309, Left Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-3-HAL-F04	Main-Outside Room 309, Left Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-3-HAL-F04	Main-Outside Room 309, Left Fountain	Initial	28-SEP-16	1.000	ppb
51286	51286-3-HAL-F06	Main-Outside Room 309, Right Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-3-HAL-F06	Main-Outside Room 309, Right Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-3-HAL-F06	Main-Outside Room 309, Right Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-3-HAL-F06	Main-Outside Room 309, Right Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-3-HAL-F06	Main-Outside Room 309, Right Fountain	Initial	28-SEP-16	1.000	ppb
51286	51286-3-HAL-F02	Main-Outside Room 330, Center Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-3-HAL-F02	Main-Outside Room 330, Center Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-3-HAL-F02	Main-Outside Room 330, Center Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-3-HAL-F02	Main-Outside Room 330, Center Fountain	Initial	28-SEP-16	1.000	ppb

**Water Quality Assessment
Calmecca Academy of Fine Arts and Dual Language**

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02	Fountain				
51286	51286-3-HAL-F01	Main-Outside Room 330, Left Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-3-HAL-F01	Main-Outside Room 330, Left Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-3-HAL-F01	Main-Outside Room 330, Left Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-3-HAL-F01	Main-Outside Room 330, Left Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-3-HAL-F01	Main-Outside Room 330, Left Fountain	Flush180	28-JUL-20	1.000	ug/L
51286	51286-3-HAL-F01	Main-Outside Room 330, Left Fountain	Initial	28-SEP-16	1.000	ppb
51286	51286-3-HAL-F01	Main-Outside Room 330, Left Fountain	Initial	28-JUL-20	1.000	ug/L
51286	51286-3-HAL-F03	Main-Outside Room 330, Right Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-3-HAL-F03	Main-Outside Room 330, Right Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-3-HAL-F03	Main-Outside Room 330, Right Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-3-HAL-F03	Main-Outside Room 330, Right Fountain	Flush180	28-SEP-16	1.000	ppb
51286	51286-3-HAL-F03	Main-Outside Room 330, Right Fountain	Initial	28-SEP-16	1.000	ppb