



Sep 10, 2024

CANTY

3740 N PANAMA AVE, Chicago IL 60634.

Dear **CANTY** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

CANTY

3740 N PANAMA AVE, Chicago IL 60634.

Estimadas familias de **CANTY**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51005	51005-2-HAL-F01	Across mechanical room	Flush180	13-SEP-16	0.180	ppb
51005	51005-2-HAL-F01	Across mechanical room	Flush180	13-SEP-16	0.190	ppb
51005	51005-2-HAL-F01	Across mechanical room	Flush180	13-SEP-16	0.180	ppb
51005	51005-2-HAL-F01	Across mechanical room	Flush180	13-SEP-16	0.210	ppb
51005	51005-2-HAL-F01	Across mechanical room	Initial	13-SEP-16	0.530	ppb
51005	51005-2-HAL-NE-F01	East Hallway-N End Left	Flush180	13-SEP-16	0.190	ppb
51005	51005-1-HAL-NE-F01	East Hallway-N End Left	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-HAL-NE-F01	East Hallway-N End Left	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-HAL-NE-F01	East Hallway-N End Left	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-HAL-NE-F01	East Hallway-N End Left	Flush180	13-SEP-16	1.000	ppb
51005	51005-2-HAL-NE-F01	East Hallway-N End Left	Flush180	13-SEP-16	0.180	ppb
51005	51005-2-HAL-NE-F01	East Hallway-N End Left	Flush180	13-SEP-16	0.160	ppb
51005	51005-2-HAL-NE-F01	East Hallway-N End Left	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-HAL-NE-F01	East Hallway-N End Left	Initial	13-SEP-16	0.170	ppb
51005	51005-2-HAL-NE-F01	East Hallway-N End Left	Initial	13-SEP-16	0.190	ppb
51005	51005-2-HAL-NE-F02	East Hallway-N End Right	Flush180	13-SEP-16	1.000	ppb
51005	51005-2-HAL-NE-F02	East Hallway-N End Right	Flush180	13-SEP-16	1.000	ppb
51005	51005-2-HAL-NE-F02	East Hallway-N End Right	Flush180	13-SEP-16	1.000	ppb
51005	51005-2-HAL-NE-F02	East Hallway-N End Right	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-HAL-NE-F02	East Hallway-N End Right	Flush180	13-SEP-16	0.210	ppb
51005	51005-1-HAL-NE-F02	East Hallway-N End Right	Flush180	13-SEP-16	0.190	ppb
51005	51005-1-HAL-NE-F02	East Hallway-N End Right	Flush180	13-SEP-16	0.190	ppb
51005	51005-1-HAL-NE-F02	East Hallway-N End Right	Flush180	13-SEP-16	0.220	ppb
51005	51005-2-HAL-NE-F02	East Hallway-N End Right	Initial	13-SEP-16	0.210	ppb
51005	51005-1-HAL-NE-F02	East Hallway-N End Right	Initial	13-SEP-16	0.300	ppb
51005	51005-2-HAL-SE-F01	East Hallway-S End Left	Flush180	13-SEP-16	0.350	ppb
51005	51005-2-HAL-SE-F01	East Hallway-S End Left	Flush180	13-SEP-16	0.350	ppb
51005	51005-2-HAL-SE-F01	East Hallway-S End Left	Flush180	13-SEP-16	0.360	ppb
51005	51005-2-HAL-SE-F01	East Hallway-S End Left	Flush180	13-SEP-16	0.360	ppb
51005	51005-2-HAL-SE-F01	East Hallway-S End Left	Initial	13-SEP-16	0.520	ppb
51005	51005-2-E-HAL-SE-F02	East Hallway-S End Right	Flush180	24-JUL-20	2.310	ug/L
51005	51005-2-E-HAL-SE-F02	East Hallway-S End Right	Flush180	02-MAR-21	1.000	ug/L
51005	51005-2-E-HAL-SE-F02	East Hallway-S End Right	Flush180	02-MAR-21	1.000	ug/L
51005	51005-2-E-HAL-SE-F02	East Hallway-S End Right	Flush180	02-MAR-21	1.000	ug/L
51005	51005-2-E-HAL-SE-F02	East Hallway-S End Right	Flush180	02-MAR-21	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51005	51005-2-E-HAL-SE-F02	East Hallway-S End Right	Flush180	13-SEP-16	0.380	ppb
51005	51005-2-E-HAL-SE-F02	East Hallway-S End Right	Flush180	13-SEP-16	0.450	ppb
51005	51005-2-E-HAL-SE-F02	East Hallway-S End Right	Flush180	13-SEP-16	0.350	ppb
51005	51005-2-E-HAL-SE-F02	East Hallway-S End Right	Flush180	13-SEP-16	0.340	ppb
51005	51005-2-E-HAL-SE-F02	East Hallway-S End Right	Initial	24-JUL-20	7.040	ug/L
51005	51005-2-E-HAL-SE-F02	East Hallway-S End Right	Initial	02-MAR-21	1.000	ug/L
51005	51005-2-E-HAL-SE-F02	East Hallway-S End Right	Initial	13-SEP-16	0.640	ppb
51005	51005-1-N-HAL-F01	Hall outside Bathroom Left	Flush180	13-SEP-16	0.250	ppb
51005	51005-1-N-HAL-F01	Hall outside Bathroom Left	Flush180	13-SEP-16	0.270	ppb
51005	51005-1-N-HAL-F01	Hall outside Bathroom Left	Flush180	13-SEP-16	0.270	ppb
51005	51005-1-N-HAL-F01	Hall outside Bathroom Left	Flush180	13-SEP-16	0.230	ppb
51005	51005-1-N-HAL-F01	Hall outside Bathroom Left	Flush180	24-JUL-20	1.000	ug/L
51005	51005-1-N-HAL-F01	Hall outside Bathroom Left	Flush180	10-SEP-20	1.000	ug/L
51005	51005-1-N-HAL-F01	Hall outside Bathroom Left	Flush180	10-SEP-20	1.000	ug/L
51005	51005-1-N-HAL-F01	Hall outside Bathroom Left	Flush180	10-SEP-20	1.000	ug/L
51005	51005-1-N-HAL-F01	Hall outside Bathroom Left	Flush180	10-SEP-20	1.000	ug/L
51005	51005-1-N-HAL-F01	Hall outside Bathroom Left	Initial	13-SEP-16	0.350	ppb
51005	51005-1-N-HAL-F01	Hall outside Bathroom Left	Initial	24-JUL-20	1.460	ug/L
51005	51005-1-N-HAL-F01	Hall outside Bathroom Left	Initial	10-SEP-20	1.000	ug/L
51005	51005-1-HAL-F02	Hall outside Bathroom Middle	Flush180	13-SEP-16	0.350	ppb
51005	51005-1-HAL-F02	Hall outside Bathroom Middle	Flush180	13-SEP-16	0.360	ppb
51005	51005-1-HAL-F02	Hall outside Bathroom Middle	Flush180	13-SEP-16	0.340	ppb
51005	51005-1-HAL-F02	Hall outside Bathroom Middle	Flush180	13-SEP-16	0.370	ppb
51005	51005-1-HAL-F02	Hall outside Bathroom Middle	Initial	13-SEP-16	0.600	ppb
51005	51005-1-HAL-F03	Hall outside Bathroom Right	Flush180	13-SEP-16	0.270	ppb
51005	51005-1-HAL-F03	Hall outside Bathroom Right	Flush180	13-SEP-16	0.190	ppb
51005	51005-1-HAL-F03	Hall outside Bathroom Right	Flush180	13-SEP-16	0.200	ppb
51005	51005-1-HAL-F03	Hall outside Bathroom Right	Flush180	13-SEP-16	0.470	ppb
51005	51005-1-HAL-F03	Hall outside Bathroom Right	Initial	13-SEP-16	0.490	ppb
51005	51005-1-KIT-S02	Kitchen Center Island	Flush180	13-SEP-16	0.730	ppb
51005	51005-1-KIT-S02	Kitchen Center Island	Flush180	13-SEP-16	1.100	ppb
51005	51005-1-KIT-S02	Kitchen Center Island	Flush180	13-SEP-16	1.200	ppb
51005	51005-1-KIT-S02	Kitchen Center Island	Flush180	13-SEP-16	0.960	ppb
51005	51005-1-KIT-S02	Kitchen Center Island	Initial	13-SEP-16	1.600	ppb
51005	51005-1-E-KIT-S01	Kitchen South Wall	Flush180	24-JUL-20	1.000	ug/L
51005	51005-1-E-KIT-S01	Kitchen South Wall	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-E-KIT-S01	Kitchen South Wall	Flush180	13-SEP-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51005	51005-1-E-KIT-S01	Kitchen South Wall	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-E-KIT-S01	Kitchen South Wall	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-E-KIT-S01	Kitchen South Wall	Initial	13-SEP-16	0.160	ppb
51005	51005-1-E-KIT-S01	Kitchen South Wall	Initial	24-JUL-20	1.000	ug/L
51005	51005-1-121-WC01	Lunchroom	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-121-WC01	Lunchroom	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-121-WC01	Lunchroom	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-121-WC01	Lunchroom	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-121-WC01	Lunchroom	Initial	13-SEP-16	0.170	ppb
51005	51005-1-121-WC02	Lunchroom-closest to wall	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-121-WC02	Lunchroom-closest to wall	Flush180	13-SEP-16	0.160	ppb
51005	51005-1-121-WC02	Lunchroom-closest to wall	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-121-WC02	Lunchroom-closest to wall	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-121-WC02	Lunchroom-closest to wall	Initial	13-SEP-16	1.000	ppb
51005	51005-2-W-HAL-F02	Middle in set of three Fountains by Bathrooms	Flush180	24-JUL-20	1.000	ug/L
51005	51005-2-W-HAL-F02	Middle in set of three Fountains by Bathrooms	Flush180	13-SEP-16	1.000	ppb
51005	51005-2-W-HAL-F02	Middle in set of three Fountains by Bathrooms	Flush180	13-SEP-16	0.200	ppb
51005	51005-2-W-HAL-F02	Middle in set of three Fountains by Bathrooms	Flush180	13-SEP-16	0.200	ppb
51005	51005-2-W-HAL-F02	Middle in set of three Fountains by Bathrooms	Flush180	13-SEP-16	0.170	ppb
51005	51005-2-W-HAL-F02	Middle in set of three Fountains by Bathrooms	Initial	24-JUL-20	1.000	ug/L
51005	51005-2-W-HAL-F02	Middle in set of three Fountains by Bathrooms	Initial	13-SEP-16	0.400	ppb
51005	51005-2-HAL-F03	Nearest to Elevator	Flush180	13-SEP-16	0.230	ppb
51005	51005-2-HAL-F03	Nearest to Elevator	Flush180	13-SEP-16	1.000	ppb
51005	51005-2-HAL-F03	Nearest to Elevator	Flush180	13-SEP-16	0.170	ppb
51005	51005-2-HAL-F03	Nearest to Elevator	Flush180	13-SEP-16	0.170	ppb
51005	51005-2-HAL-F03	Nearest to Elevator	Initial	13-SEP-16	0.290	ppb
51005	51005-2-HAL-N-F01	North Hallway Left fountain	Flush180	13-SEP-16	0.580	ppb
51005	51005-1-HAL-N-F01	North Hallway Left fountain	Flush180	13-SEP-16	0.210	ppb
51005	51005-1-HAL-N-F01	North Hallway Left fountain	Flush180	13-SEP-16	0.180	ppb
51005	51005-2-HAL-N-F01	North Hallway Left fountain	Flush180	13-SEP-16	0.300	ppb
51005	51005-2-HAL-N-F01	North Hallway Left fountain	Flush180	13-SEP-16	0.290	ppb
51005	51005-1-HAL-N-F01	North Hallway Left fountain	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-HAL-N-F01	North Hallway Left fountain	Flush180	13-SEP-16	1.000	ppb
51005	51005-2-HAL-N-F01	North Hallway Left fountain	Flush180	13-SEP-16	0.450	ppb
51005	51005-1-HAL-N-F01	North Hallway Left fountain	Initial	13-SEP-16	0.300	ppb
51005	51005-2-HAL-N-F01	North Hallway Left fountain	Initial	13-SEP-16	0.770	ppb
51005	51005-1-HAL-N-F02	North Hallway Right Fountain	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-HAL-N-F02	North Hallway Right Fountain	Flush180	13-SEP-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	N-F02					
51005	51005-1-HAL-N-F02	North Hallway Right Fountain	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-HAL-N-F02	North Hallway Right Fountain	Flush180	13-SEP-16	1.000	ppb
51005	51005-2-HAL-N-F02	North Hallway Right Fountain	Flush180	13-SEP-16	0.420	ppb
51005	51005-2-HAL-N-F02	North Hallway Right Fountain	Flush180	13-SEP-16	0.220	ppb
51005	51005-2-HAL-N-F02	North Hallway Right Fountain	Flush180	13-SEP-16	0.600	ppb
51005	51005-2-HAL-N-F02	North Hallway Right Fountain	Flush180	13-SEP-16	0.280	ppb
51005	51005-1-HAL-N-F02	North Hallway Right Fountain	Initial	13-SEP-16	0.160	ppb
51005	51005-2-HAL-N-F02	North Hallway Right Fountain	Initial	13-SEP-16	0.510	ppb
51005	51005-1-HAL-SE-F01	Outside Assembly Hall	Flush180	13-SEP-16	0.620	ppb
51005	51005-1-HAL-SE-F01	Outside Assembly Hall	Flush180	13-SEP-16	0.560	ppb
51005	51005-1-HAL-SE-F01	Outside Assembly Hall	Flush180	13-SEP-16	0.430	ppb
51005	51005-1-HAL-SE-F01	Outside Assembly Hall	Flush180	13-SEP-16	0.490	ppb
51005	51005-1-HAL-SE-F01	Outside Assembly Hall	Initial	13-SEP-16	0.700	ppb
51005	51005-1-HAL-SE-F02	Outside Assembly Hall closest to Hal	Flush180	13-SEP-16	0.250	ppb
51005	51005-1-HAL-SE-F02	Outside Assembly Hall closest to Hal	Flush180	13-SEP-16	0.240	ppb
51005	51005-1-HAL-SE-F02	Outside Assembly Hall closest to Hal	Flush180	13-SEP-16	0.190	ppb
51005	51005-1-HAL-SE-F02	Outside Assembly Hall closest to Hal	Flush180	13-SEP-16	0.280	ppb
51005	51005-1-HAL-SE-F02	Outside Assembly Hall closest to Hal	Initial	13-SEP-16	0.240	ppb
51005	51005-1-101-S01	Room 101	Flush180	13-SEP-16	0.670	ppb
51005	51005-1-101-S01	Room 101	Flush180	13-SEP-16	0.600	ppb
51005	51005-1-101-S01	Room 101	Flush180	13-SEP-16	0.440	ppb
51005	51005-1-101-S01	Room 101	Flush180	13-SEP-16	0.490	ppb
51005	51005-1-101-S01	Room 101	Initial	13-SEP-16	1.600	ppb
51005	51005-1-125-S01	Room 125	Flush180	13-SEP-16	0.160	ppb
51005	51005-1-125-S01	Room 125	Flush180	13-SEP-16	0.230	ppb
51005	51005-1-125-S01	Room 125	Flush180	13-SEP-16	0.200	ppb
51005	51005-1-125-S01	Room 125	Flush180	13-SEP-16	0.180	ppb
51005	51005-1-125-S01	Room 125	Initial	13-SEP-16	0.510	ppb
51005	51005-1-125-F01	Room 125 Fountain	Flush180	13-SEP-16	0.490	ppb
51005	51005-1-125-F01	Room 125 Fountain	Flush180	13-SEP-16	0.530	ppb
51005	51005-1-125-F01	Room 125 Fountain	Flush180	13-SEP-16	0.400	ppb
51005	51005-1-125-F01	Room 125 Fountain	Flush180	13-SEP-16	0.540	ppb
51005	51005-1-125-F01	Room 125 Fountain	Initial	13-SEP-16	1.300	ppb
51005	51005-1-126-S01	Room 126	Flush180	13-SEP-16	0.230	ppb
51005	51005-1-126-S01	Room 126	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-126-S01	Room 126	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-126-S01	Room 126	Flush180	13-SEP-16	0.230	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S01					
51005	51005-1-126-S01	Room 126	Initial	13-SEP-16	0.380	ppb
51005	51005-1-126-F01	Room 126 Fountain	Flush180	13-SEP-16	0.220	ppb
51005	51005-1-126-F01	Room 126 Fountain	Flush180	13-SEP-16	0.190	ppb
51005	51005-1-126-F01	Room 126 Fountain	Flush180	13-SEP-16	0.310	ppb
51005	51005-1-126-F01	Room 126 Fountain	Flush180	13-SEP-16	0.300	ppb
51005	51005-1-126-F01	Room 126 Fountain	Initial	13-SEP-16	0.660	ppb
51005	51005-1-127-S01	Room 127	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-127-S01	Room 127	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-127-S01	Room 127	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-127-S01	Room 127	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-127-S01	Room 127	Initial	13-SEP-16	0.260	ppb
51005	51005-1-127-F01	Room 127 Fountain	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-127-F01	Room 127 Fountain	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-127-F01	Room 127 Fountain	Flush180	13-SEP-16	0.160	ppb
51005	51005-1-127-F01	Room 127 Fountain	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-127-F01	Room 127 Fountain	Initial	13-SEP-16	0.490	ppb
51005	51005-1-128-S01	Room 128	Flush180	13-SEP-16	0.240	ppb
51005	51005-1-128-S01	Room 128	Flush180	13-SEP-16	0.180	ppb
51005	51005-1-128-S01	Room 128	Flush180	13-SEP-16	0.240	ppb
51005	51005-1-128-S01	Room 128	Flush180	13-SEP-16	0.230	ppb
51005	51005-1-128-S01	Room 128	Initial	13-SEP-16	0.580	ppb
51005	51005-1-128-F01	Room 128 Fountain	Flush180	13-SEP-16	0.160	ppb
51005	51005-1-128-F01	Room 128 Fountain	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-128-F01	Room 128 Fountain	Flush180	13-SEP-16	0.170	ppb
51005	51005-1-128-F01	Room 128 Fountain	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-128-F01	Room 128 Fountain	Initial	13-SEP-16	0.310	ppb
51005	51005-1-129-S01	Room 129 Pre-k	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-129-S01	Room 129 Pre-k	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-129-S01	Room 129 Pre-k	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-129-S01	Room 129 Pre-k	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-129-S01	Room 129 Pre-k	Initial	13-SEP-16	0.290	ppb
51005	51005-1-129-F01	Room 129 Pre-k Fountain	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-129-F01	Room 129 Pre-k Fountain	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-129-F01	Room 129 Pre-k Fountain	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-129-F01	Room 129 Pre-k Fountain	Flush180	13-SEP-16	1.000	ppb
51005	51005-1-129-F01	Room 129 Pre-k Fountain	Initial	13-SEP-16	0.330	ppb
51005	51005-1-TL-S01	Teacher's Lounge	Flush180	13-SEP-16	1.100	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51005	51005-1-TL-S01	Teacher's Lounge	Flush180	13-SEP-16	1.200	ppb
51005	51005-1-TL-S01	Teacher's Lounge	Flush180	13-SEP-16	1.200	ppb
51005	51005-1-TL-S01	Teacher's Lounge	Flush180	13-SEP-16	1.200	ppb
51005	51005-1-TL-S01	Teacher's Lounge	Initial	13-SEP-16	2.000	ppb
54784	54784-1-HAL-F02	Hallway by main entrance	Flush180	13-SEP-16	0.200	ppb
54784	54784-1-HAL-F02	Hallway by main entrance	Flush180	13-SEP-16	0.190	ppb
54784	54784-1-HAL-F02	Hallway by main entrance	Flush180	13-SEP-16	0.170	ppb
54784	54784-1-HAL-F02	Hallway by main entrance	Flush180	13-SEP-16	0.180	ppb
54784	54784-1-HAL-F01	Hallway by main entrance	Flush180	13-SEP-16	0.230	ppb
54784	54784-1-HAL-F01	Hallway by main entrance	Flush180	13-SEP-16	0.220	ppb
54784	54784-1-HAL-F01	Hallway by main entrance	Flush180	13-SEP-16	0.240	ppb
54784	54784-1-HAL-F01	Hallway by main entrance	Flush180	13-SEP-16	0.210	ppb
54784	54784-1-HAL-F01	Hallway by main entrance	Initial	13-SEP-16	0.420	ppb
54784	54784-1-HAL-F02	Hallway by main entrance	Initial	13-SEP-16	0.250	ppb
54784	54784-1-301-S01	Room 301	Flush180	13-SEP-16	0.220	ppb
54784	54784-1-301-S01	Room 301	Flush180	13-SEP-16	0.230	ppb
54784	54784-1-301-S01	Room 301	Flush180	13-SEP-16	0.220	ppb
54784	54784-1-301-S01	Room 301	Flush180	13-SEP-16	0.240	ppb
54784	54784-1-301-S01	Room 301	Flush180	18-AUG-20	1.000	ug/L
54784	54784-1-301-S01	Room 301	Initial	13-SEP-16	0.250	ppb
54784	54784-1-301-S01	Room 301	Initial	18-AUG-20	1.000	ug/L
54784	54784-1-301-F01	Room 301 Fountain	Flush180	13-SEP-16	2.000	ppb
54784	54784-1-301-F01	Room 301 Fountain	Flush180	13-SEP-16	0.098	ppb
54784	54784-1-301-F01	Room 301 Fountain	Flush180	13-SEP-16	0.420	ppb
54784	54784-1-301-F01	Room 301 Fountain	Flush180	13-SEP-16	0.260	ppb
54784	54784-1-301-F01	Room 301 Fountain	Initial	13-SEP-16	0.160	ppb
54784	54784-1-302-S01	Room 302	Flush180	13-SEP-16	0.230	ppb
54784	54784-1-302-S01	Room 302	Flush180	13-SEP-16	0.220	ppb
54784	54784-1-302-S01	Room 302	Flush180	13-SEP-16	0.250	ppb
54784	54784-1-302-S01	Room 302	Flush180	13-SEP-16	0.250	ppb
54784	54784-1-302-S01	Room 302	Initial	13-SEP-16	0.270	ppb
54784	54784-1-302-F01	Room 302 Fountain	Flush180	13-SEP-16	0.250	ppb
54784	54784-1-302-F01	Room 302 Fountain	Flush180	13-SEP-16	0.180	ppb
54784	54784-1-302-F01	Room 302 Fountain	Flush180	13-SEP-16	0.310	ppb
54784	54784-1-302-F01	Room 302 Fountain	Flush180	13-SEP-16	0.240	ppb
54784	54784-1-302-F01	Room 302 Fountain	Initial	13-SEP-16	0.250	ppb
54784	54784-1-303-S01	Room 303	Flush180	13-SEP-16	0.250	ppb

**Water Quality Assessment
Arthur E Canty Elementary School**

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
54784	54784-1-303-S01	Room 303	Flush180	13-SEP-16	0.240	ppb
54784	54784-1-303-S01	Room 303	Flush180	13-SEP-16	0.240	ppb
54784	54784-1-303-S01	Room 303	Flush180	13-SEP-16	0.240	ppb
54784	54784-1-303-S01	Room 303	Initial	13-SEP-16	0.170	ppb
54784	54784-1-303-F01	Room 303 Fountain	Flush180	13-SEP-16	1.000	ppb
54784	54784-1-303-F01	Room 303 Fountain	Flush180	13-SEP-16	1.000	ppb
54784	54784-1-303-F01	Room 303 Fountain	Flush180	13-SEP-16	1.000	ppb
54784	54784-1-303-F01	Room 303 Fountain	Flush180	13-SEP-16	1.000	ppb
54784	54784-1-303-F01	Room 303 Fountain	Flush180	18-AUG-20	1.000	ug/L
54784	54784-1-303-F01	Room 303 Fountain	Initial	13-SEP-16	0.080	ppb
54784	54784-1-303-F01	Room 303 Fountain	Initial	18-AUG-20	1.000	ug/L