



**Sep 10, 2024**

**CARSON**

**5516 S MAPLEWOOD AVE, Chicago IL 60629.**

Dear **CARSON** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**CARSON**

**5516 S MAPLEWOOD AVE, Chicago IL 60629.**

Estimadas familias de **CARSON**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51317	51317-1-N-121-F01	1st Floor, ??? End, Room 121	Flush180	18-SEP-19	1.000	ug/L
51317	51317-1-N-121-F01	1st Floor, ??? End, Room 121	Flush180	18-SEP-19	1.000	ug/L
51317	51317-1-N-121-F01	1st Floor, ??? End, Room 121	Flush180	18-SEP-19	1.000	ug/L
51317	51317-1-N-121-F01	1st Floor, ??? End, Room 121	Flush180	18-SEP-19	1.000	ug/L
51317	51317-1-N-121-S01	1st Floor, ??? End, Room 121	Flush180	18-SEP-19	1.000	ug/L
51317	51317-1-N-121-S01	1st Floor, ??? End, Room 121	Flush180	18-SEP-19	1.000	ug/L
51317	51317-1-N-121-S01	1st Floor, ??? End, Room 121	Flush180	18-SEP-19	1.000	ug/L
51317	51317-1-N-121-S01	1st Floor, ??? End, Room 121	Flush180	18-SEP-19	1.000	ug/L
51317	51317-1-N-121-F01	1st Floor, ??? End, Room 121	Initial	18-SEP-19	1.000	ug/L
51317	51317-1-N-121-S01	1st Floor, ??? End, Room 121	Initial	18-SEP-19	1.000	ug/L
51317	51317-1-HAL-RBF01	Main - Between Girls & Boys Toilet across Cafeteria	Flush	17-JAN-2024	1.000	ug/L
51317	51317-1-HAL-RBF01	Main - Between Girls & Boys Toilet across Cafeteria	Flush	17-JAN-2024	1.000	ug/L
51317	51317-1-HAL-RBF01	Main - Between Girls & Boys Toilet across Cafeteria	Flush	17-JAN-2024	1.000	ug/L
51317	51317-1-HAL-RBF01	Main - Between Girls & Boys Toilet across Cafeteria	Flush	17-JAN-2024	1.000	ug/L
51317	51317-1-HAL-RBF01	Main - Between Girls & Boys Toilet across Cafeteria	Initial	17-JAN-2024	1.000	ug/L
51317	51317-1-HAL-F03	Main - Between Girls & Boys Toilet across Cafeteria	Flush	17-JAN-2024	1.000	ug/L
51317	51317-1-HAL-F03	Main - Between Girls & Boys Toilet across Cafeteria	Flush	17-JAN-2024	1.000	ug/L
51317	51317-1-HAL-F03	Main - Between Girls & Boys Toilet across Cafeteria	Flush	17-JAN-2024	1.000	ug/L
51317	51317-1-HAL-F03	Main - Between Girls & Boys Toilet across Cafeteria	Initial	17-JAN-2024	1.000	ug/L
51317	51317-1-KIT-KS04	Main - Cafeteria	Flush	17-JAN-2024	1.000	ug/L
51317	51317-1-KIT-KS04	Main - Cafeteria	Flush	17-JAN-2024	1.000	ug/L
51317	51317-1-KIT-KS04	Main - Cafeteria	Flush	17-JAN-2024	1.000	ug/L
51317	51317-1-KIT-KS04	Main - Cafeteria	Initial	17-JAN-2024	1.000	ug/L
51317	51317-2-HAL-BF01	Main - Near Room 207, Bottle Filler	Flush	17-JAN-2024	1.000	ug/L
51317	51317-2-HAL-BF01	Main - Near Room 207, Bottle Filler	Flush	17-JAN-2024	1.000	ug/L
51317	51317-2-HAL-BF01	Main - Near Room 207, Bottle Filler	Flush	17-JAN-2024	1.000	ug/L
51317	51317-2-HAL-BF01	Main - Near Room 207, Bottle Filler	Flush	17-JAN-2024	1.000	ug/L
51317	51317-2-HAL-BF01	Main - Near Room 207, Bottle Filler	Initial	17-JAN-2024	1.000	ug/L
51317	51317-2-HAL-F01	Main - Near Room 207, Fountain	Flush	17-JAN-2024	1.000	ug/L
51317	51317-2-HAL-F01	Main - Near Room 207, Fountain	Flush	17-JAN-2024	1.000	ug/L
51317	51317-2-HAL-F01	Main - Near Room 207, Fountain	Flush	17-JAN-2024	1.000	ug/L
51317	51317-2-HAL-F01	Main - Near Room 207, Fountain	Flush	17-JAN-2024	1.000	ug/L
51317	51317-2-HAL-F01	Main - Near Room 207, Fountain	Initial	17-JAN-2024	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51317	51317-3-HAL-BF01	Main - Near Room 307	Flush	17-JAN-2024	1.000	ug/L
51317	51317-3-HAL-BF01	Main - Near Room 307	Flush	17-JAN-2024	1.310	ug/L
51317	51317-3-HAL-BF01	Main - Near Room 307	Flush	17-JAN-2024	2.510	ug/L
51317	51317-3-HAL-BF01	Main - Near Room 307	Flush	17-JAN-2024	4.870	ug/L
51317	51317-3-HAL-BF01	Main - Near Room 307	Initial	17-JAN-2024	1.000	ug/L
51317	51317-1-HAL-BF01	Main - Outside Principles Office	Flush	17-JAN-2024	1.000	ug/L
51317	51317-1-HAL-BF01	Main - Outside Principles Office	Flush	17-JAN-2024	1.000	ug/L
51317	51317-1-HAL-BF01	Main - Outside Principles Office	Flush	17-JAN-2024	1.000	ug/L
51317	51317-1-HAL-BF01	Main - Outside Principles Office	Flush	17-JAN-2024	1.000	ug/L
51317	51317-1-HAL-BF01	Main - Outside Principles Office	Initial	17-JAN-2024	1.000	ug/L
51317	51317-1-HAL-F05	Main - Outside Principles Office, Left Fountain	Flush	17-JAN-2024	1.000	ug/L
51317	51317-1-HAL-F05	Main - Outside Principles Office, Left Fountain	Flush	17-JAN-2024	1.000	ug/L
51317	51317-1-HAL-F05	Main - Outside Principles Office, Left Fountain	Flush	17-JAN-2024	1.000	ug/L
51317	51317-1-HAL-F05	Main - Outside Principles Office, Left Fountain	Flush	17-JAN-2024	1.000	ug/L
51317	51317-1-HAL-F05	Main - Outside Principles Office, Left Fountain	Initial	17-JAN-2024	1.000	ug/L
51317	51317-1-HAL-F06	Main - Outside Principles Office, Right Fountain	Flush	17-JAN-2024	1.000	ug/L
51317	51317-1-HAL-F06	Main - Outside Principles Office, Right Fountain	Flush	17-JAN-2024	1.000	ug/L
51317	51317-1-HAL-F06	Main - Outside Principles Office, Right Fountain	Flush	17-JAN-2024	1.000	ug/L
51317	51317-1-HAL-F06	Main - Outside Principles Office, Right Fountain	Flush	17-JAN-2024	1.000	ug/L
51317	51317-1-HAL-F06	Main - Outside Principles Office, Right Fountain	Initial	17-JAN-2024	1.000	ug/L
51317	51317-1-HAL-F07	Main - South end of Hall next to Boys Toilet room	Flush	17-JAN-2024	1.000	ug/L
51317	51317-1-HAL-F07	Main - South end of Hall next to Boys Toilet room	Flush	17-JAN-2024	1.000	ug/L
51317	51317-1-HAL-F07	Main - South end of Hall next to Boys Toilet room	Flush	17-JAN-2024	1.040	ug/L
51317	51317-1-HAL-F07	Main - South end of Hall next to Boys Toilet room	Flush	17-JAN-2024	1.110	ug/L
51317	51317-1-HAL-F07	Main - South end of Hall next to Boys Toilet room	Initial	17-JAN-2024	1.000	ug/L
51317	51317-1-HAL-F03	Main- 1st Floor Outside Womens Washroom, Right Fou	Flush180	28-MAY-16	0.800	ppb
51317	51317-1-HAL-F03	Main- 1st Floor Outside Womens Washroom, Right Fou	Flush180	28-MAY-16	0.803	ppb
51317	51317-1-HAL-F03	Main- 1st Floor Outside Womens Washroom, Right Fou	Flush180	28-MAY-16	0.834	ppb
51317	51317-1-HAL-F03	Main- 1st Floor Outside Womens Washroom, Right Fou	Flush180	28-MAY-16	0.768	ppb
51317	51317-1-HAL-F03	Main- 1st Floor Outside Womens Washroom, Right Fou	Initial	28-MAY-16	1.050	ppb
51317	51317-1-KIT-KS04	Main- 1st floor Kitchen Cleaning, East Wall Sink	Flush180	28-MAY-16	0.885	ppb
51317	51317-1-KIT-KS04	Main- 1st floor Kitchen Cleaning, East Wall Sink	Flush180	28-MAY-16	0.942	ppb
51317	51317-1-KIT-KS04	Main- 1st floor Kitchen Cleaning, East Wall Sink	Flush180	28-MAY-16	1.070	ppb
51317	51317-1-KIT-KS04	Main- 1st floor Kitchen Cleaning, East Wall Sink	Flush180	28-MAY-16	0.810	ppb
51317	51317-1-KIT-KS04	Main- 1st floor Kitchen Cleaning, East Wall Sink	Flush180	06-AUG-20	1.150	ug/L
51317	51317-1-KIT-KS04	Main- 1st floor Kitchen Cleaning, East Wall Sink	Initial	28-MAY-16	0.884	ppb
51317	51317-1-KIT-KS04	Main- 1st floor Kitchen Cleaning, East Wall Sink	Initial	06-AUG-20	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51317	51317-1-KIT-KS05	Main- 1st floor Kitchen Cleaning, South Wall Sink	Flush180	28-MAY-16	1.970	ppb
51317	51317-1-KIT-KS05	Main- 1st floor Kitchen Cleaning, South Wall Sink	Flush180	28-MAY-16	1.540	ppb
51317	51317-1-KIT-KS05	Main- 1st floor Kitchen Cleaning, South Wall Sink	Flush180	28-MAY-16	3.990	ppb
51317	51317-1-KIT-KS05	Main- 1st floor Kitchen Cleaning, South Wall Sink	Flush180	28-MAY-16	2.630	ppb
51317	51317-1-KIT-KS05	Main- 1st floor Kitchen Cleaning, South Wall Sink	Initial	28-MAY-16	1.560	ppb
51317	51317-1-HAL-F06	Main- 1st floor Outside Principal Office, Fountain	Flush180	28-MAY-16	0.371	ppb
51317	51317-1-HAL-F06	Main- 1st floor Outside Principal Office, Fountain	Flush180	28-MAY-16	0.424	ppb
51317	51317-1-HAL-F06	Main- 1st floor Outside Principal Office, Fountain	Flush180	28-MAY-16	0.345	ppb
51317	51317-1-HAL-F06	Main- 1st floor Outside Principal Office, Fountain	Flush180	28-MAY-16	0.386	ppb
51317	51317-1-HAL-F06	Main- 1st floor Outside Principal Office, Fountain	Initial	28-MAY-16	0.619	ppb
51317	51317-1-HAL-F08	Main- 1st floor South End Of Corridor, Center Foun	Flush180	28-MAY-16	1.540	ppb
51317	51317-1-HAL-F08	Main- 1st floor South End Of Corridor, Center Foun	Flush180	28-MAY-16	1.530	ppb
51317	51317-1-HAL-F08	Main- 1st floor South End Of Corridor, Center Foun	Flush180	28-MAY-16	1.530	ppb
51317	51317-1-HAL-F08	Main- 1st floor South End Of Corridor, Center Foun	Flush180	28-MAY-16	1.430	ppb
51317	51317-1-HAL-F08	Main- 1st floor South End Of Corridor, Center Foun	Initial	28-MAY-16	1.490	ppb
51317	51317-1-HAL-F07	Main- 1st floor South End Of Corridor, Right Fount	Flush180	28-MAY-16	1.880	ppb
51317	51317-1-HAL-F07	Main- 1st floor South End Of Corridor, Right Fount	Flush180	28-MAY-16	1.320	ppb
51317	51317-1-HAL-F07	Main- 1st floor South End Of Corridor, Right Fount	Flush180	28-MAY-16	1.090	ppb
51317	51317-1-HAL-F07	Main- 1st floor South End Of Corridor, Right Fount	Flush180	28-MAY-16	1.610	ppb
51317	51317-1-HAL-F07	Main- 1st floor South End Of Corridor, Right Fount	Initial	28-MAY-16	1.640	ppb
51317	51317-2-HAL-F03	Main- 2nd Floor Outside Room 209, Center Fountain	Flush	17-JAN-2024	1.000	ug/L
51317	51317-2-HAL-F03	Main- 2nd Floor Outside Room 209, Center Fountain	Flush	17-JAN-2024	1.000	ug/L
51317	51317-2-HAL-F03	Main- 2nd Floor Outside Room 209, Center Fountain	Flush	17-JAN-2024	1.000	ug/L
51317	51317-2-HAL-F03	Main- 2nd Floor Outside Room 209, Center Fountain	Flush	17-JAN-2024	1.000	ug/L
51317	51317-2-HAL-F03	Main- 2nd Floor Outside Room 209, Center Fountain	Flush180	28-MAY-16	0.282	ppb
51317	51317-2-HAL-F03	Main- 2nd Floor Outside Room 209, Center Fountain	Flush180	28-MAY-16	0.375	ppb
51317	51317-2-HAL-F03	Main- 2nd Floor Outside Room 209, Center Fountain	Flush180	28-MAY-16	0.343	ppb
51317	51317-2-HAL-F03	Main- 2nd Floor Outside Room 209, Center Fountain	Flush180	28-MAY-16	0.372	ppb
51317	51317-2-HAL-F03	Main- 2nd Floor Outside Room 209, Center Fountain	Initial	28-MAY-16	0.355	ppb
51317	51317-2-HAL-F03	Main- 2nd Floor Outside Room 209, Center Fountain	Initial	17-JAN-2024	1.000	ug/L
51317	51317-2-HAL-F02	Main- 2nd Floor Outside Room 209, Left Fountain	Flush	17-JAN-2024	1.000	ug/L
51317	51317-2-HAL-F02	Main- 2nd Floor Outside Room 209, Left Fountain	Flush	17-JAN-2024	1.000	ug/L
51317	51317-2-HAL-F02	Main- 2nd Floor Outside Room 209, Left Fountain	Flush	17-JAN-2024	1.000	ug/L
51317	51317-2-HAL-F02	Main- 2nd Floor Outside Room 209, Left Fountain	Flush	17-JAN-2024	1.000	ug/L
51317	51317-2-HAL-F02	Main- 2nd Floor Outside Room 209, Left Fountain	Flush180	28-MAY-16	0.572	ppb
51317	51317-2-HAL-F02	Main- 2nd Floor Outside Room 209, Left Fountain	Flush180	28-MAY-16	0.489	ppb
51317	51317-2-HAL-F02	Main- 2nd Floor Outside Room 209, Left Fountain	Flush180	28-MAY-16	0.415	ppb
51317	51317-2-HAL-	Main- 2nd Floor Outside Room	Flush180	28-MAY-16	0.486	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02	209, Left Fountain				
51317	51317-2-HAL-F02	Main- 2nd Floor Outside Room 209, Left Fountain	Initial	28-MAY-16	0.346	ppb
51317	51317-2-HAL-F02	Main- 2nd Floor Outside Room 209, Left Fountain	Initial	17-JAN-2024	1.000	ug/L
51317	51317-2-HAL-F04	Main- 2nd Floor Outside Room 209, Right Fountain	Flush	17-JAN-2024	1.000	ug/L
51317	51317-2-HAL-F04	Main- 2nd Floor Outside Room 209, Right Fountain	Flush	17-JAN-2024	1.000	ug/L
51317	51317-2-HAL-F04	Main- 2nd Floor Outside Room 209, Right Fountain	Flush	17-JAN-2024	1.000	ug/L
51317	51317-2-HAL-F04	Main- 2nd Floor Outside Room 209, Right Fountain	Flush	17-JAN-2024	1.000	ug/L
51317	51317-2-HAL-F04	Main- 2nd Floor Outside Room 209, Right Fountain	Flush180	28-MAY-16	0.487	ppb
51317	51317-2-HAL-F04	Main- 2nd Floor Outside Room 209, Right Fountain	Flush180	28-MAY-16	0.311	ppb
51317	51317-2-HAL-F04	Main- 2nd Floor Outside Room 209, Right Fountain	Flush180	28-MAY-16	0.395	ppb
51317	51317-2-HAL-F04	Main- 2nd Floor Outside Room 209, Right Fountain	Flush180	28-MAY-16	0.420	ppb
51317	51317-2-HAL-F04	Main- 2nd Floor Outside Room 209, Right Fountain	Initial	28-MAY-16	0.319	ppb
51317	51317-2-HAL-F04	Main- 2nd Floor Outside Room 209, Right Fountain	Initial	17-JAN-2024	1.000	ug/L
51317	51317-3-HAL-F01	Main- 3rd Floor Corridor North, Fountain	Flush180	28-MAY-16	1.060	ppb
51317	51317-3-HAL-F01	Main- 3rd Floor Corridor North, Fountain	Flush180	28-MAY-16	1.350	ppb
51317	51317-3-HAL-F01	Main- 3rd Floor Corridor North, Fountain	Flush180	28-MAY-16	1.600	ppb
51317	51317-3-HAL-F01	Main- 3rd Floor Corridor North, Fountain	Flush180	28-MAY-16	1.210	ppb
51317	51317-3-HAL-F01	Main- 3rd Floor Corridor North, Fountain	Flush180	06-AUG-20	5.590	ug/L
51317	51317-3-HAL-F01	Main- 3rd Floor Corridor North, Fountain	Flush180	29-OCT-20	1.000	ug/L
51317	51317-3-HAL-F01	Main- 3rd Floor Corridor North, Fountain	Flush180	29-OCT-20	1.000	ug/L
51317	51317-3-HAL-F01	Main- 3rd Floor Corridor North, Fountain	Flush180	29-OCT-20	1.000	ug/L
51317	51317-3-HAL-F01	Main- 3rd Floor Corridor North, Fountain	Initial	28-MAY-16	1.410	ppb
51317	51317-3-HAL-F01	Main- 3rd Floor Corridor North, Fountain	Initial	06-AUG-20	5.620	ug/L
51317	51317-3-HAL-F01	Main- 3rd Floor Corridor North, Fountain	Initial	29-OCT-20	1.000	ug/L
52327	52327-2-HAL-F01	Annex, 2nd Fl by elevator, North fountain	Flush	17-JAN-2024	1.000	ug/L
52327	52327-2-HAL-F01	Annex, 2nd Fl by elevator, North fountain	Flush	17-JAN-2024	1.000	ug/L
52327	52327-2-HAL-F01	Annex, 2nd Fl by elevator, North fountain	Flush	17-JAN-2024	1.000	ug/L
52327	52327-2-HAL-F01	Annex, 2nd Fl by elevator, North fountain	Flush	17-JAN-2024	1.000	ug/L
52327	52327-2-HAL-F01	Annex, 2nd Fl by elevator, North fountain	Initial	17-JAN-2024	1.000	ug/L
52327	52327-1-131-S27	Annex, Inside RM 131, Center Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-131-S27	Annex, Inside RM 131, Center Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-131-S27	Annex, Inside RM 131, Center Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-131-S27	Annex, Inside RM 131, Center Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-131-S27	Annex, Inside RM 131, Center Sink	Initial	17-JAN-2024	1.470	ug/L
52327	52327-1-131-F26	Annex, Inside RM 131, Fountain	Flush	17-JAN-2024	3.610	ug/L
52327	52327-1-131-F26	Annex, Inside RM 131, Fountain	Flush	17-JAN-2024	2.310	ug/L
52327	52327-1-131-	Annex, Inside RM 131, Fountain	Flush	17-JAN-2024	1.760	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F26					
52327	52327-1-131-F26	Annex, Inside RM 131, Fountain	Flush	17-JAN-2024	1.070	ug/L
52327	52327-1-131-F26	Annex, Inside RM 131, Fountain	Initial	17-JAN-2024	2.470	ug/L
52327	52327-1-HAL-F01	Annex- 1st Floor Northeast Hallway, Left Fountain	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-HAL-F01	Annex- 1st Floor Northeast Hallway, Left Fountain	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-HAL-F01	Annex- 1st Floor Northeast Hallway, Left Fountain	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-HAL-F01	Annex- 1st Floor Northeast Hallway, Left Fountain	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-HAL-F01	Annex- 1st Floor Northeast Hallway, Left Fountain	Initial	17-JAN-2024	1.000	ug/L
52327	52327-1-HAL-F01	Annex- 1st Floor Northeast Hallway, North Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-HAL-F01	Annex- 1st Floor Northeast Hallway, North Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-HAL-F01	Annex- 1st Floor Northeast Hallway, North Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-HAL-F01	Annex- 1st Floor Northeast Hallway, North Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-HAL-F01	Annex- 1st Floor Northeast Hallway, North Fountain	Initial	28-MAY-16	1.000	ppb
52327	52327-1-HAL-F02	Annex- 1st Floor Northeast Hallway, Right Fountain	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-HAL-F02	Annex- 1st Floor Northeast Hallway, Right Fountain	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-HAL-F02	Annex- 1st Floor Northeast Hallway, Right Fountain	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-HAL-F02	Annex- 1st Floor Northeast Hallway, Right Fountain	Initial	17-JAN-2024	1.000	ug/L
52327	52327-1-HAL-F22	Annex- 1st Floor Outside Gym, North Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-HAL-F22	Annex- 1st Floor Outside Gym, North Fountain	Flush180	28-MAY-16	0.131	ppb
52327	52327-1-HAL-F22	Annex- 1st Floor Outside Gym, North Fountain	Flush180	28-MAY-16	0.125	ppb
52327	52327-1-HAL-F22	Annex- 1st Floor Outside Gym, North Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-HAL-F22	Annex- 1st Floor Outside Gym, North Fountain	Initial	28-MAY-16	0.145	ppb
52327	52327-1-HAL-F21	Annex- 1st Floor Outside Gym, South Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-HAL-F21	Annex- 1st Floor Outside Gym, South Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-HAL-F21	Annex- 1st Floor Outside Gym, South Fountain	Flush180	06-AUG-20	1.000	ug/L
52327	52327-1-HAL-F21	Annex- 1st Floor Outside Gym, South Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-HAL-F21	Annex- 1st Floor Outside Gym, South Fountain	Initial	06-AUG-20	1.000	ug/L
52327	52327-1-HAL-F21	Annex- 1st Floor Outside Gym, South Fountain	Initial	28-MAY-16	1.000	ppb
52327	52327-1-HAL-F04	Annex- 1st Floor Southeast Hallway, Left Fountain	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-HAL-F04	Annex- 1st Floor Southeast Hallway, Left Fountain	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-HAL-F04	Annex- 1st Floor Southeast Hallway, Left Fountain	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-HAL-F04	Annex- 1st Floor Southeast Hallway, Left Fountain	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-HAL-F04	Annex- 1st Floor Southeast Hallway, Left Fountain	Initial	17-JAN-2024	1.000	ug/L
52327	52327-1-HAL-F04	Annex- 1st Floor Southeast Hallway, North Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-HAL-F04	Annex- 1st Floor Southeast Hallway, North Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-HAL-F04	Annex- 1st Floor Southeast Hallway, North Fountain	Flush180	28-MAY-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52327	52327-1-HAL-F04	Annex- 1st Floor Southeast Hallway, North Fountain	Flush180	28-MAY-16	1.800	ppb
52327	52327-1-HAL-F04	Annex- 1st Floor Southeast Hallway, North Fountain	Initial	28-MAY-16	1.000	ppb
52327	52327-1-HAL-F05	Annex- 1st Floor Southeast Hallway, Right Fountain	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-HAL-F05	Annex- 1st Floor Southeast Hallway, Right Fountain	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-HAL-F05	Annex- 1st Floor Southeast Hallway, Right Fountain	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-HAL-F05	Annex- 1st Floor Southeast Hallway, Right Fountain	Initial	17-JAN-2024	1.000	ug/L
52327	52327-1-HAL-F05	Annex- 1st Floor Southeast Hallway, Right Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-HAL-F05	Annex- 1st Floor Southeast Hallway, South Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-HAL-F05	Annex- 1st Floor Southeast Hallway, South Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-HAL-F05	Annex- 1st Floor Southeast Hallway, South Fountain	Initial	28-MAY-16	1.000	ppb
52327	52327-1-TL-S03	Annex- 1st Floor Teachers Lounge, Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-TL-S03	Annex- 1st Floor Teachers Lounge, Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-TL-S03	Annex- 1st Floor Teachers Lounge, Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-TL-S03	Annex- 1st Floor Teachers Lounge, Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-TL-S03	Annex- 1st Floor Teachers Lounge, Sink	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-TL-S03	Annex- 1st Floor Teachers Lounge, Sink	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-TL-S03	Annex- 1st Floor Teachers Lounge, Sink	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-TL-S03	Annex- 1st Floor Teachers Lounge, Sink	Flush180	28-MAY-16	0.144	ppb
52327	52327-1-TL-S03	Annex- 1st Floor Teachers Lounge, Sink	Initial	28-MAY-16	0.130	ppb
52327	52327-1-TL-S03	Annex- 1st Floor Teachers Lounge, Sink	Initial	17-JAN-2024	1.000	ug/L
52327	52327-2-HAL-F01	Annex- 2nd Floor By Elevator, North Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-2-HAL-F01	Annex- 2nd Floor By Elevator, North Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-2-HAL-F01	Annex- 2nd Floor By Elevator, North Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-2-HAL-F01	Annex- 2nd Floor By Elevator, North Fountain	Initial	28-MAY-16	1.000	ppb
52327	52327-2-HAL-F02	Annex- 2nd Floor By Elevator, South Fountain	Flush	17-JAN-2024	1.000	ug/L
52327	52327-2-HAL-F02	Annex- 2nd Floor By Elevator, South Fountain	Flush	17-JAN-2024	1.000	ug/L
52327	52327-2-HAL-F02	Annex- 2nd Floor By Elevator, South Fountain	Flush	17-JAN-2024	1.000	ug/L
52327	52327-2-HAL-F02	Annex- 2nd Floor By Elevator, South Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-2-HAL-F02	Annex- 2nd Floor By Elevator, South Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-2-HAL-F02	Annex- 2nd Floor By Elevator, South Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-2-HAL-F02	Annex- 2nd Floor By Elevator, South Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-2-HAL-F02	Annex- 2nd Floor By Elevator, South Fountain	Initial	28-MAY-16	1.000	ppb
52327	52327-2-HAL-F02	Annex- 2nd Floor By Elevator, South Fountain	Initial	17-JAN-2024	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52327	52327-2-HAL-F03	Annex- 2nd Floor Outside Room 222, North Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-2-HAL-F03	Annex- 2nd Floor Outside Room 222, North Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-2-HAL-F03	Annex- 2nd Floor Outside Room 222, North Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-2-HAL-F03	Annex- 2nd Floor Outside Room 222, North Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-2-HAL-F03	Annex- 2nd Floor Outside Room 222, North Fountain	Flush180	06-AUG-20	1.000	ug/L
52327	52327-2-HAL-F03	Annex- 2nd Floor Outside Room 222, North Fountain	Initial	28-MAY-16	1.000	ppb
52327	52327-2-HAL-F03	Annex- 2nd Floor Outside Room 222, North Fountain	Initial	06-AUG-20	1.000	ug/L
52327	52327-2-HAL-F04	Annex- 2nd Floor Outside Room 222, South Fountain	Flush	17-JAN-2024	1.000	ug/L
52327	52327-2-HAL-F04	Annex- 2nd Floor Outside Room 222, South Fountain	Flush	17-JAN-2024	1.000	ug/L
52327	52327-2-HAL-F04	Annex- 2nd Floor Outside Room 222, South Fountain	Flush	17-JAN-2024	1.000	ug/L
52327	52327-2-HAL-F04	Annex- 2nd Floor Outside Room 222, South Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-2-HAL-F04	Annex- 2nd Floor Outside Room 222, South Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-2-HAL-F04	Annex- 2nd Floor Outside Room 222, South Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-2-HAL-F04	Annex- 2nd Floor Outside Room 222, South Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-2-HAL-F04	Annex- 2nd Floor Outside Room 222, South Fountain	Initial	28-MAY-16	1.000	ppb
52327	52327-2-HAL-F04	Annex- 2nd Floor Outside Room 222, South Fountain	Initial	17-JAN-2024	1.000	ug/L
52327	52327-1-122-S06	Annex- Inside Room 122, Sink	Flush180	28-MAY-16	2.430	ppb
52327	52327-1-122-S06	Annex- Inside Room 122, Sink	Flush180	28-MAY-16	0.535	ppb
52327	52327-1-122-S06	Annex- Inside Room 122, Sink	Flush180	28-MAY-16	0.280	ppb
52327	52327-1-122-S06	Annex- Inside Room 122, Sink	Flush180	28-MAY-16	0.385	ppb
52327	52327-1-122-S06	Annex- Inside Room 122, Sink	Initial	28-MAY-16	0.262	ppb
52327	52327-1-122-S06	Annex- Inside Room 122, Sink	Flush	17-JAN-2024	1.460	ug/L
52327	52327-1-122-S06	Annex- Inside Room 122, Sink	Flush	17-JAN-2024	1.270	ug/L
52327	52327-1-122-S06	Annex- Inside Room 122, Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-122-S06	Annex- Inside Room 122, Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-122-S06	Annex- Inside Room 122, Sink	Initial	17-JAN-2024	4.030	ug/L
52327	52327-1-123-S08	Annex- Inside Room 123 Center, Sink 1	Flush	22-MAR-2024	1.000	ug/L
52327	52327-1-123-S08	Annex- Inside Room 123 Center, Sink 1	Flush	22-MAR-2024	1.000	ug/L
52327	52327-1-123-S08	Annex- Inside Room 123 Center, Sink 1	Flush	22-MAR-2024	1.000	ug/L
52327	52327-1-123-S08	Annex- Inside Room 123 Center, Sink 1	Flush	22-MAR-2024	1.000	ug/L
52327	52327-1-123-S08	Annex- Inside Room 123 Center, Sink 1	Flush	17-JAN-2024	37.400	ug/L
52327	52327-1-123-S08	Annex- Inside Room 123 Center, Sink 1	Flush	17-JAN-2024	14.000	ug/L
52327	52327-1-123-S08	Annex- Inside Room 123 Center, Sink 1	Flush	17-JAN-2024	20.000	ug/L
52327	52327-1-123-S08	Annex- Inside Room 123 Center, Sink 1	Flush	17-JAN-2024	21.700	ug/L
52327	52327-1-123-S08	Annex- Inside Room 123 Center, Sink 1	Flush180	13-JUL-16	2.230	ppb
52327	52327-1-123-S08	Annex- Inside Room 123 Center, Sink 1	Flush180	13-JUL-16	1.810	ppb
52327	52327-1-123-S08	Annex- Inside Room 123 Center, Sink 1	Flush180	13-JUL-16	4.940	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S08	Sink 1				
52327	52327-1-123-S08	Annex- Inside Room 123 Center, Sink 1	Flush180	28-MAY-16	0.155	ppb
52327	52327-1-123-S08	Annex- Inside Room 123 Center, Sink 1	Flush180	28-MAY-16	0.281	ppb
52327	52327-1-123-S08	Annex- Inside Room 123 Center, Sink 1	Flush180	28-MAY-16	0.191	ppb
52327	52327-1-123-S08	Annex- Inside Room 123 Center, Sink 1	Flush180	28-MAY-16	1.440	ppb
52327	52327-1-123-S08	Annex- Inside Room 123 Center, Sink 1	Flush180	13-JUL-16	5.730	ppb
52327	52327-1-123-S08	Annex- Inside Room 123 Center, Sink 1	Initial	13-JUL-16	2.660	ppb
52327	52327-1-123-S08	Annex- Inside Room 123 Center, Sink 1	Initial	28-MAY-16	32.100	ppb
52327	52327-1-123-S08	Annex- Inside Room 123 Center, Sink 1	Initial	22-MAR-2024	1.000	ug/L
52327	52327-1-123-S08	Annex- Inside Room 123 Center, Sink 1	Initial	17-JAN-2024	29.900	ug/L
52327	52327-1-123-S09	Annex- Inside Room 123 Right, Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-123-S09	Annex- Inside Room 123 Right, Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-123-S09	Annex- Inside Room 123 Right, Sink	Flush	17-JAN-2024	1.100	ug/L
52327	52327-1-123-S09	Annex- Inside Room 123 Right, Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-123-S09	Annex- Inside Room 123 Right, Sink	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-123-S09	Annex- Inside Room 123 Right, Sink	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-123-S09	Annex- Inside Room 123 Right, Sink	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-123-S09	Annex- Inside Room 123 Right, Sink	Initial	28-MAY-16	0.152	ppb
52327	52327-1-123-S09	Annex- Inside Room 123 Right, Sink	Initial	17-JAN-2024	1.000	ug/L
52327	52327-1-123-F07	Annex- Inside Room 123, Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-123-F07	Annex- Inside Room 123, Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-123-F07	Annex- Inside Room 123, Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-123-F07	Annex- Inside Room 123, Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-123-F07	Annex- Inside Room 123, Fountain	Initial	28-MAY-16	0.166	ppb
52327	52327-1-123-F07	Annex- Inside Room 123, Fountain	Flush	17-JAN-2024	1.210	ug/L
52327	52327-1-123-F07	Annex- Inside Room 123, Fountain	Flush	17-JAN-2024	1.080	ug/L
52327	52327-1-123-F07	Annex- Inside Room 123, Fountain	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-123-F07	Annex- Inside Room 123, Fountain	Flush	17-JAN-2024	1.470	ug/L
52327	52327-1-123-F07	Annex- Inside Room 123, Fountain	Initial	17-JAN-2024	1.020	ug/L
52327	52327-1-124-S10	Annex- Inside Room 124, Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-124-S10	Annex- Inside Room 124, Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-124-S10	Annex- Inside Room 124, Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-124-S10	Annex- Inside Room 124, Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-124-S10	Annex- Inside Room 124, Sink	Flush180	28-MAY-16	0.326	ppb
52327	52327-1-124-S10	Annex- Inside Room 124, Sink	Flush180	28-MAY-16	0.876	ppb
52327	52327-1-124-S10	Annex- Inside Room 124, Sink	Flush180	28-MAY-16	0.463	ppb
52327	52327-1-124-S10	Annex- Inside Room 124, Sink	Flush180	28-MAY-16	4.780	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S10					
52327	52327-1-124-S10	Annex- Inside Room 124, Sink	Initial	28-MAY-16	0.581	ppb
52327	52327-1-124-S10	Annex- Inside Room 124, Sink	Initial	17-JAN-2024	1.000	ug/L
52327	52327-1-125-F12	Annex- Inside Room 125, Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-125-F12	Annex- Inside Room 125, Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-125-F12	Annex- Inside Room 125, Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-125-F12	Annex- Inside Room 125, Fountain	Flush180	28-MAY-16	0.137	ppb
52327	52327-1-125-F12	Annex- Inside Room 125, Fountain	Initial	28-MAY-16	1.000	ppb
52327	52327-1-125-S14	Annex- Inside Room 125, Sink	Flush	17-JAN-2024	1.450	ug/L
52327	52327-1-125-S14	Annex- Inside Room 125, Sink	Flush	17-JAN-2024	1.090	ug/L
52327	52327-1-125-S14	Annex- Inside Room 125, Sink	Flush	17-JAN-2024	1.040	ug/L
52327	52327-1-125-S14	Annex- Inside Room 125, Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-125-S14	Annex- Inside Room 125, Sink	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-125-S14	Annex- Inside Room 125, Sink	Flush180	28-MAY-16	0.148	ppb
52327	52327-1-125-S14	Annex- Inside Room 125, Sink	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-125-S14	Annex- Inside Room 125, Sink	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-125-S14	Annex- Inside Room 125, Sink	Initial	28-MAY-16	1.000	ppb
52327	52327-1-125-S14	Annex- Inside Room 125, Sink	Initial	17-JAN-2024	1.000	ug/L
52327	52327-1-126-S11	Annex- Inside Room 126, Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-126-S11	Annex- Inside Room 126, Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-126-S11	Annex- Inside Room 126, Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-126-S11	Annex- Inside Room 126, Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-126-S11	Annex- Inside Room 126, Sink	Flush180	28-MAY-16	0.232	ppb
52327	52327-1-126-S11	Annex- Inside Room 126, Sink	Flush180	28-MAY-16	1.370	ppb
52327	52327-1-126-S11	Annex- Inside Room 126, Sink	Flush180	28-MAY-16	0.220	ppb
52327	52327-1-126-S11	Annex- Inside Room 126, Sink	Flush180	28-MAY-16	0.163	ppb
52327	52327-1-126-S11	Annex- Inside Room 126, Sink	Initial	28-MAY-16	0.184	ppb
52327	52327-1-126-S11	Annex- Inside Room 126, Sink	Initial	17-JAN-2024	1.270	ug/L
52327	52327-1-127-F17	Annex- Inside Room 127 Center, Sink 1	Flush180	28-MAY-16	3.940	ppb
52327	52327-1-127-F17	Annex- Inside Room 127 Center, Sink 1	Flush180	28-MAY-16	1.360	ppb
52327	52327-1-127-F17	Annex- Inside Room 127 Center, Sink 1	Flush180	28-MAY-16	1.080	ppb
52327	52327-1-127-S17	Annex- Inside Room 127 Center, Sink 1	Flush180	05-AUG-16	1.000	ppb
52327	52327-1-127-S17	Annex- Inside Room 127 Center, Sink 1	Flush180	05-AUG-16	1.000	ppb
52327	52327-1-127-S17	Annex- Inside Room 127 Center, Sink 1	Flush180	05-AUG-16	1.000	ppb
52327	52327-1-127-S17	Annex- Inside Room 127 Center, Sink 1	Flush180	05-AUG-16	2.300	ppb
52327	52327-1-127-F17	Annex- Inside Room 127 Center, Sink 1	Flush180	28-MAY-16	0.993	ppb
52327	52327-1-127-F17	Annex- Inside Room 127 Center, Sink 1	Flush180	13-JUL-16	3.350	ppb
52327	52327-1-127-F17	Annex- Inside Room 127 Center, Sink 1	Flush180	13-JUL-16	2.970	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52327	52327-1-127-F17	Annex- Inside Room 127 Center, Sink 1	Flush180	13-JUL-16	3.050	ppb
52327	52327-1-127-F17	Annex- Inside Room 127 Center, Sink 1	Flush180	13-JUL-16	11.200	ppb
52327	52327-1-127-F17	Annex- Inside Room 127 Center, Sink 1	Initial	28-MAY-16	38.300	ppb
52327	52327-1-127-F17	Annex- Inside Room 127 Center, Sink 1	Initial	13-JUL-16	15.800	ppb
52327	52327-1-127-S17	Annex- Inside Room 127 Center, Sink 1	Initial	05-AUG-16	2.100	ppb
52327	52327-1-127-S17	Annex- Inside Room 127 Right Sink	Flush	22-MAR-2024	1.700	ug/L
52327	52327-1-127-S17	Annex- Inside Room 127 Right Sink	Flush	18-APR-2024	1.000	ug/L
52327	52327-1-127-S17	Annex- Inside Room 127 Right Sink	Flush	18-APR-2024	1.000	ug/L
52327	52327-1-127-S17	Annex- Inside Room 127 Right Sink	Flush	18-APR-2024	1.000	ug/L
52327	52327-1-127-S17	Annex- Inside Room 127 Right Sink	Flush	18-APR-2024	1.000	ug/L
52327	52327-1-127-S17	Annex- Inside Room 127 Right Sink	Flush	22-MAR-2024	19.200	ug/L
52327	52327-1-127-S17	Annex- Inside Room 127 Right Sink	Flush	22-MAR-2024	1.350	ug/L
52327	52327-1-127-S17	Annex- Inside Room 127 Right Sink	Flush	22-MAR-2024	1.140	ug/L
52327	52327-1-127-S17	Annex- Inside Room 127 Right Sink	Flush	17-JAN-2024	5.450	ug/L
52327	52327-1-127-S17	Annex- Inside Room 127 Right Sink	Flush	17-JAN-2024	3.930	ug/L
52327	52327-1-127-S17	Annex- Inside Room 127 Right Sink	Flush	17-JAN-2024	3.460	ug/L
52327	52327-1-127-S17	Annex- Inside Room 127 Right Sink	Flush	17-JAN-2024	2.560	ug/L
52327	52327-1-127-S17	Annex- Inside Room 127 Right Sink	Initial	18-APR-2024	1.000	ug/L
52327	52327-1-127-S17	Annex- Inside Room 127 Right Sink	Initial	22-MAR-2024	20.600	ug/L
52327	52327-1-127-S17	Annex- Inside Room 127 Right Sink	Initial	17-JAN-2024	9.970	ug/L
52327	52327-1-127-F16	Annex- Inside Room 127, Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-127-F16	Annex- Inside Room 127, Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-127-F16	Annex- Inside Room 127, Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-127-F16	Annex- Inside Room 127, Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-127-F16	Annex- Inside Room 127, Fountain	Initial	28-MAY-16	1.000	ppb
52327	52327-1-127-S18	Annex- Inside Room 127, Right Sink	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-127-S18	Annex- Inside Room 127, Right Sink	Flush180	28-MAY-16	0.148	ppb
52327	52327-1-127-S18	Annex- Inside Room 127, Right Sink	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-127-S18	Annex- Inside Room 127, Right Sink	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-127-S18	Annex- Inside Room 127, Right Sink	Initial	28-MAY-16	0.388	ppb
52327	52327-1-128-S35	Annex- Inside Room 128, Right Sink	Flush	17-JAN-2024	4.720	ug/L
52327	52327-1-128-S35	Annex- Inside Room 128, Right Sink	Flush	17-JAN-2024	4.480	ug/L
52327	52327-1-128-S35	Annex- Inside Room 128, Right Sink	Flush	17-JAN-2024	3.310	ug/L
52327	52327-1-128-S35	Annex- Inside Room 128, Right Sink	Flush	17-JAN-2024	1.790	ug/L
52327	52327-1-128-S35	Annex- Inside Room 128, Right Sink	Initial	17-JAN-2024	1.000	ug/L
52327	52327-1-125-S15	Annex- Inside Room 128, Sink	Flush	17-JAN-2024	4.270	ug/L
52327	52327-1-125-S15	Annex- Inside Room 128, Sink	Flush	17-JAN-2024	3.790	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52327	52327-1-125-S15	Annex- Inside Room 128, Sink	Flush	17-JAN-2024	1.590	ug/L
52327	52327-1-125-S15	Annex- Inside Room 128, Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-125-S15	Annex- Inside Room 128, Sink	Flush180	28-MAY-16	0.475	ppb
52327	52327-1-125-S15	Annex- Inside Room 128, Sink	Flush180	28-MAY-16	9.200	ppb
52327	52327-1-125-S15	Annex- Inside Room 128, Sink	Flush180	28-MAY-16	4.860	ppb
52327	52327-1-125-S15	Annex- Inside Room 128, Sink	Flush180	28-MAY-16	1.270	ppb
52327	52327-1-125-S15	Annex- Inside Room 128, Sink	Initial	28-MAY-16	1.650	ppb
52327	52327-1-125-S15	Annex- Inside Room 128, Sink	Initial	17-JAN-2024	3.050	ug/L
52327	52327-1-130-F23	Annex- Inside Room 130, Fountain	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-130-F23	Annex- Inside Room 130, Fountain	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-130-F23	Annex- Inside Room 130, Fountain	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-130-F23	Annex- Inside Room 130, Fountain	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-130-F23	Annex- Inside Room 130, Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-130-F23	Annex- Inside Room 130, Fountain	Flush180	28-MAY-16	0.138	ppb
52327	52327-1-130-F23	Annex- Inside Room 130, Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-130-F23	Annex- Inside Room 130, Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-130-F23	Annex- Inside Room 130, Fountain	Initial	28-MAY-16	0.151	ppb
52327	52327-1-130-F23	Annex- Inside Room 130, Fountain	Initial	17-JAN-2024	1.000	ug/L
52327	52327-1-130-S25	Annex- Inside Room 130, Left Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-130-S25	Annex- Inside Room 130, Left Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-130-S25	Annex- Inside Room 130, Left Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-130-S25	Annex- Inside Room 130, Left Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-130-S25	Annex- Inside Room 130, Left Sink	Flush180	28-MAY-16	0.154	ppb
52327	52327-1-130-S25	Annex- Inside Room 130, Left Sink	Flush180	28-MAY-16	0.181	ppb
52327	52327-1-130-S25	Annex- Inside Room 130, Left Sink	Flush180	28-MAY-16	1.130	ppb
52327	52327-1-130-S25	Annex- Inside Room 130, Left Sink	Flush180	28-MAY-16	0.160	ppb
52327	52327-1-130-S25	Annex- Inside Room 130, Left Sink	Initial	28-MAY-16	0.186	ppb
52327	52327-1-130-S25	Annex- Inside Room 130, Left Sink	Initial	17-JAN-2024	1.540	ug/L
52327	52327-1-131-S27	Annex- Inside Room 131 Center, Sink 1	Flush180	28-MAY-16	2.590	ppb
52327	52327-1-131-S27	Annex- Inside Room 131 Center, Sink 1	Flush180	28-MAY-16	35.400	ppb
52327	52327-1-131-S27	Annex- Inside Room 131 Center, Sink 1	Flush180	28-MAY-16	1.970	ppb
52327	52327-1-131-S27	Annex- Inside Room 131 Center, Sink 1	Flush180	13-JUL-16	0.784	ppb
52327	52327-1-131-S27	Annex- Inside Room 131 Center, Sink 1	Flush180	13-JUL-16	2.240	ppb
52327	52327-1-131-S27	Annex- Inside Room 131 Center, Sink 1	Flush180	13-JUL-16	8.810	ppb
52327	52327-1-131-S27	Annex- Inside Room 131 Center, Sink 1	Flush180	13-JUL-16	0.411	ppb
52327	52327-1-131-S27	Annex- Inside Room 131 Center, Sink 1	Flush180	28-MAY-16	4.450	ppb
52327	52327-1-131-S27	Annex- Inside Room 131 Center, Sink 1	Initial	13-JUL-16	2.070	ppb
52327	52327-1-131-S27	Annex- Inside Room 131 Center, Sink 1	Initial	28-MAY-16	1.290	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S27	Sink 1				
52327	52327-1-131-S28	Annex- Inside Room 131 Right Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-131-S28	Annex- Inside Room 131 Right Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-131-S28	Annex- Inside Room 131 Right Sink	Flush	17-JAN-2024	2.670	ug/L
52327	52327-1-131-S28	Annex- Inside Room 131 Right Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-131-S28	Annex- Inside Room 131 Right Sink	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-131-S28	Annex- Inside Room 131 Right Sink	Flush180	28-MAY-16	0.127	ppb
52327	52327-1-131-S28	Annex- Inside Room 131 Right Sink	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-131-S28	Annex- Inside Room 131 Right Sink	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-131-S28	Annex- Inside Room 131 Right Sink	Initial	28-MAY-16	0.146	ppb
52327	52327-1-131-S28	Annex- Inside Room 131 Right Sink	Initial	17-JAN-2024	2.470	ug/L
52327	52327-1-131-F26	Annex- Inside Room 131, FoAnnex- Inside Room 131,	Flush180	28-MAY-16	1.710	ppb
52327	52327-1-131-F26	Annex- Inside Room 131, FoAnnex- Inside Room 131,	Flush180	28-MAY-16	0.910	ppb
52327	52327-1-131-F26	Annex- Inside Room 131, FoAnnex- Inside Room 131,	Flush180	28-MAY-16	0.587	ppb
52327	52327-1-131-F26	Annex- Inside Room 131, FoAnnex- Inside Room 131,	Flush180	28-MAY-16	0.256	ppb
52327	52327-1-131-F26	Annex- Inside Room 131, FoAnnex- Inside Room 131,	Initial	28-MAY-16	0.328	ppb
52327	52327-1-132-S30	Annex- Inside Room 132 Center Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-132-S30	Annex- Inside Room 132 Center Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-132-S30	Annex- Inside Room 132 Center Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-132-S30	Annex- Inside Room 132 Center Sink	Flush	17-JAN-2024	1.310	ug/L
52327	52327-1-132-S30	Annex- Inside Room 132 Center Sink	Flush180	28-MAY-16	0.390	ppb
52327	52327-1-132-S30	Annex- Inside Room 132 Center Sink	Flush180	28-MAY-16	0.418	ppb
52327	52327-1-132-S30	Annex- Inside Room 132 Center Sink	Flush180	28-MAY-16	0.618	ppb
52327	52327-1-132-S30	Annex- Inside Room 132 Center Sink	Flush180	28-MAY-16	0.309	ppb
52327	52327-1-132-S30	Annex- Inside Room 132 Center Sink	Initial	28-MAY-16	4.930	ppb
52327	52327-1-132-S30	Annex- Inside Room 132 Center Sink	Initial	17-JAN-2024	1.000	ug/L
52327	52327-1-132-S31	Annex- Inside Room 132 Right Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-132-S31	Annex- Inside Room 132 Right Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-132-S31	Annex- Inside Room 132 Right Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-132-S31	Annex- Inside Room 132 Right Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-132-S31	Annex- Inside Room 132 Right Sink	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-132-S31	Annex- Inside Room 132 Right Sink	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-132-S31	Annex- Inside Room 132 Right Sink	Flush180	28-MAY-16	0.264	ppb
52327	52327-1-132-S31	Annex- Inside Room 132 Right Sink	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-132-S31	Annex- Inside Room 132 Right Sink	Initial	28-MAY-16	1.000	ppb
52327	52327-1-132-S31	Annex- Inside Room 132 Right Sink	Initial	17-JAN-2024	1.140	ug/L
52327	52327-1-132-F29	Annex- Inside Room 132, Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-132-	Annex- Inside Room 132, Fountain	Flush180	28-MAY-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F29					
52327	52327-1-132-F29	Annex- Inside Room 132, Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-132-F29	Annex- Inside Room 132, Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-132-F29	Annex- Inside Room 132, Fountain	Initial	28-MAY-16	1.000	ppb
52327	52327-1-134-S33	Annex- Inside Room 134, Center Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-134-S33	Annex- Inside Room 134, Center Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-134-S33	Annex- Inside Room 134, Center Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-134-S33	Annex- Inside Room 134, Center Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-134-S33	Annex- Inside Room 134, Center Sink	Flush180	28-MAY-16	0.249	ppb
52327	52327-1-134-S33	Annex- Inside Room 134, Center Sink	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-134-S33	Annex- Inside Room 134, Center Sink	Flush180	28-MAY-16	0.289	ppb
52327	52327-1-134-S33	Annex- Inside Room 134, Center Sink	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-134-S33	Annex- Inside Room 134, Center Sink	Initial	28-MAY-16	0.727	ppb
52327	52327-1-134-S33	Annex- Inside Room 134, Center Sink	Initial	17-JAN-2024	1.000	ug/L
52327	52327-1-134-F32	Annex- Inside Room 134, Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-134-F32	Annex- Inside Room 134, Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-134-F32	Annex- Inside Room 134, Fountain	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-134-F32	Annex- Inside Room 134, Fountain	Initial	28-MAY-16	1.000	ppb
52327	52327-1-134-S34	Annex- Inside Room 134, Right Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-134-S34	Annex- Inside Room 134, Right Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-134-S34	Annex- Inside Room 134, Right Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-134-S34	Annex- Inside Room 134, Right Sink	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-134-S34	Annex- Inside Room 134, Right Sink	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-134-S34	Annex- Inside Room 134, Right Sink	Flush180	28-MAY-16	0.167	ppb
52327	52327-1-134-S34	Annex- Inside Room 134, Right Sink	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-134-S34	Annex- Inside Room 134, Right Sink	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-134-S34	Annex- Inside Room 134, Right Sink	Initial	28-MAY-16	0.294	ppb
52327	52327-1-134-S34	Annex- Inside Room 134, Right Sink	Initial	17-JAN-2024	1.000	ug/L
52327	52327-1-KIT-KS19	Annex- Kitchen, East Wall, Sink	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-KIT-KS19	Annex- Kitchen, East Wall, Sink	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-KIT-KS19	Annex- Kitchen, East Wall, Sink	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-KIT-KS19	Annex- Kitchen, East Wall, Sink	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-KIT-KS19	Annex- Kitchen, East Wall, Sink	Initial	28-MAY-16	1.000	ppb
52327	52327-1-KIT-KS20	Annex- Kitchen, North Wall, Sink	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-KIT-KS20	Annex- Kitchen, North Wall, Sink	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-KIT-KS20	Annex- Kitchen, North Wall, Sink	Flush180	28-MAY-16	1.000	ppb
52327	52327-1-KIT-KS20	Annex- Kitchen, North Wall, Sink	Flush180	28-MAY-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52327	52327-1-KIT-KS20	Annex- Kitchen, North Wall, Sink	Initial	28-MAY-16	1.000	ppb
52327	52327-1-HAL-BF01	First Hall bottle filler by elevator	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-HAL-BF01	First Hall bottle filler by elevator	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-HAL-BF01	First Hall bottle filler by elevator	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-HAL-BF01	First Hall bottle filler by elevator	Flush	17-JAN-2024	1.000	ug/L
52327	52327-1-HAL-BF01	First Hall bottle filler by elevator	Flush180	23-DEC-20	1.340	ug/L
52327	52327-1-HAL-BF01	First Hall bottle filler by elevator	Flush180	23-DEC-20	2.490	ug/L
52327	52327-1-HAL-BF01	First Hall bottle filler by elevator	Flush180	23-DEC-20	3.090	ug/L
52327	52327-1-HAL-BF01	First Hall bottle filler by elevator	Flush180	23-DEC-20	4.460	ug/L
52327	52327-1-HAL-BF01	First Hall bottle filler by elevator	Flush180	09-AUG-23	1.000	ug/L
52327	52327-1-HAL-BF01	First Hall bottle filler by elevator	Flush180	09-AUG-23	1.000	ug/L
52327	52327-1-HAL-BF01	First Hall bottle filler by elevator	Flush180	09-AUG-23	1.000	ug/L
52327	52327-1-HAL-BF01	First Hall bottle filler by elevator	Flush180	09-AUG-23	1.000	ug/L
52327	52327-1-HAL-BF01	First Hall bottle filler by elevator	Initial	23-DEC-20	35.600	ug/L
52327	52327-1-HAL-BF01	First Hall bottle filler by elevator	Initial	09-AUG-23	1.000	ug/L
52327	52327-1-HAL-BF01	First Hall bottle filler by elevator	Initial	17-JAN-2024	1.000	ug/L
52327	52327-2-HAL-BF01	Second Floor Bottle Filler across from boys bathroom	Flush180	23-DEC-20	1.000	ug/L
52327	52327-2-HAL-BF01	Second Floor Bottle Filler across from boys bathroom	Flush180	23-DEC-20	1.000	ug/L
52327	52327-2-HAL-BF01	Second Floor Bottle Filler across from boys bathroom	Flush180	23-DEC-20	1.000	ug/L
52327	52327-2-HAL-BF01	Second Floor Bottle Filler across from boys bathroom	Flush180	23-DEC-20	1.000	ug/L
52327	52327-2-HAL-BF01	Second Floor Bottle Filler across from boys bathroom	Flush180	07-JAN-21	1.000	ug/L
52327	52327-2-HAL-BF01	Second Floor Bottle Filler across from boys bathroom	Flush180	07-JAN-21	1.000	ug/L
52327	52327-2-HAL-BF01	Second Floor Bottle Filler across from boys bathroom	Flush180	07-JAN-21	1.000	ug/L
52327	52327-2-HAL-BF01	Second Floor Bottle Filler across from boys bathroom	Flush180	07-JAN-21	1.000	ug/L
52327	52327-2-HAL-BF01	Second Floor Bottle Filler across from boys bathroom	Initial	23-DEC-20	7.720	ug/L
52327	52327-2-HAL-BF01	Second Floor Bottle Filler across from boys bathroom	Initial	07-JAN-21	1.000	ug/L