



Sep 10, 2024

CARTER

5740 S MICHIGAN AVE, Chicago IL 60637.

Dear **CARTER** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

CARTER

5740 S MICHIGAN AVE, Chicago IL 60637.

Estimadas familias de **CARTER**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51348	51348-ANX-1-KIT-KS02	Annex - Kitchen Sink, Right	Flush180	09-NOV-21	1.000	ug/L
51348	51348-ANX-1-KIT-KS02	Annex - Kitchen Sink, Right	Flush180	09-NOV-21	1.000	ug/L
51348	51348-ANX-1-KIT-KS02	Annex - Kitchen Sink, Right	Flush180	09-NOV-21	1.000	ug/L
51348	51348-ANX-1-KIT-KS02	Annex - Kitchen Sink, Right	Flush180	09-NOV-21	1.000	ug/L
51348	51348-ANX-1-KIT-KS02	Annex - Kitchen Sink, Right	Initial	09-NOV-21	2.300	ug/L
51348	51348-ANX-1-KIT-KS01	Annex- Kitchen Sink, Left	Flush180	15-JUN-16	0.524	ppb
51348	51348-ANX-1-KIT-KS01	Annex- Kitchen Sink, Left	Flush180	15-JUN-16	1.000	ppb
51348	51348-ANX-1-KIT-KS01	Annex- Kitchen Sink, Left	Flush180	15-JUN-16	0.232	ppb
51348	51348-ANX-1-KIT-KS01	Annex- Kitchen Sink, Left	Flush180	15-JUN-16	0.158	ppb
51348	51348-ANX-1-KIT-KS01	Annex- Kitchen Sink, Left	Flush180	09-NOV-21	1.000	ug/L
51348	51348-ANX-1-KIT-KS01	Annex- Kitchen Sink, Left	Flush180	09-NOV-21	1.000	ug/L
51348	51348-ANX-1-KIT-KS01	Annex- Kitchen Sink, Left	Flush180	09-NOV-21	1.000	ug/L
51348	51348-ANX-1-KIT-KS01	Annex- Kitchen Sink, Left	Flush180	09-NOV-21	1.000	ug/L
51348	51348-ANX-1-KIT-KS01	Annex- Kitchen Sink, Left	Initial	15-JUN-16	7.630	ppb
51348	51348-ANX-1-KIT-KS01	Annex- Kitchen Sink, Left	Initial	09-NOV-21	1.000	ug/L
51348	51348-1-HAL-RBF-01	Main - Outside Room 103, Retrofit Bottle Filler	Flush180	09-NOV-21	1.200	ug/L
51348	51348-1-HAL-RBF-01	Main - Outside Room 103, Retrofit Bottle Filler	Flush180	09-NOV-21	1.120	ug/L
51348	51348-1-HAL-RBF-01	Main - Outside Room 103, Retrofit Bottle Filler	Flush180	09-NOV-21	1.030	ug/L
51348	51348-1-HAL-RBF-01	Main - Outside Room 103, Retrofit Bottle Filler	Flush180	09-NOV-21	1.110	ug/L
51348	51348-1-HAL-RBF-01	Main - Outside Room 103, Retrofit Bottle Filler	Initial	09-NOV-21	1.000	ug/L
51348	51348-2-HAL-RBF01	Main - Outside Room 202, Retrofit Bottle Filler	Flush180	09-NOV-21	1.000	ug/L
51348	51348-2-HAL-RBF01	Main - Outside Room 202, Retrofit Bottle Filler	Flush180	09-NOV-21	1.260	ug/L
51348	51348-2-HAL-RBF01	Main - Outside Room 202, Retrofit Bottle Filler	Flush180	09-NOV-21	1.100	ug/L
51348	51348-2-HAL-RBF01	Main - Outside Room 202, Retrofit Bottle Filler	Flush180	09-NOV-21	1.050	ug/L
51348	51348-2-HAL-RBF01	Main - Outside Room 202, Retrofit Bottle Filler	Initial	09-NOV-21	1.000	ug/L
51348	51348-3-HAL-RBF01	Main - Outside Room 302, Retrofit Bottle Filler	Flush180	09-NOV-21	1.000	ug/L
51348	51348-3-HAL-RBF01	Main - Outside Room 302, Retrofit Bottle Filler	Flush180	09-NOV-21	1.000	ug/L
51348	51348-3-HAL-RBF01	Main - Outside Room 302, Retrofit Bottle Filler	Flush180	09-NOV-21	1.000	ug/L
51348	51348-3-HAL-RBF01	Main - Outside Room 302, Retrofit Bottle Filler	Flush180	09-NOV-21	1.000	ug/L
51348	51348-3-HAL-RBF01	Main - Outside Room 302, Retrofit Bottle Filler	Initial	09-NOV-21	1.000	ug/L
51348	51348-1-103-BF01	Main- Inside Room 103, Bottle Filler	Flush180	15-FEB-23	2.850	ug/L
51348	51348-1-103-BF01	Main- Inside Room 103, Bottle Filler	Flush180	15-FEB-23	1.750	ug/L
51348	51348-1-103-BF01	Main- Inside Room 103, Bottle Filler	Flush180	15-FEB-23	1.520	ug/L
51348	51348-1-103-BF01	Main- Inside Room 103, Bottle Filler	Flush180	15-FEB-23	1.510	ug/L
51348	51348-1-103-BF01	Main- Inside Room 103, Bottle Filler	Flush180	22-NOV-22	11.600	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51348	51348-1-103-BF01	Main- Inside Room 103, Bottle Filler	Flush180	22-NOV-22	7.130	ug/L
51348	51348-1-103-BF01	Main- Inside Room 103, Bottle Filler	Flush180	22-NOV-22	5.990	ug/L
51348	51348-1-103-BF01	Main- Inside Room 103, Bottle Filler	Flush180	22-NOV-22	5.120	ug/L
51348	51348-1-103-BF01	Main- Inside Room 103, Bottle Filler	Initial	15-FEB-23	2.700	ug/L
51348	51348-1-103-BF01	Main- Inside Room 103, Bottle Filler	Initial	22-NOV-22	15.000	ug/L
51348	51348-1-103-F04	Main- Inside Room 103, Fountain	Flush180	15-JUN-16	0.399	ppb
51348	51348-1-103-F04	Main- Inside Room 103, Fountain	Flush180	15-JUN-16	0.884	ppb
51348	51348-1-103-F04	Main- Inside Room 103, Fountain	Flush180	15-JUN-16	0.697	ppb
51348	51348-1-103-F04	Main- Inside Room 103, Fountain	Flush180	15-JUN-16	1.070	ppb
51348	51348-1-103-F04	Main- Inside Room 103, Fountain	Initial	15-JUN-16	0.123	ppb
51348	51348-1-103-F01	Main- Inside Room 103, Fountain	Flush180	15-FEB-23	1.000	ug/L
51348	51348-1-103-F01	Main- Inside Room 103, Fountain	Flush180	15-FEB-23	1.000	ug/L
51348	51348-1-103-F01	Main- Inside Room 103, Fountain	Flush180	15-FEB-23	1.000	ug/L
51348	51348-1-103-F01	Main- Inside Room 103, Fountain	Flush180	15-FEB-23	1.000	ug/L
51348	51348-1-103-F01	Main- Inside Room 103, Fountain	Flush180	15-FEB-23	1.000	ug/L
51348	51348-1-103-F01	Main- Inside Room 103, Fountain	Flush180	22-NOV-22	5.480	ug/L
51348	51348-1-103-F01	Main- Inside Room 103, Fountain	Flush180	22-NOV-22	4.530	ug/L
51348	51348-1-103-F01	Main- Inside Room 103, Fountain	Flush180	22-NOV-22	4.470	ug/L
51348	51348-1-103-F01	Main- Inside Room 103, Fountain	Flush180	22-NOV-22	4.250	ug/L
51348	51348-1-103-F01	Main- Inside Room 103, Fountain	Initial	15-FEB-23	1.000	ug/L
51348	51348-1-103-F01	Main- Inside Room 103, Fountain	Initial	22-NOV-22	7.750	ug/L
51348	51348-1-103-S01	Main- Inside Room 103, Left Sink	Flush180	15-FEB-23	1.000	ug/L
51348	51348-1-103-S01	Main- Inside Room 103, Left Sink	Flush180	15-FEB-23	1.000	ug/L
51348	51348-1-103-S01	Main- Inside Room 103, Left Sink	Flush180	15-FEB-23	1.000	ug/L
51348	51348-1-103-S01	Main- Inside Room 103, Left Sink	Flush180	15-FEB-23	1.000	ug/L
51348	51348-1-103-S01	Main- Inside Room 103, Left Sink	Flush180	22-NOV-22	30.000	ug/L
51348	51348-1-103-S01	Main- Inside Room 103, Left Sink	Flush180	22-NOV-22	14.300	ug/L
51348	51348-1-103-S01	Main- Inside Room 103, Left Sink	Flush180	22-NOV-22	5.890	ug/L
51348	51348-1-103-S01	Main- Inside Room 103, Left Sink	Flush180	22-NOV-22	3.880	ug/L
51348	51348-1-103-S01	Main- Inside Room 103, Left Sink	Initial	15-FEB-23	1.000	ug/L
51348	51348-1-103-S01	Main- Inside Room 103, Left Sink	Initial	22-NOV-22	180.000	ug/L
51348	51348-1-103-S02	Main- Inside Room 103, Right Sink	Flush180	15-FEB-23	1.000	ug/L
51348	51348-1-103-S02	Main- Inside Room 103, Right Sink	Flush180	15-FEB-23	1.040	ug/L
51348	51348-1-103-S02	Main- Inside Room 103, Right Sink	Flush180	15-FEB-23	1.000	ug/L
51348	51348-1-103-S02	Main- Inside Room 103, Right Sink	Flush180	15-FEB-23	1.000	ug/L
51348	51348-1-103-S02	Main- Inside Room 103, Right Sink	Flush180	22-NOV-22	7.730	ug/L
51348	51348-1-103-S02	Main- Inside Room 103, Right Sink	Flush180	22-NOV-22	3.890	ug/L
51348	51348-1-103-S02	Main- Inside Room 103, Right Sink	Flush180	22-NOV-22	3.350	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51348	51348-1-103-S02	Main- Inside Room 103, Right Sink	Flush180	22-NOV-22	3.320	ug/L
51348	51348-1-103-S02	Main- Inside Room 103, Right Sink	Initial	15-FEB-23	1.290	ug/L
51348	51348-1-103-S02	Main- Inside Room 103, Right Sink	Initial	22-NOV-22	80.000	ug/L
51348	51348-1-112-S05	Main- Inside Room 112, Sink	Flush	07-MAY-2024	1.980	ug/L
51348	51348-1-112-S05	Main- Inside Room 112, Sink	Flush	07-MAY-2024	2.300	ug/L
51348	51348-1-112-S05	Main- Inside Room 112, Sink	Flush	07-MAY-2024	2.140	ug/L
51348	51348-1-112-S05	Main- Inside Room 112, Sink	Flush	07-MAY-2024	1.420	ug/L
51348	51348-1-112-S05	Main- Inside Room 112, Sink	Flush180	15-JUN-16	1.960	ppb
51348	51348-1-112-S05	Main- Inside Room 112, Sink	Flush180	15-JUN-16	0.777	ppb
51348	51348-1-112-S05	Main- Inside Room 112, Sink	Flush180	15-JUN-16	11.900	ppb
51348	51348-1-112-S05	Main- Inside Room 112, Sink	Flush180	15-JUN-16	0.972	ppb
51348	51348-1-112-S05	Main- Inside Room 112, Sink	Flush180	09-NOV-21	1.000	ug/L
51348	51348-1-112-S05	Main- Inside Room 112, Sink	Flush180	09-NOV-21	1.280	ug/L
51348	51348-1-112-S05	Main- Inside Room 112, Sink	Flush180	09-NOV-21	1.010	ug/L
51348	51348-1-112-S05	Main- Inside Room 112, Sink	Flush180	09-NOV-21	3.080	ug/L
51348	51348-1-112-S05	Main- Inside Room 112, Sink	Initial	15-JUN-16	9.750	ppb
51348	51348-1-112-S05	Main- Inside Room 112, Sink	Initial	09-NOV-21	16.100	ug/L
51348	51348-1-112-S05	Main- Inside Room 112, Sink	Initial	07-MAY-2024	2.830	ug/L
51348	51348-1-HAL-F02	Main- Outside Boys Room, Left Fountain	Flush180	15-JUN-16	1.170	ppb
51348	51348-1-HAL-F02	Main- Outside Boys Room, Left Fountain	Flush180	15-JUN-16	1.040	ppb
51348	51348-1-HAL-F02	Main- Outside Boys Room, Left Fountain	Flush180	15-JUN-16	1.060	ppb
51348	51348-1-HAL-F02	Main- Outside Boys Room, Left Fountain	Flush180	15-JUN-16	1.110	ppb
51348	51348-1-HAL-F02	Main- Outside Boys Room, Left Fountain	Flush180	24-JUL-20	1.000	ug/L
51348	51348-1-HAL-F02	Main- Outside Boys Room, Left Fountain	Flush180	09-NOV-21	1.560	ug/L
51348	51348-1-HAL-F02	Main- Outside Boys Room, Left Fountain	Flush180	09-NOV-21	1.490	ug/L
51348	51348-1-HAL-F02	Main- Outside Boys Room, Left Fountain	Flush180	09-NOV-21	1.410	ug/L
51348	51348-1-HAL-F02	Main- Outside Boys Room, Left Fountain	Flush180	09-NOV-21	1.230	ug/L
51348	51348-1-HAL-F02	Main- Outside Boys Room, Left Fountain	Initial	15-JUN-16	0.861	ppb
51348	51348-1-HAL-F02	Main- Outside Boys Room, Left Fountain	Initial	24-JUL-20	1.000	ug/L
51348	51348-1-HAL-F02	Main- Outside Boys Room, Left Fountain	Initial	09-NOV-21	1.480	ug/L
51348	51348-1-HAL-F01	Main- Outside Boys Room, Right Fountain	Flush180	15-JUN-16	0.990	ppb
51348	51348-1-HAL-F01	Main- Outside Boys Room, Right Fountain	Flush180	15-JUN-16	1.120	ppb
51348	51348-1-HAL-F01	Main- Outside Boys Room, Right Fountain	Flush180	15-JUN-16	0.752	ppb
51348	51348-1-HAL-F01	Main- Outside Boys Room, Right Fountain	Flush180	15-JUN-16	1.150	ppb
51348	51348-1-HAL-F01	Main- Outside Boys Room, Right Fountain	Flush180	09-NOV-21	1.000	ug/L
51348	51348-1-HAL-F01	Main- Outside Boys Room, Right Fountain	Flush180	09-NOV-21	1.000	ug/L
51348	51348-1-HAL-F01	Main- Outside Boys Room, Right Fountain	Flush180	09-NOV-21	1.170	ug/L
51348	51348-1-HAL-F01	Main- Outside Boys Room, Right Fountain	Flush180	09-NOV-21	1.310	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01	Fountain				
51348	51348-1-HAL-F01	Main- Outside Boys Room, Right Fountain	Initial	15-JUN-16	0.999	ppb
51348	51348-1-HAL-F01	Main- Outside Boys Room, Right Fountain	Initial	09-NOV-21	1.000	ug/L
51348	51348-3-HAL-F01	Main- Outside Girls Room, North End Fountain	Flush180	15-JUN-16	0.123	ppb
51348	51348-3-HAL-F01	Main- Outside Girls Room, North End Fountain	Flush180	15-JUN-16	0.272	ppb
51348	51348-3-HAL-F01	Main- Outside Girls Room, North End Fountain	Flush180	15-JUN-16	0.231	ppb
51348	51348-3-HAL-F01	Main- Outside Girls Room, North End Fountain	Flush180	15-JUN-16	0.252	ppb
51348	51348-3-HAL-F01	Main- Outside Girls Room, North End Fountain	Flush180	09-NOV-21	1.000	ug/L
51348	51348-3-HAL-F01	Main- Outside Girls Room, North End Fountain	Flush180	09-NOV-21	1.000	ug/L
51348	51348-3-HAL-F01	Main- Outside Girls Room, North End Fountain	Flush180	09-NOV-21	1.000	ug/L
51348	51348-3-HAL-F01	Main- Outside Girls Room, North End Fountain	Initial	15-JUN-16	1.000	ppb
51348	51348-3-HAL-F01	Main- Outside Girls Room, North End Fountain	Initial	09-NOV-21	1.000	ug/L
51348	51348-2-HAL-F01	Main- Outside Girls Room, South End Fountain	Flush180	15-JUN-16	0.140	ppb
51348	51348-2-HAL-F01	Main- Outside Girls Room, South End Fountain	Flush180	15-JUN-16	1.000	ppb
51348	51348-2-HAL-F01	Main- Outside Girls Room, South End Fountain	Flush180	15-JUN-16	1.000	ppb
51348	51348-2-HAL-F01	Main- Outside Girls Room, South End Fountain	Flush180	15-JUN-16	0.207	ppb
51348	51348-2-HAL-F01	Main- Outside Girls Room, South End Fountain	Flush180	09-NOV-21	1.000	ug/L
51348	51348-2-HAL-F01	Main- Outside Girls Room, South End Fountain	Flush180	09-NOV-21	1.000	ug/L
51348	51348-2-HAL-F01	Main- Outside Girls Room, South End Fountain	Flush180	09-NOV-21	1.000	ug/L
51348	51348-2-HAL-F01	Main- Outside Girls Room, South End Fountain	Initial	15-JUN-16	1.000	ppb
51348	51348-2-HAL-F01	Main- Outside Girls Room, South End Fountain	Initial	09-NOV-21	1.000	ug/L
51348	51348-1-HAL-F03	Main- Outside Room 103, Fountain	Flush180	15-JUN-16	0.476	ppb
51348	51348-1-HAL-F03	Main- Outside Room 103, Fountain	Flush180	15-JUN-16	0.609	ppb
51348	51348-1-HAL-F03	Main- Outside Room 103, Fountain	Flush180	15-JUN-16	0.732	ppb
51348	51348-1-HAL-F03	Main- Outside Room 103, Fountain	Flush180	15-JUN-16	0.831	ppb
51348	51348-1-HAL-F03	Main- Outside Room 103, Fountain	Initial	15-JUN-16	0.255	ppb
51348	51348-2-HAL-F02	Main- Outside Room 202, Fountain	Flush180	15-JUN-16	0.552	ppb
51348	51348-2-HAL-F02	Main- Outside Room 202, Fountain	Flush180	15-JUN-16	0.390	ppb
51348	51348-2-HAL-F02	Main- Outside Room 202, Fountain	Flush180	15-JUN-16	0.446	ppb
51348	51348-2-HAL-F02	Main- Outside Room 202, Fountain	Flush180	15-JUN-16	0.287	ppb
51348	51348-2-HAL-F02	Main- Outside Room 202, Fountain	Initial	15-JUN-16	0.220	ppb
51348	51348-3-HAL-F02	Main- Outside Room 302, Fountain	Flush180	15-JUN-16	0.338	ppb
51348	51348-3-HAL-F02	Main- Outside Room 302, Fountain	Flush180	15-JUN-16	0.453	ppb
51348	51348-3-HAL-F02	Main- Outside Room 302, Fountain	Flush180	15-JUN-16	0.281	ppb
51348	51348-3-HAL-F02	Main- Outside Room 302, Fountain	Flush180	15-JUN-16	0.434	ppb
51348	51348-3-HAL-F02	Main- Outside Room 302, Fountain	Flush180	24-JUL-20	1.000	ug/L

Water Quality Assessment
William W Carter Elementary School

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02	Fountain				
51348	51348-3-HAL-F02	Main- Outside Room 302, Fountain	Initial	15-JUN-16	0.272	ppb
51348	51348-3-HAL-F02	Main- Outside Room 302, Fountain	Initial	24-JUL-20	1.000	ug/L