



Sep 10, 2024

CARVER G

901 E 133RD PL, Chicago IL 60827.

Dear **CARVER G** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

CARVER G

901 E 133RD PL, Chicago IL 60827.

Estimadas familias de **CARVER G**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51499	51499-2-N-HAL-F03		Flush180	28-JUL-20	3.080	ug/L
51499	51499-1-S-HAL-F03		Flush180	11-FEB-20	1.000	ug/L
51499	51499-1-S-HAL-F03		Flush180	11-FEB-20	1.000	ug/L
51499	51499-1-S-HAL-F03		Flush180	11-FEB-20	1.000	ug/L
51499	51499-1-S-HAL-F03		Flush180	11-FEB-20	1.000	ug/L
51499	51499-2-N-HAL-F03		Flush180	11-FEB-20	1.000	ug/L
51499	51499-2-N-HAL-F03		Flush180	11-FEB-20	1.000	ug/L
51499	51499-2-N-HAL-F03		Flush180	11-FEB-20	1.000	ug/L
51499	51499-2-N-HAL-F03		Flush180	11-FEB-20	1.000	ug/L
51499	51499-2-N-HAL-F03		Initial	28-JUL-20	2.050	ug/L
51499	51499-1-S-HAL-F03		Initial	11-FEB-20	1.580	ug/L
51499	51499-2-N-HAL-F03		Initial	11-FEB-20	1.000	ug/L
51499	51499-1-N-HAL-F01	Main- Fountain Across Room 101	Flush180	01-JUN-16	0.779	ppb
51499	51499-1-N-HAL-F01	Main- Fountain Across Room 101	Flush180	01-JUN-16	0.755	ppb
51499	51499-1-N-HAL-F01	Main- Fountain Across Room 101	Flush180	01-JUN-16	0.853	ppb
51499	51499-1-N-HAL-F01	Main- Fountain Across Room 101	Flush180	01-JUN-16	0.757	ppb
51499	51499-1-N-HAL-F01	Main- Fountain Across Room 101	Flush180	05-MAR-20	1.000	ug/L
51499	51499-1-N-HAL-F01	Main- Fountain Across Room 101	Flush180	05-MAR-20	1.000	ug/L
51499	51499-1-N-HAL-F01	Main- Fountain Across Room 101	Flush180	05-MAR-20	1.000	ug/L
51499	51499-1-N-HAL-F01	Main- Fountain Across Room 101	Flush180	05-MAR-20	1.000	ug/L
51499	51499-1-N-HAL-F01	Main- Fountain Across Room 101	Flush180	11-FEB-20	5.530	ug/L
51499	51499-1-N-HAL-F01	Main- Fountain Across Room 101	Flush180	11-FEB-20	2.350	ug/L
51499	51499-1-N-HAL-F01	Main- Fountain Across Room 101	Flush180	11-FEB-20	5.640	ug/L
51499	51499-1-N-HAL-F01	Main- Fountain Across Room 101	Flush180	11-FEB-20	3.430	ug/L
51499	51499-1-N-HAL-F01	Main- Fountain Across Room 101	Initial	01-JUN-16	1.400	ppb
51499	51499-1-N-HAL-F01	Main- Fountain Across Room 101	Initial	05-MAR-20	1.260	ug/L
51499	51499-1-N-HAL-F01	Main- Fountain Across Room 101	Initial	11-FEB-20	2.260	ug/L
51499	51499-1-S-HAL-F02	Main- Fountain Across Room 110	Flush180	01-JUN-16	0.154	ppb
51499	51499-1-S-HAL-F02	Main- Fountain Across Room 110	Flush180	01-JUN-16	1.000	ppb
51499	51499-1-S-HAL-F02	Main- Fountain Across Room 110	Flush180	01-JUN-16	1.000	ppb
51499	51499-1-HAL-F02	Main- Fountain Across Room 110	Flush180	01-JUN-16	0.122	ppb
51499	51499-1-HAL-F02	Main- Fountain Across Room 110	Flush180	28-JUL-20	1.360	ug/L
51499	51499-1-S-HAL-F02	Main- Fountain Across Room 110	Flush180	11-FEB-20	1.000	ug/L
51499	51499-1-S-HAL-F02	Main- Fountain Across Room 110	Flush180	11-FEB-20	1.000	ug/L
51499	51499-1-S-HAL-F02	Main- Fountain Across Room 110	Flush180	11-FEB-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51499	51499-1-S-HAL-F02	Main- Fountain Across Room 110	Flush180	11-FEB-20	1.000	ug/L
51499	51499-1-S-HAL-F02	Main- Fountain Across Room 110	Initial	01-JUN-16	0.583	ppb
51499	51499-1-HAL-F02	Main- Fountain Across Room 110	Initial	28-JUL-20	4.490	ug/L
51499	51499-1-S-HAL-F02	Main- Fountain Across Room 110	Initial	11-FEB-20	1.360	ug/L
51499	51499-2-N-HAL-F02	Main- Fountain Across Room 210	Flush180	01-JUN-16	0.747	ppb
51499	51499-2-N-HAL-F02	Main- Fountain Across Room 210	Flush180	01-JUN-16	0.611	ppb
51499	51499-2-N-HAL-F02	Main- Fountain Across Room 210	Flush180	01-JUN-16	0.682	ppb
51499	51499-2-N-HAL-F02	Main- Fountain Across Room 210	Flush180	01-JUN-16	0.622	ppb
51499	51499-2-N-HAL-F02	Main- Fountain Across Room 210	Flush180	11-FEB-20	1.590	ug/L
51499	51499-2-N-HAL-F02	Main- Fountain Across Room 210	Flush180	11-FEB-20	1.410	ug/L
51499	51499-2-N-HAL-F02	Main- Fountain Across Room 210	Flush180	11-FEB-20	1.000	ug/L
51499	51499-2-N-HAL-F02	Main- Fountain Across Room 210	Flush180	11-FEB-20	1.120	ug/L
51499	51499-2-N-HAL-F02	Main- Fountain Across Room 210	Initial	01-JUN-16	0.524	ppb
51499	51499-2-N-HAL-F02	Main- Fountain Across Room 210	Initial	11-FEB-20	1.270	ug/L
51499	51499-2-N-HAL-F01	Main- Fountain Next to Room 202	Flush180	01-JUN-16	2.090	ppb
51499	51499-2-N-HAL-F01	Main- Fountain Next to Room 202	Flush180	01-JUN-16	2.540	ppb
51499	51499-2-N-HAL-F01	Main- Fountain Next to Room 202	Flush180	01-JUN-16	3.250	ppb
51499	51499-2-N-HAL-F01	Main- Fountain Next to Room 202	Flush180	01-JUN-16	3.460	ppb
51499	51499-2-N-HAL-F01	Main- Fountain Next to Room 202	Flush180	11-FEB-20	2.370	ug/L
51499	51499-2-N-HAL-F01	Main- Fountain Next to Room 202	Flush180	11-FEB-20	3.180	ug/L
51499	51499-2-N-HAL-F01	Main- Fountain Next to Room 202	Flush180	11-FEB-20	2.660	ug/L
51499	51499-2-N-HAL-F01	Main- Fountain Next to Room 202	Flush180	11-FEB-20	2.270	ug/L
51499	51499-2-N-HAL-F01	Main- Fountain Next to Room 202	Initial	01-JUN-16	2.850	ppb
51499	51499-2-N-HAL-F01	Main- Fountain Next to Room 202	Initial	11-FEB-20	2.530	ug/L
51529	51529-1-HAL-F01	Bldg D- Across Main Office, North Fountain	Flush180	01-JUN-16	0.647	ppb
51529	51529-1-HAL-F01	Bldg D- Across Main Office, North Fountain	Flush180	01-JUN-16	0.538	ppb
51529	51529-1-HAL-F01	Bldg D- Across Main Office, North Fountain	Flush180	01-JUN-16	0.512	ppb
51529	51529-1-HAL-F01	Bldg D- Across Main Office, North Fountain	Flush180	01-JUN-16	0.577	ppb
51529	51529-1-HAL-F01	Bldg D- Across Main Office, North Fountain	Initial	01-JUN-16	1.390	ppb
51529	51529-1-W-HAL-F02	Bldg D- Across Main Office, South Fountain	Flush180	01-JUN-16	0.596	ppb
51529	51529-1-W-HAL-F02	Bldg D- Across Main Office, South Fountain	Flush180	01-JUN-16	1.060	ppb
51529	51529-1-W-HAL-F02	Bldg D- Across Main Office, South Fountain	Flush180	01-JUN-16	0.704	ppb
51529	51529-1-W-HAL-F02	Bldg D- Across Main Office, South Fountain	Flush180	01-JUN-16	0.735	ppb
51529	51529-1-W-HAL-F02	Bldg D- Across Main Office, South Fountain	Flush180	11-FEB-20	1.280	ug/L
51529	51529-1-W-HAL-F02	Bldg D- Across Main Office, South Fountain	Flush180	11-FEB-20	1.080	ug/L
51529	51529-1-W-HAL-F02	Bldg D- Across Main Office, South Fountain	Flush180	11-FEB-20	1.160	ug/L
51529	51529-1-W-HAL-F02	Bldg D- Across Main Office, South Fountain	Flush180	11-FEB-20	1.290	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51529	51529-1-W-HAL-F02	Bldg D- Across Main Office, South Fountain	Initial	01-JUN-16	0.928	ppb
51529	51529-1-W-HAL-F02	Bldg D- Across Main Office, South Fountain	Initial	11-FEB-20	1.310	ug/L
51529	51529-1-S-HAL-F04	Bldg D- Across Room 310, East Center Fountain	Flush180	01-JUN-16	3.370	ppb
51529	51529-1-S-HAL-F04	Bldg D- Across Room 310, East Center Fountain	Flush180	01-JUN-16	3.270	ppb
51529	51529-1-S-HAL-F04	Bldg D- Across Room 310, East Center Fountain	Flush180	01-JUN-16	2.270	ppb
51529	51529-1-S-HAL-F04	Bldg D- Across Room 310, East Center Fountain	Flush180	01-JUN-16	3.400	ppb
51529	51529-1-S-HAL-F04	Bldg D- Across Room 310, East Center Fountain	Flush180	11-FEB-20	1.860	ug/L
51529	51529-1-S-HAL-F04	Bldg D- Across Room 310, East Center Fountain	Flush180	11-FEB-20	1.000	ug/L
51529	51529-1-S-HAL-F04	Bldg D- Across Room 310, East Center Fountain	Flush180	11-FEB-20	1.000	ug/L
51529	51529-1-S-HAL-F04	Bldg D- Across Room 310, East Center Fountain	Flush180	11-FEB-20	1.000	ug/L
51529	51529-1-S-HAL-F04	Bldg D- Across Room 310, East Center Fountain	Flush180	27-JUL-16	1.000	ppb
51529	51529-1-S-HAL-F04	Bldg D- Across Room 310, East Center Fountain	Flush180	27-JUL-16	1.000	ppb
51529	51529-1-S-HAL-F04	Bldg D- Across Room 310, East Center Fountain	Flush180	16-NOV-16	1.340	ppb
51529	51529-1-S-HAL-F04	Bldg D- Across Room 310, East Center Fountain	Flush180	16-NOV-16	1.900	ppb
51529	51529-1-S-HAL-F04	Bldg D- Across Room 310, East Center Fountain	Flush180	16-NOV-16	2.140	ppb
51529	51529-1-S-HAL-F04	Bldg D- Across Room 310, East Center Fountain	Flush180	16-NOV-16	1.530	ppb
51529	51529-1-S-HAL-F04	Bldg D- Across Room 310, East Center Fountain	Flush180	27-JUL-16	1.000	ppb
51529	51529-1-S-HAL-F04	Bldg D- Across Room 310, East Center Fountain	Flush180	27-JUL-16	1.000	ppb
51529	51529-1-S-HAL-F04	Bldg D- Across Room 310, East Center Fountain	Initial	11-FEB-20	1.350	ug/L
51529	51529-1-S-HAL-F04	Bldg D- Across Room 310, East Center Fountain	Initial	16-NOV-16	3.400	ppb
51529	51529-1-S-HAL-F04	Bldg D- Across Room 310, East Center Fountain	Initial	27-JUL-16	1.000	ppb
51529	51529-1-S-HAL-F04	Bldg D- Across Room 310, East Center Fountain	Initial	01-JUN-16	31.700	ppb
51529	51529-1-S-HAL-F03	Bldg D- Across Room 310, East Fountain	Flush180	01-JUN-16	1.120	ppb
51529	51529-1-S-HAL-F03	Bldg D- Across Room 310, East Fountain	Flush180	01-JUN-16	0.958	ppb
51529	51529-1-S-HAL-F03	Bldg D- Across Room 310, East Fountain	Flush180	01-JUN-16	0.842	ppb
51529	51529-1-S-HAL-F03	Bldg D- Across Room 310, East Fountain	Flush180	01-JUN-16	1.200	ppb
51529	51529-1-S-HAL-F03	Bldg D- Across Room 310, East Fountain	Flush180	28-JUL-20	1.500	ug/L
51529	51529-1-S-HAL-F03	Bldg D- Across Room 310, East Fountain	Flush180	11-FEB-20	1.410	ug/L
51529	51529-1-S-HAL-F03	Bldg D- Across Room 310, East Fountain	Flush180	11-FEB-20	1.110	ug/L
51529	51529-1-S-HAL-F03	Bldg D- Across Room 310, East Fountain	Flush180	11-FEB-20	1.000	ug/L
51529	51529-1-S-HAL-F03	Bldg D- Across Room 310, East Fountain	Flush180	11-FEB-20	1.000	ug/L
51529	51529-1-S-HAL-F03	Bldg D- Across Room 310, East Fountain	Initial	01-JUN-16	1.620	ppb
51529	51529-1-S-HAL-F03	Bldg D- Across Room 310, East Fountain	Initial	28-JUL-20	2.880	ug/L
51529	51529-1-S-HAL-F03	Bldg D- Across Room 310, East Fountain	Initial	11-FEB-20	1.880	ug/L
51529	51529-1-W-HAL-F05	Bldg D- Across Room 310, West Center Fountain	Flush180	11-FEB-20	1.000	ug/L
51529	51529-1-W-HAL-F05	Bldg D- Across Room 310, West Center Fountain	Flush180	11-FEB-20	2.090	ug/L
51529	51529-1-W-HAL-F05	Bldg D- Across Room 310, West Center Fountain	Flush180	11-FEB-20	1.720	ug/L
51529	51529-1-W-HAL-F05	Bldg D- Across Room 310, West Center Fountain	Flush180	11-FEB-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F05	Center Fountain				
51529	51529-1-W-HAL-F05	Bldg D- Across Room 310, West Center Fountain	Flush180	01-JUN-16	2.600	ppb
51529	51529-1-W-HAL-F05	Bldg D- Across Room 310, West Center Fountain	Flush180	01-JUN-16	1.830	ppb
51529	51529-1-W-HAL-F05	Bldg D- Across Room 310, West Center Fountain	Flush180	01-JUN-16	1.350	ppb
51529	51529-1-W-HAL-F05	Bldg D- Across Room 310, West Center Fountain	Flush180	01-JUN-16	1.420	ppb
51529	51529-1-W-HAL-F05	Bldg D- Across Room 310, West Center Fountain	Initial	11-FEB-20	1.260	ug/L
51529	51529-1-W-HAL-F05	Bldg D- Across Room 310, West Center Fountain	Initial	01-JUN-16	3.800	ppb
51529	51529-1-W-HAL-F06	Bldg D- Across Room 310, West Fountain	Flush180	11-FEB-20	1.010	ug/L
51529	51529-1-W-HAL-F06	Bldg D- Across Room 310, West Fountain	Flush180	11-FEB-20	1.000	ug/L
51529	51529-1-W-HAL-F06	Bldg D- Across Room 310, West Fountain	Flush180	11-FEB-20	1.070	ug/L
51529	51529-1-W-HAL-F06	Bldg D- Across Room 310, West Fountain	Flush180	11-FEB-20	1.000	ug/L
51529	51529-1-W-HAL-F06	Bldg D- Across Room 310, West Fountain	Flush180	01-JUN-16	1.440	ppb
51529	51529-1-W-HAL-F06	Bldg D- Across Room 310, West Fountain	Flush180	01-JUN-16	1.430	ppb
51529	51529-1-W-HAL-F06	Bldg D- Across Room 310, West Fountain	Flush180	01-JUN-16	1.530	ppb
51529	51529-1-W-HAL-F06	Bldg D- Across Room 310, West Fountain	Flush180	01-JUN-16	1.480	ppb
51529	51529-1-W-HAL-F06	Bldg D- Across Room 310, West Fountain	Initial	11-FEB-20	1.110	ug/L
51529	51529-1-W-HAL-F06	Bldg D- Across Room 310, West Fountain	Initial	01-JUN-16	2.540	ppb
51529	51529-1-S-313-S07	Bldg D- Inside Pre-K Room 313 Sink	Flush180	01-JUN-16	1.210	ppb
51529	51529-1-S-313-S07	Bldg D- Inside Pre-K Room 313 Sink	Flush180	01-JUN-16	1.360	ppb
51529	51529-1-S-313-S07	Bldg D- Inside Pre-K Room 313 Sink	Flush180	01-JUN-16	2.550	ppb
51529	51529-1-S-313-S07	Bldg D- Inside Pre-K Room 313 Sink	Flush180	01-JUN-16	2.890	ppb
51529	51529-1-S-313-S07	Bldg D- Inside Pre-K Room 313 Sink	Flush180	11-FEB-20	1.000	ug/L
51529	51529-1-S-313-S07	Bldg D- Inside Pre-K Room 313 Sink	Flush180	11-FEB-20	2.260	ug/L
51529	51529-1-S-313-S07	Bldg D- Inside Pre-K Room 313 Sink	Flush180	11-FEB-20	1.000	ug/L
51529	51529-1-S-313-S07	Bldg D- Inside Pre-K Room 313 Sink	Flush180	11-FEB-20	1.000	ug/L
51529	51529-1-S-313-S07	Bldg D- Inside Pre-K Room 313 Sink	Initial	01-JUN-16	1.300	ppb
51529	51529-1-S-313-S07	Bldg D- Inside Pre-K Room 313 Sink	Initial	11-FEB-20	1.000	ug/L
51529	51529-1-N-307-F01	Fountain in Clasroom 307	Flush180	28-JUL-20	1.000	ug/L
51529	51529-1-N-307-F01	Fountain in Clasroom 307	Initial	28-JUL-20	1.610	ug/L
52411	52411-1-W-HAL-F01	Bldg A- North Fountain, Next to Copy Room	Flush180	01-JUN-16	4.180	ppb
52411	52411-1-W-HAL-F01	Bldg A- North Fountain, Next to Copy Room	Flush180	27-JUL-16	1.000	ppb
52411	52411-1-W-HAL-F01	Bldg A- North Fountain, Next to Copy Room	Flush180	27-JUL-16	2.300	ppb
52411	52411-1-W-HAL-F01	Bldg A- North Fountain, Next to Copy Room	Flush180	16-NOV-16	1.230	ppb
52411	52411-1-W-HAL-F01	Bldg A- North Fountain, Next to Copy Room	Flush180	16-NOV-16	1.320	ppb
52411	52411-1-W-HAL-F01	Bldg A- North Fountain, Next to Copy Room	Flush180	16-NOV-16	1.260	ppb
52411	52411-1-W-HAL-F01	Bldg A- North Fountain, Next to Copy Room	Flush180	27-JUL-16	1.000	ppb
52411	52411-1-W-HAL-F01	Bldg A- North Fountain, Next to Copy Room	Flush180	16-NOV-16	1.850	ppb
52411	52411-1-W-	Bldg A- North Fountain, Next to	Flush180	27-JUL-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F01	Copy Room				
52411	52411-1-W-HAL-F01	Bldg A- North Fountain, Next to Copy Room	Flush180	01-JUN-16	6.180	ppb
52411	52411-1-W-HAL-F01	Bldg A- North Fountain, Next to Copy Room	Flush180	01-JUN-16	3.320	ppb
52411	52411-1-W-HAL-F01	Bldg A- North Fountain, Next to Copy Room	Flush180	01-JUN-16	16.300	ppb
52411	52411-1-W-HAL-F01	Bldg A- North Fountain, Next to Copy Room	Flush180	11-FEB-20	1.500	ug/L
52411	52411-1-W-HAL-F01	Bldg A- North Fountain, Next to Copy Room	Flush180	11-FEB-20	1.000	ug/L
52411	52411-1-W-HAL-F01	Bldg A- North Fountain, Next to Copy Room	Flush180	11-FEB-20	1.000	ug/L
52411	52411-1-W-HAL-F01	Bldg A- North Fountain, Next to Copy Room	Flush180	11-FEB-20	1.000	ug/L
52411	52411-1-W-HAL-F01	Bldg A- North Fountain, Next to Copy Room	Initial	16-NOV-16	2.710	ppb
52411	52411-1-W-HAL-F01	Bldg A- North Fountain, Next to Copy Room	Initial	27-JUL-16	2.100	ppb
52411	52411-1-W-HAL-F01	Bldg A- North Fountain, Next to Copy Room	Initial	11-FEB-20	1.000	ug/L
52411	52411-1-W-HAL-F01	Bldg A- North Fountain, Next to Copy Room	Initial	01-JUN-16	16.700	ppb
52411	52411-1-W-HAL-F03	Bldg A- North Fountain, Next to Teachers Lounge	Flush180	01-JUN-16	0.480	ppb
52411	52411-1-W-HAL-F03	Bldg A- North Fountain, Next to Teachers Lounge	Flush180	01-JUN-16	0.426	ppb
52411	52411-1-W-HAL-F03	Bldg A- North Fountain, Next to Teachers Lounge	Flush180	01-JUN-16	0.522	ppb
52411	52411-1-W-HAL-F03	Bldg A- North Fountain, Next to Teachers Lounge	Flush180	01-JUN-16	0.523	ppb
52411	52411-1-W-HAL-F03	Bldg A- North Fountain, Next to Teachers Lounge	Flush180	28-JUL-20	1.540	ug/L
52411	52411-1-W-HAL-F03	Bldg A- North Fountain, Next to Teachers Lounge	Flush180	11-FEB-20	1.000	ug/L
52411	52411-1-W-HAL-F03	Bldg A- North Fountain, Next to Teachers Lounge	Flush180	11-FEB-20	1.000	ug/L
52411	52411-1-W-HAL-F03	Bldg A- North Fountain, Next to Teachers Lounge	Flush180	11-FEB-20	1.000	ug/L
52411	52411-1-W-HAL-F03	Bldg A- North Fountain, Next to Teachers Lounge	Initial	01-JUN-16	0.751	ppb
52411	52411-1-W-HAL-F03	Bldg A- North Fountain, Next to Teachers Lounge	Initial	28-JUL-20	1.420	ug/L
52411	52411-1-W-HAL-F03	Bldg A- North Fountain, Next to Teachers Lounge	Initial	11-FEB-20	1.000	ug/L
52411	52411-1-W-HAL-F02	Bldg A- South Fountain, Next to Copy Room	Flush180	16-NOV-16	1.340	ppb
52411	52411-1-W-HAL-F02	Bldg A- South Fountain, Next to Copy Room	Flush180	01-JUN-16	4.930	ppb
52411	52411-1-W-HAL-F02	Bldg A- South Fountain, Next to Copy Room	Flush180	01-JUN-16	6.670	ppb
52411	52411-1-W-HAL-F02	Bldg A- South Fountain, Next to Copy Room	Flush180	01-JUN-16	9.350	ppb
52411	52411-1-W-HAL-F02	Bldg A- South Fountain, Next to Copy Room	Flush180	01-JUN-16	2.580	ppb
52411	52411-1-W-HAL-F02	Bldg A- South Fountain, Next to Copy Room	Flush180	02-SEP-16	1.000	ppb
52411	52411-1-W-HAL-F02	Bldg A- South Fountain, Next to Copy Room	Flush180	02-SEP-16	1.000	ppb
52411	52411-1-W-HAL-F02	Bldg A- South Fountain, Next to Copy Room	Flush180	02-SEP-16	1.000	ppb
52411	52411-1-W-HAL-F02	Bldg A- South Fountain, Next to Copy Room	Flush180	16-NOV-16	1.110	ppb
52411	52411-1-W-HAL-F02	Bldg A- South Fountain, Next to Copy Room	Flush180	16-NOV-16	1.170	ppb
52411	52411-1-W-HAL-F02	Bldg A- South Fountain, Next to Copy Room	Flush180	16-NOV-16	1.700	ppb
52411	52411-1-W-HAL-F02	Bldg A- South Fountain, Next to Copy Room	Flush180	28-JUL-20	1.000	ug/L
52411	52411-1-W-HAL-F02	Bldg A- South Fountain, Next to Copy Room	Flush180	11-FEB-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52411	52411-1-W-HAL-F02	Bldg A- South Fountain, Next to Copy Room	Flush180	11-FEB-20	1.000	ug/L
52411	52411-1-W-HAL-F02	Bldg A- South Fountain, Next to Copy Room	Flush180	11-FEB-20	1.000	ug/L
52411	52411-1-W-HAL-F02	Bldg A- South Fountain, Next to Copy Room	Flush180	11-FEB-20	1.000	ug/L
52411	52411-1-W-HAL-F02	Bldg A- South Fountain, Next to Copy Room	Initial	01-JUN-16	25.700	ppb
52411	52411-1-W-HAL-F02	Bldg A- South Fountain, Next to Copy Room	Initial	02-SEP-16	1.000	ppb
52411	52411-1-W-HAL-F02	Bldg A- South Fountain, Next to Copy Room	Initial	16-NOV-16	1.750	ppb
52411	52411-1-W-HAL-F02	Bldg A- South Fountain, Next to Copy Room	Initial	28-JUL-20	1.490	ug/L
52411	52411-1-W-HAL-F02	Bldg A- South Fountain, Next to Copy Room	Initial	11-FEB-20	1.000	ug/L
52411	52411-1-W-HAL-F04	Bldg A- South Fountain, Next to Teachers Lounge	Flush180	01-JUN-16	0.564	ppb
52411	52411-1-W-HAL-F04	Bldg A- South Fountain, Next to Teachers Lounge	Flush180	01-JUN-16	1.090	ppb
52411	52411-1-W-HAL-F04	Bldg A- South Fountain, Next to Teachers Lounge	Flush180	01-JUN-16	2.010	ppb
52411	52411-1-W-HAL-F04	Bldg A- South Fountain, Next to Teachers Lounge	Flush180	01-JUN-16	0.806	ppb
52411	52411-1-W-HAL-F04	Bldg A- South Fountain, Next to Teachers Lounge	Flush180	11-FEB-20	1.000	ug/L
52411	52411-1-W-HAL-F04	Bldg A- South Fountain, Next to Teachers Lounge	Flush180	11-FEB-20	1.000	ug/L
52411	52411-1-W-HAL-F04	Bldg A- South Fountain, Next to Teachers Lounge	Flush180	11-FEB-20	1.000	ug/L
52411	52411-1-W-HAL-F04	Bldg A- South Fountain, Next to Teachers Lounge	Flush180	11-FEB-20	1.000	ug/L
52411	52411-1-W-HAL-F04	Bldg A- South Fountain, Next to Teachers Lounge	Initial	01-JUN-16	4.550	ppb
52411	52411-1-W-HAL-F04	Bldg A- South Fountain, Next to Teachers Lounge	Initial	11-FEB-20	1.000	ug/L
52412	52412-1-S-KIT-KS02		Flush180	11-FEB-20	1.000	ug/L
52412	52412-1-S-KIT-KS02		Flush180	11-FEB-20	1.000	ug/L
52412	52412-1-S-KIT-KS02		Flush180	11-FEB-20	1.000	ug/L
52412	52412-1-S-KIT-KS02		Flush180	11-FEB-20	1.000	ug/L
52412	52412-1-S-KIT-KS03		Flush180	11-FEB-20	1.000	ug/L
52412	52412-1-S-KIT-KS03		Flush180	11-FEB-20	1.000	ug/L
52412	52412-1-S-KIT-KS03		Flush180	11-FEB-20	1.000	ug/L
52412	52412-1-S-KIT-KS03		Flush180	11-FEB-20	1.000	ug/L
52412	52412-1-S-KIT-KS02		Initial	11-FEB-20	1.000	ug/L
52412	52412-1-S-KIT-KS03		Initial	11-FEB-20	1.000	ug/L
52412	52412-1-S-GYM-S01	Bldg B- Gym Sink near stage	Flush180	28-JUL-20	1.000	ug/L
52412	52412-1-S-GYM-S01	Bldg B- Gym Sink near stage	Flush180	15-SEP-20	1.000	ug/L
52412	52412-1-S-GYM-S01	Bldg B- Gym Sink near stage	Flush180	15-SEP-20	1.000	ug/L
52412	52412-1-S-GYM-S01	Bldg B- Gym Sink near stage	Flush180	15-SEP-20	1.000	ug/L
52412	52412-1-S-GYM-S01	Bldg B- Gym Sink near stage	Flush180	15-SEP-20	1.000	ug/L
52412	52412-1-S-GYM-S01	Bldg B- Gym Sink near stage	Initial	28-JUL-20	8.190	ug/L
52412	52412-1-S-GYM-S01	Bldg B- Gym Sink near stage	Initial	15-SEP-20	4.880	ug/L
52412	52412-1-W-GYM-F03	Bldg. B- Gym, Center Fountain	Flush180	01-JUN-16	0.216	ppb
52412	52412-1-W-GYM-F03	Bldg. B- Gym, Center Fountain	Flush180	01-JUN-16	0.201	ppb

Water Quality Assessment George Washington Carver Primary School

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52412	52412-1-W-GYM-F03	Bldg. B- Gym, Center Fountain	Flush180	01-JUN-16	0.205	ppb
52412	52412-1-W-GYM-F03	Bldg. B- Gym, Center Fountain	Flush180	01-JUN-16	0.188	ppb
52412	52412-1-W-GYM-F03	Bldg. B- Gym, Center Fountain	Flush180	28-JUL-20	1.000	ug/L
52412	52412-1-W-GYM-F03	Bldg. B- Gym, Center Fountain	Flush180	11-FEB-20	1.000	ug/L
52412	52412-1-W-GYM-F03	Bldg. B- Gym, Center Fountain	Flush180	11-FEB-20	1.000	ug/L
52412	52412-1-W-GYM-F03	Bldg. B- Gym, Center Fountain	Flush180	11-FEB-20	1.000	ug/L
52412	52412-1-W-GYM-F03	Bldg. B- Gym, Center Fountain	Flush180	11-FEB-20	1.000	ug/L
52412	52412-1-W-GYM-F03	Bldg. B- Gym, Center Fountain	Initial	01-JUN-16	0.288	ppb
52412	52412-1-W-GYM-F03	Bldg. B- Gym, Center Fountain	Initial	28-JUL-20	2.470	ug/L
52412	52412-1-W-GYM-F03	Bldg. B- Gym, Center Fountain	Initial	11-FEB-20	1.000	ug/L
52412	52412-1-W-GYM-F02	Bldg. B- Gym, North Fountain	Flush180	01-JUN-16	0.292	ppb
52412	52412-1-W-GYM-F02	Bldg. B- Gym, North Fountain	Flush180	01-JUN-16	0.247	ppb
52412	52412-1-W-GYM-F02	Bldg. B- Gym, North Fountain	Flush180	01-JUN-16	0.245	ppb
52412	52412-1-W-GYM-F02	Bldg. B- Gym, North Fountain	Flush180	01-JUN-16	0.319	ppb
52412	52412-1-W-GYM-F02	Bldg. B- Gym, North Fountain	Flush180	11-FEB-20	1.000	ug/L
52412	52412-1-W-GYM-F02	Bldg. B- Gym, North Fountain	Flush180	11-FEB-20	1.000	ug/L
52412	52412-1-W-GYM-F02	Bldg. B- Gym, North Fountain	Flush180	11-FEB-20	1.000	ug/L
52412	52412-1-W-GYM-F02	Bldg. B- Gym, North Fountain	Flush180	11-FEB-20	1.000	ug/L
52412	52412-1-W-GYM-F02	Bldg. B- Gym, North Fountain	Initial	01-JUN-16	0.284	ppb
52412	52412-1-W-GYM-F02	Bldg. B- Gym, North Fountain	Initial	11-FEB-20	1.000	ug/L
52412	52412-1-W-GYM-F04	Bldg. B- Gym, South Fountain	Flush180	01-JUN-16	0.208	ppb
52412	52412-1-W-GYM-F04	Bldg. B- Gym, South Fountain	Flush180	01-JUN-16	0.172	ppb
52412	52412-1-W-GYM-F04	Bldg. B- Gym, South Fountain	Flush180	01-JUN-16	0.173	ppb
52412	52412-1-W-GYM-F04	Bldg. B- Gym, South Fountain	Flush180	01-JUN-16	0.168	ppb
52412	52412-1-W-GYM-F04	Bldg. B- Gym, South Fountain	Flush180	11-FEB-20	1.000	ug/L
52412	52412-1-W-GYM-F04	Bldg. B- Gym, South Fountain	Flush180	11-FEB-20	1.000	ug/L
52412	52412-1-W-GYM-F04	Bldg. B- Gym, South Fountain	Flush180	11-FEB-20	1.000	ug/L
52412	52412-1-W-GYM-F04	Bldg. B- Gym, South Fountain	Flush180	11-FEB-20	1.000	ug/L
52412	52412-1-W-GYM-F04	Bldg. B- Gym, South Fountain	Initial	01-JUN-16	0.343	ppb
52412	52412-1-W-GYM-F04	Bldg. B- Gym, South Fountain	Initial	11-FEB-20	1.000	ug/L
52412	52412-1-S-KIT-KS01	Bldg. B- Kitchen Sink	Flush180	01-JUN-16	0.841	ppb
52412	52412-1-S-KIT-KS01	Bldg. B- Kitchen Sink	Flush180	01-JUN-16	0.868	ppb
52412	52412-1-S-KIT-KS01	Bldg. B- Kitchen Sink	Flush180	01-JUN-16	0.895	ppb
52412	52412-1-S-KIT-KS01	Bldg. B- Kitchen Sink	Flush180	01-JUN-16	1.030	ppb
52412	52412-1-S-KIT-KS01	Bldg. B- Kitchen Sink	Flush180	11-FEB-20	1.000	ug/L
52412	52412-1-S-KIT-KS01	Bldg. B- Kitchen Sink	Flush180	11-FEB-20	1.000	ug/L
52412	52412-1-S-KIT-KS01	Bldg. B- Kitchen Sink	Flush180	11-FEB-20	1.000	ug/L
52412	52412-1-S-KIT-KS01	Bldg. B- Kitchen Sink	Flush180	11-FEB-20	1.170	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KIT-KS01					
52412	52412-1-S-KIT-KS01	Bldg. B- Kitchen Sink	Initial	01-JUN-16	1.700	ppb
52412	52412-1-S-KIT-KS01	Bldg. B- Kitchen Sink	Initial	11-FEB-20	1.000	ug/L