



Sep 10, 2024

CASELL

11314 S SPAULDING AVE, Chicago IL 60655.

Dear **CASELL** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

CASELL

11314 S SPAULDING AVE, Chicago IL 60655.

Estimadas familias de **CASELL**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarle y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51426	51426-1-N-HAL-F02	Main- 1st Floor Adjacent to Lunch Room, Left Fountain	Flush180	05-DEC-19	1.000	ug/L
51426	51426-1-N-HAL-F02	Main- 1st Floor Adjacent to Lunch Room, Left Fountain	Flush180	05-DEC-19	1.000	ug/L
51426	51426-1-N-HAL-F02	Main- 1st Floor Adjacent to Lunch Room, Left Fountain	Flush180	05-DEC-19	1.000	ug/L
51426	51426-1-N-HAL-F02	Main- 1st Floor Adjacent to Lunch Room, Left Fountain	Flush180	05-DEC-19	1.000	ug/L
51426	51426-1-N-HAL-F02	Main- 1st Floor Adjacent to Lunch Room, Left Fountain	Flush180	21-SEP-16	1.000	ppb
51426	51426-1-N-HAL-F02	Main- 1st Floor Adjacent to Lunch Room, Left Fountain	Flush180	21-SEP-16	1.000	ppb
51426	51426-1-N-HAL-F02	Main- 1st Floor Adjacent to Lunch Room, Left Fountain	Flush180	21-SEP-16	1.000	ppb
51426	51426-1-N-HAL-F02	Main- 1st Floor Adjacent to Lunch Room, Left Fountain	Flush180	21-SEP-16	1.000	ppb
51426	51426-1-N-HAL-F02	Main- 1st Floor Adjacent to Lunch Room, Left Fountain	Initial	05-DEC-19	1.000	ug/L
51426	51426-1-N-HAL-F02	Main- 1st Floor Adjacent to Lunch Room, Left Fountain	Initial	21-SEP-16	1.000	ppb
51426	51426-1-N-HAL-F01	Main- 1st Floor Adjacent to Lunch Room, Right Fountain	Flush180	21-SEP-16	1.000	ppb
51426	51426-1-N-HAL-F01	Main- 1st Floor Adjacent to Lunch Room, Right Fountain	Flush180	21-SEP-16	1.000	ppb
51426	51426-1-N-HAL-F01	Main- 1st Floor Adjacent to Lunch Room, Right Fountain	Flush180	21-SEP-16	1.000	ppb
51426	51426-1-N-HAL-F01	Main- 1st Floor Adjacent to Lunch Room, Right Fountain	Flush180	21-SEP-16	1.000	ppb
51426	51426-1-N-HAL-F01	Main- 1st Floor Adjacent to Lunch Room, Right Fountain	Flush180	05-DEC-19	1.000	ug/L
51426	51426-1-N-HAL-F01	Main- 1st Floor Adjacent to Lunch Room, Right Fountain	Flush180	05-DEC-19	1.000	ug/L
51426	51426-1-N-HAL-F01	Main- 1st Floor Adjacent to Lunch Room, Right Fountain	Flush180	05-DEC-19	1.000	ug/L
51426	51426-1-N-HAL-F01	Main- 1st Floor Adjacent to Lunch Room, Right Fountain	Flush180	05-DEC-19	1.000	ug/L
51426	51426-1-N-HAL-F01	Main- 1st Floor Adjacent to Lunch Room, Right Fountain	Flush180	04-AUG-20	1.000	ug/L
51426	51426-1-N-HAL-F01	Main- 1st Floor Adjacent to Lunch Room, Right Fountain	Initial	21-SEP-16	1.000	ppb
51426	51426-1-N-HAL-F01	Main- 1st Floor Adjacent to Lunch Room, Right Fountain	Initial	05-DEC-19	1.000	ug/L
51426	51426-1-N-HAL-F01	Main- 1st Floor Adjacent to Lunch Room, Right Fountain	Initial	04-AUG-20	1.000	ug/L
51426	51426-1-E-101-F01	Main- 1st Floor Inside Room 101, Fountain	Flush180	21-SEP-16	3.200	ppb
51426	51426-1-E-101-F01	Main- 1st Floor Inside Room 101, Fountain	Flush180	21-SEP-16	3.000	ppb
51426	51426-1-E-101-F01	Main- 1st Floor Inside Room 101, Fountain	Flush180	21-SEP-16	3.100	ppb
51426	51426-1-E-101-F01	Main- 1st Floor Inside Room 101, Fountain	Flush180	21-SEP-16	3.000	ppb
51426	51426-1-E-101-F01	Main- 1st Floor Inside Room 101, Fountain	Flush180	05-DEC-19	5.140	ug/L
51426	51426-1-E-101-F01	Main- 1st Floor Inside Room 101, Fountain	Flush180	05-DEC-19	5.880	ug/L
51426	51426-1-E-101-F01	Main- 1st Floor Inside Room 101, Fountain	Flush180	05-DEC-19	5.800	ug/L
51426	51426-1-E-101-F01	Main- 1st Floor Inside Room 101, Fountain	Flush180	05-DEC-19	5.480	ug/L
51426	51426-1-E-101-F01	Main- 1st Floor Inside Room 101, Fountain	Initial	21-SEP-16	7.200	ppb
51426	51426-1-E-101-F01	Main- 1st Floor Inside Room 101, Fountain	Initial	05-DEC-19	8.050	ug/L
51426	51426-1-E-101-S01	Main- 1st Floor Inside Room 101, Sink	Flush180	27-JUN-23	2.580	ug/L
51426	51426-1-E-101-S01	Main- 1st Floor Inside Room 101, Sink	Flush180	27-JUN-23	2.210	ug/L
51426	51426-1-E-101-S01	Main- 1st Floor Inside Room 101, Sink	Flush180	27-JUN-23	2.840	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51426	51426-1-E-101-S01	Main- 1st Floor Inside Room 101, Sink	Flush180	27-JUN-23	2.280	ug/L
51426	51426-1-E-101-S01	Main- 1st Floor Inside Room 101, Sink	Flush180	05-DEC-19	5.340	ug/L
51426	51426-1-E-101-S01	Main- 1st Floor Inside Room 101, Sink	Flush180	05-DEC-19	4.820	ug/L
51426	51426-1-E-101-S01	Main- 1st Floor Inside Room 101, Sink	Flush180	05-DEC-19	3.790	ug/L
51426	51426-1-E-101-S01	Main- 1st Floor Inside Room 101, Sink	Flush180	05-DEC-19	2.570	ug/L
51426	51426-1-E-101-S01	Main- 1st Floor Inside Room 101, Sink	Flush180	18-FEB-20	1.360	ug/L
51426	51426-1-E-101-S01	Main- 1st Floor Inside Room 101, Sink	Flush180	18-FEB-20	1.300	ug/L
51426	51426-1-E-101-S01	Main- 1st Floor Inside Room 101, Sink	Flush180	18-FEB-20	1.120	ug/L
51426	51426-1-E-101-S01	Main- 1st Floor Inside Room 101, Sink	Flush180	18-FEB-20	1.030	ug/L
51426	51426-1-E-101-S01	Main- 1st Floor Inside Room 101, Sink	Initial	27-JUN-23	2.240	ug/L
51426	51426-1-E-101-S01	Main- 1st Floor Inside Room 101, Sink	Initial	05-DEC-19	5.330	ug/L
51426	51426-1-E-101-S01	Main- 1st Floor Inside Room 101, Sink	Initial	18-FEB-20	1.330	ug/L
51426	51426-1-W-102-F01	Main- 1st Floor Inside Room 102, Fountain	Flush180	05-DEC-19	2.920	ug/L
51426	51426-1-W-102-F01	Main- 1st Floor Inside Room 102, Fountain	Flush180	05-DEC-19	3.540	ug/L
51426	51426-1-W-102-F01	Main- 1st Floor Inside Room 102, Fountain	Flush180	05-DEC-19	4.350	ug/L
51426	51426-1-W-102-F01	Main- 1st Floor Inside Room 102, Fountain	Flush180	05-DEC-19	4.140	ug/L
51426	51426-1-W-102-F01	Main- 1st Floor Inside Room 102, Fountain	Initial	05-DEC-19	2.300	ug/L
51426	51426-1-W-102-S01	Main- 1st Floor Inside Room 102, Sink	Flush180	20-JUL-23	1.000	ug/L
51426	51426-1-W-102-S01	Main- 1st Floor Inside Room 102, Sink	Flush180	20-JUL-23	1.000	ug/L
51426	51426-1-W-102-S01	Main- 1st Floor Inside Room 102, Sink	Flush180	20-JUL-23	1.000	ug/L
51426	51426-1-W-102-S01	Main- 1st Floor Inside Room 102, Sink	Flush180	20-JUL-23	1.000	ug/L
51426	51426-1-W-102-S01	Main- 1st Floor Inside Room 102, Sink	Flush180	27-JUN-23	9.110	ug/L
51426	51426-1-W-102-S01	Main- 1st Floor Inside Room 102, Sink	Flush180	27-JUN-23	5.540	ug/L
51426	51426-1-W-102-S01	Main- 1st Floor Inside Room 102, Sink	Flush180	27-JUN-23	4.550	ug/L
51426	51426-1-W-102-S01	Main- 1st Floor Inside Room 102, Sink	Flush180	27-JUN-23	4.750	ug/L
51426	51426-1-W-102-S01	Main- 1st Floor Inside Room 102, Sink	Flush180	05-DEC-19	42.100	ug/L
51426	51426-1-W-102-S01	Main- 1st Floor Inside Room 102, Sink	Flush180	05-DEC-19	18.400	ug/L
51426	51426-1-W-102-S01	Main- 1st Floor Inside Room 102, Sink	Flush180	05-DEC-19	16.900	ug/L
51426	51426-1-W-102-S01	Main- 1st Floor Inside Room 102, Sink	Flush180	05-DEC-19	16.400	ug/L
51426	51426-1-W-102-S01	Main- 1st Floor Inside Room 102, Sink	Flush180	18-FEB-20	7.170	ug/L
51426	51426-1-W-102-S01	Main- 1st Floor Inside Room 102, Sink	Flush180	18-FEB-20	4.810	ug/L
51426	51426-1-W-102-S01	Main- 1st Floor Inside Room 102, Sink	Flush180	18-FEB-20	6.930	ug/L
51426	51426-1-W-102-S01	Main- 1st Floor Inside Room 102, Sink	Flush180	18-FEB-20	2.750	ug/L
51426	51426-1-W-102-S01	Main- 1st Floor Inside Room 102, Sink	Initial	20-JUL-23	1.980	ug/L
51426	51426-1-W-102-S01	Main- 1st Floor Inside Room 102, Sink	Initial	27-JUN-23	6.380	ug/L
51426	51426-1-W-102-S01	Main- 1st Floor Inside Room 102, Sink	Initial	05-DEC-19	21.100	ug/L
51426	51426-1-W-102-S01	Main- 1st Floor Inside Room 102, Sink	Initial	18-FEB-20	15.300	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51426	51426-1-E-103-S01	Main- 1st Floor Inside Room 103, Sink	Flush180	05-DEC-19	1.600	ug/L
51426	51426-1-E-103-S01	Main- 1st Floor Inside Room 103, Sink	Flush180	05-DEC-19	1.490	ug/L
51426	51426-1-E-103-S01	Main- 1st Floor Inside Room 103, Sink	Flush180	05-DEC-19	1.390	ug/L
51426	51426-1-E-103-S01	Main- 1st Floor Inside Room 103, Sink	Flush180	05-DEC-19	2.130	ug/L
51426	51426-1-E-103-S01	Main- 1st Floor Inside Room 103, Sink	Initial	05-DEC-19	2.010	ug/L
51426	51426-1-W-104-F01	Main- 1st Floor Inside Room 104, Fountain	Flush180	21-SEP-16	2.400	ppb
51426	51426-1-W-104-F01	Main- 1st Floor Inside Room 104, Fountain	Flush180	21-SEP-16	2.600	ppb
51426	51426-1-W-104-F01	Main- 1st Floor Inside Room 104, Fountain	Flush180	21-SEP-16	2.600	ppb
51426	51426-1-W-104-F01	Main- 1st Floor Inside Room 104, Fountain	Flush180	21-SEP-16	2.500	ppb
51426	51426-1-W-104-F01	Main- 1st Floor Inside Room 104, Fountain	Flush180	05-DEC-19	1.030	ug/L
51426	51426-1-W-104-F01	Main- 1st Floor Inside Room 104, Fountain	Flush180	05-DEC-19	1.080	ug/L
51426	51426-1-W-104-S01	Main- 1st Floor Inside Room 104, Fountain	Flush180	05-DEC-19	1.390	ug/L
51426	51426-1-W-104-S01	Main- 1st Floor Inside Room 104, Fountain	Flush180	05-DEC-19	1.240	ug/L
51426	51426-1-W-104-S01	Main- 1st Floor Inside Room 104, Fountain	Flush180	05-DEC-19	1.130	ug/L
51426	51426-1-W-104-S01	Main- 1st Floor Inside Room 104, Fountain	Flush180	05-DEC-19	1.440	ug/L
51426	51426-1-W-104-F01	Main- 1st Floor Inside Room 104, Fountain	Flush180	05-DEC-19	1.360	ug/L
51426	51426-1-W-104-F01	Main- 1st Floor Inside Room 104, Fountain	Flush180	05-DEC-19	1.050	ug/L
51426	51426-1-W-104-F01	Main- 1st Floor Inside Room 104, Fountain	Initial	21-SEP-16	6.400	ppb
51426	51426-1-W-104-S01	Main- 1st Floor Inside Room 104, Fountain	Initial	05-DEC-19	2.050	ug/L
51426	51426-1-W-104-F01	Main- 1st Floor Inside Room 104, Fountain	Initial	05-DEC-19	1.450	ug/L
51426	51426-1-E-105-F01	Main- 1st Floor Inside Room 105, Fountain	Flush180	21-SEP-16	2.600	ppb
51426	51426-1-E-105-F01	Main- 1st Floor Inside Room 105, Fountain	Flush180	21-SEP-16	2.200	ppb
51426	51426-1-E-105-F01	Main- 1st Floor Inside Room 105, Fountain	Flush180	21-SEP-16	2.100	ppb
51426	51426-1-E-105-F01	Main- 1st Floor Inside Room 105, Fountain	Flush180	21-SEP-16	2.900	ppb
51426	51426-1-E-105-F01	Main- 1st Floor Inside Room 105, Fountain	Flush180	05-DEC-19	1.960	ug/L
51426	51426-1-E-105-F01	Main- 1st Floor Inside Room 105, Fountain	Flush180	05-DEC-19	2.100	ug/L
51426	51426-1-E-105-F01	Main- 1st Floor Inside Room 105, Fountain	Flush180	05-DEC-19	1.870	ug/L
51426	51426-1-E-105-F01	Main- 1st Floor Inside Room 105, Fountain	Flush180	05-DEC-19	1.630	ug/L
51426	51426-1-E-105-F01	Main- 1st Floor Inside Room 105, Fountain	Initial	05-DEC-19	4.190	ug/L
51426	51426-1-E-105-S01	Main- 1st Floor Inside Room 105, Sink	Flush180	27-JUN-23	2.120	ug/L
51426	51426-1-E-105-S01	Main- 1st Floor Inside Room 105, Sink	Flush180	27-JUN-23	1.700	ug/L
51426	51426-1-E-105-S01	Main- 1st Floor Inside Room 105, Sink	Flush180	27-JUN-23	1.580	ug/L
51426	51426-1-E-105-S01	Main- 1st Floor Inside Room 105, Sink	Flush180	27-JUN-23	1.260	ug/L
51426	51426-1-E-105-S01	Main- 1st Floor Inside Room 105, Sink	Flush180	05-DEC-19	2.170	ug/L
51426	51426-1-E-105-S01	Main- 1st Floor Inside Room 105, Sink	Flush180	05-DEC-19	2.070	ug/L
51426	51426-1-E-105-S01	Main- 1st Floor Inside Room 105, Sink	Flush180	05-DEC-19	2.150	ug/L
51426	51426-1-E-105-S01	Main- 1st Floor Inside Room 105, Sink	Flush180	05-DEC-19	1.680	ug/L
51426	51426-1-E-	Main- 1st Floor Inside Room 105,	Flush180	18-FEB-20	250.00	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	105-S01	Sink			0	
51426	51426-1-E-105-S01	Main- 1st Floor Inside Room 105, Sink	Flush180	18-FEB-20	441.000	ug/L
51426	51426-1-E-105-S01	Main- 1st Floor Inside Room 105, Sink	Flush180	18-FEB-20	410.000	ug/L
51426	51426-1-E-105-S01	Main- 1st Floor Inside Room 105, Sink	Flush180	18-FEB-20	49.200	ug/L
51426	51426-1-E-105-S01	Main- 1st Floor Inside Room 105, Sink	Initial	27-JUN-23	3.420	ug/L
51426	51426-1-E-105-S01	Main- 1st Floor Inside Room 105, Sink	Initial	05-DEC-19	5.050	ug/L
51426	51426-1-E-105-S01	Main- 1st Floor Inside Room 105, Sink	Initial	18-FEB-20	582.000	ug/L
51426	51426-1-W-106-S01	Main- 1st Floor Inside Room 106, Sink	Flush180	05-DEC-19	1.220	ug/L
51426	51426-1-W-106-S01	Main- 1st Floor Inside Room 106, Sink	Flush180	05-DEC-19	1.000	ug/L
51426	51426-1-W-106-S01	Main- 1st Floor Inside Room 106, Sink	Flush180	05-DEC-19	1.000	ug/L
51426	51426-1-W-106-S01	Main- 1st Floor Inside Room 106, Sink	Flush180	05-DEC-19	1.390	ug/L
51426	51426-1-W-106-S01	Main- 1st Floor Inside Room 106, Sink	Initial	05-DEC-19	1.780	ug/L
51426	51426-1-E-107-F01	Main- 1st Floor Inside Room 107, Fountain	Flush180	05-DEC-19	4.240	ug/L
51426	51426-1-E-107-F01	Main- 1st Floor Inside Room 107, Fountain	Flush180	05-DEC-19	5.020	ug/L
51426	51426-1-E-107-F01	Main- 1st Floor Inside Room 107, Fountain	Flush180	05-DEC-19	4.520	ug/L
51426	51426-1-E-107-F01	Main- 1st Floor Inside Room 107, Fountain	Flush180	05-DEC-19	3.430	ug/L
51426	51426-1-E-107-F01	Main- 1st Floor Inside Room 107, Fountain	Initial	05-DEC-19	6.110	ug/L
51426	51426-1-E-107-S01	Main- 1st Floor Inside Room 107, Sink	Flush180	27-JUN-23	1.320	ug/L
51426	51426-1-E-107-S01	Main- 1st Floor Inside Room 107, Sink	Flush180	27-JUN-23	2.100	ug/L
51426	51426-1-E-107-S01	Main- 1st Floor Inside Room 107, Sink	Flush180	27-JUN-23	1.700	ug/L
51426	51426-1-E-107-S01	Main- 1st Floor Inside Room 107, Sink	Flush180	27-JUN-23	1.390	ug/L
51426	51426-1-E-107-S01	Main- 1st Floor Inside Room 107, Sink	Flush180	05-DEC-19	12.700	ug/L
51426	51426-1-E-107-S01	Main- 1st Floor Inside Room 107, Sink	Flush180	05-DEC-19	6.500	ug/L
51426	51426-1-E-107-S01	Main- 1st Floor Inside Room 107, Sink	Flush180	05-DEC-19	7.650	ug/L
51426	51426-1-E-107-S01	Main- 1st Floor Inside Room 107, Sink	Flush180	05-DEC-19	7.740	ug/L
51426	51426-1-E-107-S01	Main- 1st Floor Inside Room 107, Sink	Flush180	18-FEB-20	241.000	ug/L
51426	51426-1-E-107-S01	Main- 1st Floor Inside Room 107, Sink	Flush180	18-FEB-20	280.000	ug/L
51426	51426-1-E-107-S01	Main- 1st Floor Inside Room 107, Sink	Flush180	18-FEB-20	83.900	ug/L
51426	51426-1-E-107-S01	Main- 1st Floor Inside Room 107, Sink	Flush180	18-FEB-20	81.900	ug/L
51426	51426-1-E-107-S01	Main- 1st Floor Inside Room 107, Sink	Initial	27-JUN-23	2.630	ug/L
51426	51426-1-E-107-S01	Main- 1st Floor Inside Room 107, Sink	Initial	05-DEC-19	13.400	ug/L
51426	51426-1-E-107-S01	Main- 1st Floor Inside Room 107, Sink	Initial	18-FEB-20	338.000	ug/L
51426	51426-1-W-108-S01	Main- 1st Floor Inside Room 108, Sink	Flush180	21-SEP-16	2.700	ppb
51426	51426-1-W-108-S01	Main- 1st Floor Inside Room 108, Sink	Flush180	21-SEP-16	3.000	ppb
51426	51426-1-W-108-S01	Main- 1st Floor Inside Room 108, Sink	Flush180	21-SEP-16	4.200	ppb
51426	51426-1-W-108-S01	Main- 1st Floor Inside Room 108, Sink	Flush180	21-SEP-16	7.000	ppb
51426	51426-1-W-108-S01	Main- 1st Floor Inside Room 108, Sink	Flush180	08-SEP-17	3.600	ppb
51426	51426-1-W-108-S01	Main- 1st Floor Inside Room 108, Sink	Flush180	08-SEP-17	2.360	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	108-S01	Sink				
51426	51426-1-W-108-S01	Main- 1st Floor Inside Room 108, Sink	Flush180	08-SEP-17	2.680	ppb
51426	51426-1-W-108-S01	Main- 1st Floor Inside Room 108, Sink	Flush180	08-SEP-17	3.110	ppb
51426	51426-1-W-108-S01	Main- 1st Floor Inside Room 108, Sink	Flush180	05-DEC-19	3.000	ug/L
51426	51426-1-W-108-S01	Main- 1st Floor Inside Room 108, Sink	Flush180	05-DEC-19	4.250	ug/L
51426	51426-1-W-108-S01	Main- 1st Floor Inside Room 108, Sink	Flush180	05-DEC-19	2.580	ug/L
51426	51426-1-W-108-S01	Main- 1st Floor Inside Room 108, Sink	Flush180	05-DEC-19	2.090	ug/L
51426	51426-1-W-108-S01	Main- 1st Floor Inside Room 108, Sink	Initial	21-SEP-16	17.000	ppb
51426	51426-1-W-108-S01	Main- 1st Floor Inside Room 108, Sink	Initial	08-SEP-17	2.110	ppb
51426	51426-1-W-108-S01	Main- 1st Floor Inside Room 108, Sink	Initial	05-DEC-19	4.360	ug/L
51426	51426-1-S-109-S01	Main- 1st Floor Inside Room 109, Sink	Flush180	21-SEP-16	1.000	ppb
51426	51426-1-S-109-S01	Main- 1st Floor Inside Room 109, Sink	Flush180	21-SEP-16	1.000	ppb
51426	51426-1-S-109-S01	Main- 1st Floor Inside Room 109, Sink	Flush180	21-SEP-16	1.000	ppb
51426	51426-1-S-109-S01	Main- 1st Floor Inside Room 109, Sink	Flush180	05-DEC-19	1.000	ug/L
51426	51426-1-S-109-S01	Main- 1st Floor Inside Room 109, Sink	Flush180	05-DEC-19	1.000	ug/L
51426	51426-1-S-109-S01	Main- 1st Floor Inside Room 109, Sink	Flush180	05-DEC-19	1.000	ug/L
51426	51426-1-S-109-S01	Main- 1st Floor Inside Room 109, Sink	Flush180	05-DEC-19	1.000	ug/L
51426	51426-1-S-109-S01	Main- 1st Floor Inside Room 109, Sink	Initial	21-SEP-16	1.000	ppb
51426	51426-1-S-109-S01	Main- 1st Floor Inside Room 109, Sink	Initial	05-DEC-19	1.000	ug/L
51426	51426-1-W-110-S01	Main- 1st Floor Inside Room 110, Sink	Flush180	27-JUN-23	2.380	ug/L
51426	51426-1-W-110-S01	Main- 1st Floor Inside Room 110, Sink	Flush180	27-JUN-23	2.070	ug/L
51426	51426-1-W-110-S01	Main- 1st Floor Inside Room 110, Sink	Flush180	27-JUN-23	2.190	ug/L
51426	51426-1-W-110-S01	Main- 1st Floor Inside Room 110, Sink	Flush180	27-JUN-23	2.350	ug/L
51426	51426-1-W-110-S01	Main- 1st Floor Inside Room 110, Sink	Flush180	05-DEC-19	1.950	ug/L
51426	51426-1-W-110-S01	Main- 1st Floor Inside Room 110, Sink	Flush180	05-DEC-19	1.640	ug/L
51426	51426-1-W-110-S01	Main- 1st Floor Inside Room 110, Sink	Flush180	05-DEC-19	2.180	ug/L
51426	51426-1-W-110-S01	Main- 1st Floor Inside Room 110, Sink	Flush180	05-DEC-19	3.790	ug/L
51426	51426-1-W-110-S01	Main- 1st Floor Inside Room 110, Sink	Flush180	18-FEB-20	11.900	ug/L
51426	51426-1-W-110-S01	Main- 1st Floor Inside Room 110, Sink	Flush180	18-FEB-20	7.030	ug/L
51426	51426-1-W-110-S01	Main- 1st Floor Inside Room 110, Sink	Flush180	18-FEB-20	10.200	ug/L
51426	51426-1-W-110-S01	Main- 1st Floor Inside Room 110, Sink	Flush180	18-FEB-20	9.230	ug/L
51426	51426-1-W-110-S01	Main- 1st Floor Inside Room 110, Sink	Flush180	21-SEP-16	4.000	ppb
51426	51426-1-W-110-S01	Main- 1st Floor Inside Room 110, Sink	Initial	27-JUN-23	2.560	ug/L
51426	51426-1-W-110-S01	Main- 1st Floor Inside Room 110, Sink	Initial	05-DEC-19	5.850	ug/L
51426	51426-1-W-110-S01	Main- 1st Floor Inside Room 110, Sink	Initial	18-FEB-20	31.300	ug/L
51426	51426-1-W-113B-S01	Main- 1st Floor Inside Room 113B, Sink	Flush180	05-DEC-19	2.370	ug/L
51426	51426-1-W-113B-S01	Main- 1st Floor Inside Room 113B, Sink	Flush180	05-DEC-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51426	51426-1-W-113B-S01	Main- 1st Floor Inside Room 113B, Sink	Flush180	05-DEC-19	1.000	ug/L
51426	51426-1-W-113B-S01	Main- 1st Floor Inside Room 113B, Sink	Flush180	05-DEC-19	1.000	ug/L
51426	51426-1-W-113B-S01	Main- 1st Floor Inside Room 113B, Sink	Initial	05-DEC-19	4.000	ug/L
51426	51426-1-W-KIT-KS02	Main- 1st Floor Kitchen Left, Sink	Flush180	05-DEC-19	1.000	ug/L
51426	51426-1-W-KIT-KS02	Main- 1st Floor Kitchen Left, Sink	Flush180	05-DEC-19	1.000	ug/L
51426	51426-1-W-KIT-KS02	Main- 1st Floor Kitchen Left, Sink	Flush180	05-DEC-19	1.000	ug/L
51426	51426-1-W-KIT-KS02	Main- 1st Floor Kitchen Left, Sink	Flush180	05-DEC-19	1.000	ug/L
51426	51426-1-W-KIT-KS02	Main- 1st Floor Kitchen Left, Sink	Flush180	21-SEP-16	1.000	ppb
51426	51426-1-W-KIT-KS02	Main- 1st Floor Kitchen Left, Sink	Flush180	21-SEP-16	1.000	ppb
51426	51426-1-W-KIT-KS02	Main- 1st Floor Kitchen Left, Sink	Flush180	21-SEP-16	1.000	ppb
51426	51426-1-W-KIT-KS02	Main- 1st Floor Kitchen Left, Sink	Flush180	21-SEP-16	1.000	ppb
51426	51426-1-W-KIT-KS02	Main- 1st Floor Kitchen Left, Sink	Initial	05-DEC-19	1.000	ug/L
51426	51426-1-W-KIT-KS02	Main- 1st Floor Kitchen Left, Sink	Initial	21-SEP-16	1.000	ppb
51426	51426-1-W-KIT-KS01	Main- 1st Floor Kitchen Right, Sink	Flush180	05-DEC-19	1.000	ug/L
51426	51426-1-W-KIT-KS01	Main- 1st Floor Kitchen Right, Sink	Flush180	05-DEC-19	1.000	ug/L
51426	51426-1-W-KIT-KS01	Main- 1st Floor Kitchen Right, Sink	Flush180	05-DEC-19	1.000	ug/L
51426	51426-1-W-KIT-KS01	Main- 1st Floor Kitchen Right, Sink	Flush180	05-DEC-19	1.000	ug/L
51426	51426-1-W-KIT-KS01	Main- 1st Floor Kitchen Right, Sink	Flush180	21-SEP-16	1.000	ppb
51426	51426-1-W-KIT-KS01	Main- 1st Floor Kitchen Right, Sink	Flush180	21-SEP-16	1.000	ppb
51426	51426-1-W-KIT-KS01	Main- 1st Floor Kitchen Right, Sink	Flush180	21-SEP-16	1.000	ppb
51426	51426-1-W-KIT-KS01	Main- 1st Floor Kitchen Right, Sink	Flush180	21-SEP-16	1.000	ppb
51426	51426-1-W-KIT-KS01	Main- 1st Floor Kitchen Right, Sink	Initial	05-DEC-19	1.000	ug/L
51426	51426-1-W-KIT-KS01	Main- 1st Floor Kitchen Right, Sink	Initial	21-SEP-16	1.000	ppb
51426	51426-1-W-HAL-F04	Main-1st Floor Between Boys/Girls Bathroom Center,	Flush180	21-SEP-16	1.000	ppb
51426	51426-1-W-HAL-F04	Main-1st Floor Between Boys/Girls Bathroom Center,	Flush180	21-SEP-16	1.000	ppb
51426	51426-1-W-HAL-F04	Main-1st Floor Between Boys/Girls Bathroom Center,	Flush180	21-SEP-16	1.000	ppb
51426	51426-1-W-HAL-F04	Main-1st Floor Between Boys/Girls Bathroom Center,	Flush180	21-SEP-16	1.000	ppb
51426	51426-1-W-HAL-F04	Main-1st Floor Between Boys/Girls Bathroom Center,	Flush180	05-DEC-19	1.000	ug/L
51426	51426-1-W-HAL-F04	Main-1st Floor Between Boys/Girls Bathroom Center,	Flush180	05-DEC-19	1.000	ug/L
51426	51426-1-W-HAL-F04	Main-1st Floor Between Boys/Girls Bathroom Center,	Flush180	05-DEC-19	1.000	ug/L
51426	51426-1-W-HAL-F04	Main-1st Floor Between Boys/Girls Bathroom Center,	Flush180	05-DEC-19	1.000	ug/L
51426	51426-1-W-HAL-F04	Main-1st Floor Between Boys/Girls Bathroom Center,	Flush180	04-AUG-20	1.000	ug/L
51426	51426-1-W-HAL-F04	Main-1st Floor Between Boys/Girls Bathroom Center,	Initial	21-SEP-16	1.000	ppb
51426	51426-1-W-HAL-F04	Main-1st Floor Between Boys/Girls Bathroom Center,	Initial	05-DEC-19	1.000	ug/L
51426	51426-1-W-HAL-F04	Main-1st Floor Between Boys/Girls Bathroom Center,	Initial	04-AUG-20	1.500	ug/L
51426	51426-1-W-HAL-F05	Main-1st Floor Between Boys/Girls Bathroom Left,	Flush180	21-SEP-16	1.000	ppb
51426	51426-1-W-HAL-F05	Main-1st Floor Between Boys/Girls Bathroom Left,	Flush180	21-SEP-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F01	Room 502 Right, Fountain				
56241	56241-1-N-HAL-F01	Modular- 1st Floor Adjacent to Room 502 Right, Fountain	Initial	06-DEC-19	1.000	ug/L
56241	56241-1-N-HAL-F01	Modular- 1st Floor Adjacent to Room 502 Right, Fountain	Initial	21-SEP-16	1.000	ppb
56241	56241-1-N-HAL-F04	Modular- 1st Floor Adjacent to Staff Bathroom Left Fountain	Flush180	06-DEC-19	1.000	ug/L
56241	56241-1-N-HAL-F04	Modular- 1st Floor Adjacent to Staff Bathroom Left Fountain	Flush180	06-DEC-19	1.000	ug/L
56241	56241-1-N-HAL-F04	Modular- 1st Floor Adjacent to Staff Bathroom Left Fountain	Flush180	06-DEC-19	1.000	ug/L
56241	56241-1-N-HAL-F04	Modular- 1st Floor Adjacent to Staff Bathroom Left Fountain	Flush180	06-DEC-19	1.000	ug/L
56241	56241-1-N-HAL-F04	Modular- 1st Floor Adjacent to Staff Bathroom Left Fountain	Flush180	04-AUG-20	1.000	ug/L
56241	56241-1-N-HAL-F04	Modular- 1st Floor Adjacent to Staff Bathroom Left Fountain	Flush180	21-SEP-16	1.000	ppb
56241	56241-1-N-HAL-F04	Modular- 1st Floor Adjacent to Staff Bathroom Left Fountain	Flush180	21-SEP-16	1.000	ppb
56241	56241-1-N-HAL-F04	Modular- 1st Floor Adjacent to Staff Bathroom Left Fountain	Flush180	21-SEP-16	1.000	ppb
56241	56241-1-N-HAL-F04	Modular- 1st Floor Adjacent to Staff Bathroom Left Fountain	Initial	06-DEC-19	1.000	ug/L
56241	56241-1-N-HAL-F04	Modular- 1st Floor Adjacent to Staff Bathroom Left Fountain	Initial	04-AUG-20	3.720	ug/L
56241	56241-1-N-HAL-F04	Modular- 1st Floor Adjacent to Staff Bathroom Left Fountain	Initial	21-SEP-16	1.000	ppb
56241	56241-1-N-HAL-F03	Modular- 1st Floor Adjacent to Staff Bathroom Right Fountain	Flush180	06-DEC-19	1.000	ug/L
56241	56241-1-N-HAL-F03	Modular- 1st Floor Adjacent to Staff Bathroom Right Fountain	Flush180	06-DEC-19	1.000	ug/L
56241	56241-1-N-HAL-F03	Modular- 1st Floor Adjacent to Staff Bathroom Right Fountain	Flush180	06-DEC-19	1.000	ug/L
56241	56241-1-N-HAL-F03	Modular- 1st Floor Adjacent to Staff Bathroom Right Fountain	Flush180	21-SEP-16	1.000	ppb
56241	56241-1-N-HAL-F03	Modular- 1st Floor Adjacent to Staff Bathroom Right Fountain	Flush180	21-SEP-16	1.000	ppb
56241	56241-1-N-HAL-F03	Modular- 1st Floor Adjacent to Staff Bathroom Right Fountain	Flush180	21-SEP-16	1.000	ppb
56241	56241-1-N-HAL-F03	Modular- 1st Floor Adjacent to Staff Bathroom Right Fountain	Initial	06-DEC-19	1.000	ug/L
56241	56241-1-N-HAL-F03	Modular- 1st Floor Adjacent to Staff Bathroom Right Fountain	Initial	21-SEP-16	1.000	ppb