



Sep 10, 2024

CHASE

2021 N POINT ST, Chicago IL 60647.

Dear **CHASE** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

CHASE

2021 N POINT ST, Chicago IL 60647.

Estimadas familias de **CHASE**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51111	51111-1-KIT-KS10	Main, Kitchen Above Stove, Faucet	Flush180	21-JUN-16	217.00 0	ppb
51111	51111-1-KIT-KS10	Main, Kitchen Above Stove, Faucet	Flush180	21-JUN-16	76.100	ppb
51111	51111-1-KIT-KS10	Main, Kitchen Above Stove, Faucet	Flush180	21-JUN-16	137.00 0	ppb
51111	51111-1-KIT-KS10	Main, Kitchen Above Stove, Faucet	Flush180	21-JUN-16	318.00 0	ppb
51111	51111-1-KIT-KS10	Main, Kitchen Above Stove, Faucet	Initial	21-JUN-16	162.00 0	ppb
51111	51111-1-KIT-KS12	Main, Kitchen Serving Line, Sink	Flush180	21-JUN-16	1.000	ppb
51111	51111-1-KIT-KS12	Main, Kitchen Serving Line, Sink	Flush180	21-JUN-16	1.000	ppb
51111	51111-1-KIT-KS12	Main, Kitchen Serving Line, Sink	Flush180	21-JUN-16	1.000	ppb
51111	51111-1-KIT-KS12	Main, Kitchen Serving Line, Sink	Flush180	21-JUN-16	1.000	ppb
51111	51111-1-KIT-KS12	Main, Kitchen Serving Line, Sink	Initial	21-JUN-16	0.247	ppb
51111	51111-1-KIT-KS07	Main, Kitchen Tray Center Sink	Flush180	21-JUN-16	0.152	ppb
51111	51111-1-KIT-KS07	Main, Kitchen Tray Center Sink	Flush180	21-JUN-16	0.237	ppb
51111	51111-1-KIT-KS07	Main, Kitchen Tray Center Sink	Flush180	21-JUN-16	0.144	ppb
51111	51111-1-KIT-KS07	Main, Kitchen Tray Center Sink	Flush180	21-JUN-16	0.547	ppb
51111	51111-1-KIT-KS07	Main, Kitchen Tray Center Sink	Initial	21-JUN-16	0.799	ppb
51111	51111-1-KIT-KS06	Main, Kitchen Tray Left Sink	Flush180	21-JUN-16	0.525	ppb
51111	51111-1-KIT-KS06	Main, Kitchen Tray Left Sink	Flush180	21-JUN-16	0.649	ppb
51111	51111-1-KIT-KS06	Main, Kitchen Tray Left Sink	Flush180	21-JUN-16	0.379	ppb
51111	51111-1-KIT-KS06	Main, Kitchen Tray Left Sink	Flush180	21-JUN-16	0.547	ppb
51111	51111-1-KIT-KS06	Main, Kitchen Tray Left Sink	Initial	21-JUN-16	0.834	ppb
51111	51111-1-KIT-KS08	Main, Kitchen Tray Right Sink	Flush180	21-JUN-16	0.157	ppb
51111	51111-1-KIT-KS08	Main, Kitchen Tray Right Sink	Flush180	21-JUN-16	1.000	ppb
51111	51111-1-KIT-KS08	Main, Kitchen Tray Right Sink	Flush180	21-JUN-16	1.000	ppb
51111	51111-1-KIT-KS08	Main, Kitchen Tray Right Sink	Flush180	21-JUN-16	0.167	ppb
51111	51111-1-KIT-KS08	Main, Kitchen Tray Right Sink	Initial	21-JUN-16	0.950	ppb
51111	51111-1-KIT-KS05	Main, Kitchen, Island Sink, East Side	Flush180	21-JUN-16	0.175	ppb
51111	51111-1-KIT-KS05	Main, Kitchen, Island Sink, East Side	Flush180	21-JUN-16	1.000	ppb
51111	51111-1-KIT-KS05	Main, Kitchen, Island Sink, East Side	Flush180	21-JUN-16	1.000	ppb
51111	51111-1-KIT-KS05	Main, Kitchen, Island Sink, East Side	Flush180	21-JUN-16	1.000	ppb
51111	51111-1-KIT-KS05	Main, Kitchen, Island Sink, East Side	Initial	21-JUN-16	0.894	ppb
51111	51111-1-KIT-KS09	Main, Kitchen, Island Sink, West Side	Flush180	21-JUN-16	0.135	ppb
51111	51111-1-KIT-KS09	Main, Kitchen, Island Sink, West Side	Flush180	21-JUN-16	0.154	ppb
51111	51111-1-KIT-KS09	Main, Kitchen, Island Sink, West Side	Flush180	21-JUN-16	1.000	ppb
51111	51111-1-KIT-KS09	Main, Kitchen, Island Sink, West Side	Flush180	21-JUN-16	0.120	ppb
51111	51111-1-KIT-KS09	Main, Kitchen, Island Sink, West Side	Initial	21-JUN-16	1.150	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51111	51111-1-KIT-KS11	Main, Kitchen, West Wall, South Faucet	Flush180	21-JUN-16	0.313	ppb
51111	51111-1-KIT-KS11	Main, Kitchen, West Wall, South Faucet	Flush180	21-JUN-16	0.206	ppb
51111	51111-1-KIT-KS11	Main, Kitchen, West Wall, South Faucet	Flush180	21-JUN-16	0.178	ppb
51111	51111-1-KIT-KS11	Main, Kitchen, West Wall, South Faucet	Flush180	21-JUN-16	0.287	ppb
51111	51111-1-KIT-KS11	Main, Kitchen, West Wall, South Faucet	Initial	21-JUN-16	2.330	ppb
51111	51111-B-HAL-F03	Main- Across from Room 010, East Fountain	Flush	02-NOV-2023	1.230	ug/L
51111	51111-B-HAL-F03	Main- Across from Room 010, East Fountain	Flush	02-NOV-2023	1.260	ug/L
51111	51111-B-HAL-F03	Main- Across from Room 010, East Fountain	Flush	02-NOV-2023	1.280	ug/L
51111	51111-B-HAL-F03	Main- Across from Room 010, East Fountain	Flush	02-NOV-2023	1.330	ug/L
51111	51111-B-HAL-F03	Main- Across from Room 010, East Fountain	Flush180	28-MAY-16	1.430	ppb
51111	51111-B-HAL-F03	Main- Across from Room 010, East Fountain	Flush180	28-MAY-16	1.420	ppb
51111	51111-B-HAL-F03	Main- Across from Room 010, East Fountain	Flush180	28-MAY-16	0.893	ppb
51111	51111-B-HAL-F03	Main- Across from Room 010, East Fountain	Flush180	28-MAY-16	0.855	ppb
51111	51111-B-HAL-F03	Main- Across from Room 010, East Fountain	Initial	28-MAY-16	0.905	ppb
51111	51111-B-HAL-F03	Main- Across from Room 010, East Fountain	Initial	02-NOV-2023	1.000	ug/L
51111	51111-B-HAL-F04	Main- Across from Room 010, West Fountain	Flush	02-NOV-2023	1.190	ug/L
51111	51111-B-HAL-F04	Main- Across from Room 010, West Fountain	Flush	02-NOV-2023	1.160	ug/L
51111	51111-B-HAL-F04	Main- Across from Room 010, West Fountain	Flush	02-NOV-2023	1.100	ug/L
51111	51111-B-HAL-F04	Main- Across from Room 010, West Fountain	Flush	02-NOV-2023	1.040	ug/L
51111	51111-B-HAL-F04	Main- Across from Room 010, West Fountain	Flush180	28-MAY-16	0.826	ppb
51111	51111-B-HAL-F04	Main- Across from Room 010, West Fountain	Flush180	28-MAY-16	0.856	ppb
51111	51111-B-HAL-F04	Main- Across from Room 010, West Fountain	Flush180	28-MAY-16	0.763	ppb
51111	51111-B-HAL-F04	Main- Across from Room 010, West Fountain	Flush180	28-MAY-16	0.611	ppb
51111	51111-B-HAL-F04	Main- Across from Room 010, West Fountain	Flush180	21-JUL-20	1.820	ug/L
51111	51111-B-HAL-F04	Main- Across from Room 010, West Fountain	Initial	28-MAY-16	0.774	ppb
51111	51111-B-HAL-F04	Main- Across from Room 010, West Fountain	Initial	21-JUL-20	1.480	ug/L
51111	51111-B-HAL-F04	Main- Across from Room 010, West Fountain	Initial	02-NOV-2023	1.000	ug/L
51111	51111-B-HAL-F02	Main- Across from Room 010, Left Fountain	Flush	02-NOV-2023	2.410	ug/L
51111	51111-B-HAL-F02	Main- Across from Room 010, Left Fountain	Flush	02-NOV-2023	4.620	ug/L
51111	51111-B-HAL-F02	Main- Across from Room 010, Left Fountain	Flush	02-NOV-2023	2.040	ug/L
51111	51111-B-HAL-F02	Main- Across from Room 010, Left Fountain	Flush	02-NOV-2023	1.790	ug/L
51111	51111-B-HAL-F02	Main- Across from Room 010, Left Fountain	Initial	02-NOV-2023	3.110	ug/L
51111	51111-B-HAL-F01	Main- Across from Room 016, East Fountain	Flush	02-NOV-2023	1.000	ug/L
51111	51111-B-HAL-F01	Main- Across from Room 016, East Fountain	Flush	02-NOV-2023	1.000	ug/L
51111	51111-B-HAL-F01	Main- Across from Room 016, East Fountain	Flush	02-NOV-2023	1.000	ug/L
51111	51111-B-HAL-F01	Main- Across from Room 016, East Fountain	Flush	02-NOV-2023	1.000	ug/L
51111	51111-B-HAL-F01	Main- Across from Room 016, East Fountain	Flush180	28-MAY-16	1.170	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51111	51111-B-HAL-F01	Main- Across from Room 016, East Fountain	Flush180	28-MAY-16	1.190	ppb
51111	51111-B-HAL-F01	Main- Across from Room 016, East Fountain	Flush180	28-MAY-16	1.120	ppb
51111	51111-B-HAL-F01	Main- Across from Room 016, East Fountain	Flush180	28-MAY-16	1.260	ppb
51111	51111-B-HAL-F01	Main- Across from Room 016, East Fountain	Initial	28-MAY-16	0.684	ppb
51111	51111-B-HAL-F01	Main- Across from Room 016, East Fountain	Initial	02-NOV-2023	1.460	ug/L
51111	51111-B-HAL-F02	Main- Across from Room 016, West Fountain	Flush180	28-MAY-16	1.170	ppb
51111	51111-B-HAL-F02	Main- Across from Room 016, West Fountain	Flush180	28-MAY-16	1.260	ppb
51111	51111-B-HAL-F02	Main- Across from Room 016, West Fountain	Flush180	28-MAY-16	1.220	ppb
51111	51111-B-HAL-F02	Main- Across from Room 016, West Fountain	Flush180	28-MAY-16	1.190	ppb
51111	51111-B-HAL-F02	Main- Across from Room 016, West Fountain	Initial	28-MAY-16	1.090	ppb
51111	51111-1-HAL-F03	Main- Across from Room 102, East Fountain	Flush	02-NOV-2023	1.410	ug/L
51111	51111-1-HAL-F03	Main- Across from Room 102, East Fountain	Flush	02-NOV-2023	1.310	ug/L
51111	51111-1-HAL-F03	Main- Across from Room 102, East Fountain	Flush	02-NOV-2023	1.240	ug/L
51111	51111-1-HAL-F03	Main- Across from Room 102, East Fountain	Flush	02-NOV-2023	1.140	ug/L
51111	51111-1-HAL-F03	Main- Across from Room 102, East Fountain	Flush180	28-MAY-16	0.613	ppb
51111	51111-1-HAL-F03	Main- Across from Room 102, East Fountain	Flush180	28-MAY-16	0.678	ppb
51111	51111-1-HAL-F03	Main- Across from Room 102, East Fountain	Flush180	28-MAY-16	0.594	ppb
51111	51111-1-HAL-F03	Main- Across from Room 102, East Fountain	Flush180	28-MAY-16	0.566	ppb
51111	51111-1-HAL-F03	Main- Across from Room 102, East Fountain	Initial	28-MAY-16	0.205	ppb
51111	51111-1-HAL-F03	Main- Across from Room 102, East Fountain	Initial	02-NOV-2023	1.000	ug/L
51111	51111-1-HAL-RBF01	Main- Across from Room 102, Right Fountain	Flush	02-NOV-2023	1.000	ug/L
51111	51111-1-HAL-RBF01	Main- Across from Room 102, Right Fountain	Flush	02-NOV-2023	1.440	ug/L
51111	51111-1-HAL-RBF01	Main- Across from Room 102, Right Fountain	Flush	02-NOV-2023	1.440	ug/L
51111	51111-1-HAL-RBF01	Main- Across from Room 102, Right Fountain	Flush	02-NOV-2023	1.480	ug/L
51111	51111-1-HAL-RBF01	Main- Across from Room 102, Right Fountain	Initial	02-NOV-2023	1.000	ug/L
51111	51111-1-HAL-F04	Main- Across from Room 102, West Fountain	Flush180	28-MAY-16	0.630	ppb
51111	51111-1-HAL-F04	Main- Across from Room 102, West Fountain	Flush180	28-MAY-16	0.697	ppb
51111	51111-1-HAL-F04	Main- Across from Room 102, West Fountain	Flush180	28-MAY-16	0.264	ppb
51111	51111-1-HAL-F04	Main- Across from Room 102, West Fountain	Flush180	28-MAY-16	0.644	ppb
51111	51111-1-HAL-F04	Main- Across from Room 102, West Fountain	Initial	28-MAY-16	0.618	ppb
51111	51111-1-HAL-F01	Main- Across from Room 106, East Fountain	Flush	02-NOV-2023	1.000	ug/L
51111	51111-1-HAL-F01	Main- Across from Room 106, East Fountain	Flush	02-NOV-2023	1.000	ug/L
51111	51111-1-HAL-F01	Main- Across from Room 106, East Fountain	Flush	02-NOV-2023	1.000	ug/L
51111	51111-1-HAL-F01	Main- Across from Room 106, East Fountain	Flush	02-NOV-2023	1.000	ug/L
51111	51111-1-HAL-F01	Main- Across from Room 106, East Fountain	Flush180	28-MAY-16	0.121	ppb
51111	51111-1-HAL-F01	Main- Across from Room 106, East Fountain	Flush180	28-MAY-16	1.000	ppb
51111	51111-1-HAL-F01	Main- Across from Room 106, East Fountain	Flush180	28-MAY-16	1.000	ppb
51111	51111-1-HAL-F01	Main- Across from Room 106, East Fountain	Flush180	28-MAY-16	1.000	ppb
51111	51111-1-HAL-F01	Main- Across from Room 106, East Fountain	Flush180	28-MAY-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01	East Fountain				
51111	51111-1-HAL-F01	Main- Across from Room 106, East Fountain	Initial	28-MAY-16	1.000	ppb
51111	51111-1-HAL-F01	Main- Across from Room 106, East Fountain	Initial	02-NOV-2023	1.000	ug/L
51111	51111-1-HAL-F02	Main- Across from Room 106, West Fountain	Flush	02-NOV-2023	1.000	ug/L
51111	51111-1-HAL-F02	Main- Across from Room 106, West Fountain	Flush	02-NOV-2023	1.000	ug/L
51111	51111-1-HAL-F02	Main- Across from Room 106, West Fountain	Flush	02-NOV-2023	1.000	ug/L
51111	51111-1-HAL-F02	Main- Across from Room 106, West Fountain	Flush	02-NOV-2023	1.000	ug/L
51111	51111-1-HAL-F02	Main- Across from Room 106, West Fountain	Flush180	28-MAY-16	1.000	ppb
51111	51111-1-HAL-F02	Main- Across from Room 106, West Fountain	Flush180	28-MAY-16	1.000	ppb
51111	51111-1-HAL-F02	Main- Across from Room 106, West Fountain	Flush180	28-MAY-16	1.000	ppb
51111	51111-1-HAL-F02	Main- Across from Room 106, West Fountain	Initial	28-MAY-16	1.000	ppb
51111	51111-1-HAL-F02	Main- Across from Room 106, West Fountain	Initial	02-NOV-2023	1.000	ug/L
51111	51111-2-HAL-F03	Main- Across from Room 202, East Fountain	Flush	02-NOV-2023	1.770	ug/L
51111	51111-2-HAL-F03	Main- Across from Room 202, East Fountain	Flush	02-NOV-2023	2.490	ug/L
51111	51111-2-HAL-F03	Main- Across from Room 202, East Fountain	Flush	02-NOV-2023	2.030	ug/L
51111	51111-2-HAL-F03	Main- Across from Room 202, East Fountain	Flush	02-NOV-2023	1.980	ug/L
51111	51111-2-HAL-F03	Main- Across from Room 202, East Fountain	Flush180	28-MAY-16	0.920	ppb
51111	51111-2-HAL-F03	Main- Across from Room 202, East Fountain	Flush180	28-MAY-16	0.784	ppb
51111	51111-2-HAL-F03	Main- Across from Room 202, East Fountain	Flush180	28-MAY-16	0.793	ppb
51111	51111-2-HAL-F03	Main- Across from Room 202, East Fountain	Flush180	28-MAY-16	0.769	ppb
51111	51111-2-HAL-F03	Main- Across from Room 202, East Fountain	Initial	28-MAY-16	0.603	ppb
51111	51111-2-HAL-F03	Main- Across from Room 202, East Fountain	Initial	02-NOV-2023	1.000	ug/L
51111	51111-2-HAL-F04	Main- Across from Room 202, West Fountain	Flush	02-NOV-2023	1.900	ug/L
51111	51111-2-HAL-F04	Main- Across from Room 202, West Fountain	Flush	02-NOV-2023	2.540	ug/L
51111	51111-2-HAL-F04	Main- Across from Room 202, West Fountain	Flush	02-NOV-2023	1.960	ug/L
51111	51111-2-HAL-F04	Main- Across from Room 202, West Fountain	Flush	02-NOV-2023	1.660	ug/L
51111	51111-2-HAL-F04	Main- Across from Room 202, West Fountain	Flush180	28-MAY-16	0.712	ppb
51111	51111-2-HAL-F04	Main- Across from Room 202, West Fountain	Flush180	28-MAY-16	0.712	ppb
51111	51111-2-HAL-F04	Main- Across from Room 202, West Fountain	Flush180	28-MAY-16	0.661	ppb
51111	51111-2-HAL-F04	Main- Across from Room 202, West Fountain	Flush180	28-MAY-16	0.683	ppb
51111	51111-2-HAL-F04	Main- Across from Room 202, West Fountain	Initial	28-MAY-16	0.304	ppb
51111	51111-2-HAL-F04	Main- Across from Room 202, West Fountain	Initial	02-NOV-2023	1.000	ug/L
51111	51111-2-HA51111-2-HAL-F01	Main- Across from Room 206, East Fountain	Flush180	28-MAY-16	1.000	ppb
51111	51111-2-HAL-F01	Main- Across from Room 206, East Fountain	Flush180	28-MAY-16	0.173	ppb
51111	51111-2-HAL-F01	Main- Across from Room 206, East Fountain	Flush180	28-MAY-16	0.139	ppb
51111	51111-2-HAL-F01	Main- Across from Room 206, East Fountain	Flush180	28-MAY-16	0.130	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51111	51111-2-HAL-F01	Main- Across from Room 206, East Fountain	Initial	28-MAY-16	1.000	ppb
51111	51111-2-HAL-F01	Main- Across from Room 206, Left Fountain	Flush	02-NOV-2023	1.000	ug/L
51111	51111-2-HAL-F01	Main- Across from Room 206, Left Fountain	Flush	02-NOV-2023	1.000	ug/L
51111	51111-2-HAL-F01	Main- Across from Room 206, Left Fountain	Flush	02-NOV-2023	1.000	ug/L
51111	51111-2-HAL-F01	Main- Across from Room 206, Left Fountain	Flush	02-NOV-2023	1.000	ug/L
51111	51111-2-HAL-F01	Main- Across from Room 206, Left Fountain	Initial	02-NOV-2023	1.000	ug/L
51111	51111-2-HAL-F02	Main- Across from Room 206, West Fountain	Flush	02-NOV-2023	1.000	ug/L
51111	51111-2-HAL-F02	Main- Across from Room 206, West Fountain	Flush	02-NOV-2023	1.000	ug/L
51111	51111-2-HAL-F02	Main- Across from Room 206, West Fountain	Flush	02-NOV-2023	1.000	ug/L
51111	51111-2-HAL-F02	Main- Across from Room 206, West Fountain	Flush	02-NOV-2023	1.000	ug/L
51111	51111-2-HAL-F02	Main- Across from Room 206, West Fountain	Flush180	28-MAY-16	0.196	ppb
51111	51111-2-HAL-F02	Main- Across from Room 206, West Fountain	Flush180	28-MAY-16	0.189	ppb
51111	51111-2-HAL-F02	Main- Across from Room 206, West Fountain	Flush180	28-MAY-16	0.197	ppb
51111	51111-2-HAL-F02	Main- Across from Room 206, West Fountain	Flush180	28-MAY-16	0.233	ppb
51111	51111-2-HAL-F02	Main- Across from Room 206, West Fountain	Initial	28-MAY-16	0.138	ppb
51111	51111-2-HAL-F02	Main- Across from Room 206, West Fountain	Initial	02-NOV-2023	1.000	ug/L
51111	51111-3-HAL-F03	Main- Across from Room 302, East Fountain	Flush	02-NOV-2023	1.000	ug/L
51111	51111-3-HAL-F03	Main- Across from Room 302, East Fountain	Flush	02-NOV-2023	1.430	ug/L
51111	51111-3-HAL-F03	Main- Across from Room 302, East Fountain	Flush	02-NOV-2023	1.560	ug/L
51111	51111-3-HAL-F03	Main- Across from Room 302, East Fountain	Flush	02-NOV-2023	1.520	ug/L
51111	51111-3-HAL-F03	Main- Across from Room 302, East Fountain	Flush180	28-MAY-16	0.306	ppb
51111	51111-3-HAL-F03	Main- Across from Room 302, East Fountain	Flush180	28-MAY-16	0.899	ppb
51111	51111-3-HAL-F03	Main- Across from Room 302, East Fountain	Flush180	28-MAY-16	1.090	ppb
51111	51111-3-HAL-F03	Main- Across from Room 302, East Fountain	Flush180	28-MAY-16	1.070	ppb
51111	51111-3-HAL-F03	Main- Across from Room 302, East Fountain	Initial	28-MAY-16	0.242	ppb
51111	51111-3-HAL-F03	Main- Across from Room 302, East Fountain	Initial	02-NOV-2023	1.000	ug/L
51111	51111-3-HAL-RBF01	Main- Across from Room 302, Retrofitted Bottle Filler	Flush	02-NOV-2023	1.100	ug/L
51111	51111-3-HAL-RBF01	Main- Across from Room 302, Retrofitted Bottle Filler	Flush	02-NOV-2023	1.060	ug/L
51111	51111-3-HAL-RBF01	Main- Across from Room 302, Retrofitted Bottle Filler	Flush	02-NOV-2023	1.060	ug/L
51111	51111-3-HAL-RBF01	Main- Across from Room 302, Retrofitted Bottle Filler	Flush	02-NOV-2023	1.140	ug/L
51111	51111-3-HAL-RBF01	Main- Across from Room 302, Retrofitted Bottle Filler	Initial	02-NOV-2023	1.200	ug/L
51111	51111-3-HAL-F04	Main- Across from Room 302, West Fountain	Flush180	28-MAY-16	0.868	ppb
51111	51111-3-HAL-F04	Main- Across from Room 302, West Fountain	Flush180	28-MAY-16	0.698	ppb
51111	51111-3-HAL-F04	Main- Across from Room 302, West Fountain	Flush180	28-MAY-16	0.936	ppb
51111	51111-3-HAL-F04	Main- Across from Room 302, West Fountain	Flush180	28-MAY-16	0.721	ppb
51111	51111-3-HAL-F04	Main- Across from Room 302, West Fountain	Initial	28-MAY-16	0.526	ppb
51111	51111-3-HAL-F02	Main- Across from Room 307c, North Fountain	Flush	02-NOV-2023	3.250	ug/L
51111	51111-3-HAL-	Main- Across from Room 307c,	Flush	02-NOV-2023	2.360	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02	North Fountain				
51111	51111-3-HAL-F02	Main- Across from Room 307c, North Fountain	Flush	02-NOV-2023	2.770	ug/L
51111	51111-3-HAL-F02	Main- Across from Room 307c, North Fountain	Flush	02-NOV-2023	3.120	ug/L
51111	51111-3-HAL-F02	Main- Across from Room 307c, North Fountain	Flush180	28-MAY-16	2.880	ppb
51111	51111-3-HAL-F02	Main- Across from Room 307c, North Fountain	Flush180	28-MAY-16	2.940	ppb
51111	51111-3-HAL-F02	Main- Across from Room 307c, North Fountain	Flush180	28-MAY-16	2.940	ppb
51111	51111-3-HAL-F02	Main- Across from Room 307c, North Fountain	Flush180	28-MAY-16	2.820	ppb
51111	51111-3-HAL-F02	Main- Across from Room 307c, North Fountain	Initial	28-MAY-16	2.730	ppb
51111	51111-3-HAL-F02	Main- Across from Room 307c, North Fountain	Initial	02-NOV-2023	1.460	ug/L
51111	51111-3-HAL-F01	Main- Across from Room 307c, South Fountain	Flush	02-NOV-2023	3.070	ug/L
51111	51111-3-HAL-F01	Main- Across from Room 307c, South Fountain	Flush	02-NOV-2023	2.890	ug/L
51111	51111-3-HAL-F01	Main- Across from Room 307c, South Fountain	Flush	02-NOV-2023	2.770	ug/L
51111	51111-3-HAL-F01	Main- Across from Room 307c, South Fountain	Flush	02-NOV-2023	2.700	ug/L
51111	51111-3-HAL-F01	Main- Across from Room 307c, South Fountain	Flush180	28-MAY-16	2.440	ppb
51111	51111-3-HAL-F01	Main- Across from Room 307c, South Fountain	Flush180	28-MAY-16	2.690	ppb
51111	51111-3-HAL-F01	Main- Across from Room 307c, South Fountain	Flush180	28-MAY-16	1.820	ppb
51111	51111-3-HAL-F01	Main- Across from Room 307c, South Fountain	Flush180	28-MAY-16	2.690	ppb
51111	51111-3-HAL-F01	Main- Across from Room 307c, South Fountain	Initial	28-MAY-16	1.630	ppb
51111	51111-3-HAL-F01	Main- Across from Room 307c, South Fountain	Initial	02-NOV-2023	2.880	ug/L
51111	51111-B-010-S07	Main- Inside Room 010, Sink	Flush	02-NOV-2023	1.000	ug/L
51111	51111-B-010-S07	Main- Inside Room 010, Sink	Flush	02-NOV-2023	1.000	ug/L
51111	51111-B-010-S07	Main- Inside Room 010, Sink	Flush	02-NOV-2023	1.000	ug/L
51111	51111-B-010-S07	Main- Inside Room 010, Sink	Flush	02-NOV-2023	1.000	ug/L
51111	51111-B-010-S07	Main- Inside Room 010, Sink	Flush180	28-MAY-16	1.370	ppb
51111	51111-B-010-S07	Main- Inside Room 010, Sink	Flush180	28-MAY-16	2.100	ppb
51111	51111-B-010-S07	Main- Inside Room 010, Sink	Flush180	28-MAY-16	1.320	ppb
51111	51111-B-010-S07	Main- Inside Room 010, Sink	Flush180	28-MAY-16	2.150	ppb
51111	51111-B-010-S07	Main- Inside Room 010, Sink	Initial	28-MAY-16	1.020	ppb
51111	51111-B-010-S07	Main- Inside Room 010, Sink	Initial	02-NOV-2023	1.000	ug/L
51111	51111-B-013-S08	Main- Inside Room 013, Sink	Flush	02-NOV-2023	1.000	ug/L
51111	51111-B-013-S08	Main- Inside Room 013, Sink	Flush	02-NOV-2023	1.030	ug/L
51111	51111-B-013-S08	Main- Inside Room 013, Sink	Flush	02-NOV-2023	1.000	ug/L
51111	51111-B-013-S08	Main- Inside Room 013, Sink	Flush	02-NOV-2023	1.000	ug/L
51111	51111-B-013-S08	Main- Inside Room 013, Sink	Flush180	28-MAY-16	1.140	ppb
51111	51111-B-013-S08	Main- Inside Room 013, Sink	Flush180	28-MAY-16	0.978	ppb
51111	51111-B-013-S08	Main- Inside Room 013, Sink	Flush180	28-MAY-16	0.933	ppb
51111	51111-B-013-S08	Main- Inside Room 013, Sink	Flush180	28-MAY-16	1.010	ppb
51111	51111-B-013-	Main- Inside Room 013, Sink	Initial	28-MAY-16	0.986	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S08					
51111	51111-B-013-S08	Main- Inside Room 013, Sink	Initial	02-NOV-2023	2.500	ug/L
51111	51111-B-014-F05	Main- Inside Room 014, Fountain	Flush	02-NOV-2023	1.000	ug/L
51111	51111-B-014-F05	Main- Inside Room 014, Fountain	Flush	02-NOV-2023	1.000	ug/L
51111	51111-B-014-F05	Main- Inside Room 014, Fountain	Flush	02-NOV-2023	1.000	ug/L
51111	51111-B-014-F05	Main- Inside Room 014, Fountain	Flush	02-NOV-2023	1.000	ug/L
51111	51111-B-014-F05	Main- Inside Room 014, Fountain	Flush180	28-MAY-16	0.479	ppb
51111	51111-B-014-F05	Main- Inside Room 014, Fountain	Flush180	28-MAY-16	0.566	ppb
51111	51111-B-014-F05	Main- Inside Room 014, Fountain	Flush180	28-MAY-16	0.500	ppb
51111	51111-B-014-F05	Main- Inside Room 014, Fountain	Flush180	28-MAY-16	0.455	ppb
51111	51111-B-014-F05	Main- Inside Room 014, Fountain	Initial	28-MAY-16	0.190	ppb
51111	51111-B-014-F05	Main- Inside Room 014, Fountain	Initial	02-NOV-2023	1.000	ug/L
51111	51111-B-014-S06	Main- Inside Room 014, Sink	Flush	02-NOV-2023	1.000	ug/L
51111	51111-B-014-S06	Main- Inside Room 014, Sink	Flush	02-NOV-2023	1.000	ug/L
51111	51111-B-014-S06	Main- Inside Room 014, Sink	Flush	02-NOV-2023	1.000	ug/L
51111	51111-B-014-S06	Main- Inside Room 014, Sink	Flush	02-NOV-2023	1.000	ug/L
51111	51111-B-014-S06	Main- Inside Room 014, Sink	Flush180	28-MAY-16	0.552	ppb
51111	51111-B-014-S06	Main- Inside Room 014, Sink	Flush180	28-MAY-16	0.999	ppb
51111	51111-B-014-S06	Main- Inside Room 014, Sink	Flush180	28-MAY-16	0.899	ppb
51111	51111-B-014-S06	Main- Inside Room 014, Sink	Flush180	28-MAY-16	0.734	ppb
51111	51111-B-014-S06	Main- Inside Room 014, Sink	Initial	28-MAY-16	0.318	ppb
51111	51111-B-014-S06	Main- Inside Room 014, Sink	Initial	02-NOV-2023	1.000	ug/L
52415	52415-2-HAL-F03	Annex, Across Room A206, North Fountain	Flush	02-NOV-2023	1.000	ug/L
52415	52415-2-HAL-F03	Annex, Across Room A206, North Fountain	Flush	02-NOV-2023	1.000	ug/L
52415	52415-2-HAL-F03	Annex, Across Room A206, North Fountain	Flush	02-NOV-2023	1.000	ug/L
52415	52415-2-HAL-F03	Annex, Across Room A206, North Fountain	Flush	02-NOV-2023	1.000	ug/L
52415	52415-2-HAL-F03	Annex, Across Room A206, North Fountain	Flush180	28-MAY-16	1.000	ppb
52415	52415-2-HAL-F03	Annex, Across Room A206, North Fountain	Flush180	28-MAY-16	1.000	ppb
52415	52415-2-HAL-F03	Annex, Across Room A206, North Fountain	Flush180	28-MAY-16	1.000	ppb
52415	52415-2-HAL-F03	Annex, Across Room A206, North Fountain	Flush180	28-MAY-16	1.000	ppb
52415	52415-2-HAL-F03	Annex, Across Room A206, North Fountain	Initial	28-MAY-16	1.000	ppb
52415	52415-2-HAL-F03	Annex, Across Room A206, North Fountain	Initial	02-NOV-2023	1.000	ug/L
52415	52415-2-HAL-F02	Annex, Across Room A206, South Fountain	Flush	02-NOV-2023	1.000	ug/L
52415	52415-2-HAL-F02	Annex, Across Room A206, South Fountain	Flush	02-NOV-2023	1.000	ug/L
52415	52415-2-HAL-F02	Annex, Across Room A206, South Fountain	Flush	02-NOV-2023	1.000	ug/L
52415	52415-2-HAL-F02	Annex, Across Room A206, South Fountain	Flush	02-NOV-2023	1.000	ug/L
52415	52415-2-HAL-F02	Annex, Across Room A206, South Fountain	Flush180	28-MAY-16	1.000	ppb
52415	52415-2-HAL-F02	Annex, Across Room A206, South Fountain	Flush180	28-MAY-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52415	52415-2-HAL-F02	Annex, Across Room A206, South Fountain	Flush180	28-MAY-16	0.241	ppb
52415	52415-2-HAL-F02	Annex, Across Room A206, South Fountain	Flush180	28-MAY-16	1.000	ppb
52415	52415-2-HAL-F02	Annex, Across Room A206, South Fountain	Initial	28-MAY-16	1.000	ppb
52415	52415-2-HAL-F02	Annex, Across Room A206, South Fountain	Initial	02-NOV-2023	1.000	ug/L
52415	52415-2-HAL-F01	Annex, Across Room A208, Fountain	Flush	02-NOV-2023	1.000	ug/L
52415	52415-2-HAL-F01	Annex, Across Room A208, Fountain	Flush	02-NOV-2023	1.000	ug/L
52415	52415-2-HAL-F01	Annex, Across Room A208, Fountain	Flush	02-NOV-2023	1.000	ug/L
52415	52415-2-HAL-F01	Annex, Across Room A208, Fountain	Flush	02-NOV-2023	1.000	ug/L
52415	52415-2-HAL-F01	Annex, Across Room A208, Fountain	Flush180	28-MAY-16	1.000	ppb
52415	52415-2-HAL-F01	Annex, Across Room A208, Fountain	Flush180	28-MAY-16	1.000	ppb
52415	52415-2-HAL-F01	Annex, Across Room A208, Fountain	Flush180	28-MAY-16	1.000	ppb
52415	52415-2-HAL-F01	Annex, Across Room A208, Fountain	Flush180	28-MAY-16	1.000	ppb
52415	52415-2-HAL-F01	Annex, Across Room A208, Fountain	Initial	28-MAY-16	1.000	ppb
52415	52415-2-HAL-F01	Annex, Across Room A208, Fountain	Initial	02-NOV-2023	1.000	ug/L
52415	52415-2-HAL-RBF01	Annex, Across Room A208, Retrofit BF	Flush	02-NOV-2023	1.000	ug/L
52415	52415-2-HAL-RBF01	Annex, Across Room A208, Retrofit BF	Flush	02-NOV-2023	1.000	ug/L
52415	52415-2-HAL-RBF01	Annex, Across Room A208, Retrofit BF	Flush	02-NOV-2023	1.000	ug/L
52415	52415-2-HAL-RBF01	Annex, Across Room A208, Retrofit BF	Flush	02-NOV-2023	1.000	ug/L
52415	52415-2-HAL-RBF01	Annex, Across Room A208, Retrofit BF	Initial	02-NOV-2023	1.000	ug/L
52415	52415-3-HAL-F03	Annex, Across Room A306, North Fountain	Flush	02-NOV-2023	1.000	ug/L
52415	52415-3-HAL-F03	Annex, Across Room A306, North Fountain	Flush	02-NOV-2023	1.000	ug/L
52415	52415-3-HAL-F03	Annex, Across Room A306, North Fountain	Flush	02-NOV-2023	1.000	ug/L
52415	52415-3-HAL-F03	Annex, Across Room A306, North Fountain	Flush	02-NOV-2023	1.000	ug/L
52415	52415-3-HAL-F03	Annex, Across Room A306, North Fountain	Flush180	28-MAY-16	1.000	ppb
52415	52415-3-HAL-F03	Annex, Across Room A306, North Fountain	Flush180	28-MAY-16	1.000	ppb
52415	52415-3-HAL-F03	Annex, Across Room A306, North Fountain	Flush180	28-MAY-16	1.000	ppb
52415	52415-3-HAL-F03	Annex, Across Room A306, North Fountain	Flush180	28-MAY-16	1.000	ppb
52415	52415-3-HAL-F03	Annex, Across Room A306, North Fountain	Initial	28-MAY-16	1.000	ppb
52415	52415-3-HAL-F03	Annex, Across Room A306, North Fountain	Initial	02-NOV-2023	1.000	ug/L
52415	52415-3-HAL-F02	Annex, Across Room A306, South Fountain	Flush	02-NOV-2023	1.000	ug/L
52415	52415-3-HAL-F02	Annex, Across Room A306, South Fountain	Flush	02-NOV-2023	1.000	ug/L
52415	52415-3-HAL-F02	Annex, Across Room A306, South Fountain	Flush	02-NOV-2023	1.000	ug/L
52415	52415-3-HAL-F02	Annex, Across Room A306, South Fountain	Flush180	28-MAY-16	1.000	ppb
52415	52415-3-HAL-F02	Annex, Across Room A306, South Fountain	Flush180	28-MAY-16	1.000	ppb
52415	52415-3-HAL-F02	Annex, Across Room A306, South Fountain	Flush180	28-MAY-16	1.000	ppb
52415	52415-3-HAL-F02	Annex, Across Room A306, South Fountain	Flush180	28-MAY-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52415	52415-3-HAL-F02	Annex, Across Room A306, South Fountain	Initial	28-MAY-16	1.000	ppb
52415	52415-3-HAL-F02	Annex, Across Room A306, South Fountain	Initial	02-NOV-2023	1.000	ug/L
52415	52415-3-HAL-RBF01	Annex, Across Room A308, Fountain	Flush	02-NOV-2023	1.000	ug/L
52415	52415-3-HAL-RBF01	Annex, Across Room A308, Fountain	Flush	02-NOV-2023	1.000	ug/L
52415	52415-3-HAL-RBF01	Annex, Across Room A308, Fountain	Flush	02-NOV-2023	1.000	ug/L
52415	52415-3-HAL-RBF01	Annex, Across Room A308, Fountain	Flush	02-NOV-2023	1.000	ug/L
52415	52415-3-HAL-F01	Annex, Across Room A308, Fountain	Flush180	28-MAY-16	1.000	ppb
52415	52415-3-HAL-F01	Annex, Across Room A308, Fountain	Flush180	28-MAY-16	1.000	ppb
52415	52415-3-HAL-F01	Annex, Across Room A308, Fountain	Flush180	28-MAY-16	1.000	ppb
52415	52415-3-HAL-F01	Annex, Across Room A308, Fountain	Flush180	28-MAY-16	1.000	ppb
52415	52415-3-HAL-F01	Annex, Across Room A308, Fountain	Flush180	21-JUL-20	1.000	ug/L
52415	52415-3-HAL-F01	Annex, Across Room A308, Fountain	Initial	28-MAY-16	1.000	ppb
52415	52415-3-HAL-F01	Annex, Across Room A308, Fountain	Initial	21-JUL-20	1.000	ug/L
52415	52415-3-HAL-RBF01	Annex, Across Room A308, Fountain	Initial	02-NOV-2023	1.000	ug/L
52415	52415-1-A106-F03	Annex, Inside Room A106, Fountain	Flush180	28-MAY-16	1.000	ppb
52415	52415-1-A106-F03	Annex, Inside Room A106, Fountain	Flush180	28-MAY-16	1.000	ppb
52415	52415-1-A106-F03	Annex, Inside Room A106, Fountain	Flush180	28-MAY-16	1.000	ppb
52415	52415-1-A106-F03	Annex, Inside Room A106, Fountain	Flush180	28-MAY-16	1.000	ppb
52415	52415-1-A106-F03	Annex, Inside Room A106, Fountain	Initial	28-MAY-16	1.000	ppb
52415	52415-1-A106-S06	Annex, Inside Room A106, Left Sink	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-A106-S06	Annex, Inside Room A106, Left Sink	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-A106-S06	Annex, Inside Room A106, Left Sink	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-A106-S06	Annex, Inside Room A106, Left Sink	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-A106-S06	Annex, Inside Room A106, Left Sink	Flush180	28-MAY-16	0.471	ppb
52415	52415-1-A106-S06	Annex, Inside Room A106, Left Sink	Flush180	28-MAY-16	0.390	ppb
52415	52415-1-A106-S06	Annex, Inside Room A106, Left Sink	Flush180	28-MAY-16	0.658	ppb
52415	52415-1-A106-S06	Annex, Inside Room A106, Left Sink	Flush180	28-MAY-16	0.538	ppb
52415	52415-1-A106-S06	Annex, Inside Room A106, Left Sink	Initial	28-MAY-16	0.996	ppb
52415	52415-1-A106-S06	Annex, Inside Room A106, Left Sink	Initial	02-NOV-2023	1.000	ug/L
52415	52415-1-A106-S07	Annex, Inside Room A106, Right Sink	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-A106-S07	Annex, Inside Room A106, Right Sink	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-A106-S07	Annex, Inside Room A106, Right Sink	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-A106-S07	Annex, Inside Room A106, Right Sink	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-A106-S07	Annex, Inside Room A106, Right Sink	Flush180	28-MAY-16	0.376	ppb
52415	52415-1-A106-S07	Annex, Inside Room A106, Right Sink	Flush180	28-MAY-16	0.763	ppb
52415	52415-1-A106-S07	Annex, Inside Room A106, Right Sink	Flush180	28-MAY-16	0.597	ppb
52415	52415-1-A106-S07	Annex, Inside Room A106, Right Sink	Flush180	28-MAY-16	0.330	ppb
52415	52415-1-	Annex, Inside Room A106, Right	Initial	28-MAY-16	0.459	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	A106-S07	Sink				
52415	52415-1-A106-S07	Annex, Inside Room A106, Right Sink	Initial	02-NOV-2023	1.000	ug/L
52415	52415-1-A108-S01	Annex, Inside Room A108, Left Sink	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-A108-S01	Annex, Inside Room A108, Left Sink	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-A108-S01	Annex, Inside Room A108, Left Sink	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-A108-S01	Annex, Inside Room A108, Left Sink	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-A108-S01	Annex, Inside Room A108, Left Sink	Flush180	28-MAY-16	1.700	ppb
52415	52415-1-A108-S01	Annex, Inside Room A108, Left Sink	Flush180	14-JUL-16	1.710	ppb
52415	52415-1-A108-S01	Annex, Inside Room A108, Left Sink	Flush180	14-JUL-16	1.270	ppb
52415	52415-1-A108-S01	Annex, Inside Room A108, Left Sink	Flush180	14-JUL-16	2.650	ppb
52415	52415-1-A108-S01	Annex, Inside Room A108, Left Sink	Flush180	14-JUL-16	1.560	ppb
52415	52415-1-A108-S01	Annex, Inside Room A108, Left Sink	Flush180	28-MAY-16	6.810	ppb
52415	52415-1-A108-S01	Annex, Inside Room A108, Left Sink	Flush180	28-MAY-16	3.130	ppb
52415	52415-1-A108-S01	Annex, Inside Room A108, Left Sink	Flush180	28-MAY-16	2.080	ppb
52415	52415-1-A108-S01	Annex, Inside Room A108, Left Sink	Flush180	07-OCT-21	1.000	ug/L
52415	52415-1-A108-S01	Annex, Inside Room A108, Left Sink	Flush180	07-OCT-21	1.000	ug/L
52415	52415-1-A108-S01	Annex, Inside Room A108, Left Sink	Flush180	07-OCT-21	1.000	ug/L
52415	52415-1-A108-S01	Annex, Inside Room A108, Left Sink	Initial	28-MAY-16	21.200	ppb
52415	52415-1-A108-S01	Annex, Inside Room A108, Left Sink	Initial	14-JUL-16	7.690	ppb
52415	52415-1-A108-S01	Annex, Inside Room A108, Left Sink	Initial	07-OCT-21	1.030	ug/L
52415	52415-1-A108-S01	Annex, Inside Room A108, Left Sink	Initial	02-NOV-2023	1.000	ug/L
52415	52415-1-A108-S02	Annex, Inside Room A108, Right Sink	Flush	02-NOV-2023	1.380	ug/L
52415	52415-1-A108-S02	Annex, Inside Room A108, Right Sink	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-A108-S02	Annex, Inside Room A108, Right Sink	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-A108-S02	Annex, Inside Room A108, Right Sink	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-A108-S02	Annex, Inside Room A108, Right Sink	Flush180	14-JUL-16	0.555	ppb
52415	52415-1-A108-S02	Annex, Inside Room A108, Right Sink	Flush180	28-MAY-16	14.700	ppb
52415	52415-1-A108-S02	Annex, Inside Room A108, Right Sink	Flush180	28-MAY-16	3.650	ppb
52415	52415-1-A108-S02	Annex, Inside Room A108, Right Sink	Flush180	28-MAY-16	5.620	ppb
52415	52415-1-A108-S02	Annex, Inside Room A108, Right Sink	Flush180	28-MAY-16	8.260	ppb
52415	52415-1-A108-S02	Annex, Inside Room A108, Right Sink	Flush180	14-JUL-16	0.645	ppb
52415	52415-1-A108-S02	Annex, Inside Room A108, Right Sink	Flush180	14-JUL-16	1.030	ppb
52415	52415-1-A108-S02	Annex, Inside Room A108, Right Sink	Flush180	14-JUL-16	2.290	ppb
52415	52415-1-A108-S02	Annex, Inside Room A108, Right Sink	Flush180	07-OCT-21	1.000	ug/L
52415	52415-1-A108-S02	Annex, Inside Room A108, Right Sink	Flush180	07-OCT-21	1.000	ug/L
52415	52415-1-A108-S02	Annex, Inside Room A108, Right Sink	Flush180	07-OCT-21	1.000	ug/L
52415	52415-1-A108-S02	Annex, Inside Room A108, Right Sink	Flush180	07-OCT-21	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	A108-S02	Sink				
52415	52415-1-A108-S02	Annex, Inside Room A108, Right Sink	Initial	28-MAY-16	37.300	ppb
52415	52415-1-A108-S02	Annex, Inside Room A108, Right Sink	Initial	14-JUL-16	3.710	ppb
52415	52415-1-A108-S02	Annex, Inside Room A108, Right Sink	Initial	07-OCT-21	1.850	ug/L
52415	52415-1-A108-S02	Annex, Inside Room A108, Right Sink	Initial	02-NOV-2023	4.010	ug/L
52415	52415-1-HAL-F05	Annex, Next To Bathroom, North Fountain	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-HAL-F05	Annex, Next To Bathroom, North Fountain	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-HAL-F05	Annex, Next To Bathroom, North Fountain	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-HAL-F05	Annex, Next To Bathroom, North Fountain	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-HAL-F05	Annex, Next To Bathroom, North Fountain	Flush180	28-MAY-16	1.000	ppb
52415	52415-1-HAL-F05	Annex, Next To Bathroom, North Fountain	Flush180	28-MAY-16	1.000	ppb
52415	52415-1-HAL-F05	Annex, Next To Bathroom, North Fountain	Flush180	28-MAY-16	1.000	ppb
52415	52415-1-HAL-F05	Annex, Next To Bathroom, North Fountain	Flush180	28-MAY-16	1.000	ppb
52415	52415-1-HAL-F05	Annex, Next To Bathroom, North Fountain	Initial	28-MAY-16	1.000	ppb
52415	52415-1-HAL-F05	Annex, Next To Bathroom, North Fountain	Initial	02-NOV-2023	1.000	ug/L
52415	52415-1-HAL-F04	Annex, Next To Bathroom, South Fountain	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-HAL-F04	Annex, Next To Bathroom, South Fountain	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-HAL-F04	Annex, Next To Bathroom, South Fountain	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-HAL-F04	Annex, Next To Bathroom, South Fountain	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-HAL-F04	Annex, Next To Bathroom, South Fountain	Flush180	28-MAY-16	1.000	ppb
52415	52415-1-HAL-F04	Annex, Next To Bathroom, South Fountain	Flush180	28-MAY-16	1.000	ppb
52415	52415-1-HAL-F04	Annex, Next To Bathroom, South Fountain	Flush180	28-MAY-16	1.000	ppb
52415	52415-1-HAL-F04	Annex, Next To Bathroom, South Fountain	Flush180	28-MAY-16	1.000	ppb
52415	52415-1-HAL-F04	Annex, Next To Bathroom, South Fountain	Initial	28-MAY-16	1.000	ppb
52415	52415-1-HAL-F04	Annex, Next To Bathroom, South Fountain	Initial	02-NOV-2023	1.000	ug/L
52415	52415-1-KIT-KS12	Main, Kitchen Serving Line, Sink	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-KIT-KS12	Main, Kitchen Serving Line, Sink	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-KIT-KS12	Main, Kitchen Serving Line, Sink	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-KIT-KS12	Main, Kitchen Serving Line, Sink	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-KIT-KS12	Main, Kitchen Serving Line, Sink	Initial	02-NOV-2023	1.000	ug/L
52415	52415-1-KIT-KS07	Main, Kitchen Tray Center Sink	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-KIT-KS07	Main, Kitchen Tray Center Sink	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-KIT-KS07	Main, Kitchen Tray Center Sink	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-KIT-KS07	Main, Kitchen Tray Center Sink	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-KIT-KS07	Main, Kitchen Tray Center Sink	Initial	02-NOV-2023	1.000	ug/L
52415	52415-1-KIT-KS06	Main, Kitchen Tray Left Sink	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-KIT-KS06	Main, Kitchen Tray Left Sink	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-KIT-KS06	Main, Kitchen Tray Left Sink	Flush	02-NOV-2023	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52415	52415-1-KIT-KS06	Main, Kitchen Tray Left Sink	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-KIT-KS06	Main, Kitchen Tray Left Sink	Initial	02-NOV-2023	2.790	ug/L
52415	52415-1-KIT-KS08	Main, Kitchen Tray Right Sink	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-KIT-KS08	Main, Kitchen Tray Right Sink	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-KIT-KS08	Main, Kitchen Tray Right Sink	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-KIT-KS08	Main, Kitchen Tray Right Sink	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-KIT-KS08	Main, Kitchen Tray Right Sink	Initial	02-NOV-2023	1.930	ug/L
52415	52415-1-KIT-KS11	North Wall Facing Sink Middle of Kitchen	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-KIT-KS11	North Wall Facing Sink Middle of Kitchen	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-KIT-KS11	North Wall Facing Sink Middle of Kitchen	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-KIT-KS11	North Wall Facing Sink Middle of Kitchen	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-KIT-KS11	North Wall Facing Sink Middle of Kitchen	Initial	02-NOV-2023	1.140	ug/L
52415	52415-1-KIT-KS09	South Wall Facing Sink Middle of Kitchen	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-KIT-KS09	South Wall Facing Sink Middle of Kitchen	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-KIT-KS09	South Wall Facing Sink Middle of Kitchen	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-KIT-KS09	South Wall Facing Sink Middle of Kitchen	Flush	02-NOV-2023	1.000	ug/L
52415	52415-1-KIT-KS09	South Wall Facing Sink Middle of Kitchen	Initial	02-NOV-2023	1.000	ug/L