



Sep 10, 2024

CHICAGO ACADEMY ES

3400 N AUSTIN AVE, Chicago IL 60634.

Dear **CHICAGO ACADEMY ES** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

CHICAGO ACADEMY ES

3400 N AUSTIN AVE, Chicago IL 60634.

Estimadas familias de **CHICAGO ACADEMY ES:**

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarle y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51041	51041-3-HAL-F03	Fountain 1 Across From Lunchroom near Womens Toile	Flush180	02-JUN-16	0.330	ppb
51041	51041-3-HAL-F03	Fountain 1 Across From Lunchroom near Womens Toile	Flush180	02-JUN-16	0.726	ppb
51041	51041-3-HAL-F03	Fountain 1 Across From Lunchroom near Womens Toile	Flush180	02-JUN-16	0.564	ppb
51041	51041-3-HAL-F03	Fountain 1 Across From Lunchroom near Womens Toile	Flush180	02-JUN-16	0.423	ppb
51041	51041-3-HAL-F03	Fountain 1 Across From Lunchroom near Womens Toile	Initial	02-JUN-16	0.318	ppb
51041	51041-2-GYM-F07	Fountain 1 Inside Gym	Flush180	02-JUN-16	1.930	ppb
51041	51041-2-GYM-F07	Fountain 1 Inside Gym	Flush180	02-JUN-16	2.050	ppb
51041	51041-2-GYM-F07	Fountain 1 Inside Gym	Flush180	02-JUN-16	1.600	ppb
51041	51041-2-GYM-F07	Fountain 1 Inside Gym	Flush180	02-JUN-16	1.310	ppb
51041	51041-2-GYM-F07	Fountain 1 Inside Gym	Initial	02-JUN-16	1.320	ppb
51041	51041-1-HAL-F10	Fountain 1 Outside Room 110	Flush180	02-JUN-16	1.000	ppb
51041	51041-1-HAL-F10	Fountain 1 Outside Room 110	Flush180	02-JUN-16	1.000	ppb
51041	51041-1-HAL-F10	Fountain 1 Outside Room 110	Flush180	02-JUN-16	0.204	ppb
51041	51041-1-HAL-F10	Fountain 1 Outside Room 110	Flush180	02-JUN-16	0.173	ppb
51041	51041-1-HAL-F10	Fountain 1 Outside Room 110	Initial	02-JUN-16	1.000	ppb
51041	51041-1-HAL-F01	Fountain 1 Outside Room 129A	Flush180	02-JUN-16	0.525	ppb
51041	51041-1-HAL-F01	Fountain 1 Outside Room 129A	Flush180	02-JUN-16	0.523	ppb
51041	51041-1-HAL-F01	Fountain 1 Outside Room 129A	Flush180	02-JUN-16	0.197	ppb
51041	51041-1-HAL-F01	Fountain 1 Outside Room 129A	Flush180	02-JUN-16	0.396	ppb
51041	51041-1-HAL-F01	Fountain 1 Outside Room 129A	Flush180	15-JUL-20	3.830	ug/L
51041	51041-1-HAL-F01	Fountain 1 Outside Room 129A	Initial	02-JUN-16	0.187	ppb
51041	51041-1-HAL-F01	Fountain 1 Outside Room 129A	Initial	15-JUL-20	1.100	ug/L
51041	51041-2-HAL-F05	Fountain 1 Outside Room 207B	Flush180	02-JUN-16	0.164	ppb
51041	51041-2-HAL-F05	Fountain 1 Outside Room 207B	Flush180	02-JUN-16	1.000	ppb
51041	51041-2-HAL-F05	Fountain 1 Outside Room 207B	Flush180	02-JUN-16	0.210	ppb
51041	51041-2-HAL-F05	Fountain 1 Outside Room 207B	Flush180	02-JUN-16	0.210	ppb
51041	51041-2-HAL-F05	Fountain 1 Outside Room 207B	Initial	02-JUN-16	1.000	ppb
51041	51041-3-HAL-F07	Fountain 1 Outside Room 309A	Flush180	02-JUN-16	0.170	ppb
51041	51041-3-HAL-F07	Fountain 1 Outside Room 309A	Flush180	02-JUN-16	0.280	ppb
51041	51041-3-HAL-F07	Fountain 1 Outside Room 309A	Flush180	02-JUN-16	0.370	ppb
51041	51041-3-HAL-F07	Fountain 1 Outside Room 309A	Flush180	02-JUN-16	0.659	ppb
51041	51041-3-HAL-F07	Fountain 1 Outside Room 309A	Flush180	15-JUL-20	1.160	ug/L
51041	51041-3-HAL-F07	Fountain 1 Outside Room 309A	Initial	02-JUN-16	0.152	ppb
51041	51041-3-HAL-F07	Fountain 1 Outside Room 309A	Initial	15-JUL-20	1.000	ug/L
51041	51041-3-HAL-F05	Fountain 1 Outside Room 316	Flush180	02-JUN-16	0.868	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51041	51041-3-HAL-F05	Fountain 1 Outside Room 316	Flush180	02-JUN-16	0.858	ppb
51041	51041-3-HAL-F05	Fountain 1 Outside Room 316	Flush180	02-JUN-16	0.763	ppb
51041	51041-3-HAL-F05	Fountain 1 Outside Room 316	Flush180	02-JUN-16	0.838	ppb
51041	51041-3-HAL-F05	Fountain 1 Outside Room 316	Initial	02-JUN-16	0.668	ppb
51041	51041-3-HAL-F04	Fountain 2 Across From Lunchroom near Womens Toile	Flush180	02-JUN-16	0.527	ppb
51041	51041-3-HAL-F04	Fountain 2 Across From Lunchroom near Womens Toile	Flush180	02-JUN-16	0.477	ppb
51041	51041-3-HAL-F04	Fountain 2 Across From Lunchroom near Womens Toile	Flush180	02-JUN-16	0.587	ppb
51041	51041-3-HAL-F04	Fountain 2 Across From Lunchroom near Womens Toile	Flush180	02-JUN-16	0.486	ppb
51041	51041-3-HAL-F04	Fountain 2 Across From Lunchroom near Womens Toile	Initial	02-JUN-16	0.591	ppb
51041	51041-2-GYM-F08	Fountain 2 Inside Gym	Flush180	02-JUN-16	1.560	ppb
51041	51041-2-GYM-F08	Fountain 2 Inside Gym	Flush180	02-JUN-16	1.470	ppb
51041	51041-2-GYM-F08	Fountain 2 Inside Gym	Flush180	02-JUN-16	1.320	ppb
51041	51041-2-GYM-F08	Fountain 2 Inside Gym	Flush180	02-JUN-16	1.100	ppb
51041	51041-2-GYM-F08	Fountain 2 Inside Gym	Initial	02-JUN-16	0.892	ppb
51041	51041-1-HAL-F11	Fountain 2 Outside Room 110	Flush180	02-JUN-16	0.128	ppb
51041	51041-1-HAL-F11	Fountain 2 Outside Room 110	Flush180	02-JUN-16	1.000	ppb
51041	51041-1-HAL-F11	Fountain 2 Outside Room 110	Flush180	02-JUN-16	0.120	ppb
51041	51041-1-HAL-F11	Fountain 2 Outside Room 110	Flush180	02-JUN-16	1.000	ppb
51041	51041-1-HAL-F11	Fountain 2 Outside Room 110	Initial	02-JUN-16	0.160	ppb
51041	51041-1-HAL-F02	Fountain 2 Outside Room 129A	Flush180	02-JUN-16	0.367	ppb
51041	51041-1-HAL-F02	Fountain 2 Outside Room 129A	Flush180	02-JUN-16	0.332	ppb
51041	51041-1-HAL-F02	Fountain 2 Outside Room 129A	Flush180	02-JUN-16	0.400	ppb
51041	51041-1-HAL-F02	Fountain 2 Outside Room 129A	Flush180	02-JUN-16	0.427	ppb
51041	51041-1-HAL-F02	Fountain 2 Outside Room 129A	Initial	02-JUN-16	0.434	ppb
51041	51041-2-HAL-F06	Fountain 2 Outside Room 207B	Flush180	02-JUN-16	0.159	ppb
51041	51041-2-HAL-F06	Fountain 2 Outside Room 207B	Flush180	02-JUN-16	0.177	ppb
51041	51041-2-HAL-F06	Fountain 2 Outside Room 207B	Flush180	02-JUN-16	0.164	ppb
51041	51041-2-HAL-F06	Fountain 2 Outside Room 207B	Flush180	02-JUN-16	0.171	ppb
51041	51041-2-HAL-F06	Fountain 2 Outside Room 207B	Initial	02-JUN-16	0.193	ppb
51041	51041-3-HAL-F08	Fountain 2 Outside Room 309A	Flush180	02-JUN-16	0.425	ppb
51041	51041-3-HAL-F08	Fountain 2 Outside Room 309A	Flush180	02-JUN-16	0.872	ppb
51041	51041-3-HAL-F08	Fountain 2 Outside Room 309A	Flush180	02-JUN-16	1.300	ppb
51041	51041-3-HAL-F08	Fountain 2 Outside Room 309A	Flush180	02-JUN-16	0.351	ppb
51041	51041-3-HAL-F08	Fountain 2 Outside Room 309A	Initial	02-JUN-16	0.185	ppb
51041	51041-3-HAL-F06	Fountain 2 Outside Room 316	Flush180	02-JUN-16	0.577	ppb
51041	51041-3-HAL-F06	Fountain 2 Outside Room 316	Flush180	02-JUN-16	0.631	ppb
51041	51041-3-HAL-F06	Fountain 2 Outside Room 316	Flush180	02-JUN-16	0.629	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51041	51041-3-HAL-F06	Fountain 2 Outside Room 316	Flush180	02-JUN-16	0.742	ppb
51041	51041-3-HAL-F06	Fountain 2 Outside Room 316	Initial	02-JUN-16	0.572	ppb
51041	51041-1-111-F08	Fountain Inside Kindergarden Room 111	Flush180	02-JUN-16	1.000	ppb
51041	51041-1-111-F08	Fountain Inside Kindergarden Room 111	Flush180	02-JUN-16	1.000	ppb
51041	51041-1-111-F08	Fountain Inside Kindergarden Room 111	Flush180	02-JUN-16	1.000	ppb
51041	51041-1-111-F08	Fountain Inside Kindergarden Room 111	Flush180	02-JUN-16	1.000	ppb
51041	51041-1-111-F08	Fountain Inside Kindergarden Room 111	Initial	02-JUN-16	1.000	ppb
51041	51041-1-121-F04	Fountain Inside Pre-K Room 121	Flush180	02-JUN-16	1.000	ppb
51041	51041-1-121-F04	Fountain Inside Pre-K Room 121	Flush180	02-JUN-16	1.000	ppb
51041	51041-1-121-F04	Fountain Inside Pre-K Room 121	Flush180	02-JUN-16	1.000	ppb
51041	51041-1-121-F04	Fountain Inside Pre-K Room 121	Flush180	02-JUN-16	1.000	ppb
51041	51041-1-121-F04	Fountain Inside Pre-K Room 121	Initial	02-JUN-16	1.000	ppb
51041	51041-1-109-F12	Fountain Inside Room 109	Flush180	02-JUN-16	1.000	ppb
51041	51041-1-109-F12	Fountain Inside Room 109	Flush180	02-JUN-16	1.000	ppb
51041	51041-1-109-F12	Fountain Inside Room 109	Flush180	02-JUN-16	1.000	ppb
51041	51041-1-109-F12	Fountain Inside Room 109	Flush180	02-JUN-16	1.000	ppb
51041	51041-1-109-F12	Fountain Inside Room 109	Initial	02-JUN-16	1.000	ppb
51041	51041-1-HAL-F16	Fountain Outside Room 107	Flush180	02-JUN-16	0.263	ppb
51041	51041-1-HAL-F16	Fountain Outside Room 107	Flush180	02-JUN-16	0.167	ppb
51041	51041-1-HAL-F16	Fountain Outside Room 107	Flush180	02-JUN-16	0.153	ppb
51041	51041-1-HAL-F16	Fountain Outside Room 107	Flush180	02-JUN-16	0.237	ppb
51041	51041-1-HAL-F16	Fountain Outside Room 107	Initial	02-JUN-16	0.132	ppb
51041	51041-1-HAL-F07	Fountain Outside Room 116	Flush180	02-JUN-16	0.282	ppb
51041	51041-1-HAL-F07	Fountain Outside Room 116	Flush180	02-JUN-16	0.258	ppb
51041	51041-1-HAL-F07	Fountain Outside Room 116	Flush180	02-JUN-16	0.271	ppb
51041	51041-1-HAL-F07	Fountain Outside Room 116	Flush180	02-JUN-16	0.286	ppb
51041	51041-1-HAL-F07	Fountain Outside Room 116	Initial	02-JUN-16	0.188	ppb
51041	51041-2-HAL-F03	Fountain Outside Room 216	Flush180	02-JUN-16	0.235	ppb
51041	51041-2-HAL-F03	Fountain Outside Room 216	Flush180	02-JUN-16	0.257	ppb
51041	51041-2-HAL-F03	Fountain Outside Room 216	Flush180	02-JUN-16	0.291	ppb
51041	51041-2-HAL-F03	Fountain Outside Room 216	Flush180	02-JUN-16	0.257	ppb
51041	51041-2-HAL-F03	Fountain Outside Room 216	Initial	02-JUN-16	0.141	ppb
51041	51041-2-HAL-F01	Fountain Outside Room 229	Flush180	02-JUN-16	0.172	ppb
51041	51041-2-HAL-F01	Fountain Outside Room 229	Flush180	02-JUN-16	1.000	ppb
51041	51041-2-HAL-F01	Fountain Outside Room 229	Flush180	02-JUN-16	0.342	ppb
51041	51041-2-HAL-F01	Fountain Outside Room 229	Flush180	02-JUN-16	0.289	ppb
51041	51041-2-HAL-F01	Fountain Outside Room 229	Initial	02-JUN-16	1.000	ppb
51041	51041-2-HAL-	Fountain Outside Room 229A	Flush180	02-JUN-16	0.340	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02					
51041	51041-2-HAL-F02	Fountain Outside Room 229A	Flush180	02-JUN-16	0.351	ppb
51041	51041-2-HAL-F02	Fountain Outside Room 229A	Flush180	02-JUN-16	0.325	ppb
51041	51041-2-HAL-F02	Fountain Outside Room 229A	Flush180	02-JUN-16	0.308	ppb
51041	51041-2-HAL-F02	Fountain Outside Room 229A	Initial	02-JUN-16	0.659	ppb
51041	51041-3-KIT-KS01	Kitchen Sink 1	Flush180	02-JUN-16	1.000	ppb
51041	51041-3-KIT-KS01	Kitchen Sink 1	Flush180	02-JUN-16	1.000	ppb
51041	51041-3-KIT-KS01	Kitchen Sink 1	Flush180	02-JUN-16	1.000	ppb
51041	51041-3-KIT-KS01	Kitchen Sink 1	Flush180	02-JUN-16	1.000	ppb
51041	51041-3-KIT-KS01	Kitchen Sink 1	Initial	02-JUN-16	1.200	ppb
51041	51041-3-KIT-KS02	Kitchen Sink 2	Flush180	02-JUN-16	2.830	ppb
51041	51041-3-KIT-KS02	Kitchen Sink 2	Flush180	02-JUN-16	1.240	ppb
51041	51041-3-KIT-KS02	Kitchen Sink 2	Flush180	02-JUN-16	1.000	ppb
51041	51041-3-KIT-KS02	Kitchen Sink 2	Flush180	02-JUN-16	1.000	ppb
51041	51041-3-KIT-KS02	Kitchen Sink 2	Initial	02-JUN-16	1.000	ppb
51041	51041-1-TL-S14	Sink 1 In Elementary Teachers Lounge	Flush180	02-JUN-16	0.827	ppb
51041	51041-1-TL-S14	Sink 1 In Elementary Teachers Lounge	Flush180	02-JUN-16	1.130	ppb
51041	51041-1-TL-S14	Sink 1 In Elementary Teachers Lounge	Flush180	02-JUN-16	1.240	ppb
51041	51041-1-TL-S14	Sink 1 In Elementary Teachers Lounge	Flush180	02-JUN-16	1.010	ppb
51041	51041-1-TL-S14	Sink 1 In Elementary Teachers Lounge	Initial	02-JUN-16	1.070	ppb
51041	51041-1-TL-S15	Sink 2 In Elementary Teachers Lounge	Flush180	02-JUN-16	0.592	ppb
51041	51041-1-TL-S15	Sink 2 In Elementary Teachers Lounge	Flush180	02-JUN-16	0.718	ppb
51041	51041-1-TL-S15	Sink 2 In Elementary Teachers Lounge	Flush180	02-JUN-16	0.389	ppb
51041	51041-1-TL-S15	Sink 2 In Elementary Teachers Lounge	Flush180	02-JUN-16	0.856	ppb
51041	51041-1-TL-S15	Sink 2 In Elementary Teachers Lounge	Initial	02-JUN-16	0.363	ppb
51041	51041-3-TL-S09	Sink Inside High School Teachers Lounge	Flush180	02-JUN-16	0.156	ppb
51041	51041-3-TL-S09	Sink Inside High School Teachers Lounge	Flush180	02-JUN-16	0.157	ppb
51041	51041-3-TL-S09	Sink Inside High School Teachers Lounge	Flush180	02-JUN-16	0.156	ppb
51041	51041-3-TL-S09	Sink Inside High School Teachers Lounge	Flush180	02-JUN-16	0.181	ppb
51041	51041-3-TL-S09	Sink Inside High School Teachers Lounge	Initial	02-JUN-16	0.248	ppb
51041	51041-1-111-S09	Sink Inside Kindergarden Room 111	Flush180	02-JUN-16	1.000	ppb
51041	51041-1-111-S09	Sink Inside Kindergarden Room 111	Flush180	02-JUN-16	1.000	ppb
51041	51041-1-111-S09	Sink Inside Kindergarden Room 111	Flush180	02-JUN-16	1.000	ppb
51041	51041-1-111-S09	Sink Inside Kindergarden Room 111	Flush180	02-JUN-16	1.000	ppb
51041	51041-1-111-S09	Sink Inside Kindergarden Room 111	Initial	02-JUN-16	1.000	ppb
51041	51041-1-121-S03	Sink Inside Pre-K Room 121	Flush180	02-JUN-16	1.000	ppb
51041	51041-1-121-S03	Sink Inside Pre-K Room 121	Flush180	02-JUN-16	1.000	ppb
51041	51041-1-121-S03	Sink Inside Pre-K Room 121	Flush180	02-JUN-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S03					
51041	51041-1-121-S03	Sink Inside Pre-K Room 121	Flush180	02-JUN-16	0.273	ppb
51041	51041-1-121-S03	Sink Inside Pre-K Room 121	Initial	02-JUN-16	1.000	ppb
51041	51041-1-109-S13	Sink Inside Room 109	Flush180	02-JUN-16	1.000	ppb
51041	51041-1-109-S13	Sink Inside Room 109	Flush180	02-JUN-16	1.000	ppb
51041	51041-1-109-S13	Sink Inside Room 109	Flush180	02-JUN-16	1.000	ppb
51041	51041-1-109-S13	Sink Inside Room 109	Flush180	02-JUN-16	1.000	ppb
51041	51041-1-109-S13	Sink Inside Room 109	Initial	02-JUN-16	1.000	ppb
51041	51041-1-115-S06	Sink Inside Room 115	Flush180	02-JUN-16	1.000	ppb
51041	51041-1-115-S06	Sink Inside Room 115	Flush180	02-JUN-16	1.290	ppb
51041	51041-1-115-S06	Sink Inside Room 115	Flush180	02-JUN-16	1.000	ppb
51041	51041-1-115-S06	Sink Inside Room 115	Flush180	02-JUN-16	0.127	ppb
51041	51041-1-115-S06	Sink Inside Room 115	Initial	02-JUN-16	1.000	ppb
51041	51041-1-106-S01	room 106 pre-k	Flush180	13-NOV-20	2.130	ug/L
51041	51041-1-106-S01	room 106 pre-k	Flush180	13-NOV-20	1.150	ug/L
51041	51041-1-106-S01	room 106 pre-k	Flush180	13-NOV-20	1.150	ug/L
51041	51041-1-106-S01	room 106 pre-k	Flush180	13-NOV-20	1.070	ug/L
51041	51041-1-106-F01	room 106 pre-k	Flush180	13-NOV-20	1.100	ug/L
51041	51041-1-106-F01	room 106 pre-k	Flush180	13-NOV-20	1.040	ug/L
51041	51041-1-106-F01	room 106 pre-k	Flush180	13-NOV-20	1.020	ug/L
51041	51041-1-106-F01	room 106 pre-k	Flush180	13-NOV-20	1.050	ug/L
51041	51041-1-106-S01	room 106 pre-k	Initial	13-NOV-20	1.760	ug/L
51041	51041-1-106-F01	room 106 pre-k	Initial	13-NOV-20	1.470	ug/L
51041	51041-1-112-S01	room 112, teachers lounge	Flush180	13-NOV-20	4.490	ug/L
51041	51041-1-112-S01	room 112, teachers lounge	Flush180	13-NOV-20	3.330	ug/L
51041	51041-1-112-S01	room 112, teachers lounge	Flush180	13-NOV-20	2.750	ug/L
51041	51041-1-112-S01	room 112, teachers lounge	Flush180	13-NOV-20	2.560	ug/L
51041	51041-1-112-S01	room 112, teachers lounge	Initial	13-NOV-20	3.610	ug/L