



Sep 10, 2024

CHICAGO VOCATIONAL HS

2100 E 87TH ST, Chicago IL 60617.

Dear **CHICAGO VOCATIONAL HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

CHICAGO VOCATIONAL HS

2100 E 87TH ST, Chicago IL 60617.

Estimadas familias de **CHICAGO VOCATIONAL HS:**

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51625	51625-1-KIT-KS07	3-basin, West Wall Left Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS07	3-basin, West Wall Left Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS07	3-basin, West Wall Left Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS07	3-basin, West Wall Left Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS07	3-basin, West Wall Left Sink	Initial	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS08	3-basin, West Wall, Middle Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS08	3-basin, West Wall, Middle Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS08	3-basin, West Wall, Middle Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS08	3-basin, West Wall, Middle Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS08	3-basin, West Wall, Middle Sink	Initial	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS09	3-basin, West Wall, Right Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS09	3-basin, West Wall, Right Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS09	3-basin, West Wall, Right Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS09	3-basin, West Wall, Right Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS09	3-basin, West Wall, Right Sink	Initial	25-JAN-2024	1.000	ug/L
51625	51625-1-HAL-RBF01	Across Auditorium Left Bottle Filler	Flush	21-FEB-2024	4.260	ug/L
51625	51625-1-HAL-RBF01	Across Auditorium Left Bottle Filler	Flush	21-FEB-2024	4.180	ug/L
51625	51625-1-HAL-RBF01	Across Auditorium Left Bottle Filler	Flush	21-FEB-2024	4.130	ug/L
51625	51625-1-HAL-RBF01	Across Auditorium Left Bottle Filler	Flush	21-FEB-2024	4.800	ug/L
51625	51625-1-HAL-RBF01	Across Auditorium Left Bottle Filler	Initial	21-FEB-2024	3.820	ug/L
51625	51625-1-HAL-F03	Across Auditorium Left Fount	Flush	21-FEB-2024	6.810	ug/L
51625	51625-1-HAL-F03	Across Auditorium Left Fount	Flush	21-FEB-2024	5.560	ug/L
51625	51625-1-HAL-F03	Across Auditorium Left Fount	Flush	21-FEB-2024	4.310	ug/L
51625	51625-1-HAL-F03	Across Auditorium Left Fount	Flush	21-FEB-2024	3.620	ug/L
51625	51625-1-HAL-F03	Across Auditorium Left Fount	Flush	25-JAN-2024	9.370	ug/L
51625	51625-1-HAL-F03	Across Auditorium Left Fount	Flush	25-JAN-2024	5.160	ug/L
51625	51625-1-HAL-F03	Across Auditorium Left Fount	Flush	25-JAN-2024	2.680	ug/L
51625	51625-1-HAL-F03	Across Auditorium Left Fount	Flush	25-JAN-2024	1.790	ug/L
51625	51625-1-HAL-F03	Across Auditorium Left Fount	Flush	15-MAR-2024	4.300	ug/L
51625	51625-1-HAL-F03	Across Auditorium Left Fount	Flush	15-MAR-2024	3.810	ug/L
51625	51625-1-HAL-F03	Across Auditorium Left Fount	Flush	15-MAR-2024	2.620	ug/L
51625	51625-1-HAL-F03	Across Auditorium Left Fount	Flush	15-MAR-2024	2.510	ug/L
51625	51625-1-HAL-F03	Across Auditorium Left Fount	Flush180	05-OCT-16	5.680	ppb
51625	51625-1-HAL-F03	Across Auditorium Left Fount	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F03	Across Auditorium Left Fount	Flush180	05-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51625	51625-1-HAL-F03	Across Auditorium Left Fount	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F03	Across Auditorium Left Fount	Initial	05-OCT-16	8.370	ppb
51625	51625-1-HAL-F03	Across Auditorium Left Fount	Initial	21-FEB-2024	3.340	ug/L
51625	51625-1-HAL-F03	Across Auditorium Left Fount	Initial	25-JAN-2024	6.790	ug/L
51625	51625-1-HAL-F03	Across Auditorium Left Fount	Initial	15-MAR-2024	3.860	ug/L
51625	51625-2-HAL-F01	Across Auditorium Left Fountain	Flush180	30-NOV-16	4.700	ppb
51625	51625-2-HAL-F01	Across Auditorium Left Fountain	Flush180	30-NOV-16	19.000	ppb
51625	51625-2-HAL-F01	Across Auditorium Left Fountain	Flush180	30-NOV-16	8.700	ppb
51625	51625-2-HAL-F01	Across Auditorium Left Fountain	Flush180	30-NOV-16	7.600	ppb
51625	51625-2-HAL-F01	Across Auditorium Left Fountain	Flush180	17-MAR-17	5.400	ppb
51625	51625-2-HAL-F01	Across Auditorium Left Fountain	Flush180	17-MAR-17	2.900	ppb
51625	51625-2-HAL-F01	Across Auditorium Left Fountain	Flush180	17-MAR-17	3.700	ppb
51625	51625-2-HAL-F01	Across Auditorium Left Fountain	Flush180	17-MAR-17	2.700	ppb
51625	51625-2-HAL-F01	Across Auditorium Left Fountain	Flush180	05-OCT-16	8.380	ppb
51625	51625-2-HAL-F01	Across Auditorium Left Fountain	Flush180	05-OCT-16	19.200	ppb
51625	51625-2-HAL-F01	Across Auditorium Left Fountain	Flush180	05-OCT-16	8.190	ppb
51625	51625-2-HAL-F01	Across Auditorium Left Fountain	Flush180	05-OCT-16	12.800	ppb
51625	51625-2-HAL-F01	Across Auditorium Left Fountain	Initial	30-NOV-16	63.000	ppb
51625	51625-2-HAL-F01	Across Auditorium Left Fountain	Initial	05-OCT-16	9.050	ppb
51625	51625-2-HAL-F01	Across Auditorium Left Fountain	Initial	17-MAR-17	6.300	ppb
51625	51625-1-HAL-F04	Across Auditorium Right Fount	Flush	25-JAN-2024	3.200	ug/L
51625	51625-1-HAL-F04	Across Auditorium Right Fount	Flush	25-JAN-2024	2.600	ug/L
51625	51625-1-HAL-F04	Across Auditorium Right Fount	Flush	25-JAN-2024	2.780	ug/L
51625	51625-1-HAL-F04	Across Auditorium Right Fount	Flush	25-JAN-2024	3.050	ug/L
51625	51625-1-HAL-F04	Across Auditorium Right Fount	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F04	Across Auditorium Right Fount	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F04	Across Auditorium Right Fount	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F04	Across Auditorium Right Fount	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F04	Across Auditorium Right Fount	Initial	05-OCT-16	5.930	ppb
51625	51625-1-HAL-F04	Across Auditorium Right Fount	Initial	25-JAN-2024	7.350	ug/L
51625	51625-2-HAL-F02	Across Auditorium Right Fountain	Flush180	05-OCT-16	13.200	ppb
51625	51625-2-HAL-F02	Across Auditorium Right Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-2-HAL-F02	Across Auditorium Right Fountain	Flush180	05-OCT-16	6.180	ppb
51625	51625-2-HAL-F02	Across Auditorium Right Fountain	Flush180	05-OCT-16	8.850	ppb
51625	51625-2-HAL-F02	Across Auditorium Right Fountain	Initial	05-OCT-16	8.610	ppb
51625	51625-1-HAL-F06	Across From RM 126	Flush180	05-OCT-16	5.660	ppb
51625	51625-1-HAL-F06	Across From RM 126	Flush180	05-OCT-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51625	51625-1-HAL-F06	Across From RM 126	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F06	Across From RM 126	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F06	Across From RM 126	Initial	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F06	Across From RM 126, right Fountain	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-HAL-F06	Across From RM 126, right Fountain	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-HAL-F06	Across From RM 126, right Fountain	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-HAL-F06	Across From RM 126, right Fountain	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-HAL-F06	Across From RM 126, right Fountain	Initial	25-JAN-2024	1.000	ug/L
51625	51625-1-HAL-F14	Across RM 022	Flush180	05-OCT-16	6.030	ppb
51625	51625-1-HAL-F14	Across RM 022	Flush180	05-OCT-16	5.980	ppb
51625	51625-1-HAL-F14	Across RM 022	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F14	Across RM 022	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F15	Across RM 022	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F15	Across RM 022	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F15	Across RM 022	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F15	Across RM 022	Initial	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F15	Across RM 022	Initial	05-OCT-16	5.280	ppb
51625	51625-1-HAL-F05	Across RM 126	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F05	Across RM 126	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F05	Across RM 126	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F05	Across RM 126	Initial	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F05	Across RM 126, Left Fountain	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-HAL-F05	Across RM 126, Left Fountain	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-HAL-F05	Across RM 126, Left Fountain	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-HAL-F05	Across RM 126, Left Fountain	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-HAL-F05	Across RM 126, Left Fountain	Initial	25-JAN-2024	1.000	ug/L
51625	51625-1-HAL-F09	Across RM 138 Left Fountain	Flush	21-FEB-2024	1.780	ug/L
51625	51625-1-HAL-F09	Across RM 138 Left Fountain	Flush	21-FEB-2024	1.550	ug/L
51625	51625-1-HAL-F09	Across RM 138 Left Fountain	Flush	21-FEB-2024	2.480	ug/L
51625	51625-1-HAL-F09	Across RM 138 Left Fountain	Flush	21-FEB-2024	1.050	ug/L
51625	51625-1-HAL-F09	Across RM 138 Left Fountain	Flush	25-JAN-2024	1.400	ug/L
51625	51625-1-HAL-F09	Across RM 138 Left Fountain	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-HAL-F09	Across RM 138 Left Fountain	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-HAL-F09	Across RM 138 Left Fountain	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-HAL-F09	Across RM 138 Left Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F09	Across RM 138 Left Fountain	Flush180	05-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F09					
51625	51625-1-HAL-F09	Across RM 138 Left Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F09	Across RM 138 Left Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F09	Across RM 138 Left Fountain	Initial	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F09	Across RM 138 Left Fountain	Initial	21-FEB-2024	4.640	ug/L
51625	51625-1-HAL-F09	Across RM 138 Left Fountain	Initial	25-JAN-2024	5.400	ug/L
51625	51625-1-HAL-F10	Across RM 138 Right Fountain	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-HAL-F10	Across RM 138 Right Fountain	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-HAL-F10	Across RM 138 Right Fountain	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-HAL-F10	Across RM 138 Right Fountain	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-HAL-F10	Across RM 138 Right Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F10	Across RM 138 Right Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F10	Across RM 138 Right Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F10	Across RM 138 Right Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F10	Across RM 138 Right Fountain	Initial	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F10	Across RM 138 Right Fountain	Initial	25-JAN-2024	1.280	ug/L
51625	51625-1-HAL-F11	Across RM 144 Left Fountain	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-HAL-F11	Across RM 144 Left Fountain	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-HAL-F11	Across RM 144 Left Fountain	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-HAL-F11	Across RM 144 Left Fountain	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-HAL-F11	Across RM 144 Left Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F11	Across RM 144 Left Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F11	Across RM 144 Left Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F11	Across RM 144 Left Fountain	Initial	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F11	Across RM 144 Left Fountain	Initial	25-JAN-2024	1.290	ug/L
51625	51625-1-HAL-F12	Across RM 144 Right Fountain	Flush	25-JAN-2024	2.990	ug/L
51625	51625-1-HAL-F12	Across RM 144 Right Fountain	Flush	25-JAN-2024	1.100	ug/L
51625	51625-1-HAL-F12	Across RM 144 Right Fountain	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-HAL-F12	Across RM 144 Right Fountain	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-HAL-F12	Across RM 144 Right Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F12	Across RM 144 Right Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F12	Across RM 144 Right Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F12	Across RM 144 Right Fountain	Initial	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F12	Across RM 144 Right Fountain	Initial	25-JAN-2024	3.200	ug/L
51625	51625-1-117-F02	Back of Auditorium Right Fountain By Womens Room	Flush	25-JAN-2024	6.370	ug/L
51625	51625-1-117-	Back of Auditorium Right Fountain	Flush	25-JAN-2024	2.560	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02	By Womens Room				
51625	51625-1-117-F02	Back of Auditorium Right Fountain By Womens Room	Flush	21-FEB-2024	1.520	ug/L
51625	51625-1-117-F02	Back of Auditorium Right Fountain By Womens Room	Flush	21-FEB-2024	1.000	ug/L
51625	51625-1-117-F02	Back of Auditorium Right Fountain By Womens Room	Flush	21-FEB-2024	1.000	ug/L
51625	51625-1-117-F02	Back of Auditorium Right Fountain By Womens Room	Flush	21-FEB-2024	1.000	ug/L
51625	51625-1-117-F02	Back of Auditorium Right Fountain By Womens Room	Flush	25-JAN-2024	1.630	ug/L
51625	51625-1-117-F02	Back of Auditorium Right Fountain By Womens Room	Flush	25-JAN-2024	1.460	ug/L
51625	51625-1-117-F02	Back of Auditorium Right Fountain By Womens Room	Flush	15-MAR-2024	1.000	ug/L
51625	51625-1-117-F02	Back of Auditorium Right Fountain By Womens Room	Flush	15-MAR-2024	1.000	ug/L
51625	51625-1-117-F02	Back of Auditorium Right Fountain By Womens Room	Flush	15-MAR-2024	1.000	ug/L
51625	51625-1-117-F02	Back of Auditorium Right Fountain By Womens Room	Flush	15-MAR-2024	1.000	ug/L
51625	51625-1-117-F02	Back of Auditorium Right Fountain By Womens Room	Initial	25-JAN-2024	23.600	ug/L
51625	51625-1-117-F02	Back of Auditorium Right Fountain By Womens Room	Initial	21-FEB-2024	5.320	ug/L
51625	51625-1-117-F02	Back of Auditorium Right Fountain By Womens Room	Initial	15-MAR-2024	1.680	ug/L
51625	51625-1-117-F01	Back of Auditorium left Fountain	Flush180	05-OCT-16	13.100	ppb
51625	51625-1-117-F01	Back of Auditorium left Fountain	Flush180	05-OCT-16	23.000	ppb
51625	51625-1-117-F01	Back of Auditorium left Fountain	Flush180	05-OCT-16	48.100	ppb
51625	51625-1-117-F01	Back of Auditorium left Fountain	Flush180	05-OCT-16	8.550	ppb
51625	51625-1-117-F01	Back of Auditorium left Fountain	Flush180	30-NOV-16	3.200	ppb
51625	51625-1-117-F01	Back of Auditorium left Fountain	Flush180	30-NOV-16	4.300	ppb
51625	51625-1-117-F01	Back of Auditorium left Fountain	Flush180	30-NOV-16	7.600	ppb
51625	51625-1-117-F01	Back of Auditorium left Fountain	Flush180	30-NOV-16	21.000	ppb
51625	51625-1-117-F01	Back of Auditorium left Fountain	Flush180	17-MAR-17	7.500	ppb
51625	51625-1-117-F01	Back of Auditorium left Fountain	Flush180	17-MAR-17	1.500	ppb
51625	51625-1-117-F01	Back of Auditorium left Fountain	Flush180	17-MAR-17	0.770	ppb
51625	51625-1-117-F01	Back of Auditorium left Fountain	Flush180	17-MAR-17	0.590	ppb
51625	51625-1-117-F01	Back of Auditorium left Fountain	Initial	30-NOV-16	40.000	ppb
51625	51625-1-117-F01	Back of Auditorium left Fountain	Initial	05-OCT-16	49.600	ppb
51625	51625-1-117-F01	Back of Auditorium left Fountain	Initial	17-MAR-17	8.500	ppb
51625	51625-1-117-F01	Back of Auditorium left Fountain By Mens Room	Flush	25-JAN-2024	12.000	ug/L
51625	51625-1-117-F01	Back of Auditorium left Fountain By Mens Room	Flush	25-JAN-2024	3.840	ug/L
51625	51625-1-117-F01	Back of Auditorium left Fountain By Mens Room	Flush	17-MAY-2024	2.880	ug/L
51625	51625-1-117-F01	Back of Auditorium left Fountain By Mens Room	Flush	17-MAY-2024	7.490	ug/L
51625	51625-1-117-F01	Back of Auditorium left Fountain By Mens Room	Flush	17-MAY-2024	4.300	ug/L
51625	51625-1-117-F01	Back of Auditorium left Fountain By Mens Room	Flush	17-MAY-2024	3.520	ug/L
51625	51625-1-117-F01	Back of Auditorium left Fountain By Mens Room	Flush	21-FEB-2024	8.000	ug/L
51625	51625-1-117-F01	Back of Auditorium left Fountain By Mens Room	Flush	21-FEB-2024	4.300	ug/L
51625	51625-1-117-F01	Back of Auditorium left Fountain By Mens Room	Flush	21-FEB-2024	2.550	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51625	51625-1-117-F01	Back of Auditorium left Fountain By Mens Room	Flush	21-FEB-2024	2.020	ug/L
51625	51625-1-117-F01	Back of Auditorium left Fountain By Mens Room	Flush	25-JAN-2024	13.500	ug/L
51625	51625-1-117-F01	Back of Auditorium left Fountain By Mens Room	Flush	25-JAN-2024	5.590	ug/L
51625	51625-1-117-F01	Back of Auditorium left Fountain By Mens Room	Flush	15-MAR-2024	2.360	ug/L
51625	51625-1-117-F01	Back of Auditorium left Fountain By Mens Room	Flush	15-MAR-2024	2.920	ug/L
51625	51625-1-117-F01	Back of Auditorium left Fountain By Mens Room	Flush	15-MAR-2024	3.750	ug/L
51625	51625-1-117-F01	Back of Auditorium left Fountain By Mens Room	Flush	15-MAR-2024	2.540	ug/L
51625	51625-1-117-F01	Back of Auditorium left Fountain By Mens Room	Initial	17-MAY-2024	11.600	ug/L
51625	51625-1-117-F01	Back of Auditorium left Fountain By Mens Room	Initial	21-FEB-2024	22.100	ug/L
51625	51625-1-117-F01	Back of Auditorium left Fountain By Mens Room	Initial	25-JAN-2024	31.100	ug/L
51625	51625-1-117-F01	Back of Auditorium left Fountain By Mens Room	Initial	15-MAR-2024	6.420	ug/L
51625	51625-1-CAF-F03	By Stair exit	Flush180	30-NOV-16	7.600	ppb
51625	51625-1-CAF-F03	By Stair exit	Flush180	30-NOV-16	2.600	ppb
51625	51625-1-CAF-F03	By Stair exit	Flush180	30-NOV-16	1.600	ppb
51625	51625-1-CAF-F03	By Stair exit	Flush180	05-OCT-16	9.390	ppb
51625	51625-1-CAF-F03	By Stair exit	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-CAF-F03	By Stair exit	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-CAF-F03	By Stair exit	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-CAF-F03	By Stair exit	Flush180	30-NOV-16	1.100	ppb
51625	51625-1-CAF-F03	By Stair exit	Initial	05-OCT-16	17.600	ppb
51625	51625-1-CAF-F03	By Stair exit	Initial	30-NOV-16	20.000	ppb
51625	51625-1-113-S01	Culinary Arts RM Left Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-113-S01	Culinary Arts RM Left Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-113-S01	Culinary Arts RM Left Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-113-S01	Culinary Arts RM Left Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-113-S01	Culinary Arts RM Left Sink	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-113-S01	Culinary Arts RM Left Sink	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-113-S01	Culinary Arts RM Left Sink	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-113-S01	Culinary Arts RM Left Sink	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-113-S01	Culinary Arts RM Left Sink	Initial	05-OCT-16	1.000	ppb
51625	51625-1-113-S01	Culinary Arts RM Left Sink	Initial	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS02	East Side of Kitchen, North Sink	Flush	25-JAN-2024	1.340	ug/L
51625	51625-1-KIT-KS02	East Side of Kitchen, North Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS02	East Side of Kitchen, North Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS02	East Side of Kitchen, North Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS02	East Side of Kitchen, North Sink	Initial	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS03	East Side of Kitchen, South Sink	Flush	25-JAN-2024	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51625	51625-1-KIT-KS03	East Side of Kitchen, South Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS03	East Side of Kitchen, South Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS03	East Side of Kitchen, South Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS03	East Side of Kitchen, South Sink	Initial	25-JAN-2024	1.090	ug/L
51625	51625-1-KIT-S02	Far right prep table left sink	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-KIT-S02	Far right prep table left sink	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-KIT-S02	Far right prep table left sink	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-KIT-S02	Far right prep table left sink	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-KIT-S02	Far right prep table left sink	Initial	05-OCT-16	1.000	ppb
51625	51625-1-KIT-KS03	Far right prep table right sink	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-KIT-KS03	Far right prep table right sink	Flush180	05-OCT-16	12.000	ppb
51625	51625-1-KIT-KS03	Far right prep table right sink	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-KIT-KS03	Far right prep table right sink	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-KIT-KS03	Far right prep table right sink	Initial	05-OCT-16	1.000	ppb
51625	51625-1-KIT-KS01	Kitchen Middle Prep Table	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS01	Kitchen Middle Prep Table	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS01	Kitchen Middle Prep Table	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS01	Kitchen Middle Prep Table	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS01	Kitchen Middle Prep Table	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-KIT-KS01	Kitchen Middle Prep Table	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-KIT-KS01	Kitchen Middle Prep Table	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-KIT-KS01	Kitchen Middle Prep Table	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-KIT-KS01	Kitchen Middle Prep Table	Initial	05-OCT-16	1.000	ppb
51625	51625-1-KIT-KS01	Kitchen Middle Prep Table	Initial	25-JAN-2024	1.000	ug/L
51625	51625-1-HAL-F07	Main Entrance Left Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F07	Main Entrance Left Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F07	Main Entrance Left Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F07	Main Entrance Left Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F07	Main Entrance Left Fountain	Initial	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F08	Main Entrance Right Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F08	Main Entrance Right Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F08	Main Entrance Right Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F08	Main Entrance Right Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F08	Main Entrance Right Fountain	Initial	05-OCT-16	1.000	ppb
51625	51625-1-135-F01	Main Office	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-135-F01	Main Office	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-135-F01	Main Office	Flush180	05-OCT-16	5.280	ppb
51625	51625-1-135-	Main Office	Flush180	05-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01					
51625	51625-1-135-F01	Main Office	Initial	05-OCT-16	5.070	ppb
51625	51625-1-CAF-F01	Middle Pillar, Left Caferia	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-CAF-F01	Middle Pillar, Left Caferia	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-CAF-F01	Middle Pillar, Left Caferia	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-CAF-F01	Middle Pillar, Left Caferia	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-CAF-F01	Middle Pillar, Left Caferia	Initial	05-OCT-16	1.000	ppb
51625	51625-1-CAF-F02	Middle Pillar, Right Cafeteria	Flush180	05-OCT-16	12.900	ppb
51625	51625-1-CAF-F02	Middle Pillar, Right Cafeteria	Flush180	05-OCT-16	5.880	ppb
51625	51625-1-CAF-F02	Middle Pillar, Right Cafeteria	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-CAF-F02	Middle Pillar, Right Cafeteria	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-CAF-F02	Middle Pillar, Right Cafeteria	Initial	05-OCT-16	11.800	ppb
51625	51625-1-CAF-RBF01	Middle Pillar, Right Cafeteria Bottle Filler	Flush	25-JAN-2024	1.870	ug/L
51625	51625-1-CAF-RBF01	Middle Pillar, Right Cafeteria Bottle Filler	Flush	25-JAN-2024	2.650	ug/L
51625	51625-1-CAF-RBF01	Middle Pillar, Right Cafeteria Bottle Filler	Flush	25-JAN-2024	2.870	ug/L
51625	51625-1-CAF-RBF01	Middle Pillar, Right Cafeteria Bottle Filler	Flush	25-JAN-2024	2.650	ug/L
51625	51625-1-CAF-RBF01	Middle Pillar, Right Cafeteria Bottle Filler	Flush	25-JAN-2024	2.070	ug/L
51625	51625-1-CAF-RBF01	Middle Pillar, Right Cafeteria Bottle Filler	Flush	25-JAN-2024	1.590	ug/L
51625	51625-1-CAF-RBF01	Middle Pillar, Right Cafeteria Bottle Filler	Flush	25-JAN-2024	2.550	ug/L
51625	51625-1-CAF-RBF01	Middle Pillar, Right Cafeteria Bottle Filler	Flush	25-JAN-2024	1.490	ug/L
51625	51625-1-CAF-RBF01	Middle Pillar, Right Cafeteria Bottle Filler	Initial	25-JAN-2024	1.550	ug/L
51625	51625-1-CAF-RBF01	Middle Pillar, Right Cafeteria Bottle Filler	Initial	25-JAN-2024	2.930	ug/L
51625	51625-1-HAL-F13	NE Corner Hall	Flush180	05-OCT-16	17.600	ppb
51625	51625-1-HAL-F13	NE Corner Hall	Flush180	17-MAR-17	8.900	ppb
51625	51625-1-HAL-F13	NE Corner Hall	Flush180	17-MAR-17	9.000	ppb
51625	51625-1-HAL-F13	NE Corner Hall	Flush180	17-MAR-17	7.000	ppb
51625	51625-1-HAL-F13	NE Corner Hall	Flush180	05-OCT-16	14.700	ppb
51625	51625-1-HAL-F13	NE Corner Hall	Flush180	05-OCT-16	16.700	ppb
51625	51625-1-HAL-F13	NE Corner Hall	Flush180	05-OCT-16	17.100	ppb
51625	51625-1-HAL-F13	NE Corner Hall	Flush180	30-DEC-16	27.000	ppb
51625	51625-1-HAL-F13	NE Corner Hall	Flush180	30-DEC-16	26.000	ppb
51625	51625-1-HAL-F13	NE Corner Hall	Flush180	30-DEC-16	26.000	ppb
51625	51625-1-HAL-F13	NE Corner Hall	Flush180	30-DEC-16	30.000	ppb
51625	51625-1-HAL-F13	NE Corner Hall	Flush180	17-MAR-17	8.400	ppb
51625	51625-1-HAL-F13	NE Corner Hall	Initial	17-MAR-17	5.100	ppb
51625	51625-1-HAL-F13	NE Corner Hall	Initial	05-OCT-16	10.000	ppb
51625	51625-1-HAL-F13	NE Corner Hall	Initial	30-DEC-16	15.000	ppb
51625	51625-1-HAL-	Next to RM 011 Left Fount.	Flush180	05-OCT-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02					
51625	51625-1-HAL-F02	Next to RM 011 Left Fount.	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F02	Next to RM 011 Left Fount.	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F02	Next to RM 011 Left Fount.	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F02	Next to RM 011 Left Fount.	Initial	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F01	Next to RM 011 Right Fount.	Flush180	30-NOV-16	2.800	ppb
51625	51625-1-HAL-F01	Next to RM 011 Right Fount.	Flush180	05-OCT-16	7.990	ppb
51625	51625-1-HAL-F01	Next to RM 011 Right Fount.	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F01	Next to RM 011 Right Fount.	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F01	Next to RM 011 Right Fount.	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-HAL-F01	Next to RM 011 Right Fount.	Flush180	30-NOV-16	0.630	ppb
51625	51625-1-HAL-F01	Next to RM 011 Right Fount.	Flush180	30-NOV-16	0.820	ppb
51625	51625-1-HAL-F01	Next to RM 011 Right Fount.	Flush180	30-NOV-16	3.100	ppb
51625	51625-1-HAL-F01	Next to RM 011 Right Fount.	Initial	05-OCT-16	15.500	ppb
51625	51625-1-HAL-F01	Next to RM 011 Right Fount.	Initial	30-NOV-16	8.000	ppb
51625	51625-2-241A-S02	Nurses Office	Flush180	05-OCT-16	1.000	ppb
51625	51625-2-241A-S02	Nurses Office	Flush180	05-OCT-16	1.000	ppb
51625	51625-2-241A-S02	Nurses Office	Flush180	05-OCT-16	1.000	ppb
51625	51625-2-241A-S051625-2-241A-S02	Nurses Office	Flush180	05-OCT-16	1.000	ppb
51625	51625-2-241A-S02	Nurses Office	Initial	05-OCT-16	1.000	ppb
51625	51625-2-241A-S01	Nurses Office sink on West Wall	Flush180	05-OCT-16	11.400	ppb
51625	51625-2-241A-S01	Nurses Office sink on West Wall	Flush180	05-OCT-16	8.770	ppb
51625	51625-2-241A-S01	Nurses Office sink on West Wall	Flush180	30-NOV-16	3.900	ppb
51625	51625-2-241A-S01	Nurses Office sink on West Wall	Flush180	05-OCT-16	18.200	ppb
51625	51625-2-241A-S01	Nurses Office sink on West Wall	Flush180	05-OCT-16	14.500	ppb
51625	51625-2-241A-S01	Nurses Office sink on West Wall	Flush180	30-NOV-16	4.400	ppb
51625	51625-2-241A-S01	Nurses Office sink on West Wall	Flush180	30-NOV-16	5.500	ppb
51625	51625-2-241A-S01	Nurses Office sink on West Wall	Flush180	30-NOV-16	5.200	ppb
51625	51625-2-241A-S01	Nurses Office sink on West Wall	Flush180	17-MAR-17	2.000	ppb
51625	51625-2-241A-S01	Nurses Office sink on West Wall	Flush180	17-MAR-17	3.200	ppb
51625	51625-2-241A-S01	Nurses Office sink on West Wall	Flush180	17-MAR-17	3.700	ppb
51625	51625-2-241A-S01	Nurses Office sink on West Wall	Flush180	17-MAR-17	1.400	ppb
51625	51625-2-241A-S01	Nurses Office sink on West Wall	Initial	05-OCT-16	16.100	ppb
51625	51625-2-241A-S01	Nurses Office sink on West Wall	Initial	30-NOV-16	40.000	ppb
51625	51625-2-241A-S01	Nurses Office sink on West Wall	Initial	17-MAR-17	2.100	ppb
51625	51625-2-HAL-F05	Outside Library	Flush180	05-OCT-16	1.000	ppb
51625	51625-2-HAL-F05	Outside Library	Flush180	05-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51625	51625-2-HAL-F05	Outside Library	Flush180	05-OCT-16	1.000	ppb
51625	51625-2-HAL-F05	Outside Library	Flush180	05-OCT-16	1.000	ppb
51625	51625-2-HAL-F05	Outside Library	Initial	05-OCT-16	5.730	ppb
51625	51625-2-HAL-F04	Outside RM 228 Right Fountain	Flush	25-JAN-2024	1.100	ug/L
51625	51625-2-HAL-F04	Outside RM 228 Right Fountain	Flush	25-JAN-2024	1.000	ug/L
51625	51625-2-HAL-F04	Outside RM 228 Right Fountain	Flush	25-JAN-2024	1.000	ug/L
51625	51625-2-HAL-F04	Outside RM 228 Right Fountain	Flush	25-JAN-2024	1.070	ug/L
51625	51625-2-HAL-F04	Outside RM 228 Right Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-2-HAL-F04	Outside RM 228 Right Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-2-HAL-F04	Outside RM 228 Right Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-2-HAL-F04	Outside RM 228 Right Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-2-HAL-F04	Outside RM 228 Right Fountain	Initial	05-OCT-16	1.000	ppb
51625	51625-2-HAL-F04	Outside RM 228 Right Fountain	Initial	25-JAN-2024	1.160	ug/L
51625	51625-2-HAL-F06	Outside RM 238 Left Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-2-HAL-F06	Outside RM 238 Left Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-2-HAL-F06	Outside RM 238 Left Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-2-HAL-F06	Outside RM 238 Left Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-2-HAL-F06	Outside RM 238 Left Fountain	Initial	05-OCT-16	1.000	ppb
51625	51625-2-HAL-F07	Outside RM 238 Right Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-2-HAL-F07	Outside RM 238 Right Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-2-HAL-F07	Outside RM 238 Right Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-2-HAL-F07	Outside RM 238 Right Fountain	Flush180	05-OCT-16	1.000	ppb
51625	51625-2-HAL-F07	Outside RM 238 Right Fountain	Initial	05-OCT-16	1.000	ppb
51625	51625-2-HAL-F09	Outside RM 245 Right Fountain	Flush180	30-NOV-16	14.000	ppb
51625	51625-2-HAL-F09	Outside RM 245 Right Fountain	Flush180	30-NOV-16	12.000	ppb
51625	51625-2-HAL-F09	Outside RM 245 Right Fountain	Flush180	05-OCT-16	14.100	ppb
51625	51625-2-HAL-F09	Outside RM 245 Right Fountain	Flush180	17-MAR-17	2.300	ppb
51625	51625-2-HAL-F09	Outside RM 245 Right Fountain	Flush180	05-OCT-16	10.200	ppb
51625	51625-2-HAL-F09	Outside RM 245 Right Fountain	Flush180	05-OCT-16	9.330	ppb
51625	51625-2-HAL-F09	Outside RM 245 Right Fountain	Flush180	05-OCT-16	17.700	ppb
51625	51625-2-HAL-F09	Outside RM 245 Right Fountain	Flush180	17-MAR-17	5.400	ppb
51625	51625-2-HAL-F09	Outside RM 245 Right Fountain	Flush180	30-NOV-16	16.000	ppb
51625	51625-2-HAL-F09	Outside RM 245 Right Fountain	Flush180	30-NOV-16	26.000	ppb
51625	51625-2-HAL-F09	Outside RM 245 Right Fountain	Flush180	17-MAR-17	6.700	ppb
51625	51625-2-HAL-F09	Outside RM 245 Right Fountain	Flush180	17-MAR-17	4.600	ppb
51625	51625-2-HAL-F09	Outside RM 245 Right Fountain	Initial	17-MAR-17	5.300	ppb
51625	51625-2-HAL-F09	Outside RM 245 Right Fountain	Initial	05-OCT-16	17.100	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51625	51625-2-HAL-F09	Outside RM 245 Right Fountain	Initial	30-NOV-16	31.000	ppb
51625	51625-2-HAL-F10	Outside RM 252	Flush180	05-OCT-16	1.000	ppb
51625	51625-2-HAL-F10	Outside RM 252	Flush180	05-OCT-16	1.000	ppb
51625	51625-2-HAL-F10	Outside RM 252	Flush180	05-OCT-16	5.080	ppb
51625	51625-2-HAL-F10	Outside RM 252	Flush180	05-OCT-16	1.000	ppb
51625	51625-2-HAL-F10	Outside RM 252	Initial	05-OCT-16	1.000	ppb
51625	51625-3-HAL-F03	Outside RM 325	Flush180	05-OCT-16	1.000	ppb
51625	51625-3-HAL-F03	Outside RM 325	Flush180	05-OCT-16	1.000	ppb
51625	51625-3-HAL-F03	Outside RM 325	Flush180	05-OCT-16	1.000	ppb
51625	51625-3-HAL-F03	Outside RM 325	Flush180	05-OCT-16	1.000	ppb
51625	51625-3-HAL-F03	Outside RM 325	Initial	05-OCT-16	1.000	ppb
51625	51625-3-HAL-F03	Outside RM 325, Left Fountain	Flush	25-JAN-2024	1.000	ug/L
51625	51625-3-HAL-F03	Outside RM 325, Left Fountain	Flush	25-JAN-2024	1.000	ug/L
51625	51625-3-HAL-F03	Outside RM 325, Left Fountain	Flush	25-JAN-2024	1.000	ug/L
51625	51625-3-HAL-F03	Outside RM 325, Left Fountain	Flush	25-JAN-2024	1.000	ug/L
51625	51625-3-HAL-F03	Outside RM 325, Left Fountain	Initial	25-JAN-2024	1.000	ug/L
51625	51625-3-HAL-F04	Outside RM 325, Right Fountain	Flush	25-JAN-2024	1.000	ug/L
51625	51625-3-HAL-F04	Outside RM 325, Right Fountain	Flush	25-JAN-2024	1.000	ug/L
51625	51625-3-HAL-F04	Outside RM 325, Right Fountain	Flush	25-JAN-2024	1.000	ug/L
51625	51625-3-HAL-F04	Outside RM 325, Right Fountain	Initial	25-JAN-2024	1.000	ug/L
51625	51625-3-HAL-F05	Outside RM 332	Flush180	05-OCT-16	1.000	ppb
51625	51625-3-HAL-F05	Outside RM 332	Flush180	05-OCT-16	7.750	ppb
51625	51625-3-HAL-F05	Outside RM 332	Flush180	05-OCT-16	5.210	ppb
51625	51625-3-HAL-F05	Outside RM 332	Flush180	05-OCT-16	1.000	ppb
51625	51625-3-HAL-F05	Outside RM 332	Flush180	30-NOV-16	4.000	ppb
51625	51625-3-HAL-F05	Outside RM 332	Flush180	30-NOV-16	4.600	ppb
51625	51625-3-HAL-F05	Outside RM 332	Flush180	30-NOV-16	6.300	ppb
51625	51625-3-HAL-F05	Outside RM 332	Flush180	17-MAR-17	2.100	ppb
51625	51625-3-HAL-F05	Outside RM 332	Flush180	30-NOV-16	8.100	ppb
51625	51625-3-HAL-F05	Outside RM 332	Flush180	17-MAR-17	1.200	ppb
51625	51625-3-HAL-F05	Outside RM 332	Flush180	17-MAR-17	0.900	ppb
51625	51625-3-HAL-F05	Outside RM 332	Flush180	17-MAR-17	1.000	ppb
51625	51625-3-HAL-F05	Outside RM 332	Initial	05-OCT-16	15.000	ppb
51625	51625-3-HAL-F05	Outside RM 332	Initial	30-NOV-16	28.000	ppb
51625	51625-3-HAL-F05	Outside RM 332	Initial	17-MAR-17	3.700	ppb
51625	51625-3-HAL-F06	Outside RM 338	Flush180	05-OCT-16	1.000	ppb
51625	51625-3-HAL-	Outside RM 338	Flush180	05-OCT-16	6.190	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F06					
51625	51625-3-HAL-F06	Outside RM 338	Flush180	05-OCT-16	8.590	ppb
51625	51625-3-HAL-F06	Outside RM 338	Flush180	05-OCT-16	7.210	ppb
51625	51625-3-HAL-F06	Outside RM 338	Initial	05-OCT-16	10.700	ppb
51625	51625-3-HAL-F06	Outside RM 338, Left Fountain	Flush	25-JAN-2024	9.210	ug/L
51625	51625-3-HAL-F06	Outside RM 338, Left Fountain	Flush	25-JAN-2024	10.500	ug/L
51625	51625-3-HAL-F06	Outside RM 338, Left Fountain	Flush	25-JAN-2024	10.300	ug/L
51625	51625-3-HAL-F06	Outside RM 338, Left Fountain	Flush	25-JAN-2024	4.260	ug/L
51625	51625-3-HAL-F06	Outside RM 338, Left Fountain	Initial	25-JAN-2024	32.600	ug/L
51625	51625-3-HAL-F07	Outside RM 338, Right Fountain	Flush	25-JAN-2024	5.160	ug/L
51625	51625-3-HAL-F07	Outside RM 338, Right Fountain	Flush	25-JAN-2024	11.000	ug/L
51625	51625-3-HAL-F07	Outside RM 338, Right Fountain	Flush	25-JAN-2024	14.900	ug/L
51625	51625-3-HAL-F07	Outside RM 338, Right Fountain	Flush	25-JAN-2024	15.200	ug/L
51625	51625-3-HAL-F07	Outside RM 338, Right Fountain	Initial	25-JAN-2024	19.000	ug/L
51625	51625-3-HAL-F08	Outside RM 342	Flush180	17-MAR-17	5.500	ppb
51625	51625-3-HAL-F08	Outside RM 342	Flush180	17-MAR-17	4.600	ppb
51625	51625-3-HAL-F08	Outside RM 342	Flush180	17-MAR-17	3.100	ppb
51625	51625-3-HAL-F08	Outside RM 342	Flush180	30-NOV-16	36.000	ppb
51625	51625-3-HAL-F08	Outside RM 342	Flush180	30-NOV-16	49.000	ppb
51625	51625-3-HAL-F08	Outside RM 342	Flush180	30-NOV-16	18.000	ppb
51625	51625-3-HAL-F08	Outside RM 342	Flush180	05-OCT-16	45.300	ppb
51625	51625-3-HAL-F08	Outside RM 342	Flush180	05-OCT-16	33.300	ppb
51625	51625-3-HAL-F08	Outside RM 342	Flush180	05-OCT-16	21.300	ppb
51625	51625-3-HAL-F08	Outside RM 342	Flush180	30-NOV-16	22.000	ppb
51625	51625-3-HAL-F08	Outside RM 342	Flush180	05-OCT-16	16.200	ppb
51625	51625-3-HAL-F08	Outside RM 342	Flush180	17-MAR-17	11.000	ppb
51625	51625-3-HAL-F08	Outside RM 342	Initial	30-NOV-16	31.000	ppb
51625	51625-3-HAL-F08	Outside RM 342	Initial	05-OCT-16	29.400	ppb
51625	51625-3-HAL-F08	Outside RM 342	Initial	17-MAR-17	13.000	ppb
51625	51625-3-HAL-F08	Outside RM 342, Left Fountain	Flush	25-JAN-2024	49.100	ug/L
51625	51625-3-HAL-F08	Outside RM 342, Left Fountain	Flush	25-JAN-2024	53.700	ug/L
51625	51625-3-HAL-F08	Outside RM 342, Left Fountain	Flush	25-JAN-2024	26.600	ug/L
51625	51625-3-HAL-F08	Outside RM 342, Left Fountain	Flush	25-JAN-2024	22.000	ug/L
51625	51625-3-HAL-F08	Outside RM 342, Left Fountain	Initial	25-JAN-2024	33.100	ug/L
51625	51625-1-113-S02	RM 113 Middle Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-113-S02	RM 113 Middle Sink	Flush	25-JAN-2024	1.500	ug/L
51625	51625-1-113-S02	RM 113 Middle Sink	Flush	25-JAN-2024	1.070	ug/L
51625	51625-1-113-	RM 113 Middle Sink	Flush	25-JAN-2024	1.570	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S02					
51625	51625-1-113-S02	RM 113 Middle Sink	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-113-S02	RM 113 Middle Sink	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-113-S02	RM 113 Middle Sink	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-113-S02	RM 113 Middle Sink	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-113-S02	RM 113 Middle Sink	Initial	05-OCT-16	1.000	ppb
51625	51625-1-113-S02	RM 113 Middle Sink	Initial	25-JAN-2024	2.520	ug/L
51625	51625-1-113-S03	RM 113 Right Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-113-S03	RM 113 Right Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-113-S03	RM 113 Right Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-113-S03	RM 113 Right Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-113-S03	RM 113 Right Sink	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-113-S03	RM 113 Right Sink	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-113-S03	RM 113 Right Sink	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-113-S03	RM 113 Right Sink	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-113-S03	RM 113 Right Sink	Initial	05-OCT-16	1.000	ppb
51625	51625-1-113-S03	RM 113 Right Sink	Initial	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS04	S Wall, 3-Basin, Left Sink	Flush	21-FEB-2024	1.000	ug/L
51625	51625-1-KIT-KS04	S Wall, 3-Basin, Left Sink	Flush	21-FEB-2024	1.000	ug/L
51625	51625-1-KIT-KS04	S Wall, 3-Basin, Left Sink	Flush	21-FEB-2024	1.000	ug/L
51625	51625-1-KIT-KS04	S Wall, 3-Basin, Left Sink	Flush	21-FEB-2024	1.000	ug/L
51625	51625-1-KIT-KS04	S Wall, 3-Basin, Left Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS04	S Wall, 3-Basin, Left Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS04	S Wall, 3-Basin, Left Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS04	S Wall, 3-Basin, Left Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS04	S Wall, 3-Basin, Left Sink	Initial	21-FEB-2024	1.000	ug/L
51625	51625-1-KIT-KS04	S Wall, 3-Basin, Left Sink	Initial	25-JAN-2024	5.230	ug/L
51625	51625-1-KIT-KS05	S Wall, 3-Basin, Middle Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS05	S Wall, 3-Basin, Middle Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS05	S Wall, 3-Basin, Middle Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS05	S Wall, 3-Basin, Middle Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS05	S Wall, 3-Basin, Middle Sink	Initial	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS06	S Wall, 3-Basin, Right Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS06	S Wall, 3-Basin, Right Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS06	S Wall, 3-Basin, Right Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS06	S Wall, 3-Basin, Right Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS06	S Wall, 3-Basin, Right Sink	Initial	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS10	S wall, 2-basin , Left Sink	Flush	25-JAN-2024	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51625	51625-1-KIT-KS10	S wall, 2-basin , Left Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS10	S wall, 2-basin , Left Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS10	S wall, 2-basin , Left Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS10	S wall, 2-basin , Left Sink	Initial	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS11	S wall, 2-basin, Right Sink	Flush	25-JAN-2024	1.230	ug/L
51625	51625-1-KIT-KS11	S wall, 2-basin, Right Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS11	S wall, 2-basin, Right Sink	Flush	25-JAN-2024	1.160	ug/L
51625	51625-1-KIT-KS11	S wall, 2-basin, Right Sink	Flush	25-JAN-2024	1.000	ug/L
51625	51625-1-KIT-KS11	S wall, 2-basin, Right Sink	Initial	25-JAN-2024	1.000	ug/L
51625	51625-1-008-S01	Teacher's Lounge	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-008-S01	Teacher's Lounge	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-008-S01	Teacher's Lounge	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-008-S01	Teacher's Lounge	Flush180	05-OCT-16	1.000	ppb
51625	51625-1-008-S01	Teacher's Lounge	Initial	05-OCT-16	1.000	ppb
52343	52343-1-HANG-S01	Hangar	Flush180	05-OCT-16	1.000	ppb
52343	52343-1-HANG-S01	Hangar	Flush180	05-OCT-16	1.000	ppb
52343	52343-1-HANG-S01	Hangar	Flush180	05-OCT-16	1.000	ppb
52343	52343-1-HANG-S01	Hangar	Flush180	05-OCT-16	1.000	ppb
52343	52343-1-HANG-S01	Hangar	Initial	05-OCT-16	1.000	ppb