



**Sep 10, 2024**

**CLARK HS**

**5101 W HARRISON ST, Chicago IL 60644.**

Dear **CLARK HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**CLARK HS**

**5101 W HARRISON ST, Chicago IL 60644.**

Estimadas familias de **CLARK HS**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51573	51573-2-BLR-F01	Boys Locker RM	Flush	07-NOV-2023	3.120	ug/L
51573	51573-2-BLR-F01	Boys Locker RM	Flush	07-NOV-2023	2.030	ug/L
51573	51573-2-BLR-F01	Boys Locker RM	Flush	07-NOV-2023	1.980	ug/L
51573	51573-2-BLR-F01	Boys Locker RM	Flush	07-NOV-2023	1.390	ug/L
51573	51573-2-BLR-F01	Boys Locker RM	Flush	25-OCT-2023	6.790	ug/L
51573	51573-2-BLR-F01	Boys Locker RM	Flush	25-OCT-2023	6.410	ug/L
51573	51573-2-BLR-F01	Boys Locker RM	Flush	25-OCT-2023	3.830	ug/L
51573	51573-2-BLR-F01	Boys Locker RM	Flush	25-OCT-2023	2.720	ug/L
51573	51573-2-BLR-F01	Boys Locker RM	Flush180	14-SEP-23	5.210	ug/L
51573	51573-2-BLR-F01	Boys Locker RM	Flush180	14-SEP-23	2.180	ug/L
51573	51573-2-BLR-F01	Boys Locker RM	Flush180	14-SEP-23	3.680	ug/L
51573	51573-2-BLR-F01	Boys Locker RM	Flush180	14-SEP-23	3.260	ug/L
51573	51573-2-BLR-F01	Boys Locker RM	Flush180	12-OCT-16	0.530	ppb
51573	51573-2-BLR-F01	Boys Locker RM	Flush180	12-OCT-16	0.490	ppb
51573	51573-2-BLR-F01	Boys Locker RM	Flush180	12-OCT-16	1.200	ppb
51573	51573-2-BLR-F01	Boys Locker RM	Flush180	12-OCT-16	0.640	ppb
51573	51573-2-BLR-F01	Boys Locker RM	Initial	14-SEP-23	12.100	ug/L
51573	51573-2-BLR-F01	Boys Locker RM	Initial	12-OCT-16	2.200	ppb
51573	51573-2-BLR-F01	Boys Locker RM	Initial	07-NOV-2023	3.880	ug/L
51573	51573-2-BLR-F01	Boys Locker RM	Initial	25-OCT-2023	136.000	ug/L
51573	51573-1-CAF-S01	Cafeteria	Flush180	14-SEP-23	4.410	ug/L
51573	51573-1-CAF-S01	Cafeteria	Flush180	14-SEP-23	4.250	ug/L
51573	51573-1-CAF-S01	Cafeteria	Flush180	14-SEP-23	3.610	ug/L
51573	51573-1-CAF-S01	Cafeteria	Flush180	14-SEP-23	2.290	ug/L
51573	51573-1-CAF-S01	Cafeteria	Flush180	12-OCT-16	4.700	ppb
51573	51573-1-CAF-S01	Cafeteria	Flush180	12-OCT-16	4.700	ppb
51573	51573-1-CAF-S01	Cafeteria	Flush180	12-OCT-16	5.600	ppb
51573	51573-1-CAF-S01	Cafeteria	Flush180	12-OCT-16	8.000	ppb
51573	51573-1-CAF-S01	Cafeteria	Initial	14-SEP-23	2.940	ug/L
51573	51573-1-CAF-S01	Cafeteria	Initial	12-OCT-16	2.000	ppb
51573	51573-1-KIT-KS03	East Wall Sink	Flush180	12-OCT-16	32.000	ppb
51573	51573-1-KIT-KS03	East Wall Sink	Flush180	12-OCT-16	66.000	ppb
51573	51573-1-KIT-KS03	East Wall Sink	Flush180	12-OCT-16	91.000	ppb
51573	51573-1-KIT-KS03	East Wall Sink	Flush180	12-OCT-16	86.000	ppb
51573	51573-1-KIT-KS03	East Wall Sink	Initial	12-OCT-16	68.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51573	51573-1-FL-WC01	Faculty Lounge	Flush180	12-OCT-16	1.000	ppb
51573	51573-1-FL-WC01	Faculty Lounge	Flush180	12-OCT-16	1.000	ppb
51573	51573-1-FL-WC01	Faculty Lounge	Flush180	12-OCT-16	1.000	ppb
51573	51573-1-FL-WC01	Faculty Lounge	Flush180	12-OCT-16	1.000	ppb
51573	51573-1-FL-WC01	Faculty Lounge	Initial	12-OCT-16	1.000	ppb
51573	51573-2-GYM-F01	GYM NE Corner	Flush180	12-OCT-16	3.000	ppb
51573	51573-2-GYM-F01	GYM NE Corner	Flush180	12-OCT-16	2.800	ppb
51573	51573-2-GYM-F01	GYM NE Corner	Flush180	12-OCT-16	2.400	ppb
51573	51573-2-GYM-F01	GYM NE Corner	Flush180	12-OCT-16	2.500	ppb
51573	51573-2-GYM-F01	GYM NE Corner	Initial	12-OCT-16	2.800	ppb
51573	51573-2-GYM-F02	GYM NW Corner	Flush180	14-SEP-23	3.600	ug/L
51573	51573-2-GYM-F02	GYM NW Corner	Flush180	14-SEP-23	3.670	ug/L
51573	51573-2-GYM-F02	GYM NW Corner	Flush180	14-SEP-23	3.230	ug/L
51573	51573-2-GYM-F02	GYM NW Corner	Flush180	14-SEP-23	2.680	ug/L
51573	51573-2-GYM-F02	GYM NW Corner	Flush180	12-OCT-16	12.000	ppb
51573	51573-2-GYM-F02	GYM NW Corner	Flush180	12-OCT-16	4.900	ppb
51573	51573-2-GYM-F02	GYM NW Corner	Flush180	12-OCT-16	12.000	ppb
51573	51573-2-GYM-F02	GYM NW Corner	Flush180	12-OCT-16	4.700	ppb
51573	51573-2-GYM-F02	GYM NW Corner	Initial	14-SEP-23	3.150	ug/L
51573	51573-2-GYM-F02	GYM NW Corner	Initial	12-OCT-16	12.000	ppb
51573	51573-2-GLR-F01	Girls Locker RM	Flush	21-NOV-2023	4.540	ug/L
51573	51573-2-GLR-F01	Girls Locker RM	Flush	21-NOV-2023	1.450	ug/L
51573	51573-2-GLR-F01	Girls Locker RM	Flush	21-NOV-2023	1.000	ug/L
51573	51573-2-GLR-F01	Girls Locker RM	Flush	21-NOV-2023	1.000	ug/L
51573	51573-2-GLR-F01	Girls Locker RM	Flush	07-NOV-2023	2.640	ug/L
51573	51573-2-GLR-F01	Girls Locker RM	Flush	07-NOV-2023	1.240	ug/L
51573	51573-2-GLR-F01	Girls Locker RM	Flush	07-NOV-2023	1.160	ug/L
51573	51573-2-GLR-F01	Girls Locker RM	Flush	07-NOV-2023	1.040	ug/L
51573	51573-2-GLR-F01	Girls Locker RM	Flush	25-OCT-2023	5.450	ug/L
51573	51573-2-GLR-F01	Girls Locker RM	Flush	25-OCT-2023	3.700	ug/L
51573	51573-2-GLR-F01	Girls Locker RM	Flush	25-OCT-2023	1.860	ug/L
51573	51573-2-GLR-F01	Girls Locker RM	Flush	25-OCT-2023	2.910	ug/L
51573	51573-2-GLR-F01	Girls Locker RM	Flush	19-DEC-2023	1.000	ug/L
51573	51573-2-GLR-F01	Girls Locker RM	Flush	19-DEC-2023	2.370	ug/L
51573	51573-2-GLR-F01	Girls Locker RM	Flush	19-DEC-2023	1.000	ug/L
51573	51573-2-GLR-F01	Girls Locker RM	Flush	19-DEC-2023	1.030	ug/L
51573	51573-2-GLR-F01	Girls Locker RM	Flush180	14-SEP-23	4.790	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51573	51573-2-GLR-F01	Girls Locker RM	Flush180	14-SEP-23	2.730	ug/L
51573	51573-2-GLR-F01	Girls Locker RM	Flush180	14-SEP-23	1.870	ug/L
51573	51573-2-GLR-F01	Girls Locker RM	Flush180	14-SEP-23	1.740	ug/L
51573	51573-2-GLR-F01	Girls Locker RM	Flush180	12-OCT-16	1.200	ppb
51573	51573-2-GLR-F01	Girls Locker RM	Flush180	12-OCT-16	0.490	ppb
51573	51573-2-GLR-F01	Girls Locker RM	Flush180	12-OCT-16	0.690	ppb
51573	51573-2-GLR-F01	Girls Locker RM	Flush180	12-OCT-16	1.800	ppb
51573	51573-2-GLR-F01	Girls Locker RM	Initial	14-SEP-23	6.890	ug/L
51573	51573-2-GLR-F01	Girls Locker RM	Initial	12-OCT-16	3.200	ppb
51573	51573-2-GLR-F01	Girls Locker RM	Initial	21-NOV-2023	8.490	ug/L
51573	51573-2-GLR-F01	Girls Locker RM	Initial	07-NOV-2023	6.220	ug/L
51573	51573-2-GLR-F01	Girls Locker RM	Initial	25-OCT-2023	30.300	ug/L
51573	51573-2-GLR-F01	Girls Locker RM	Initial	19-DEC-2023	5.180	ug/L
51573	51573-2-HAL-F01	Hall Outside RM 251 Left Fount	Flush180	12-OCT-16	0.510	ppb
51573	51573-2-HAL-F01	Hall Outside RM 251 Left Fount	Flush180	12-OCT-16	0.480	ppb
51573	51573-2-HAL-F01	Hall Outside RM 251 Left Fount	Flush180	12-OCT-16	1.300	ppb
51573	51573-2-HAL-F01	Hall Outside RM 251 Left Fount	Flush180	12-OCT-16	0.800	ppb
51573	51573-2-HAL-F01	Hall Outside RM 251 Left Fount	Initial	12-OCT-16	1.300	ppb
51573	51573-1-CAF-S02	Hallway Outside Cafeteria House 2	Flush180	12-OCT-16	1.200	ppb
51573	51573-1-CAF-S02	Hallway Outside Cafeteria House 2	Flush180	12-OCT-16	1.500	ppb
51573	51573-1-CAF-S02	Hallway Outside Cafeteria House 2	Flush180	12-OCT-16	1.100	ppb
51573	51573-1-CAF-S02	Hallway Outside Cafeteria House 2	Flush180	12-OCT-16	1.300	ppb
51573	51573-1-CAF-S02	Hallway Outside Cafeteria House 2	Initial	12-OCT-16	9.300	ppb
51573	51573-2-HAL-BF02	Hallway next to Room 250	Flush180	14-SEP-23	1.000	ug/L
51573	51573-2-HAL-BF02	Hallway next to Room 250	Flush180	14-SEP-23	1.000	ug/L
51573	51573-2-HAL-BF02	Hallway next to Room 250	Flush180	14-SEP-23	1.000	ug/L
51573	51573-2-HAL-BF02	Hallway next to Room 250	Flush180	14-SEP-23	1.000	ug/L
51573	51573-2-HAL-BF02	Hallway next to Room 250	Initial	14-SEP-23	1.000	ug/L
51573	51573-2-212-BF01	Inside Room 212 / Counselors office	Flush	25-OCT-2023	2.380	ug/L
51573	51573-2-212-BF01	Inside Room 212 / Counselors office	Flush	25-OCT-2023	2.730	ug/L
51573	51573-2-212-BF01	Inside Room 212 / Counselors office	Flush	25-OCT-2023	3.050	ug/L
51573	51573-2-212-BF01	Inside Room 212 / Counselors office	Flush	25-OCT-2023	4.450	ug/L
51573	51573-2-212-BF01	Inside Room 212 / Counselors office	Flush180	14-SEP-23	5.560	ug/L
51573	51573-2-212-BF01	Inside Room 212 / Counselors office	Flush180	14-SEP-23	6.050	ug/L
51573	51573-2-212-BF01	Inside Room 212 / Counselors office	Flush180	14-SEP-23	4.470	ug/L
51573	51573-2-212-BF01	Inside Room 212 / Counselors office	Flush180	14-SEP-23	4.930	ug/L
51573	51573-2-212-BF01	Inside Room 212 / Counselors office	Initial	14-SEP-23	4.240	ug/L
51573	51573-2-212-	Inside Room 212 / Counselors	Initial	25-OCT-2023	2.340	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	BF01	office				
51573	51573-1-KIT-KS01	Kitchen South Wall Sink	Flush	25-OCT-2023	1.200	ug/L
51573	51573-1-KIT-KS01	Kitchen South Wall Sink	Flush	25-OCT-2023	1.200	ug/L
51573	51573-1-KIT-KS01	Kitchen South Wall Sink	Flush	25-OCT-2023	1.000	ug/L
51573	51573-1-KIT-KS01	Kitchen South Wall Sink	Flush	25-OCT-2023	1.000	ug/L
51573	51573-1-KIT-KS01	Kitchen South Wall Sink	Flush180	14-SEP-23	3.360	ug/L
51573	51573-1-KIT-KS01	Kitchen South Wall Sink	Flush180	14-SEP-23	3.730	ug/L
51573	51573-1-KIT-KS01	Kitchen South Wall Sink	Flush180	14-SEP-23	6.140	ug/L
51573	51573-1-KIT-KS01	Kitchen South Wall Sink	Flush180	14-SEP-23	3.020	ug/L
51573	51573-1-KIT-KS01	Kitchen South Wall Sink	Flush180	12-OCT-16	0.880	ppb
51573	51573-1-KIT-KS01	Kitchen South Wall Sink	Flush180	12-OCT-16	1.400	ppb
51573	51573-1-KIT-KS01	Kitchen South Wall Sink	Flush180	12-OCT-16	1.100	ppb
51573	51573-1-KIT-KS01	Kitchen South Wall Sink	Flush180	12-OCT-16	0.370	ppb
51573	51573-1-KIT-KS01	Kitchen South Wall Sink	Initial	14-SEP-23	1.260	ug/L
51573	51573-1-KIT-KS01	Kitchen South Wall Sink	Initial	12-OCT-16	0.630	ppb
51573	51573-1-KIT-KS01	Kitchen South Wall Sink	Initial	25-OCT-2023	1.000	ug/L
51573	51573-2-250-F01	Left Fountain next to Room 250	Flush180	14-SEP-23	1.150	ug/L
51573	51573-2-250-F01	Left Fountain next to Room 250	Flush180	14-SEP-23	1.000	ug/L
51573	51573-2-250-F01	Left Fountain next to Room 250	Flush180	14-SEP-23	1.000	ug/L
51573	51573-2-250-F01	Left Fountain next to Room 250	Flush180	14-SEP-23	1.000	ug/L
51573	51573-2-250-F01	Left Fountain next to Room 250	Initial	14-SEP-23	3.330	ug/L
51573	51573-2-HAL-F05	Outside 230 Left Fountain	Flush180	14-SEP-23	1.000	ug/L
51573	51573-2-HAL-F05	Outside 230 Left Fountain	Flush180	14-SEP-23	1.000	ug/L
51573	51573-2-HAL-F05	Outside 230 Left Fountain	Flush180	14-SEP-23	1.000	ug/L
51573	51573-2-HAL-F05	Outside 230 Left Fountain	Flush180	14-SEP-23	1.000	ug/L
51573	51573-2-HAL-F05	Outside 230 Left Fountain	Flush180	12-OCT-16	0.600	ppb
51573	51573-2-HAL-F05	Outside 230 Left Fountain	Flush180	12-OCT-16	0.360	ppb
51573	51573-2-HAL-F05	Outside 230 Left Fountain	Flush180	12-OCT-16	0.330	ppb
51573	51573-2-HAL-F05	Outside 230 Left Fountain	Flush180	12-OCT-16	0.330	ppb
51573	51573-2-HAL-F05	Outside 230 Left Fountain	Initial	14-SEP-23	1.180	ug/L
51573	51573-2-HAL-F05	Outside 230 Left Fountain	Initial	12-OCT-16	0.590	ppb
51573	51573-2-HAL-F06	Outside 230 Right Fountain	Flush180	12-OCT-16	0.390	ppb
51573	51573-2-HAL-F06	Outside 230 Right Fountain	Flush180	12-OCT-16	0.350	ppb
51573	51573-2-HAL-F06	Outside 230 Right Fountain	Flush180	12-OCT-16	0.350	ppb
51573	51573-2-HAL-F06	Outside 230 Right Fountain	Flush180	12-OCT-16	0.360	ppb
51573	51573-2-HAL-F06	Outside 230 Right Fountain	Initial	12-OCT-16	0.540	ppb
51573	51573-1-HAL-BF01	Outside Cafeteria Bottle Filler	Flush180	14-SEP-23	1.000	ug/L
51573	51573-1-HAL-	Outside Cafeteria Bottle Filler	Flush180	14-SEP-23	1.000	ug/L

## Water Quality Assessment Michele Clark Academic Prep Magnet High School

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	BF01					
51573	51573-1-HAL-BF01	Outside Cafeteria Bottle Filler	Flush180	14-SEP-23	1.000	ug/L
51573	51573-1-HAL-BF01	Outside Cafeteria Bottle Filler	Flush180	14-SEP-23	1.000	ug/L
51573	51573-1-HAL-BF01	Outside Cafeteria Bottle Filler	Initial	14-SEP-23	1.000	ug/L
51573	51573-1-HAL-F01	Outside Cafeteria Left Fountain	Flush180	14-SEP-23	1.830	ug/L
51573	51573-1-HAL-F01	Outside Cafeteria Left Fountain	Flush180	14-SEP-23	1.830	ug/L
51573	51573-1-HAL-F01	Outside Cafeteria Left Fountain	Flush180	14-SEP-23	1.560	ug/L
51573	51573-1-HAL-F01	Outside Cafeteria Left Fountain	Flush180	14-SEP-23	1.240	ug/L
51573	51573-1-HAL-F01	Outside Cafeteria Left Fountain	Flush180	12-OCT-16	0.780	ppb
51573	51573-1-HAL-F01	Outside Cafeteria Left Fountain	Flush180	12-OCT-16	0.770	ppb
51573	51573-1-HAL-F01	Outside Cafeteria Left Fountain	Flush180	12-OCT-16	0.720	ppb
51573	51573-1-HAL-F01	Outside Cafeteria Left Fountain	Flush180	12-OCT-16	0.830	ppb
51573	51573-1-HAL-F01	Outside Cafeteria Left Fountain	Initial	14-SEP-23	4.580	ug/L
51573	51573-1-HAL-F01	Outside Cafeteria Left Fountain	Initial	12-OCT-16	1.200	ppb
51573	51573-1-HAL-F02	Outside Cafeteria Right Fountain	Flush180	14-SEP-23	1.000	ug/L
51573	51573-1-HAL-F02	Outside Cafeteria Right Fountain	Flush180	14-SEP-23	1.000	ug/L
51573	51573-1-HAL-F02	Outside Cafeteria Right Fountain	Flush180	14-SEP-23	1.000	ug/L
51573	51573-1-HAL-F02	Outside Cafeteria Right Fountain	Flush180	14-SEP-23	1.000	ug/L
51573	51573-1-HAL-F02	Outside Cafeteria Right Fountain	Flush180	12-OCT-16	1.900	ppb
51573	51573-1-HAL-F02	Outside Cafeteria Right Fountain	Flush180	12-OCT-16	1.100	ppb
51573	51573-1-HAL-F02	Outside Cafeteria Right Fountain	Flush180	12-OCT-16	1.300	ppb
51573	51573-1-HAL-F02	Outside Cafeteria Right Fountain	Flush180	12-OCT-16	1.300	ppb
51573	51573-1-HAL-F02	Outside Cafeteria Right Fountain	Initial	14-SEP-23	1.000	ug/L
51573	51573-1-HAL-F02	Outside Cafeteria Right Fountain	Initial	12-OCT-16	2.600	ppb
51573	51573-2-HAL-F03	Outside Gym East End	Flush180	14-SEP-23	1.000	ug/L
51573	51573-2-HAL-F03	Outside Gym East End	Flush180	14-SEP-23	1.000	ug/L
51573	51573-2-HAL-F03	Outside Gym East End	Flush180	14-SEP-23	1.000	ug/L
51573	51573-2-HAL-F03	Outside Gym East End	Flush180	14-SEP-23	1.000	ug/L
51573	51573-2-HAL-F03	Outside Gym East End	Flush180	12-OCT-16	2.500	ppb
51573	51573-2-HAL-F03	Outside Gym East End	Flush180	12-OCT-16	2.900	ppb
51573	51573-2-HAL-F03	Outside Gym East End	Flush180	12-OCT-16	13.000	ppb
51573	51573-2-HAL-F03	Outside Gym East End	Flush180	12-OCT-16	2.000	ppb
51573	51573-2-HAL-F03	Outside Gym East End	Initial	14-SEP-23	1.000	ug/L
51573	51573-2-HAL-F03	Outside Gym East End	Initial	12-OCT-16	1.000	ppb
51573	51573-2-HAL-F04	Outside Gym West End	Flush180	14-SEP-23	1.400	ug/L
51573	51573-2-HAL-F04	Outside Gym West End	Flush180	14-SEP-23	1.120	ug/L
51573	51573-2-HAL-F04	Outside Gym West End	Flush180	14-SEP-23	1.000	ug/L
51573	51573-2-HAL-F04	Outside Gym West End	Flush180	14-SEP-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51573	51573-2-HAL-F04	Outside Gym West End	Flush180	12-OCT-16	2.300	ppb
51573	51573-2-HAL-F04	Outside Gym West End	Flush180	12-OCT-16	1.300	ppb
51573	51573-2-HAL-F04	Outside Gym West End	Flush180	12-OCT-16	3.500	ppb
51573	51573-2-HAL-F04	Outside Gym West End	Flush180	12-OCT-16	2.400	ppb
51573	51573-2-HAL-F04	Outside Gym West End	Initial	14-SEP-23	1.000	ug/L
51573	51573-2-HAL-F04	Outside Gym West End	Initial	12-OCT-16	1.300	ppb
51573	51573-1-HAL-F03	Outside RM 132 Left Fountain	Flush180	14-SEP-23	1.940	ug/L
51573	51573-1-HAL-F03	Outside RM 132 Left Fountain	Flush180	14-SEP-23	1.230	ug/L
51573	51573-1-HAL-F03	Outside RM 132 Left Fountain	Flush180	14-SEP-23	1.000	ug/L
51573	51573-1-HAL-F03	Outside RM 132 Left Fountain	Flush180	14-SEP-23	1.000	ug/L
51573	51573-1-HAL-F03	Outside RM 132 Left Fountain	Flush180	12-OCT-16	0.580	ppb
51573	51573-1-HAL-F03	Outside RM 132 Left Fountain	Flush180	12-OCT-16	0.950	ppb
51573	51573-1-HAL-F03	Outside RM 132 Left Fountain	Flush180	12-OCT-16	1.100	ppb
51573	51573-1-HAL-F03	Outside RM 132 Left Fountain	Flush180	12-OCT-16	0.780	ppb
51573	51573-1-HAL-F03	Outside RM 132 Left Fountain	Initial	14-SEP-23	1.800	ug/L
51573	51573-1-HAL-F03	Outside RM 132 Left Fountain	Initial	12-OCT-16	0.670	ppb
51573	51573-1-HAL-F04	Outside RM 132 Right Fountain	Flush180	14-SEP-23	1.740	ug/L
51573	51573-1-HAL-F04	Outside RM 132 Right Fountain	Flush180	14-SEP-23	1.000	ug/L
51573	51573-1-HAL-F04	Outside RM 132 Right Fountain	Flush180	14-SEP-23	1.000	ug/L
51573	51573-1-HAL-F04	Outside RM 132 Right Fountain	Flush180	14-SEP-23	1.000	ug/L
51573	51573-1-HAL-F04	Outside RM 132 Right Fountain	Flush180	12-OCT-16	0.840	ppb
51573	51573-1-HAL-F04	Outside RM 132 Right Fountain	Flush180	12-OCT-16	0.880	ppb
51573	51573-1-HAL-F04	Outside RM 132 Right Fountain	Flush180	12-OCT-16	0.680	ppb
51573	51573-1-HAL-F04	Outside RM 132 Right Fountain	Flush180	12-OCT-16	1.300	ppb
51573	51573-1-HAL-F04	Outside RM 132 Right Fountain	Initial	14-SEP-23	1.460	ug/L
51573	51573-1-HAL-F04	Outside RM 132 Right Fountain	Initial	12-OCT-16	1.000	ppb
51573	51573-2-HAL-F02	Outside RM 251 Right Fount	Flush180	12-OCT-16	0.590	ppb
51573	51573-2-HAL-F02	Outside RM 251 Right Fount	Flush180	12-OCT-16	1.700	ppb
51573	51573-2-HAL-F02	Outside RM 251 Right Fount	Flush180	12-OCT-16	0.930	ppb
51573	51573-2-HAL-F02	Outside RM 251 Right Fount	Flush180	12-OCT-16	0.510	ppb
51573	51573-2-HAL-F02	Outside RM 251 Right Fount	Initial	12-OCT-16	1.500	ppb
51573	51573-1-POOL-F02	Pool Left on North Wall	Flush	25-OCT-2023	2.450	ug/L
51573	51573-1-POOL-F02	Pool Left on North Wall	Flush	25-OCT-2023	3.700	ug/L
51573	51573-1-POOL-F02	Pool Left on North Wall	Flush	25-OCT-2023	4.310	ug/L
51573	51573-1-POOL-F02	Pool Left on North Wall	Flush	25-OCT-2023	2.550	ug/L
51573	51573-1-POOL-F02	Pool Left on North Wall	Flush180	14-SEP-23	7.840	ug/L
51573	51573-1-POOL-F02	Pool Left on North Wall	Flush180	14-SEP-23	7.330	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51573	51573-1-POOL-F02	Pool Left on North Wall	Flush180	14-SEP-23	4.990	ug/L
51573	51573-1-POOL-F02	Pool Left on North Wall	Flush180	14-SEP-23	3.290	ug/L
51573	51573-1-POOL-F02	Pool Left on North Wall	Flush180	12-OCT-16	0.630	ppb
51573	51573-1-POOL-F02	Pool Left on North Wall	Flush180	12-OCT-16	0.710	ppb
51573	51573-1-POOL-F02	Pool Left on North Wall	Flush180	12-OCT-16	0.780	ppb
51573	51573-1-POOL-F02	Pool Left on North Wall	Flush180	12-OCT-16	0.720	ppb
51573	51573-1-POOL-F02	Pool Left on North Wall	Initial	14-SEP-23	7.470	ug/L
51573	51573-1-POOL-F02	Pool Left on North Wall	Initial	12-OCT-16	1.000	ppb
51573	51573-1-POOL-F02	Pool Left on North Wall	Initial	25-OCT-2023	2.490	ug/L
51573	51573-1-POOL-F03	Pool Right On North Wall	Flush	25-OCT-2023	1.710	ug/L
51573	51573-1-POOL-F03	Pool Right On North Wall	Flush	25-OCT-2023	1.670	ug/L
51573	51573-1-POOL-F03	Pool Right On North Wall	Flush	25-OCT-2023	1.750	ug/L
51573	51573-1-POOL-F03	Pool Right On North Wall	Flush	25-OCT-2023	1.440	ug/L
51573	51573-1-POOL-F03	Pool Right On North Wall	Flush180	14-SEP-23	3.540	ug/L
51573	51573-1-POOL-F03	Pool Right On North Wall	Flush180	14-SEP-23	22.900	ug/L
51573	51573-1-POOL-F03	Pool Right On North Wall	Flush180	14-SEP-23	22.800	ug/L
51573	51573-1-POOL-F03	Pool Right On North Wall	Flush180	14-SEP-23	19.800	ug/L
51573	51573-1-POOL-F03	Pool Right On North Wall	Flush180	12-OCT-16	1.500	ppb
51573	51573-1-POOL-F03	Pool Right On North Wall	Flush180	12-OCT-16	1.200	ppb
51573	51573-1-POOL-F03	Pool Right On North Wall	Flush180	12-OCT-16	1.300	ppb
51573	51573-1-POOL-F03	Pool Right On North Wall	Flush180	12-OCT-16	1.300	ppb
51573	51573-1-POOL-F03	Pool Right On North Wall	Initial	14-SEP-23	7.800	ug/L
51573	51573-1-POOL-F03	Pool Right On North Wall	Initial	12-OCT-16	2.300	ppb
51573	51573-1-POOL-F03	Pool Right On North Wall	Initial	25-OCT-2023	3.920	ug/L
51573	51573-2-212-F01	RM 212 Counselors Office	Flush180	14-SEP-23	3.680	ug/L
51573	51573-2-212-F01	RM 212 Counselors Office	Flush180	14-SEP-23	3.150	ug/L
51573	51573-2-212-F01	RM 212 Counselors Office	Flush180	14-SEP-23	3.450	ug/L
51573	51573-2-212-F01	RM 212 Counselors Office	Flush180	14-SEP-23	3.630	ug/L
51573	51573-2-212-F01	RM 212 Counselors Office	Flush180	12-OCT-16	1.400	ppb
51573	51573-2-212-F01	RM 212 Counselors Office	Flush180	12-OCT-16	2.000	ppb
51573	51573-2-212-F01	RM 212 Counselors Office	Flush180	12-OCT-16	4.000	ppb
51573	51573-2-212-F01	RM 212 Counselors Office	Flush180	12-OCT-16	3.100	ppb
51573	51573-2-212-F01	RM 212 Counselors Office	Initial	14-SEP-23	2.630	ug/L
51573	51573-2-212-F01	RM 212 Counselors Office	Initial	12-OCT-16	1.400	ppb
51573	51573-2-HAL-BF01	Right Fountain by Room 232	Flush180	14-SEP-23	1.000	ug/L
51573	51573-2-HAL-BF01	Right Fountain by Room 232	Flush180	14-SEP-23	1.000	ug/L
51573	51573-2-HAL-BF01	Right Fountain by Room 232	Flush180	14-SEP-23	1.000	ug/L
51573	51573-2-HAL-	Right Fountain by Room 232	Flush180	14-SEP-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	BF01					
51573	51573-2-HAL-BF01	Right Fountain by Room 232	Flush180	14-SEP-23	1.000	ug/L
51573	51573-2-HAL-BF01	Right Fountain by Room 232	Flush180	14-SEP-23	1.000	ug/L
51573	51573-2-HAL-BF01	Right Fountain by Room 232	Flush180	14-SEP-23	1.000	ug/L
51573	51573-2-HAL-BF01	Right Fountain by Room 232	Flush180	14-SEP-23	1.000	ug/L
51573	51573-2-HAL-BF01	Right Fountain by Room 232	Initial	14-SEP-23	1.690	ug/L
51573	51573-2-HAL-BF01	Right Fountain by Room 232	Initial	14-SEP-23	1.000	ug/L
51573	51573-1-FL-S01	Sink in Faculty Lounge	Flush	07-NOV-2023	1.000	ug/L
51573	51573-1-FL-S01	Sink in Faculty Lounge	Flush	07-NOV-2023	1.000	ug/L
51573	51573-1-FL-S01	Sink in Faculty Lounge	Flush	07-NOV-2023	1.000	ug/L
51573	51573-1-FL-S01	Sink in Faculty Lounge	Flush	07-NOV-2023	1.000	ug/L
51573	51573-1-FL-S01	Sink in Faculty Lounge	Flush	25-OCT-2023	29.900	ug/L
51573	51573-1-FL-S01	Sink in Faculty Lounge	Flush	25-OCT-2023	5.430	ug/L
51573	51573-1-FL-S01	Sink in Faculty Lounge	Flush	25-OCT-2023	4.130	ug/L
51573	51573-1-FL-S01	Sink in Faculty Lounge	Flush	25-OCT-2023	4.340	ug/L
51573	51573-1-FL-S01	Sink in Faculty Lounge	Flush180	14-SEP-23	5.840	ug/L
51573	51573-1-FL-S01	Sink in Faculty Lounge	Flush180	14-SEP-23	2.020	ug/L
51573	51573-1-FL-S01	Sink in Faculty Lounge	Flush180	14-SEP-23	2.770	ug/L
51573	51573-1-FL-S01	Sink in Faculty Lounge	Flush180	14-SEP-23	3.850	ug/L
51573	51573-1-FL-S01	Sink in Faculty Lounge	Initial	14-SEP-23	4.140	ug/L
51573	51573-1-FL-S01	Sink in Faculty Lounge	Initial	07-NOV-2023	1.000	ug/L
51573	51573-1-FL-S01	Sink in Faculty Lounge	Initial	25-OCT-2023	80.400	ug/L
51573	51573-1-KIT-KS02	West Wall Sink	Flush180	12-OCT-16	0.370	ppb
51573	51573-1-KIT-KS02	West Wall Sink	Flush180	12-OCT-16	0.180	ppb
51573	51573-1-KIT-KS02	West Wall Sink	Flush180	12-OCT-16	1.300	ppb
51573	51573-1-KIT-KS02	West Wall Sink	Flush180	12-OCT-16	4.200	ppb
51573	51573-1-KIT-KS02	West Wall Sink	Initial	12-OCT-16	0.670	ppb