



Sep 10, 2024

CLAY

13231 S BURLEY AVE, Chicago IL 60633.

Dear **CLAY** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

CLAY

13231 S BURLEY AVE, Chicago IL 60633.

Estimadas familias de **CLAY**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarle y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51502	51502-3-HAL-F05	3rd Floor Outside Boys Washroom, Left Fountain	Flush180	04-JUN-16	1.530	ppb
51502	51502-3-HAL-F05	3rd Floor Outside Boys Washroom, Left Fountain	Flush180	04-JUN-16	1.620	ppb
51502	51502-3-HAL-F05	3rd Floor Outside Boys Washroom, Left Fountain	Flush180	04-JUN-16	1.650	ppb
51502	51502-3-HAL-F05	3rd Floor Outside Boys Washroom, Left Fountain	Flush180	04-JUN-16	1.080	ppb
51502	51502-3-HAL-F05	3rd Floor Outside Boys Washroom, Left Fountain	Flush180	13-JAN-22	1.360	ug/L
51502	51502-3-HAL-F05	3rd Floor Outside Boys Washroom, Left Fountain	Flush180	13-JAN-22	1.570	ug/L
51502	51502-3-HAL-F05	3rd Floor Outside Boys Washroom, Left Fountain	Flush180	13-JAN-22	1.800	ug/L
51502	51502-3-HAL-F05	3rd Floor Outside Boys Washroom, Left Fountain	Flush180	13-JAN-22	1.060	ug/L
51502	51502-3-HAL-F05	3rd Floor Outside Boys Washroom, Left Fountain	Initial	04-JUN-16	1.580	ppb
51502	51502-3-HAL-F05	3rd Floor Outside Boys Washroom, Left Fountain	Initial	13-JAN-22	1.000	ug/L
51502	51502-3-HAL-F06	3rd Floor Outside Boys Washroom, Right Fountain	Flush180	04-JUN-16	0.862	ppb
51502	51502-3-HAL-F06	3rd Floor Outside Boys Washroom, Right Fountain	Flush180	04-JUN-16	1.580	ppb
51502	51502-3-HAL-F06	3rd Floor Outside Boys Washroom, Right Fountain	Flush180	04-JUN-16	0.929	ppb
51502	51502-3-HAL-F06	3rd Floor Outside Boys Washroom, Right Fountain	Flush180	04-JUN-16	1.630	ppb
51502	51502-3-HAL-F06	3rd Floor Outside Boys Washroom, Right Fountain	Flush180	13-JAN-22	2.220	ug/L
51502	51502-3-HAL-F06	3rd Floor Outside Boys Washroom, Right Fountain	Flush180	13-JAN-22	2.410	ug/L
51502	51502-3-HAL-F06	3rd Floor Outside Boys Washroom, Right Fountain	Flush180	13-JAN-22	2.900	ug/L
51502	51502-3-HAL-F06	3rd Floor Outside Boys Washroom, Right Fountain	Flush180	13-JAN-22	2.800	ug/L
51502	51502-3-HAL-F06	3rd Floor Outside Boys Washroom, Right Fountain	Flush180	09-OCT-20	1.920	ug/L
51502	51502-3-HAL-F06	3rd Floor Outside Boys Washroom, Right Fountain	Initial	04-JUN-16	1.350	ppb
51502	51502-3-HAL-F06	3rd Floor Outside Boys Washroom, Right Fountain	Initial	13-JAN-22	2.580	ug/L
51502	51502-3-HAL-F06	3rd Floor Outside Boys Washroom, Right Fountain	Initial	09-OCT-20	1.660	ug/L
51502	51502-1-CAF-BF01	Inside Cafeteria, Bottle Filler	Flush180	13-JAN-22	1.000	ug/L
51502	51502-1-CAF-BF01	Inside Cafeteria, Bottle Filler	Flush180	13-JAN-22	1.000	ug/L
51502	51502-1-CAF-BF01	Inside Cafeteria, Bottle Filler	Flush180	13-JAN-22	1.000	ug/L
51502	51502-1-CAF-BF01	Inside Cafeteria, Bottle Filler	Flush180	13-JAN-22	1.000	ug/L
51502	51502-1-CAF-BF01	Inside Cafeteria, Bottle Filler	Initial	13-JAN-22	1.000	ug/L
51502	51502-1-CAF-F02	Inside Cafeteria, Center Fountain	Flush180	13-JAN-22	1.000	ug/L
51502	51502-1-CAF-F02	Inside Cafeteria, Center Fountain	Flush180	13-JAN-22	1.000	ug/L
51502	51502-1-CAF-F02	Inside Cafeteria, Center Fountain	Flush180	13-JAN-22	1.000	ug/L
51502	51502-1-CAF-F02	Inside Cafeteria, Center Fountain	Flush180	13-JAN-22	1.000	ug/L
51502	51502-1-CAF-F02	Inside Cafeteria, Center Fountain	Initial	13-JAN-22	1.000	ug/L
51502	51502-1-CAF-F01	Inside Cafeteria, Left Fountain	Flush180	13-JAN-22	1.000	ug/L
51502	51502-1-CAF-F01	Inside Cafeteria, Left Fountain	Flush180	13-JAN-22	1.000	ug/L
51502	51502-1-CAF-F01	Inside Cafeteria, Left Fountain	Flush180	13-JAN-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51502	51502-1-CAF-F01	Inside Cafeteria, Left Fountain	Flush180	13-JAN-22	1.000	ug/L
51502	51502-1-CAF-F01	Inside Cafeteria, Left Fountain	Initial	13-JAN-22	1.000	ug/L
51502	51502-1-CAF-F03	Inside Cafeteria, Right Fountain	Flush180	13-JAN-22	1.000	ug/L
51502	51502-1-CAF-F03	Inside Cafeteria, Right Fountain	Flush180	13-JAN-22	1.000	ug/L
51502	51502-1-CAF-F03	Inside Cafeteria, Right Fountain	Flush180	13-JAN-22	1.000	ug/L
51502	51502-1-CAF-F03	Inside Cafeteria, Right Fountain	Initial	13-JAN-22	1.000	ug/L
51502	51502-1-CAF-KS07	Inside Lunch Room Serving Line, Sink	Flush180	04-JUN-16	1.000	ppb
51502	51502-1-CAF-KS07	Inside Lunch Room Serving Line, Sink	Flush180	04-JUN-16	0.543	ppb
51502	51502-1-CAF-KS07	Inside Lunch Room Serving Line, Sink	Flush180	04-JUN-16	1.740	ppb
51502	51502-1-CAF-KS07	Inside Lunch Room Serving Line, Sink	Flush180	04-JUN-16	1.840	ppb
51502	51502-1-CAF-KS07	Inside Lunch Room Serving Line, Sink	Initial	04-JUN-16	0.282	ppb
51502	51502-1-102-S01	Inside Room 102, Sink	Flush180	13-JAN-22	2.310	ug/L
51502	51502-1-102-S01	Inside Room 102, Sink	Flush180	13-JAN-22	2.110	ug/L
51502	51502-1-102-S01	Inside Room 102, Sink	Flush180	13-JAN-22	1.580	ug/L
51502	51502-1-102-S01	Inside Room 102, Sink	Flush180	13-JAN-22	1.490	ug/L
51502	51502-1-102-S01	Inside Room 102, Sink	Initial	13-JAN-22	2.680	ug/L
51502	51502-1-HAL-F06	Outside Lunchroom, Left Fountain	Flush180	02-NOV-22	10.700	ug/L
51502	51502-1-HAL-F06	Outside Lunchroom, Left Fountain	Flush180	02-NOV-22	7.860	ug/L
51502	51502-1-HAL-F06	Outside Lunchroom, Left Fountain	Flush180	02-NOV-22	9.250	ug/L
51502	51502-1-HAL-F06	Outside Lunchroom, Left Fountain	Flush180	02-NOV-22	8.590	ug/L
51502	51502-1-HAL-F06	Outside Lunchroom, Left Fountain	Flush180	04-JUN-16	1.470	ppb
51502	51502-1-HAL-F06	Outside Lunchroom, Left Fountain	Flush180	04-JUN-16	1.450	ppb
51502	51502-1-HAL-F06	Outside Lunchroom, Left Fountain	Flush180	04-JUN-16	1.500	ppb
51502	51502-1-HAL-F06	Outside Lunchroom, Left Fountain	Flush180	04-JUN-16	2.070	ppb
51502	51502-1-HAL-F06	Outside Lunchroom, Left Fountain	Flush180	13-JAN-22	7.190	ug/L
51502	51502-1-HAL-F06	Outside Lunchroom, Left Fountain	Flush180	13-JAN-22	12.200	ug/L
51502	51502-1-HAL-F06	Outside Lunchroom, Left Fountain	Flush180	13-JAN-22	7.170	ug/L
51502	51502-1-HAL-F06	Outside Lunchroom, Left Fountain	Flush180	13-JAN-22	4.450	ug/L
51502	51502-1-HAL-F06	Outside Lunchroom, Left Fountain	Flush180	09-OCT-20	4.770	ug/L
51502	51502-1-HAL-F06	Outside Lunchroom, Left Fountain	Flush180	12-AUG-22	7.700	ug/L
51502	51502-1-HAL-F06	Outside Lunchroom, Left Fountain	Flush180	12-AUG-22	5.020	ug/L
51502	51502-1-HAL-F06	Outside Lunchroom, Left Fountain	Flush180	12-AUG-22	5.500	ug/L
51502	51502-1-HAL-F06	Outside Lunchroom, Left Fountain	Flush180	12-AUG-22	5.240	ug/L
51502	51502-1-HAL-F06	Outside Lunchroom, Left Fountain	Flush180	14-SEP-22	79.000	ug/L
51502	51502-1-HAL-F06	Outside Lunchroom, Left Fountain	Flush180	14-SEP-22	30.100	ug/L
51502	51502-1-HAL-F06	Outside Lunchroom, Left Fountain	Flush180	14-SEP-22	19.800	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51502	51502-1-HAL-F06	Outside Lunchroom, Left Fountain	Flush180	14-SEP-22	13.000	ug/L
51502	51502-1-HAL-F06	Outside Lunchroom, Left Fountain	Initial	02-NOV-22	14.200	ug/L
51502	51502-1-HAL-F06	Outside Lunchroom, Left Fountain	Initial	04-JUN-16	1.860	ppb
51502	51502-1-HAL-F06	Outside Lunchroom, Left Fountain	Initial	13-JAN-22	9.250	ug/L
51502	51502-1-HAL-F06	Outside Lunchroom, Left Fountain	Initial	09-OCT-20	4.640	ug/L
51502	51502-1-HAL-F06	Outside Lunchroom, Left Fountain	Initial	12-AUG-22	3.570	ug/L
51502	51502-1-HAL-F06	Outside Lunchroom, Left Fountain	Initial	14-SEP-22	110.000	ug/L
51502	51502-1-HAL-F01	Outside Room 107, Left Fountain	Flush180	04-JUN-16	1.130	ppb
51502	51502-1-HAL-F01	Outside Room 107, Left Fountain	Flush180	04-JUN-16	1.530	ppb
51502	51502-1-HAL-F01	Outside Room 107, Left Fountain	Flush180	04-JUN-16	2.530	ppb
51502	51502-1-HAL-F01	Outside Room 107, Left Fountain	Flush180	04-JUN-16	2.160	ppb
51502	51502-1-HAL-F01	Outside Room 107, Left Fountain	Initial	04-JUN-16	1.130	ppb
51502	51502-1-HAL-F04	Outside Room 109, Fountain 2	Flush180	04-JUN-16	0.289	ppb
51502	51502-1-HAL-F04	Outside Room 109, Fountain 2	Flush180	04-JUN-16	0.123	ppb
51502	51502-1-HAL-F04	Outside Room 109, Fountain 2	Flush180	04-JUN-16	0.196	ppb
51502	51502-1-HAL-F04	Outside Room 109, Fountain 2	Flush180	04-JUN-16	0.240	ppb
51502	51502-1-HAL-F04	Outside Room 109, Fountain 2	Initial	04-JUN-16	0.142	ppb
51502	51502-1-HAL-F03	Outside Room 109, Left Fountain	Flush180	04-JUN-16	0.375	ppb
51502	51502-1-HAL-F03	Outside Room 109, Left Fountain	Flush180	04-JUN-16	0.327	ppb
51502	51502-1-HAL-F03	Outside Room 109, Left Fountain	Flush180	04-JUN-16	0.305	ppb
51502	51502-1-HAL-F03	Outside Room 109, Left Fountain	Flush180	04-JUN-16	0.352	ppb
51502	51502-1-HAL-F03	Outside Room 109, Left Fountain	Initial	04-JUN-16	0.404	ppb
51502	51502-2-HAL-F05	Outside Room 205, Fountain	Flush180	13-JAN-22	6.200	ug/L
51502	51502-2-HAL-F05	Outside Room 205, Fountain	Flush180	13-JAN-22	5.710	ug/L
51502	51502-2-HAL-F05	Outside Room 205, Fountain	Flush180	13-JAN-22	5.530	ug/L
51502	51502-2-HAL-F05	Outside Room 205, Fountain	Flush180	13-JAN-22	4.810	ug/L
51502	51502-2-HAL-F05	Outside Room 205, Fountain	Flush180	12-AUG-22	3.470	ug/L
51502	51502-2-HAL-F05	Outside Room 205, Fountain	Flush180	12-AUG-22	2.410	ug/L
51502	51502-2-HAL-F05	Outside Room 205, Fountain	Flush180	12-AUG-22	2.280	ug/L
51502	51502-2-HAL-F05	Outside Room 205, Fountain	Flush180	12-AUG-22	1.690	ug/L
51502	51502-2-HAL-F05	Outside Room 205, Fountain	Initial	13-JAN-22	7.830	ug/L
51502	51502-2-HAL-F05	Outside Room 205, Fountain	Initial	12-AUG-22	2.160	ug/L
51502	51502-2-HAL-RBF01	Outside Room 205, Retrofit Bottle Filler	Flush180	02-NOV-22	1.650	ug/L
51502	51502-2-HAL-RBF01	Outside Room 205, Retrofit Bottle Filler	Flush180	02-NOV-22	1.890	ug/L
51502	51502-2-HAL-RBF01	Outside Room 205, Retrofit Bottle Filler	Flush180	02-NOV-22	1.830	ug/L
51502	51502-2-HAL-RBF01	Outside Room 205, Retrofit Bottle Filler	Flush180	02-NOV-22	1.400	ug/L
51502	51502-2-HAL-RBF01	Outside Room 205, Retrofit Bottle Filler	Flush180	13-JAN-22	5.070	ug/L
51502	51502-2-HAL-	Outside Room 205, Retrofit Bottle	Flush180	13-JAN-22	2.160	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	RBF01	Filler				
51502	51502-2-HAL-RBF01	Outside Room 205, Retrofit Bottle Filler	Flush180	13-JAN-22	2.970	ug/L
51502	51502-2-HAL-RBF01	Outside Room 205, Retrofit Bottle Filler	Flush180	13-JAN-22	4.750	ug/L
51502	51502-2-HAL-RBF01	Outside Room 205, Retrofit Bottle Filler	Flush180	14-SEP-22	4.910	ug/L
51502	51502-2-HAL-RBF01	Outside Room 205, Retrofit Bottle Filler	Flush180	14-SEP-22	5.920	ug/L
51502	51502-2-HAL-RBF01	Outside Room 205, Retrofit Bottle Filler	Flush180	14-SEP-22	5.170	ug/L
51502	51502-2-HAL-RBF01	Outside Room 205, Retrofit Bottle Filler	Flush180	12-AUG-22	1.390	ug/L
51502	51502-2-HAL-RBF01	Outside Room 205, Retrofit Bottle Filler	Flush180	12-AUG-22	3.860	ug/L
51502	51502-2-HAL-RBF01	Outside Room 205, Retrofit Bottle Filler	Flush180	12-AUG-22	5.140	ug/L
51502	51502-2-HAL-RBF01	Outside Room 205, Retrofit Bottle Filler	Flush180	12-AUG-22	8.220	ug/L
51502	51502-2-HAL-RBF01	Outside Room 205, Retrofit Bottle Filler	Flush180	14-SEP-22	6.650	ug/L
51502	51502-2-HAL-RBF01	Outside Room 205, Retrofit Bottle Filler	Initial	02-NOV-22	1.370	ug/L
51502	51502-2-HAL-RBF01	Outside Room 205, Retrofit Bottle Filler	Initial	13-JAN-22	6.440	ug/L
51502	51502-2-HAL-RBF01	Outside Room 205, Retrofit Bottle Filler	Initial	12-AUG-22	11.700	ug/L
51502	51502-2-HAL-RBF01	Outside Room 205, Retrofit Bottle Filler	Initial	14-SEP-22	4.770	ug/L
51502	51502-2-HAL-F03	Outside Room 207, Left Fountain	Flush180	04-JUN-16	0.629	ppb
51502	51502-2-HAL-F03	Outside Room 207, Left Fountain	Flush180	04-JUN-16	0.525	ppb
51502	51502-2-HAL-F03	Outside Room 207, Left Fountain	Flush180	04-JUN-16	0.556	ppb
51502	51502-2-HAL-F03	Outside Room 207, Left Fountain	Flush180	04-JUN-16	0.299	ppb
51502	51502-2-HAL-F03	Outside Room 207, Left Fountain	Flush180	13-JAN-22	1.000	ug/L
51502	51502-2-HAL-F03	Outside Room 207, Left Fountain	Flush180	13-JAN-22	1.000	ug/L
51502	51502-2-HAL-F03	Outside Room 207, Left Fountain	Flush180	13-JAN-22	1.000	ug/L
51502	51502-2-HAL-F03	Outside Room 207, Left Fountain	Flush180	13-JAN-22	1.000	ug/L
51502	51502-2-HAL-F03	Outside Room 207, Left Fountain	Initial	04-JUN-16	0.644	ppb
51502	51502-2-HAL-F03	Outside Room 207, Left Fountain	Initial	13-JAN-22	1.000	ug/L
51502	51502-2-HAL-F04	Outside Room 207, Right Fountain	Flush180	04-JUN-16	0.642	ppb
51502	51502-2-HAL-F04	Outside Room 207, Right Fountain	Flush180	04-JUN-16	0.516	ppb
51502	51502-2-HAL-F04	Outside Room 207, Right Fountain	Flush180	04-JUN-16	0.511	ppb
51502	51502-2-HAL-F04	Outside Room 207, Right Fountain	Flush180	04-JUN-16	0.162	ppb
51502	51502-2-HAL-F04	Outside Room 207, Right Fountain	Flush180	13-JAN-22	1.000	ug/L
51502	51502-2-HAL-F04	Outside Room 207, Right Fountain	Flush180	13-JAN-22	1.000	ug/L
51502	51502-2-HAL-F04	Outside Room 207, Right Fountain	Flush180	13-JAN-22	1.000	ug/L
51502	51502-2-HAL-F04	Outside Room 207, Right Fountain	Flush180	13-JAN-22	1.000	ug/L
51502	51502-2-HAL-F04	Outside Room 207, Right Fountain	Initial	04-JUN-16	0.597	ppb
51502	51502-2-HAL-F04	Outside Room 207, Right Fountain	Initial	13-JAN-22	1.000	ug/L
51502	51502-2-HAL-F01	Outside Room 211, Left Fountain	Flush180	04-JUN-16	5.590	ppb
51502	51502-2-HAL-F01	Outside Room 211, Left Fountain	Flush180	04-JUN-16	2.940	ppb
51502	51502-2-HAL-F01	Outside Room 211, Left Fountain	Flush180	04-JUN-16	3.980	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01					
51502	51502-2-HAL-F01	Outside Room 211, Left Fountain	Flush180	04-JUN-16	5.210	ppb
51502	51502-2-HAL-F01	Outside Room 211, Left Fountain	Initial	04-JUN-16	3.560	ppb
51502	51502-2-HAL-F02	Outside Room 211, Right Fountain	Flush180	04-JUN-16	1.970	ppb
51502	51502-2-HAL-F02	Outside Room 211, Right Fountain	Flush180	04-JUN-16	3.270	ppb
51502	51502-2-HAL-F02	Outside Room 211, Right Fountain	Flush180	04-JUN-16	2.880	ppb
51502	51502-2-HAL-F02	Outside Room 211, Right Fountain	Flush180	04-JUN-16	3.370	ppb
51502	51502-2-HAL-F02	Outside Room 211, Right Fountain	Flush180	13-JAN-22	2.120	ug/L
51502	51502-2-HAL-F02	Outside Room 211, Right Fountain	Flush180	13-JAN-22	1.570	ug/L
51502	51502-2-HAL-F02	Outside Room 211, Right Fountain	Flush180	13-JAN-22	1.430	ug/L
51502	51502-2-HAL-F02	Outside Room 211, Right Fountain	Flush180	13-JAN-22	1.410	ug/L
51502	51502-2-HAL-F02	Outside Room 211, Right Fountain	Initial	04-JUN-16	2.190	ppb
51502	51502-2-HAL-F02	Outside Room 211, Right Fountain	Initial	13-JAN-22	2.440	ug/L
51502	51502-3-HAL-F01	Outside Room 310, Fountain	Flush180	04-JUN-16	1.710	ppb
51502	51502-3-HAL-F01	Outside Room 310, Fountain	Flush180	04-JUN-16	1.780	ppb
51502	51502-3-HAL-F01	Outside Room 310, Fountain	Flush180	04-JUN-16	3.320	ppb
51502	51502-3-HAL-F01	Outside Room 310, Fountain	Flush180	04-JUN-16	2.760	ppb
51502	51502-3-HAL-F01	Outside Room 310, Fountain	Initial	04-JUN-16	2.660	ppb
51502	51502-3-HAL-F02	Outside Room 310, Fountain 2	Flush180	04-JUN-16	2.800	ppb
51502	51502-3-HAL-F02	Outside Room 310, Fountain 2	Flush180	04-JUN-16	1.690	ppb
51502	51502-3-HAL-F02	Outside Room 310, Fountain 2	Flush180	04-JUN-16	3.290	ppb
51502	51502-3-HAL-F02	Outside Room 310, Fountain 2	Flush180	04-JUN-16	3.310	ppb
51502	51502-3-HAL-F02	Outside Room 310, Fountain 2	Initial	04-JUN-16	2.040	ppb
51502	51502-3-HAL-RBF01	Outside Room 310, Retrofit Bottle Filler	Flush180	13-JAN-22	1.560	ug/L
51502	51502-3-HAL-RBF01	Outside Room 310, Retrofit Bottle Filler	Flush180	13-JAN-22	2.060	ug/L
51502	51502-3-HAL-RBF01	Outside Room 310, Retrofit Bottle Filler	Flush180	13-JAN-22	2.110	ug/L
51502	51502-3-HAL-RBF01	Outside Room 310, Retrofit Bottle Filler	Flush180	13-JAN-22	1.830	ug/L
51502	51502-3-HAL-RBF01	Outside Room 310, Retrofit Bottle Filler	Initial	13-JAN-22	1.880	ug/L
52420	52420-1-HAL-F01	Lobby	Flush180	22-JUN-16	1.000	ppb
52420	52420-1-HAL-F01	Lobby	Flush180	22-JUN-16	1.000	ppb
52420	52420-1-HAL-F01	Lobby	Flush180	22-JUN-16	1.000	ppb
52420	52420-1-HAL-F01	Lobby	Flush180	22-JUN-16	1.000	ppb
52420	52420-1-MPR-BF01	Multi Purpose Room Bottle Filler	Flush180	25-AUG-23	1.000	ug/L
52420	52420-1-MPR-BF01	Multi Purpose Room Bottle Filler	Flush180	25-AUG-23	1.000	ug/L
52420	52420-1-MPR-BF01	Multi Purpose Room Bottle Filler	Flush180	25-AUG-23	1.000	ug/L
52420	52420-1-MPR-BF01	Multi Purpose Room Bottle Filler	Flush180	25-AUG-23	1.000	ug/L
52420	52420-1-MPR-BF01	Multi Purpose Room Bottle Filler	Initial	25-AUG-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52420	52420-1-MPR-F01	Multi Purpose Room Fountain	Flush180	25-AUG-23	1.000	ug/L
52420	52420-1-MPR-F01	Multi Purpose Room Fountain	Flush180	25-AUG-23	1.000	ug/L
52420	52420-1-MPR-F01	Multi Purpose Room Fountain	Flush180	25-AUG-23	1.000	ug/L
52420	52420-1-MPR-F01	Multi Purpose Room Fountain	Flush180	25-AUG-23	1.000	ug/L
52420	52420-1-MPR-F01	Multi Purpose Room Fountain	Initial	25-AUG-23	1.000	ug/L
52420	52420-1-HAL-WC01	Room Kindergarten	Flush180	22-JUN-16	1.000	ppb
52420	52420-1-HAL-WC01	Room Kindergarten	Flush180	22-JUN-16	1.000	ppb
52420	52420-1-HAL-WC01	Room Kindergarten	Flush180	22-JUN-16	1.000	ppb
52420	52420-1-HAL-WC01	Room Kindergarten	Flush180	22-JUN-16	1.000	ppb
52420	52420-1-HAL-WC01	Room Kindergarten	Initial	22-JUN-16	1.000	ppb