



**Sep 10, 2024**

**CLEMENTE HS**

**1147 N WESTERN AVE, Chicago IL 60622.**

Dear **CLEMENTE HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**CLEMENTE HS**

**1147 N WESTERN AVE, Chicago IL 60622.**

Estimadas familias de **CLEMENTE HS**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarle y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51556	51556-1-HAL-F01	1st FL Entry By Door 1	Flush	14-DEC-2023	42.000	ug/L
51556	51556-1-HAL-F01	1st FL Entry By Door 1	Flush	14-DEC-2023	28.700	ug/L
51556	51556-1-HAL-F01	1st FL Entry By Door 1	Flush	14-DEC-2023	28.900	ug/L
51556	51556-1-HAL-F01	1st FL Entry By Door 1	Flush	14-DEC-2023	17.900	ug/L
51556	51556-1-HAL-F01	1st FL Entry By Door 1	Initial	14-DEC-2023	61.400	ug/L
51556	51556-1-HAL-F01	1st FL Entry North End	Flush180	13-OCT-16	6.400	ppb
51556	51556-1-HAL-F01	1st FL Entry North End	Flush180	13-OCT-16	4.900	ppb
51556	51556-1-HAL-F01	1st FL Entry North End	Flush180	13-OCT-16	6.700	ppb
51556	51556-1-HAL-F01	1st FL Entry North End	Flush180	13-OCT-16	6.300	ppb
51556	51556-1-HAL-F01	1st FL Entry North End	Initial	13-OCT-16	2.600	ppb
51556	51556-1-HAL-F02	1st FL Entry South End	Flush180	15-DEC-16	6.500	ppb
51556	51556-1-HAL-F02	1st FL Entry South End	Flush180	13-OCT-16	9.700	ppb
51556	51556-1-HAL-F02	1st FL Entry South End	Flush180	13-OCT-16	18.000	ppb
51556	51556-1-HAL-F02	1st FL Entry South End	Flush180	15-DEC-16	6.800	ppb
51556	51556-1-HAL-F02	1st FL Entry South End	Flush180	15-DEC-16	5.900	ppb
51556	51556-1-HAL-F02	1st FL Entry South End	Flush180	15-DEC-16	7.200	ppb
51556	51556-1-HAL-F02	1st FL Entry South End	Flush180	13-OCT-16	12.000	ppb
51556	51556-1-HAL-F02	1st FL Entry South End	Flush180	13-OCT-16	15.000	ppb
51556	51556-1-HAL-F02	1st FL Entry South End	Initial	15-DEC-16	8.600	ppb
51556	51556-1-HAL-F02	1st FL Entry South End	Initial	13-OCT-16	12.000	ppb
51556	51556-1-HAL-F02	1st FL Entry opposite of door 1	Flush	14-DEC-2023	16.300	ug/L
51556	51556-1-HAL-F02	1st FL Entry opposite of door 1	Flush	14-DEC-2023	12.000	ug/L
51556	51556-1-HAL-F02	1st FL Entry opposite of door 1	Flush	14-DEC-2023	13.900	ug/L
51556	51556-1-HAL-F02	1st FL Entry opposite of door 1	Flush	14-DEC-2023	15.600	ug/L
51556	51556-1-HAL-F02	1st FL Entry opposite of door 1	Initial	14-DEC-2023	5.050	ug/L
51556	51556-7-HAL-F03	By RM 703 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-7-HAL-F03	By RM 703 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-7-HAL-F03	By RM 703 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-7-HAL-F03	By RM 703 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-7-HAL-F03	By RM 703 Left Fountain	Initial	14-DEC-2023	1.000	ug/L
51556	51556-7-HAL-F04	By RM 703 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-7-HAL-F04	By RM 703 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-7-HAL-F04	By RM 703 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-7-HAL-F04	By RM 703 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-7-HAL-F04	By RM 703 Right Fountain	Initial	14-DEC-2023	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51556	51556-7-HAL-F01	By RM 720 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-7-HAL-F01	By RM 720 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-7-HAL-F01	By RM 720 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-7-HAL-F01	By RM 720 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-7-HAL-F01	By RM 720 Left Fountain	Initial	14-DEC-2023	1.000	ug/L
51556	51556-7-HAL-F02	By RM 720 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-7-HAL-F02	By RM 720 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-7-HAL-F02	By RM 720 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-7-HAL-F02	By RM 720 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-7-HAL-F02	By RM 720 Right Fountain	Initial	14-DEC-2023	1.000	ug/L
51556	51556-5-HAL-F03	By Rm 503 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-5-HAL-F03	By Rm 503 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-5-HAL-F03	By Rm 503 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-5-HAL-F03	By Rm 503 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-5-HAL-F03	By Rm 503 Left Fountain	Initial	14-DEC-2023	1.000	ug/L
51556	51556-5-HAL-F04	By Rm 503 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-5-HAL-F04	By Rm 503 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-5-HAL-F04	By Rm 503 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-5-HAL-F04	By Rm 503 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-5-HAL-F04	By Rm 503 Right Fountain	Initial	14-DEC-2023	1.000	ug/L
51556	51556-5-HAL-F01	By Rm 520 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-5-HAL-F01	By Rm 520 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-5-HAL-F01	By Rm 520 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-5-HAL-F01	By Rm 520 Left Fountain	Initial	14-DEC-2023	1.000	ug/L
51556	51556-5-HAL-RBF01	By Rm 520 Right Retrofit BF	Flush	14-DEC-2023	1.000	ug/L
51556	51556-5-HAL-RBF01	By Rm 520 Right Retrofit BF	Flush	14-DEC-2023	1.000	ug/L
51556	51556-5-HAL-RBF01	By Rm 520 Right Retrofit BF	Flush	14-DEC-2023	1.000	ug/L
51556	51556-5-HAL-RBF01	By Rm 520 Right Retrofit BF	Flush	14-DEC-2023	1.000	ug/L
51556	51556-5-HAL-RBF01	By Rm 520 Right Retrofit BF	Initial	14-DEC-2023	1.000	ug/L
51556	51556-3-HAL-F01	By Room 305 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-3-HAL-F01	By Room 305 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-3-HAL-F01	By Room 305 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-3-HAL-F01	By Room 305 Left Fountain	Initial	14-DEC-2023	1.000	ug/L
51556	51556-1-HAL-RBF01	By Room 305 Right Retrofit BF	Flush	14-DEC-2023	1.000	ug/L
51556	51556-1-HAL-RBF01	By Room 305 Right Retrofit BF	Flush	14-DEC-2023	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51556	51556-1-HAL-RBF01	By Room 305 Right Retrofit BF	Flush	14-DEC-2023	1.000	ug/L
51556	51556-1-HAL-RBF01	By Room 305 Right Retrofit BF	Flush	14-DEC-2023	1.000	ug/L
51556	51556-1-HAL-RBF01	By Room 305 Right Retrofit BF	Initial	14-DEC-2023	1.000	ug/L
51556	51556-3-HAL-F03	By Room 316 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-3-HAL-F03	By Room 316 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-3-HAL-F03	By Room 316 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-3-HAL-F03	By Room 316 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-3-HAL-F03	By Room 316 Left Fountain	Initial	14-DEC-2023	1.000	ug/L
51556	51556-3-HAL-F04	By Room 316 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-3-HAL-F04	By Room 316 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-3-HAL-F04	By Room 316 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-3-HAL-F04	By Room 316 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-3-HAL-F04	By Room 316 Right Fountain	Initial	14-DEC-2023	1.000	ug/L
51556	51556-8-801-S11	Center of RM East of Deep Fryer	Flush180	13-OCT-16	160.00 0	ppb
51556	51556-8-801-S11	Center of RM East of Deep Fryer	Flush180	13-OCT-16	53.000	ppb
51556	51556-8-801-S11	Center of RM East of Deep Fryer	Flush180	13-OCT-16	86.000	ppb
51556	51556-8-801-S11	Center of RM East of Deep Fryer	Flush180	13-OCT-16	46.000	ppb
51556	51556-8-801-S11	Center of RM East of Deep Fryer	Flush180	15-DEC-16	16.000	ppb
51556	51556-8-801-S11	Center of RM East of Deep Fryer	Flush180	15-DEC-16	17.000	ppb
51556	51556-8-801-S11	Center of RM East of Deep Fryer	Flush180	15-DEC-16	13.000	ppb
51556	51556-8-801-S11	Center of RM East of Deep Fryer	Flush180	15-DEC-16	9.300	ppb
51556	51556-8-801-S11	Center of RM East of Deep Fryer	Initial	13-OCT-16	230.00 0	ppb
51556	51556-8-801-S11	Center of RM East of Deep Fryer	Initial	15-DEC-16	27.000	ppb
51556	51556-LL-KIT-KS01	Kitchen West Wall 2-Basin sink on LEFT	Flush	14-DEC-2023	1.000	ug/L
51556	51556-LL-KIT-KS01	Kitchen West Wall 2-Basin sink on LEFT	Flush	14-DEC-2023	1.000	ug/L
51556	51556-LL-KIT-KS01	Kitchen West Wall 2-Basin sink on LEFT	Flush	14-DEC-2023	1.000	ug/L
51556	51556-LL-KIT-KS01	Kitchen West Wall 2-Basin sink on LEFT	Flush	14-DEC-2023	1.000	ug/L
51556	51556-LL-KIT-KS01	Kitchen West Wall 2-Basin sink on LEFT	Flush180	13-OCT-16	0.620	ppb
51556	51556-LL-KIT-KS01	Kitchen West Wall 2-Basin sink on LEFT	Flush180	13-OCT-16	0.570	ppb
51556	51556-LL-KIT-KS01	Kitchen West Wall 2-Basin sink on LEFT	Flush180	13-OCT-16	0.360	ppb
51556	51556-LL-KIT-KS01	Kitchen West Wall 2-Basin sink on LEFT	Flush180	13-OCT-16	0.520	ppb
51556	51556-LL-KIT-KS01	Kitchen West Wall 2-Basin sink on LEFT	Initial	13-OCT-16	0.310	ppb
51556	51556-LL-KIT-KS01	Kitchen West Wall 2-Basin sink on LEFT	Initial	14-DEC-2023	1.000	ug/L
51556	51556-LL-KIT-KS02	Kitchen West Wall 2-Basin sink on RIGHT	Flush	14-DEC-2023	1.000	ug/L
51556	51556-LL-KIT-KS02	Kitchen West Wall 2-Basin sink on RIGHT	Flush	14-DEC-2023	1.000	ug/L
51556	51556-LL-KIT-KS02	Kitchen West Wall 2-Basin sink on RIGHT	Flush	14-DEC-2023	1.000	ug/L
51556	51556-LL-KIT-KS02	Kitchen West Wall 2-Basin sink on RIGHT	Flush	14-DEC-2023	1.000	ug/L
51556	51556-LL-KIT-KS02	Kitchen West Wall 2-Basin sink on RIGHT	Flush180	13-OCT-16	0.620	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS02	RIGHT				
51556	51556-LL-KIT-KS02	Kitchen West Wall 2-Basin sink on RIGHT	Flush180	13-OCT-16	0.550	ppb
51556	51556-LL-KIT-KS02	Kitchen West Wall 2-Basin sink on RIGHT	Flush180	13-OCT-16	0.540	ppb
51556	51556-LL-KIT-KS02	Kitchen West Wall 2-Basin sink on RIGHT	Flush180	13-OCT-16	0.570	ppb
51556	51556-LL-KIT-KS02	Kitchen West Wall 2-Basin sink on RIGHT	Initial	13-OCT-16	0.540	ppb
51556	51556-LL-KIT-KS02	Kitchen West Wall 2-Basin sink on RIGHT	Initial	14-DEC-2023	1.000	ug/L
51556	51556-LL-KIT-KS05	Kitchen West Wall 3-Basin sink Left	Flush	14-DEC-2023	1.000	ug/L
51556	51556-LL-KIT-KS05	Kitchen West Wall 3-Basin sink Left	Flush	14-DEC-2023	1.000	ug/L
51556	51556-LL-KIT-KS05	Kitchen West Wall 3-Basin sink Left	Flush	14-DEC-2023	1.000	ug/L
51556	51556-LL-KIT-KS05	Kitchen West Wall 3-Basin sink Left	Flush	14-DEC-2023	1.000	ug/L
51556	51556-LL-KIT-KS05	Kitchen West Wall 3-Basin sink Left	Flush180	13-OCT-16	0.220	ppb
51556	51556-LL-KIT-KS05	Kitchen West Wall 3-Basin sink Left	Flush180	13-OCT-16	0.470	ppb
51556	51556-LL-KIT-KS05	Kitchen West Wall 3-Basin sink Left	Flush180	13-OCT-16	0.550	ppb
51556	51556-LL-KIT-KS05	Kitchen West Wall 3-Basin sink Left	Flush180	13-OCT-16	0.220	ppb
51556	51556-LL-KIT-KS05	Kitchen West Wall 3-Basin sink Left	Initial	13-OCT-16	5.800	ppb
51556	51556-LL-KIT-KS05	Kitchen West Wall 3-Basin sink Left	Initial	14-DEC-2023	1.000	ug/L
51556	51556-LL-KIT-KS04	Kitchen West Wall 3-Basin sink Middle	Flush	14-DEC-2023	1.000	ug/L
51556	51556-LL-KIT-KS04	Kitchen West Wall 3-Basin sink Middle	Flush	14-DEC-2023	1.280	ug/L
51556	51556-LL-KIT-KS04	Kitchen West Wall 3-Basin sink Middle	Flush	14-DEC-2023	1.320	ug/L
51556	51556-LL-KIT-KS04	Kitchen West Wall 3-Basin sink Middle	Flush	14-DEC-2023	1.000	ug/L
51556	51556-LL-KIT-KS04	Kitchen West Wall 3-Basin sink Middle	Flush180	13-OCT-16	0.510	ppb
51556	51556-LL-KIT-KS04	Kitchen West Wall 3-Basin sink Middle	Flush180	13-OCT-16	0.420	ppb
51556	51556-LL-KIT-KS04	Kitchen West Wall 3-Basin sink Middle	Flush180	13-OCT-16	0.790	ppb
51556	51556-LL-KIT-KS04	Kitchen West Wall 3-Basin sink Middle	Flush180	13-OCT-16	0.370	ppb
51556	51556-LL-KIT-KS04	Kitchen West Wall 3-Basin sink Middle	Initial	13-OCT-16	2.800	ppb
51556	51556-LL-KIT-KS04	Kitchen West Wall 3-Basin sink Middle	Initial	14-DEC-2023	1.000	ug/L
51556	51556-LL-KIT-KS03	Kitchen West Wall 3-Basin sink on left	Flush	14-DEC-2023	1.000	ug/L
51556	51556-LL-KIT-KS03	Kitchen West Wall 3-Basin sink on left	Flush	14-DEC-2023	1.000	ug/L
51556	51556-LL-KIT-KS03	Kitchen West Wall 3-Basin sink on left	Flush	14-DEC-2023	1.000	ug/L
51556	51556-LL-KIT-KS03	Kitchen West Wall 3-Basin sink on left	Flush180	13-OCT-16	0.380	ppb
51556	51556-LL-KIT-KS03	Kitchen West Wall 3-Basin sink on left	Flush180	13-OCT-16	0.580	ppb
51556	51556-LL-KIT-KS03	Kitchen West Wall 3-Basin sink on left	Flush180	13-OCT-16	0.480	ppb
51556	51556-LL-KIT-KS03	Kitchen West Wall 3-Basin sink on left	Flush180	13-OCT-16	0.540	ppb
51556	51556-LL-KIT-KS03	Kitchen West Wall 3-Basin sink on left	Initial	13-OCT-16	0.420	ppb
51556	51556-LL-KIT-KS03	Kitchen West Wall 3-Basin sink on left	Initial	14-DEC-2023	1.000	ug/L
51556	51556-LL-HAL-F02	Lower Level South Corridor	Flush	14-DEC-2023	20.300	ug/L
51556	51556-LL-	Lower Level South Corridor	Flush	14-DEC-2023	10.600	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F02					
51556	51556-LL-HAL-F02	Lower Level South Corridor	Flush	14-DEC-2023	17.700	ug/L
51556	51556-LL-HAL-F02	Lower Level South Corridor	Flush	14-DEC-2023	31.100	ug/L
51556	51556-LL-HAL-F02	Lower Level South Corridor	Flush180	13-OCT-16	7.000	ppb
51556	51556-LL-HAL-F02	Lower Level South Corridor	Flush180	13-OCT-16	4.600	ppb
51556	51556-LL-HAL-F02	Lower Level South Corridor	Flush180	13-OCT-16	5.100	ppb
51556	51556-LL-HAL-F02	Lower Level South Corridor	Flush180	15-DEC-16	4.500	ppb
51556	51556-LL-HAL-F02	Lower Level South Corridor	Flush180	15-DEC-16	13.000	ppb
51556	51556-LL-HAL-F02	Lower Level South Corridor	Flush180	15-DEC-16	4.200	ppb
51556	51556-LL-HAL-F02	Lower Level South Corridor	Flush180	15-DEC-16	4.000	ppb
51556	51556-LL-HAL-F02	Lower Level South Corridor	Flush180	13-OCT-16	9.000	ppb
51556	51556-LL-HAL-F02	Lower Level South Corridor	Initial	13-OCT-16	40.000	ppb
51556	51556-LL-HAL-F02	Lower Level South Corridor	Initial	15-DEC-16	4.200	ppb
51556	51556-LL-HAL-F02	Lower Level South Corridor	Initial	14-DEC-2023	51.500	ug/L
51556	51556-LL-HAL-F01	Lower level North Corridor	Flush180	13-OCT-16	5.200	ppb
51556	51556-LL-HAL-F01	Lower level North Corridor	Flush180	13-OCT-16	2.900	ppb
51556	51556-LL-HAL-F01	Lower level North Corridor	Flush180	13-OCT-16	4.500	ppb
51556	51556-LL-HAL-F01	Lower level North Corridor	Flush180	13-OCT-16	6.000	ppb
51556	51556-LL-HAL-F01	Lower level North Corridor	Flush180	15-DEC-16	0.900	ppb
51556	51556-LL-HAL-F01	Lower level North Corridor	Flush180	15-DEC-16	0.880	ppb
51556	51556-LL-HAL-F01	Lower level North Corridor	Flush180	15-DEC-16	1.300	ppb
51556	51556-LL-HAL-F01	Lower level North Corridor	Flush180	15-DEC-16	1.200	ppb
51556	51556-LL-HAL-F01	Lower level North Corridor	Initial	13-OCT-16	18.000	ppb
51556	51556-LL-HAL-F01	Lower level North Corridor	Initial	15-DEC-16	1.900	ppb
51556	51556-B-HAL-F01	Main- Basement Hallway Across From Room 011	Flush180	02-MAR-21	1.000	ug/L
51556	51556-B-HAL-F01	Main- Basement Hallway Across From Room 011	Flush180	02-MAR-21	1.000	ug/L
51556	51556-B-HAL-F01	Main- Basement Hallway Across From Room 011	Flush180	02-MAR-21	1.000	ug/L
51556	51556-B-HAL-F01	Main- Basement Hallway Across From Room 011	Flush180	02-MAR-21	1.000	ug/L
51556	51556-B-HAL-F01	Main- Basement Hallway Across From Room 011	Flush180	17-DEC-20	8.780	ug/L
51556	51556-B-HAL-F01	Main- Basement Hallway Across From Room 011	Initial	02-MAR-21	1.000	ug/L
51556	51556-B-HAL-F01	Main- Basement Hallway Across From Room 011	Initial	17-DEC-20	38.900	ug/L
51556	51556-8-801-S10	N Wall Middle 3-Basin Sink Right Faucet	Flush	14-DEC-2023	1.000	ug/L
51556	51556-8-801-S10	N Wall Middle 3-Basin Sink Right Faucet	Flush	14-DEC-2023	1.000	ug/L
51556	51556-8-801-S10	N Wall Middle 3-Basin Sink Right Faucet	Flush	14-DEC-2023	1.000	ug/L
51556	51556-8-801-S10	N Wall Middle 3-Basin Sink Right Faucet	Flush	14-DEC-2023	1.010	ug/L
51556	51556-8-801-S10	N Wall Middle 3-Basin Sink Right Faucet	Flush180	13-OCT-16	0.240	ppb
51556	51556-8-801-S10	N Wall Middle 3-Basin Sink Right Faucet	Flush180	13-OCT-16	0.230	ppb
51556	51556-8-801-S10	N Wall Middle 3-Basin Sink Right Faucet	Flush180	13-OCT-16	2.500	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51556	51556-8-801-S10	N Wall Middle 3-Basin Sink Right Faucet	Flush180	13-OCT-16	0.370	ppb
51556	51556-8-801-S10	N Wall Middle 3-Basin Sink Right Faucet	Initial	13-OCT-16	3.200	ppb
51556	51556-8-801-S10	N Wall Middle 3-Basin Sink Right Faucet	Initial	14-DEC-2023	2.200	ug/L
51556	51556-8-801-S09	N. Wall Middle 3-Basin sink Left faucet	Flush	14-DEC-2023	2.680	ug/L
51556	51556-8-801-S09	N. Wall Middle 3-Basin sink Left faucet	Flush	14-DEC-2023	1.230	ug/L
51556	51556-8-801-S09	N. Wall Middle 3-Basin sink Left faucet	Flush	14-DEC-2023	1.410	ug/L
51556	51556-8-801-S09	N. Wall Middle 3-Basin sink Left faucet	Flush	14-DEC-2023	1.000	ug/L
51556	51556-8-801-S09	N. Wall Middle 3-Basin sink Left faucet	Flush	14-DEC-2023	2.370	ug/L
51556	51556-8-801-S09	N. Wall Middle 3-Basin sink Left faucet	Flush	14-DEC-2023	2.340	ug/L
51556	51556-8-801-S09	N. Wall Middle 3-Basin sink Left faucet	Flush	14-DEC-2023	2.130	ug/L
51556	51556-8-801-S09	N. Wall Middle 3-Basin sink Left faucet	Flush	14-DEC-2023	1.830	ug/L
51556	51556-8-801-S09	N. Wall Middle 3-Basin sink Left faucet	Flush180	13-OCT-16	0.930	ppb
51556	51556-8-801-S09	N. Wall Middle 3-Basin sink Left faucet	Flush180	13-OCT-16	0.430	ppb
51556	51556-8-801-S09	N. Wall Middle 3-Basin sink Left faucet	Flush180	13-OCT-16	0.380	ppb
51556	51556-8-801-S09	N. Wall Middle 3-Basin sink Left faucet	Flush180	13-OCT-16	0.380	ppb
51556	51556-8-801-S09	N. Wall Middle 3-Basin sink Left faucet	Initial	13-OCT-16	1.300	ppb
51556	51556-8-801-S09	N. Wall Middle 3-Basin sink Left faucet	Initial	14-DEC-2023	1.700	ug/L
51556	51556-8-801-S09	N. Wall Middle 3-Basin sink Left faucet	Initial	14-DEC-2023	3.820	ug/L
51556	51556-2-HAL-F01	North Corridor Left Fountain	Flush180	13-OCT-16	0.770	ppb
51556	51556-2-HAL-F01	North Corridor Left Fountain	Flush180	13-OCT-16	0.630	ppb
51556	51556-2-HAL-F01	North Corridor Left Fountain	Flush180	13-OCT-16	0.700	ppb
51556	51556-2-HAL-F01	North Corridor Left Fountain	Flush180	13-OCT-16	0.690	ppb
51556	51556-3-HAL-F01	North Corridor Left Fountain	Flush180	13-OCT-16	0.690	ppb
51556	51556-3-HAL-F01	North Corridor Left Fountain	Flush180	13-OCT-16	0.650	ppb
51556	51556-3-HAL-F01	North Corridor Left Fountain	Flush180	13-OCT-16	0.770	ppb
51556	51556-3-HAL-F01	North Corridor Left Fountain	Flush180	13-OCT-16	0.650	ppb
51556	51556-2-HAL-F01	North Corridor Left Fountain	Initial	13-OCT-16	1.200	ppb
51556	51556-3-HAL-F01	North Corridor Left Fountain	Initial	13-OCT-16	0.870	ppb
51556	51556-2-HAL-F02	North Corridor Right Fountain	Flush180	13-OCT-16	0.820	ppb
51556	51556-2-HAL-F02	North Corridor Right Fountain	Flush180	13-OCT-16	0.900	ppb
51556	51556-2-HAL-F02	North Corridor Right Fountain	Flush180	13-OCT-16	0.850	ppb
51556	51556-2-HAL-F02	North Corridor Right Fountain	Flush180	13-OCT-16	0.900	ppb
51556	51556-3-HAL-F02	North Corridor Right Fountain	Flush180	13-OCT-16	0.680	ppb
51556	51556-3-HAL-F02	North Corridor Right Fountain	Flush180	13-OCT-16	0.640	ppb
51556	51556-3-HAL-F02	North Corridor Right Fountain	Flush180	13-OCT-16	0.680	ppb
51556	51556-3-HAL-F02	North Corridor Right Fountain	Flush180	13-OCT-16	0.680	ppb
51556	51556-2-HAL-F02	North Corridor Right Fountain	Initial	13-OCT-16	0.710	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51556	51556-3-HAL-F02	North Corridor Right Fountain	Initial	13-OCT-16	0.540	ppb
51556	51556-8-HAL-F01	North End Hall Left Fountain	Flush180	13-OCT-16	0.370	ppb
51556	51556-8-HAL-F01	North End Hall Left Fountain	Flush180	13-OCT-16	0.350	ppb
51556	51556-8-HAL-F01	North End Hall Left Fountain	Flush180	13-OCT-16	0.350	ppb
51556	51556-8-HAL-F01	North End Hall Left Fountain	Flush180	13-OCT-16	0.350	ppb
51556	51556-8-HAL-F01	North End Hall Left Fountain	Initial	13-OCT-16	0.290	ppb
51556	51556-5-HAL-F01	North End Left Fountain	Flush180	13-OCT-16	0.440	ppb
51556	51556-5-HAL-F01	North End Left Fountain	Flush180	13-OCT-16	0.370	ppb
51556	51556-5-HAL-F01	North End Left Fountain	Flush180	13-OCT-16	0.330	ppb
51556	51556-5-HAL-F01	North End Left Fountain	Flush180	13-OCT-16	0.330	ppb
51556	51556-7-HAL-F01	North End Left Fountain	Flush180	13-OCT-16	0.270	ppb
51556	51556-7-HAL-F01	North End Left Fountain	Flush180	13-OCT-16	0.220	ppb
51556	51556-7-HAL-F01	North End Left Fountain	Flush180	13-OCT-16	0.260	ppb
51556	51556-7-HAL-F01	North End Left Fountain	Flush180	13-OCT-16	0.300	ppb
51556	51556-4-HAL-F01	North End Left Fountain	Flush180	13-OCT-16	0.500	ppb
51556	51556-6-HAL-F01	North End Left Fountain	Flush180	13-OCT-16	0.160	ppb
51556	51556-6-HAL-F01	North End Left Fountain	Flush180	13-OCT-16	0.210	ppb
51556	51556-6-HAL-F01	North End Left Fountain	Flush180	13-OCT-16	0.200	ppb
51556	51556-6-HAL-F01	North End Left Fountain	Flush180	13-OCT-16	0.180	ppb
51556	51556-4-HAL-F01	North End Left Fountain	Flush180	13-OCT-16	0.530	ppb
51556	51556-4-HAL-F01	North End Left Fountain	Flush180	13-OCT-16	0.530	ppb
51556	51556-4-HAL-F01	North End Left Fountain	Flush180	13-OCT-16	0.530	ppb
51556	51556-5-HAL-F01	North End Left Fountain	Initial	13-OCT-16	0.780	ppb
51556	51556-7-HAL-F01	North End Left Fountain	Initial	13-OCT-16	0.370	ppb
51556	51556-6-HAL-F01	North End Left Fountain	Initial	13-OCT-16	0.230	ppb
51556	51556-4-HAL-F01	North End Left Fountain	Initial	13-OCT-16	0.570	ppb
51556	51556-4-HAL-F02	North End Right Fountain	Flush180	13-OCT-16	0.470	ppb
51556	51556-4-HAL-F02	North End Right Fountain	Flush180	13-OCT-16	0.480	ppb
51556	51556-8-HAL-F02	North End Right Fountain	Flush180	13-OCT-16	0.330	ppb
51556	51556-7-HAL-F02	North End Right Fountain	Flush180	13-OCT-16	0.170	ppb
51556	51556-7-HAL-F02	North End Right Fountain	Flush180	13-OCT-16	0.170	ppb
51556	51556-8-HAL-F02	North End Right Fountain	Flush180	13-OCT-16	0.290	ppb
51556	51556-8-HAL-F02	North End Right Fountain	Flush180	13-OCT-16	0.310	ppb
51556	51556-8-HAL-F02	North End Right Fountain	Flush180	13-OCT-16	0.310	ppb
51556	51556-6-HAL-F02	North End Right Fountain	Flush180	13-OCT-16	1.000	ppb
51556	51556-6-HAL-F02	North End Right Fountain	Flush180	13-OCT-16	0.180	ppb
51556	51556-6-HAL-F02	North End Right Fountain	Flush180	13-OCT-16	1.000	ppb
51556	51556-6-HAL-F02	North End Right Fountain	Flush180	13-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02					
51556	51556-7-HAL-F02	North End Right Fountain	Flush180	13-OCT-16	1.000	ppb
51556	51556-7-HAL-F02	North End Right Fountain	Flush180	13-OCT-16	1.000	ppb
51556	51556-4-HAL-F02	North End Right Fountain	Flush180	13-OCT-16	0.440	ppb
51556	51556-4-HAL-F02	North End Right Fountain	Flush180	13-OCT-16	0.410	ppb
51556	51556-5-HAL-F02	North End Right Fountain	Flush180	13-OCT-16	0.270	ppb
51556	51556-5-HAL-F02	North End Right Fountain	Flush180	13-OCT-16	0.260	ppb
51556	51556-5-HAL-F02	North End Right Fountain	Flush180	13-OCT-16	0.230	ppb
51556	51556-5-HAL-F02	North End Right Fountain	Flush180	13-OCT-16	0.220	ppb
51556	51556-8-HAL-F02	North End Right Fountain	Flush180	02-MAR-21	1.000	ug/L
51556	51556-8-HAL-F02	North End Right Fountain	Flush180	02-MAR-21	1.000	ug/L
51556	51556-8-HAL-F02	North End Right Fountain	Flush180	02-MAR-21	1.000	ug/L
51556	51556-8-HAL-F02	North End Right Fountain	Flush180	02-MAR-21	1.000	ug/L
51556	51556-8-HAL-F02	North End Right Fountain	Flush180	17-DEC-20	27.300	ug/L
51556	51556-4-HAL-F02	North End Right Fountain	Initial	13-OCT-16	0.440	ppb
51556	51556-7-HAL-F02	North End Right Fountain	Initial	13-OCT-16	0.170	ppb
51556	51556-8-HAL-F02	North End Right Fountain	Initial	13-OCT-16	0.220	ppb
51556	51556-6-HAL-F02	North End Right Fountain	Initial	13-OCT-16	1.000	ppb
51556	51556-5-HAL-F02	North End Right Fountain	Initial	13-OCT-16	0.360	ppb
51556	51556-8-HAL-F02	North End Right Fountain	Initial	02-MAR-21	1.000	ug/L
51556	51556-8-HAL-F02	North End Right Fountain	Initial	17-DEC-20	88.700	ug/L
51556	51556-8-801-S08	North Wall West side single basin nort of commerci	Flush180	15-DEC-16	2.300	ppb
51556	51556-8-801-S08	North Wall West side single basin nort of commerci	Flush180	15-DEC-16	4.200	ppb
51556	51556-8-801-S08	North Wall West side single basin nort of commerci	Flush180	13-OCT-16	51.000	ppb
51556	51556-8-801-S08	North Wall West side single basin nort of commerci	Flush180	13-OCT-16	44.000	ppb
51556	51556-8-801-S08	North Wall West side single basin nort of commerci	Flush180	15-DEC-16	1.300	ppb
51556	51556-8-801-S08	North Wall West side single basin nort of commerci	Flush180	15-DEC-16	2.100	ppb
51556	51556-8-801-S08	North Wall West side single basin nort of commerci	Flush180	13-OCT-16	52.000	ppb
51556	51556-8-801-S08	North Wall West side single basin nort of commerci	Flush180	13-OCT-16	34.000	ppb
51556	51556-8-801-S08	North Wall West side single basin nort of commerci	Initial	15-DEC-16	8.300	ppb
51556	51556-8-801-S08	North Wall West side single basin nort of commerci	Initial	13-OCT-16	180.000	ppb
51556	51556-8-801-S08	North Wall West side single basin nort of commerci	Flush	14-DEC-2023	7.700	ug/L
51556	51556-8-801-S08	North Wall West side single basin nort of commerci	Flush	14-DEC-2023	4.330	ug/L
51556	51556-8-801-S08	North Wall West side single basin nort of commerci	Flush	14-DEC-2023	3.360	ug/L
51556	51556-8-801-S08	North Wall West side single basin nort of commerci	Initial	14-DEC-2023	12.600	ug/L
51556	51556-2-HAL-F03	Outside Room 201 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-2-HAL-F03	Outside Room 201 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-2-HAL-F03	Outside Room 201 Left Fountain	Flush	14-DEC-2023	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F03					
51556	51556-2-HAL-F03	Outside Room 201 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-2-HAL-F03	Outside Room 201 Left Fountain	Initial	14-DEC-2023	1.030	ug/L
51556	51556-2-HAL-RBF01	Outside Room 201 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-2-HAL-RBF01	Outside Room 201 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-2-HAL-RBF01	Outside Room 201 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-2-HAL-RBF01	Outside Room 201 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-2-HAL-RBF01	Outside Room 201 Right Fountain	Initial	14-DEC-2023	1.000	ug/L
51556	51556-2-HAL-F01	Outside Room 216 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-2-HAL-F01	Outside Room 216 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-2-HAL-F01	Outside Room 216 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-2-HAL-F01	Outside Room 216 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-2-HAL-F01	Outside Room 216 Left Fountain	Initial	14-DEC-2023	1.000	ug/L
51556	51556-2-HAL-F02	Outside Room 216 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-2-HAL-F02	Outside Room 216 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-2-HAL-F02	Outside Room 216 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-2-HAL-F02	Outside Room 216 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-2-HAL-F02	Outside Room 216 Right Fountain	Initial	14-DEC-2023	1.000	ug/L
51556	51556-4-HAL-F03	Outside Room 403 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-4-HAL-F03	Outside Room 403 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-4-HAL-F03	Outside Room 403 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-4-HAL-F03	Outside Room 403 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-4-HAL-F03	Outside Room 403 Left Fountain	Initial	14-DEC-2023	1.000	ug/L
51556	51556-4-HAL-F04	Outside Room 403 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-4-HAL-F04	Outside Room 403 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-4-HAL-F04	Outside Room 403 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-4-HAL-F04	Outside Room 403 Right Fountain	Initial	14-DEC-2023	1.000	ug/L
51556	51556-4-HAL-F01	Outside Room 420 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-4-HAL-F01	Outside Room 420 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-4-HAL-F01	Outside Room 420 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-4-HAL-F01	Outside Room 420 Right Fountain	Initial	14-DEC-2023	1.000	ug/L
51556	51556-6-HAL-RBF01	Outside Room 603 Bottle Filler	Flush	14-DEC-2023	1.000	ug/L
51556	51556-6-HAL-RBF01	Outside Room 603 Bottle Filler	Flush	14-DEC-2023	1.000	ug/L
51556	51556-6-HAL-RBF01	Outside Room 603 Bottle Filler	Flush	14-DEC-2023	1.000	ug/L
51556	51556-6-HAL-RBF01	Outside Room 603 Bottle Filler	Flush	14-DEC-2023	1.000	ug/L
51556	51556-6-HAL-RBF01	Outside Room 603 Bottle Filler	Initial	14-DEC-2023	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51556	51556-6-HAL-F03	Outside Room 603 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-6-HAL-F03	Outside Room 603 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-6-HAL-F03	Outside Room 603 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-6-HAL-F03	Outside Room 603 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-6-HAL-F03	Outside Room 603 Left Fountain	Initial	14-DEC-2023	1.000	ug/L
51556	51556-6-HAL-F01	Outside Room 620 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-6-HAL-F01	Outside Room 620 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-6-HAL-F01	Outside Room 620 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-6-HAL-F01	Outside Room 620 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-6-HAL-F01	Outside Room 620 Left Fountain	Initial	14-DEC-2023	1.000	ug/L
51556	51556-8-HAL-F01	Outside Room 812 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-8-HAL-F01	Outside Room 812 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-8-HAL-F01	Outside Room 812 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-8-HAL-F01	Outside Room 812 Left Fountain	Initial	14-DEC-2023	1.000	ug/L
51556	51556-8-HAL-RBF01	Outside Room 812 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-8-HAL-RBF01	Outside Room 812 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-8-HAL-RBF01	Outside Room 812 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-8-HAL-RBF01	Outside Room 812 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-8-HAL-RBF01	Outside Room 812 Right Fountain	Initial	14-DEC-2023	1.000	ug/L
51556	51556-8-HAL-F03	Outside Room 826 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-8-HAL-F03	Outside Room 826 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-8-HAL-F03	Outside Room 826 Left Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-8-HAL-F03	Outside Room 826 Left Fountain	Initial	14-DEC-2023	1.000	ug/L
51556	51556-8-HAL-F04	Outside Room 826 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-8-HAL-F04	Outside Room 826 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-8-HAL-F04	Outside Room 826 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-8-HAL-F04	Outside Room 826 Right Fountain	Flush	14-DEC-2023	1.000	ug/L
51556	51556-8-HAL-F04	Outside Room 826 Right Fountain	Initial	14-DEC-2023	1.000	ug/L
51556	51556-8-801-S07	RM 801 North Wall West side single basin NW corner	Flush	14-DEC-2023	20.100	ug/L
51556	51556-8-801-S07	RM 801 North Wall West side single basin NW corner	Flush	14-DEC-2023	14.200	ug/L
51556	51556-8-801-S07	RM 801 North Wall West side single basin NW corner	Flush	14-DEC-2023	17.700	ug/L
51556	51556-8-801-S07	RM 801 North Wall West side single basin NW corner	Flush	14-DEC-2023	27.600	ug/L
51556	51556-8-801-S07	RM 801 North Wall West side single basin NW corner	Flush180	13-OCT-16	67.000	ppb
51556	51556-8-801-S07	RM 801 North Wall West side single basin NW corner	Flush180	13-OCT-16	120.000	ppb
51556	51556-8-801-S07	RM 801 North Wall West side single basin NW corner	Flush180	13-OCT-16	200.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51556	51556-8-801-S07	RM 801 North Wall West side single basin NW corner	Flush180	13-OCT-16	160.00 0	ppb
51556	51556-8-801-S07	RM 801 North Wall West side single basin NW corner	Flush180	15-DEC-16	3.100	ppb
51556	51556-8-801-S07	RM 801 North Wall West side single basin NW corner	Flush180	15-DEC-16	4.500	ppb
51556	51556-8-801-S07	RM 801 North Wall West side single basin NW corner	Flush180	15-DEC-16	8.900	ppb
51556	51556-8-801-S07	RM 801 North Wall West side single basin NW corner	Flush180	15-DEC-16	11.000	ppb
51556	51556-8-801-S07	RM 801 North Wall West side single basin NW corner	Initial	13-OCT-16	150.00 0	ppb
51556	51556-8-801-S07	RM 801 North Wall West side single basin NW corner	Initial	15-DEC-16	12.000	ppb
51556	51556-8-801-S07	RM 801 North Wall West side single basin NW corner	Initial	14-DEC-2023	45.600	ug/L
51556	51556-8-801-S06	RM 801 West Wall North End	Flush	14-DEC-2023	19.400	ug/L
51556	51556-8-801-S06	RM 801 West Wall North End	Flush	14-DEC-2023	17.200	ug/L
51556	51556-8-801-S06	RM 801 West Wall North End	Flush	14-DEC-2023	18.200	ug/L
51556	51556-8-801-S06	RM 801 West Wall North End	Flush	14-DEC-2023	21.700	ug/L
51556	51556-8-801-S06	RM 801 West Wall North End	Flush180	13-OCT-16	82.000	ppb
51556	51556-8-801-S06	RM 801 West Wall North End	Flush180	13-OCT-16	32.000	ppb
51556	51556-8-801-S06	RM 801 West Wall North End	Flush180	13-OCT-16	15.000	ppb
51556	51556-8-801-S06	RM 801 West Wall North End	Flush180	15-DEC-16	4.000	ppb
51556	51556-8-801-S06	RM 801 West Wall North End	Flush180	15-DEC-16	2.000	ppb
51556	51556-8-801-S06	RM 801 West Wall North End	Flush180	15-DEC-16	2.600	ppb
51556	51556-8-801-S06	RM 801 West Wall North End	Flush180	15-DEC-16	1.800	ppb
51556	51556-8-801-S06	RM 801 West Wall North End	Flush180	13-OCT-16	43.000	ppb
51556	51556-8-801-S06	RM 801 West Wall North End	Initial	13-OCT-16	43.000	ppb
51556	51556-8-801-S06	RM 801 West Wall North End	Initial	15-DEC-16	10.000	ppb
51556	51556-8-801-S06	RM 801 West Wall North End	Initial	14-DEC-2023	25.100	ug/L
51556	51556-2-HAL-F03	South Corridor Left Fountain	Flush180	13-OCT-16	0.480	ppb
51556	51556-2-HAL-F03	South Corridor Left Fountain	Flush180	13-OCT-16	0.660	ppb
51556	51556-2-HAL-F03	South Corridor Left Fountain	Flush180	13-OCT-16	0.760	ppb
51556	51556-2-HAL-F03	South Corridor Left Fountain	Flush180	13-OCT-16	0.530	ppb
51556	51556-3-HAL-F03	South Corridor Left Fountain	Flush180	13-OCT-16	0.430	ppb
51556	51556-3-HAL-F03	South Corridor Left Fountain	Flush180	13-OCT-16	0.460	ppb
51556	51556-3-HAL-F03	South Corridor Left Fountain	Flush180	13-OCT-16	0.400	ppb
51556	51556-3-HAL-F03	South Corridor Left Fountain	Flush180	13-OCT-16	0.380	ppb
51556	51556-2-HAL-F03	South Corridor Left Fountain	Initial	13-OCT-16	0.810	ppb
51556	51556-3-HAL-F03	South Corridor Left Fountain	Initial	13-OCT-16	0.390	ppb
51556	51556-2-HAL-F04	South Corridor Right Fountain	Flush180	13-OCT-16	0.380	ppb
51556	51556-2-HAL-F04	South Corridor Right Fountain	Flush180	13-OCT-16	0.460	ppb
51556	51556-2-HAL-F04	South Corridor Right Fountain	Flush180	13-OCT-16	0.390	ppb
51556	51556-2-HAL-F04	South Corridor Right Fountain	Flush180	13-OCT-16	0.440	ppb
51556	51556-3-HAL-	South Corridor Right Fountain	Flush180	13-OCT-16	0.370	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F04					
51556	51556-3-HAL-F04	South Corridor Right Fountain	Flush180	13-OCT-16	0.360	ppb
51556	51556-3-HAL-F04	South Corridor Right Fountain	Flush180	13-OCT-16	0.380	ppb
51556	51556-3-HAL-F04	South Corridor Right Fountain	Flush180	13-OCT-16	0.360	ppb
51556	51556-2-HAL-F04	South Corridor Right Fountain	Initial	13-OCT-16	0.410	ppb
51556	51556-3-HAL-F04	South Corridor Right Fountain	Initial	13-OCT-16	0.290	ppb
51556	51556-4-HAL-F03	South End Hall Left Fountain	Flush180	13-OCT-16	0.450	ppb
51556	51556-4-HAL-F03	South End Hall Left Fountain	Flush180	13-OCT-16	0.420	ppb
51556	51556-4-HAL-F03	South End Hall Left Fountain	Flush180	13-OCT-16	0.380	ppb
51556	51556-4-HAL-F03	South End Hall Left Fountain	Flush180	13-OCT-16	0.480	ppb
51556	51556-4-HAL-F03	South End Hall Left Fountain	Initial	13-OCT-16	0.360	ppb
51556	51556-4-HAL-F04	South End Hall Right Fountain	Flush180	13-OCT-16	0.350	ppb
51556	51556-4-HAL-F04	South End Hall Right Fountain	Flush180	13-OCT-16	0.340	ppb
51556	51556-4-HAL-F04	South End Hall Right Fountain	Flush180	13-OCT-16	0.430	ppb
51556	51556-4-HAL-F04	South End Hall Right Fountain	Flush180	13-OCT-16	0.400	ppb
51556	51556-4-HAL-F04	South End Hall Right Fountain	Initial	13-OCT-16	0.320	ppb
51556	51556-7-HAL-F03	South End Left Fountain	Flush180	13-OCT-16	0.160	ppb
51556	51556-7-HAL-F03	South End Left Fountain	Flush180	13-OCT-16	0.200	ppb
51556	51556-8-HAL-F03	South End Left Fountain	Flush180	13-OCT-16	0.570	ppb
51556	51556-8-HAL-F03	South End Left Fountain	Flush180	13-OCT-16	0.460	ppb
51556	51556-8-HAL-F03	South End Left Fountain	Flush180	13-OCT-16	0.470	ppb
51556	51556-8-HAL-F03	South End Left Fountain	Flush180	13-OCT-16	0.480	ppb
51556	51556-6-HAL-F03	South End Left Fountain	Flush180	13-OCT-16	0.190	ppb
51556	51556-6-HAL-F03	South End Left Fountain	Flush180	13-OCT-16	0.190	ppb
51556	51556-6-HAL-F03	South End Left Fountain	Flush180	13-OCT-16	0.170	ppb
51556	51556-6-HAL-F03	South End Left Fountain	Flush180	13-OCT-16	0.230	ppb
51556	51556-5-HAL-F03	South End Left Fountain	Flush180	13-OCT-16	0.210	ppb
51556	51556-5-HAL-F03	South End Left Fountain	Flush180	13-OCT-16	0.190	ppb
51556	51556-5-HAL-F03	South End Left Fountain	Flush180	13-OCT-16	0.220	ppb
51556	51556-7-HAL-F03	South End Left Fountain	Flush180	13-OCT-16	0.170	ppb
51556	51556-7-HAL-F03	South End Left Fountain	Flush180	13-OCT-16	0.220	ppb
51556	51556-5-HAL-F03	South End Left Fountain	Flush180	13-OCT-16	0.260	ppb
51556	51556-7-HAL-F03	South End Left Fountain	Initial	13-OCT-16	0.310	ppb
51556	51556-8-HAL-F03	South End Left Fountain	Initial	13-OCT-16	0.320	ppb
51556	51556-6-HAL-F03	South End Left Fountain	Initial	13-OCT-16	0.240	ppb
51556	51556-5-HAL-F03	South End Left Fountain	Initial	13-OCT-16	0.330	ppb
51556	51556-8-HAL-F04	South End Right Fountain	Flush180	13-OCT-16	0.400	ppb
51556	51556-6-HAL-	South End Right Fountain	Flush180	13-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F04					
51556	51556-6-HAL-F04	South End Right Fountain	Flush180	13-OCT-16	1.000	ppb
51556	51556-6-HAL-F04	South End Right Fountain	Flush180	13-OCT-16	1.000	ppb
51556	51556-6-HAL-F04	South End Right Fountain	Flush180	13-OCT-16	1.000	ppb
51556	51556-5-HAL-F04	South End Right Fountain	Flush180	13-OCT-16	1.000	ppb
51556	51556-5-HAL-F04	South End Right Fountain	Flush180	13-OCT-16	1.000	ppb
51556	51556-5-HAL-F04	South End Right Fountain	Flush180	13-OCT-16	0.180	ppb
51556	51556-5-HAL-F04	South End Right Fountain	Flush180	13-OCT-16	1.000	ppb
51556	51556-7-HAL-F04	South End Right Fountain	Flush180	13-OCT-16	0.290	ppb
51556	51556-7-HAL-F04	South End Right Fountain	Flush180	13-OCT-16	0.250	ppb
51556	51556-7-HAL-F04	South End Right Fountain	Flush180	13-OCT-16	0.330	ppb
51556	51556-7-HAL-F04	South End Right Fountain	Flush180	13-OCT-16	0.330	ppb
51556	51556-8-HAL-F04	South End Right Fountain	Flush180	13-OCT-16	0.410	ppb
51556	51556-8-HAL-F04	South End Right Fountain	Flush180	13-OCT-16	0.420	ppb
51556	51556-8-HAL-F04	South End Right Fountain	Flush180	13-OCT-16	0.390	ppb
51556	51556-6-HAL-F04	South End Right Fountain	Initial	13-OCT-16	1.000	ppb
51556	51556-5-HAL-F04	South End Right Fountain	Initial	13-OCT-16	1.000	ppb
51556	51556-7-HAL-F04	South End Right Fountain	Initial	13-OCT-16	0.300	ppb
51556	51556-8-HAL-F04	South End Right Fountain	Initial	13-OCT-16	0.500	ppb
51556	51556-8-801-S03	South Wall East End RM 801	Flush	14-DEC-2023	1.000	ug/L
51556	51556-8-801-S03	South Wall East End RM 801	Flush	14-DEC-2023	1.000	ug/L
51556	51556-8-801-S03	South Wall East End RM 801	Flush	14-DEC-2023	1.000	ug/L
51556	51556-8-801-S03	South Wall East End RM 801	Flush	14-DEC-2023	1.000	ug/L
51556	51556-8-801-S03	South Wall East End RM 801	Flush180	13-OCT-16	0.510	ppb
51556	51556-8-801-S03	South Wall East End RM 801	Flush180	13-OCT-16	0.410	ppb
51556	51556-8-801-S03	South Wall East End RM 801	Flush180	13-OCT-16	0.710	ppb
51556	51556-8-801-S03	South Wall East End RM 801	Flush180	13-OCT-16	0.430	ppb
51556	51556-8-801-S03	South Wall East End RM 801	Initial	13-OCT-16	0.770	ppb
51556	51556-8-801-S03	South Wall East End RM 801	Initial	14-DEC-2023	1.000	ug/L
51556	51556-8-801-S05	West Wall South End RM 801	Flush	14-DEC-2023	80.700	ug/L
51556	51556-8-801-S05	West Wall South End RM 801	Flush	14-DEC-2023	17.900	ug/L
51556	51556-8-801-S05	West Wall South End RM 801	Flush	14-DEC-2023	15.800	ug/L
51556	51556-8-801-S05	West Wall South End RM 801	Flush	14-DEC-2023	8.240	ug/L
51556	51556-8-801-S05	West Wall South End RM 801	Flush180	13-OCT-16	2.300	ppb
51556	51556-8-801-S05	West Wall South End RM 801	Flush180	13-OCT-16	2.900	ppb
51556	51556-8-801-S05	West Wall South End RM 801	Flush180	13-OCT-16	3.300	ppb
51556	51556-8-801-S05	West Wall South End RM 801	Flush180	13-OCT-16	2.100	ppb
51556	51556-8-801-S05	West Wall South End RM 801	Initial	13-OCT-16	7.100	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51556	51556-8-801-S05	West Wall South End RM 801	Initial	14-DEC-2023	11.100	ug/L