



Sep 10, 2024

COLUMBIA EXPLORERS

4520 S KEDZIE AVE, Chicago IL 60632.

Dear **COLUMBIA EXPLORERS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

COLUMBIA EXPLORERS

4520 S KEDZIE AVE, Chicago IL 60632.

Estimadas familias de **COLUMBIA EXPLORERS**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarle y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51279	55259-1-HAL-RBF01	1st floor Corridor, Annex #1 Bottle Filler	Flush	06-DEC-2023	1.000	ug/L
51279	55259-1-HAL-RBF01	1st floor Corridor, Annex #1 Bottle Filler	Flush	06-DEC-2023	1.000	ug/L
51279	55259-1-HAL-RBF01	1st floor Corridor, Annex #1 Bottle Filler	Flush	06-DEC-2023	1.000	ug/L
51279	55259-1-HAL-RBF01	1st floor Corridor, Annex #1 Bottle Filler	Flush	06-DEC-2023	1.000	ug/L
51279	55259-1-HAL-RBF01	1st floor Corridor, Annex #1 Bottle Filler	Initial	06-DEC-2023	1.000	ug/L
51279	51279-1-113-S10	Main Building inside Room 113, left Sink	Flush	06-DEC-2023	1.020	ug/L
51279	51279-1-113-S10	Main Building inside Room 113, left Sink	Flush	06-DEC-2023	1.030	ug/L
51279	51279-1-113-S10	Main Building inside Room 113, left Sink	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-113-S10	Main Building inside Room 113, left Sink	Flush	22-FEB-2024	1.000	ug/L
51279	51279-1-113-S10	Main Building inside Room 113, left Sink	Flush	22-FEB-2024	1.000	ug/L
51279	51279-1-113-S10	Main Building inside Room 113, left Sink	Flush	22-FEB-2024	1.000	ug/L
51279	51279-1-113-S10	Main Building inside Room 113, left Sink	Flush	22-FEB-2024	1.000	ug/L
51279	51279-1-113-S10	Main Building inside Room 113, left Sink	Flush	22-FEB-2024	1.000	ug/L
51279	51279-1-113-S10	Main Building inside Room 113, left Sink	Flush	31-JAN-2024	1.000	ug/L
51279	51279-1-113-S10	Main Building inside Room 113, left Sink	Flush	10-JAN-2024	2.260	ug/L
51279	51279-1-113-S10	Main Building inside Room 113, left Sink	Flush	10-JAN-2024	1.310	ug/L
51279	51279-1-113-S10	Main Building inside Room 113, left Sink	Flush	10-JAN-2024	2.260	ug/L
51279	51279-1-113-S10	Main Building inside Room 113, left Sink	Flush	10-JAN-2024	1.340	ug/L
51279	51279-1-113-S10	Main Building inside Room 113, left Sink	Flush	31-JAN-2024	1.280	ug/L
51279	51279-1-113-S10	Main Building inside Room 113, left Sink	Flush	31-JAN-2024	1.000	ug/L
51279	51279-1-113-S10	Main Building inside Room 113, left Sink	Flush	31-JAN-2024	1.000	ug/L
51279	51279-1-113-S10	Main Building inside Room 113, left Sink	Flush	06-DEC-2023	1.450	ug/L
51279	51279-1-113-S10	Main Building inside Room 113, left Sink	Initial	22-FEB-2024	1.100	ug/L
51279	51279-1-113-S10	Main Building inside Room 113, left Sink	Initial	31-JAN-2024	10.300	ug/L
51279	51279-1-113-S10	Main Building inside Room 113, left Sink	Initial	10-JAN-2024	5.170	ug/L
51279	51279-1-113-S10	Main Building inside Room 113, left Sink	Initial	06-DEC-2023	6.820	ug/L
51279	51279-1-113-S11	Main Building inside Room 113, Right Sink	Flush	06-DEC-2023	2.110	ug/L
51279	51279-1-113-S11	Main Building inside Room 113, Right Sink	Flush	06-DEC-2023	2.640	ug/L
51279	51279-1-113-S11	Main Building inside Room 113, Right Sink	Flush	31-JAN-2024	1.000	ug/L
51279	51279-1-113-S11	Main Building inside Room 113, Right Sink	Flush	31-JAN-2024	1.000	ug/L
51279	51279-1-113-S11	Main Building inside Room 113, Right Sink	Flush	31-JAN-2024	1.000	ug/L
51279	51279-1-113-S11	Main Building inside Room 113, Right Sink	Flush	31-JAN-2024	1.000	ug/L
51279	51279-1-113-S11	Main Building inside Room 113, Right Sink	Flush	10-JAN-2024	2.490	ug/L
51279	51279-1-113-S11	Main Building inside Room 113, Right Sink	Flush	10-JAN-2024	2.010	ug/L
51279	51279-1-113-S11	Main Building inside Room 113, Right Sink	Flush	10-JAN-2024	2.070	ug/L
51279	51279-1-113-S11	Main Building inside Room 113, Right Sink	Flush	10-JAN-2024	2.270	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51279	51279-1-113-S11	Main Building inside Room 113, Right Sink	Flush	06-DEC-2023	2.160	ug/L
51279	51279-1-113-S11	Main Building inside Room 113, Right Sink	Flush	06-DEC-2023	2.030	ug/L
51279	51279-1-113-S11	Main Building inside Room 113, Right Sink	Initial	31-JAN-2024	1.190	ug/L
51279	51279-1-113-S11	Main Building inside Room 113, Right Sink	Initial	10-JAN-2024	14.000	ug/L
51279	51279-1-113-S11	Main Building inside Room 113, Right Sink	Initial	06-DEC-2023	8.750	ug/L
51279	51279-1-115-F01	Main Building inside Room 115, Fountain	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-115-F01	Main Building inside Room 115, Fountain	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-115-F01	Main Building inside Room 115, Fountain	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-115-F01	Main Building inside Room 115, Fountain	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-115-F01	Main Building inside Room 115, Fountain	Initial	06-DEC-2023	1.000	ug/L
51279	51279-1-HAL-WC03	Main Building, Corridor 1st Fl North, Fountain 1	Flush180	28-MAY-16	0.231	ppb
51279	51279-1-HAL-WC03	Main Building, Corridor 1st Fl North, Fountain 1	Flush180	28-MAY-16	1.000	ppb
51279	51279-1-HAL-WC03	Main Building, Corridor 1st Fl North, Fountain 1	Flush180	28-MAY-16	1.000	ppb
51279	51279-1-HAL-WC03	Main Building, Corridor 1st Fl North, Fountain 1	Flush180	28-MAY-16	1.000	ppb
51279	51279-1-HAL-WC03	Main Building, Corridor 1st Fl North, Fountain 1	Initial	28-MAY-16	1.000	ppb
51279	51279-1-HAL-WC04	Main Building, Corridor 1st Fl North, Fountain 2	Flush180	28-MAY-16	0.135	ppb
51279	51279-1-HAL-WC04	Main Building, Corridor 1st Fl North, Fountain 2	Flush180	28-MAY-16	1.000	ppb
51279	51279-1-HAL-WC04	Main Building, Corridor 1st Fl North, Fountain 2	Flush180	28-MAY-16	1.000	ppb
51279	51279-1-HAL-WC04	Main Building, Corridor 1st Fl North, Fountain 2	Flush180	28-MAY-16	0.141	ppb
51279	51279-1-HAL-WC04	Main Building, Corridor 1st Fl North, Fountain 2	Flush180	24-JUL-20	1.000	ug/L
51279	51279-1-HAL-WC04	Main Building, Corridor 1st Fl North, Fountain 2	Initial	28-MAY-16	0.177	ppb
51279	51279-1-HAL-WC04	Main Building, Corridor 1st Fl North, Fountain 2	Initial	24-JUL-20	1.000	ug/L
51279	51279-1-HAL-RBF02	Main Building, Corridor 1st Fl North, Retrofitted Bottle Filler	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-HAL-RBF02	Main Building, Corridor 1st Fl North, Retrofitted Bottle Filler	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-HAL-RBF02	Main Building, Corridor 1st Fl North, Retrofitted Bottle Filler	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-HAL-RBF02	Main Building, Corridor 1st Fl North, Retrofitted Bottle Filler	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-HAL-RBF02	Main Building, Corridor 1st Fl North, Retrofitted Bottle Filler	Initial	06-DEC-2023	1.000	ug/L
51279	51279-1-HAL-WC24	Main Building, Corridor 1st Fl South, Fountain	Flush180	28-MAY-16	1.000	ppb
51279	51279-1-HAL-WC24	Main Building, Corridor 1st Fl South, Fountain	Flush180	28-MAY-16	1.000	ppb
51279	51279-1-HAL-WC24	Main Building, Corridor 1st Fl South, Fountain	Flush180	28-MAY-16	1.000	ppb
51279	51279-1-HAL-WC24	Main Building, Corridor 1st Fl South, Fountain	Flush180	28-MAY-16	1.000	ppb
51279	51279-1-HAL-WC24	Main Building, Corridor 1st Fl South, Fountain	Initial	28-MAY-16	1.000	ppb
51279	51279-1-HAL-RBF01	Main Building, Corridor 1st Fl South, Retrofitted Bottle Filler	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-HAL-RBF01	Main Building, Corridor 1st Fl South, Retrofitted Bottle Filler	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-HAL-RBF01	Main Building, Corridor 1st Fl South, Retrofitted Bottle Filler	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-HAL-RBF01	Main Building, Corridor 1st Fl South, Retrofitted Bottle Filler	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-HAL-RBF01	Main Building, Corridor 1st Fl South, Retrofitted Bottle Filler	Initial	06-DEC-2023	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51279	51279-2-HAL-RBF01	Main Building, Corridor 2nd FL. North BF	Flush	06-DEC-2023	1.000	ug/L
51279	51279-2-HAL-RBF01	Main Building, Corridor 2nd FL. North BF	Flush	06-DEC-2023	1.000	ug/L
51279	51279-2-HAL-RBF01	Main Building, Corridor 2nd FL. North BF	Flush	06-DEC-2023	1.000	ug/L
51279	51279-2-HAL-RBF01	Main Building, Corridor 2nd FL. North BF	Flush	06-DEC-2023	1.000	ug/L
51279	51279-2-HAL-RBF01	Main Building, Corridor 2nd FL. North BF	Initial	06-DEC-2023	1.000	ug/L
51279	51279-2-HAL-RBF02	Main Building, Corridor 2nd FL. South BF	Flush	06-DEC-2023	1.000	ug/L
51279	51279-2-HAL-RBF02	Main Building, Corridor 2nd FL. South BF	Flush	06-DEC-2023	1.000	ug/L
51279	51279-2-HAL-RBF02	Main Building, Corridor 2nd FL. South BF	Flush	06-DEC-2023	1.000	ug/L
51279	51279-2-HAL-RBF02	Main Building, Corridor 2nd FL. South BF	Flush	06-DEC-2023	1.000	ug/L
51279	51279-2-HAL-RBF02	Main Building, Corridor 2nd FL. South BF	Initial	06-DEC-2023	1.000	ug/L
51279	51279-2-HAL-WC01	Main Building, Corridor 2nd Fl North, Fountain 1	Flush	06-DEC-2023	1.000	ug/L
51279	51279-2-HAL-WC01	Main Building, Corridor 2nd Fl North, Fountain 1	Flush	06-DEC-2023	1.000	ug/L
51279	51279-2-HAL-WC01	Main Building, Corridor 2nd Fl North, Fountain 1	Flush	06-DEC-2023	1.000	ug/L
51279	51279-2-HAL-WC01	Main Building, Corridor 2nd Fl North, Fountain 1	Flush	06-DEC-2023	1.000	ug/L
51279	51279-2-HAL-WC01	Main Building, Corridor 2nd Fl North, Fountain 1	Flush180	28-MAY-16	1.000	ppb
51279	51279-2-HAL-WC01	Main Building, Corridor 2nd Fl North, Fountain 1	Flush180	28-MAY-16	1.000	ppb
51279	51279-2-HAL-WC01	Main Building, Corridor 2nd Fl North, Fountain 1	Flush180	28-MAY-16	1.000	ppb
51279	51279-2-HAL-WC01	Main Building, Corridor 2nd Fl North, Fountain 1	Flush180	28-MAY-16	1.000	ppb
51279	51279-2-HAL-WC01	Main Building, Corridor 2nd Fl North, Fountain 1	Initial	28-MAY-16	1.000	ppb
51279	51279-2-HAL-WC01	Main Building, Corridor 2nd Fl North, Fountain 1	Initial	06-DEC-2023	1.000	ug/L
51279	51279-2-HAL-WC02	Main Building, Corridor 2nd Fl North, Fountain 2	Flush180	28-MAY-16	1.000	ppb
51279	51279-2-HAL-WC02	Main Building, Corridor 2nd Fl North, Fountain 2	Flush180	28-MAY-16	1.000	ppb
51279	51279-2-HAL-WC02	Main Building, Corridor 2nd Fl North, Fountain 2	Flush180	28-MAY-16	1.000	ppb
51279	51279-2-HAL-WC02	Main Building, Corridor 2nd Fl North, Fountain 2	Flush180	28-MAY-16	1.000	ppb
51279	51279-2-HAL-WC02	Main Building, Corridor 2nd Fl North, Fountain 2	Initial	28-MAY-16	1.000	ppb
51279	51279-2-HAL-WC03	Main Building, Corridor 2nd Fl South, Fountain	Flush180	28-MAY-16	1.000	ppb
51279	51279-2-HAL-WC03	Main Building, Corridor 2nd Fl South, Fountain	Flush180	28-MAY-16	0.368	ppb
51279	51279-2-HAL-WC03	Main Building, Corridor 2nd Fl South, Fountain	Flush180	28-MAY-16	1.000	ppb
51279	51279-2-HAL-WC03	Main Building, Corridor 2nd Fl South, Fountain	Flush180	28-MAY-16	1.000	ppb
51279	51279-2-HAL-WC03	Main Building, Corridor 2nd Fl South, Fountain	Initial	28-MAY-16	1.000	ppb
51279	51279-3-HAL-RBF02	Main Building, Corridor 3rd FL. North Bottle Filler	Flush	06-DEC-2023	1.000	ug/L
51279	51279-3-HAL-RBF02	Main Building, Corridor 3rd FL. North Bottle Filler	Flush	06-DEC-2023	1.000	ug/L
51279	51279-3-HAL-RBF02	Main Building, Corridor 3rd FL. North Bottle Filler	Flush	06-DEC-2023	1.000	ug/L
51279	51279-3-HAL-RBF02	Main Building, Corridor 3rd FL. North Bottle Filler	Flush	06-DEC-2023	1.000	ug/L
51279	51279-3-HAL-RBF02	Main Building, Corridor 3rd FL. North Bottle Filler	Initial	06-DEC-2023	1.000	ug/L
51279	51279-3-HAL-RBF01	Main Building, Corridor 3rd FL. South Bottle Filler	Flush	06-DEC-2023	1.000	ug/L
51279	51279-3-HAL-RBF01	Main Building, Corridor 3rd FL. South Bottle Filler	Flush	06-DEC-2023	1.000	ug/L
51279	51279-3-HAL-RBF01	Main Building, Corridor 3rd FL. South Bottle Filler	Flush	06-DEC-2023	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	RBF01	South Bottle Filler				
51279	51279-3-HAL-RBF01	Main Building, Corridor 3rd FL. South Bottle Filler	Flush	06-DEC-2023	1.000	ug/L
51279	51279-3-HAL-RBF01	Main Building, Corridor 3rd FL. South Bottle Filler	Initial	06-DEC-2023	1.000	ug/L
51279	51279-3-HAL-WC01	Main Building, Corridor 3rd Fl North, Fountain 1	Flush	06-DEC-2023	1.000	ug/L
51279	51279-3-HAL-WC01	Main Building, Corridor 3rd Fl North, Fountain 1	Flush	06-DEC-2023	1.000	ug/L
51279	51279-3-HAL-WC01	Main Building, Corridor 3rd Fl North, Fountain 1	Flush	06-DEC-2023	1.000	ug/L
51279	51279-3-HAL-WC01	Main Building, Corridor 3rd Fl North, Fountain 1	Flush	06-DEC-2023	1.000	ug/L
51279	51279-3-HAL-WC01	Main Building, Corridor 3rd Fl North, Fountain 1	Flush180	28-MAY-16	1.000	ppb
51279	51279-3-HAL-WC01	Main Building, Corridor 3rd Fl North, Fountain 1	Flush180	28-MAY-16	1.000	ppb
51279	51279-3-HAL-WC01	Main Building, Corridor 3rd Fl North, Fountain 1	Flush180	28-MAY-16	1.000	ppb
51279	51279-3-HAL-WC01	Main Building, Corridor 3rd Fl North, Fountain 1	Flush180	28-MAY-16	1.000	ppb
51279	51279-3-HAL-WC01	Main Building, Corridor 3rd Fl North, Fountain 1	Initial	28-MAY-16	1.000	ppb
51279	51279-3-HAL-WC01	Main Building, Corridor 3rd Fl North, Fountain 1	Initial	06-DEC-2023	1.000	ug/L
51279	51279-3-HAL-WC02	Main Building, Corridor 3rd Fl North, Fountain 2	Flush180	28-MAY-16	1.000	ppb
51279	51279-3-HAL-WC02	Main Building, Corridor 3rd Fl North, Fountain 2	Flush180	28-MAY-16	1.000	ppb
51279	51279-3-HAL-WC02	Main Building, Corridor 3rd Fl North, Fountain 2	Flush180	28-MAY-16	1.000	ppb
51279	51279-3-HAL-WC02	Main Building, Corridor 3rd Fl North, Fountain 2	Initial	28-MAY-16	1.000	ppb
51279	51279-3-HAL-WC03	Main Building, Corridor 3rd Fl South, Fountain	Flush180	28-MAY-16	0.140	ppb
51279	51279-3-HAL-WC03	Main Building, Corridor 3rd Fl South, Fountain	Flush180	28-MAY-16	0.174	ppb
51279	51279-3-HAL-WC03	Main Building, Corridor 3rd Fl South, Fountain	Flush180	28-MAY-16	0.141	ppb
51279	51279-3-HAL-WC03	Main Building, Corridor 3rd Fl South, Fountain	Flush180	28-MAY-16	0.161	ppb
51279	51279-3-HAL-WC03	Main Building, Corridor 3rd Fl South, Fountain	Flush180	24-JUL-20	1.000	ug/L
51279	51279-3-HAL-WC03	Main Building, Corridor 3rd Fl South, Fountain	Initial	28-MAY-16	0.153	ppb
51279	51279-3-HAL-WC03	Main Building, Corridor 3rd Fl South, Fountain	Initial	24-JUL-20	1.000	ug/L
51279	51279-1-107-S20	Main Building, Inside Romm 107, Sink 2 (Right)	Flush	31-JAN-2024	1.000	ug/L
51279	51279-1-107-S20	Main Building, Inside Romm 107, Sink 2 (Right)	Flush	31-JAN-2024	1.000	ug/L
51279	51279-1-107-S20	Main Building, Inside Romm 107, Sink 2 (Right)	Flush	31-JAN-2024	1.000	ug/L
51279	51279-1-107-S20	Main Building, Inside Romm 107, Sink 2 (Right)	Flush	31-JAN-2024	1.640	ug/L
51279	51279-1-107-S20	Main Building, Inside Romm 107, Sink 2 (Right)	Flush	06-DEC-2023	11.700	ug/L
51279	51279-1-107-S20	Main Building, Inside Romm 107, Sink 2 (Right)	Flush	06-DEC-2023	5.310	ug/L
51279	51279-1-107-S20	Main Building, Inside Romm 107, Sink 2 (Right)	Flush	06-DEC-2023	5.720	ug/L
51279	51279-1-107-S20	Main Building, Inside Romm 107, Sink 2 (Right)	Flush	06-DEC-2023	2.570	ug/L
51279	51279-1-107-S20	Main Building, Inside Romm 107, Sink 2 (Right)	Flush	10-JAN-2024	11.500	ug/L
51279	51279-1-107-S20	Main Building, Inside Romm 107, Sink 2 (Right)	Flush	10-JAN-2024	2.620	ug/L
51279	51279-1-107-S20	Main Building, Inside Romm 107, Sink 2 (Right)	Flush	10-JAN-2024	6.860	ug/L
51279	51279-1-107-S20	Main Building, Inside Romm 107, Sink 2 (Right)	Flush	10-JAN-2024	4.850	ug/L
51279	51279-1-107-	Main Building, Inside Romm 107,	Initial	31-JAN-2024	2.810	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S20	Sink 2 (Right)				
51279	51279-1-107-S20	Main Building, Inside Romm 107, Sink 2 (Right)	Initial	06-DEC-2023	54.500	ug/L
51279	51279-1-107-S20	Main Building, Inside Romm 107, Sink 2 (Right)	Initial	10-JAN-2024	59.900	ug/L
51279	51279-1-105-WC21	Main Building, Inside Room 105 next to toilet , Fo	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-105-WC21	Main Building, Inside Room 105 next to toilet , Fo	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-105-WC21	Main Building, Inside Room 105 next to toilet , Fo	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-105-WC21	Main Building, Inside Room 105 next to toilet , Fo	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-105-WC21	Main Building, Inside Room 105 next to toilet , Fo	Flush180	28-MAY-16	1.000	ppb
51279	51279-1-105-WC21	Main Building, Inside Room 105 next to toilet , Fo	Flush180	28-MAY-16	0.141	ppb
51279	51279-1-105-WC21	Main Building, Inside Room 105 next to toilet , Fo	Flush180	28-MAY-16	0.142	ppb
51279	51279-1-105-WC21	Main Building, Inside Room 105 next to toilet , Fo	Flush180	28-MAY-16	0.148	ppb
51279	51279-1-105-WC21	Main Building, Inside Room 105 next to toilet , Fo	Initial	28-MAY-16	0.141	ppb
51279	51279-1-105-WC21	Main Building, Inside Room 105 next to toilet , Fo	Initial	06-DEC-2023	1.000	ug/L
51279	51279-1-105-S22	Main Building, Inside Room 105, Sink 1	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-105-S22	Main Building, Inside Room 105, Sink 1	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-105-S22	Main Building, Inside Room 105, Sink 1	Flush	06-DEC-2023	1.540	ug/L
51279	51279-1-105-S22	Main Building, Inside Room 105, Sink 1	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-105-S22	Main Building, Inside Room 105, Sink 1	Flush180	28-MAY-16	3.960	ppb
51279	51279-1-105-S22	Main Building, Inside Room 105, Sink 1	Flush180	28-MAY-16	7.120	ppb
51279	51279-1-105-S22	Main Building, Inside Room 105, Sink 1	Flush180	28-MAY-16	2.810	ppb
51279	51279-1-105-S22	Main Building, Inside Room 105, Sink 1	Flush180	28-MAY-16	2.650	ppb
51279	51279-1-105-S22	Main Building, Inside Room 105, Sink 1	Flush180	15-JUL-16	0.254	ppb
51279	51279-1-105-S22	Main Building, Inside Room 105, Sink 1	Flush180	15-JUL-16	0.204	ppb
51279	51279-1-105-S22	Main Building, Inside Room 105, Sink 1	Flush180	15-JUL-16	0.227	ppb
51279	51279-1-105-S22	Main Building, Inside Room 105, Sink 1	Flush180	15-JUL-16	0.217	ppb
51279	51279-1-105-S22	Main Building, Inside Room 105, Sink 1	Flush180	27-OCT-16	0.266	ppb
51279	51279-1-105-S22	Main Building, Inside Room 105, Sink 1	Flush180	27-OCT-16	0.338	ppb
51279	51279-1-105-S22	Main Building, Inside Room 105, Sink 1	Flush180	27-OCT-16	0.379	ppb
51279	51279-1-105-S22	Main Building, Inside Room 105, Sink 1	Flush180	27-OCT-16	0.338	ppb
51279	51279-1-105-S22	Main Building, Inside Room 105, Sink 1	Initial	28-MAY-16	35.500	ppb
51279	51279-1-105-S22	Main Building, Inside Room 105, Sink 1	Initial	15-JUL-16	1.420	ppb
51279	51279-1-105-S22	Main Building, Inside Room 105, Sink 1	Initial	27-OCT-16	2.140	ppb
51279	51279-1-105-S22	Main Building, Inside Room 105, Sink 1	Initial	06-DEC-2023	1.000	ug/L
51279	51279-1-105-S23	Main Building, Inside Room 105, Sink 2	Flush	06-DEC-2023	1.150	ug/L
51279	51279-1-105-S23	Main Building, Inside Room 105, Sink 2	Flush	06-DEC-2023	1.430	ug/L
51279	51279-1-105-S23	Main Building, Inside Room 105, Sink 2	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-105-S23	Main Building, Inside Room 105, Sink 2	Flush	06-DEC-2023	1.420	ug/L
51279	51279-1-105-S23	Main Building, Inside Room 105, Sink 2	Flush180	28-MAY-16	0.992	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51279	51279-1-105-S23	Main Building, Inside Room 105, Sink 2	Flush180	28-MAY-16	1.060	ppb
51279	51279-1-105-S23	Main Building, Inside Room 105, Sink 2	Flush180	28-MAY-16	0.870	ppb
51279	51279-1-105-S23	Main Building, Inside Room 105, Sink 2	Flush180	28-MAY-16	0.623	ppb
51279	51279-1-105-S23	Main Building, Inside Room 105, Sink 2	Initial	28-MAY-16	1.150	ppb
51279	51279-1-105-S23	Main Building, Inside Room 105, Sink 2	Initial	06-DEC-2023	2.760	ug/L
51279	51279-1-107-WC18	Main Building, Inside Room 107 next to toilet, Fou	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-107-WC18	Main Building, Inside Room 107 next to toilet, Fou	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-107-WC18	Main Building, Inside Room 107 next to toilet, Fou	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-107-WC18	Main Building, Inside Room 107 next to toilet, Fou	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-107-WC18	Main Building, Inside Room 107 next to toilet, Fou	Flush180	28-MAY-16	1.000	ppb
51279	51279-1-107-WC18	Main Building, Inside Room 107 next to toilet, Fou	Flush180	28-MAY-16	1.000	ppb
51279	51279-1-107-WC18	Main Building, Inside Room 107 next to toilet, Fou	Flush180	28-MAY-16	1.000	ppb
51279	51279-1-107-WC18	Main Building, Inside Room 107 next to toilet, Fou	Flush180	28-MAY-16	1.000	ppb
51279	51279-1-107-WC18	Main Building, Inside Room 107 next to toilet, Fou	Initial	28-MAY-16	0.129	ppb
51279	51279-1-107-WC18	Main Building, Inside Room 107 next to toilet, Fou	Initial	06-DEC-2023	1.000	ug/L
51279	51279-1-107-S20	Main Building, Inside Room 107, Sink 2	Flush180	28-MAY-16	1.800	ppb
51279	51279-1-107-S20	Main Building, Inside Room 107, Sink 2	Flush180	28-MAY-16	2.290	ppb
51279	51279-1-107-S20	Main Building, Inside Room 107, Sink 2	Flush180	28-MAY-16	1.790	ppb
51279	51279-1-107-S20	Main Building, Inside Room 107, Sink 2	Flush180	28-MAY-16	1.650	ppb
51279	51279-1-107-S20	Main Building, Inside Room 107, Sink 2	Initial	28-MAY-16	1.740	ppb
51279	51279-1-109-WC15	Main Building, Inside Room 109 next to toilet, Fou	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-109-WC15	Main Building, Inside Room 109 next to toilet, Fou	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-109-WC15	Main Building, Inside Room 109 next to toilet, Fou	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-109-WC15	Main Building, Inside Room 109 next to toilet, Fou	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-109-WC15	Main Building, Inside Room 109 next to toilet, Fou	Flush180	28-MAY-16	1.000	ppb
51279	51279-1-109-WC15	Main Building, Inside Room 109 next to toilet, Fou	Flush180	28-MAY-16	0.365	ppb
51279	51279-1-109-WC15	Main Building, Inside Room 109 next to toilet, Fou	Flush180	28-MAY-16	1.000	ppb
51279	51279-1-109-WC15	Main Building, Inside Room 109 next to toilet, Fou	Flush180	28-MAY-16	1.000	ppb
51279	51279-1-109-WC15	Main Building, Inside Room 109 next to toilet, Fou	Initial	28-MAY-16	0.143	ppb
51279	51279-1-109-WC15	Main Building, Inside Room 109 next to toilet, Fou	Initial	06-DEC-2023	1.000	ug/L
51279	51279-1-109-S16	Main Building, Inside Room 109, Sink 1	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-109-S16	Main Building, Inside Room 109, Sink 1	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-109-S16	Main Building, Inside Room 109, Sink 1	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-109-S16	Main Building, Inside Room 109, Sink 1	Flush180	28-MAY-16	1.480	ppb
51279	51279-1-109-S16	Main Building, Inside Room 109, Sink 1	Flush180	28-MAY-16	1.910	ppb
51279	51279-1-109-S16	Main Building, Inside Room 109, Sink 1	Flush180	28-MAY-16	1.640	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51279	51279-1-109-S16	Main Building, Inside Room 109, Sink 1	Flush180	28-MAY-16	1.990	ppb
51279	51279-1-109-S16	Main Building, Inside Room 109, Sink 1	Initial	28-MAY-16	5.270	ppb
51279	51279-1-109-S16	Main Building, Inside Room 109, Sink 1	Initial	06-DEC-2023	1.000	ug/L
51279	51279-1-111-WC12	Main Building, Inside Room 111 next to toilet, Fou	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-111-WC12	Main Building, Inside Room 111 next to toilet, Fou	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-111-WC12	Main Building, Inside Room 111 next to toilet, Fou	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-111-WC12	Main Building, Inside Room 111 next to toilet, Fou	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-111-WC12	Main Building, Inside Room 111 next to toilet, Fou	Flush180	28-MAY-16	0.138	ppb
51279	51279-1-111-WC12	Main Building, Inside Room 111 next to toilet, Fou	Flush180	28-MAY-16	0.144	ppb
51279	51279-1-111-WC12	Main Building, Inside Room 111 next to toilet, Fou	Flush180	28-MAY-16	0.137	ppb
51279	51279-1-111-WC12	Main Building, Inside Room 111 next to toilet, Fou	Flush180	28-MAY-16	0.154	ppb
51279	51279-1-111-WC12	Main Building, Inside Room 111 next to toilet, Fou	Initial	28-MAY-16	0.128	ppb
51279	51279-1-111-WC12	Main Building, Inside Room 111 next to toilet, Fou	Initial	06-DEC-2023	1.000	ug/L
51279	51279-1-111-S13	Main Building, Inside Room 111, Sink 1	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-111-S13	Main Building, Inside Room 111, Sink 1	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-111-S13	Main Building, Inside Room 111, Sink 1	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-111-S13	Main Building, Inside Room 111, Sink 1	Flush180	28-MAY-16	1.440	ppb
51279	51279-1-111-S13	Main Building, Inside Room 111, Sink 1	Flush180	28-MAY-16	1.020	ppb
51279	51279-1-111-S13	Main Building, Inside Room 111, Sink 1	Flush180	28-MAY-16	1.340	ppb
51279	51279-1-111-S13	Main Building, Inside Room 111, Sink 1	Flush180	28-MAY-16	2.360	ppb
51279	51279-1-111-S13	Main Building, Inside Room 111, Sink 1	Initial	28-MAY-16	0.533	ppb
51279	51279-1-111-S13	Main Building, Inside Room 111, Sink 1	Initial	06-DEC-2023	1.000	ug/L
51279	51279-1-111-S14	Main Building, Inside Room 111, Sink 2	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-111-S14	Main Building, Inside Room 111, Sink 2	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-111-S14	Main Building, Inside Room 111, Sink 2	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-111-S14	Main Building, Inside Room 111, Sink 2	Flush180	28-MAY-16	2.690	ppb
51279	51279-1-111-S14	Main Building, Inside Room 111, Sink 2	Flush180	28-MAY-16	2.400	ppb
51279	51279-1-111-S14	Main Building, Inside Room 111, Sink 2	Flush180	28-MAY-16	1.050	ppb
51279	51279-1-111-S14	Main Building, Inside Room 111, Sink 2	Flush180	28-MAY-16	1.550	ppb
51279	51279-1-111-S14	Main Building, Inside Room 111, Sink 2	Initial	28-MAY-16	6.790	ppb
51279	51279-1-111-S14	Main Building, Inside Room 111, Sink 2	Initial	06-DEC-2023	1.000	ug/L
51279	51279-1-113-WC09	Main Building, Inside Room 113, Fountain	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-113-WC09	Main Building, Inside Room 113, Fountain	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-113-WC09	Main Building, Inside Room 113, Fountain	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-113-WC09	Main Building, Inside Room 113, Fountain	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-113-	Main Building, Inside Room 113,	Flush180	28-MAY-16	0.631	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	WC09	Fountain				
51279	51279-1-113-WC09	Main Building, Inside Room 113, Fountain	Flush180	28-MAY-16	0.630	ppb
51279	51279-1-113-WC09	Main Building, Inside Room 113, Fountain	Flush180	28-MAY-16	0.666	ppb
51279	51279-1-113-WC09	Main Building, Inside Room 113, Fountain	Flush180	28-MAY-16	0.655	ppb
51279	51279-1-113-WC09	Main Building, Inside Room 113, Fountain	Initial	28-MAY-16	0.413	ppb
51279	51279-1-113-WC09	Main Building, Inside Room 113, Fountain	Initial	06-DEC-2023	1.000	ug/L
51279	51279-1-113-S10	Main Building, Inside Room 113, Sink 1	Flush180	28-MAY-16	0.373	ppb
51279	51279-1-113-S10	Main Building, Inside Room 113, Sink 1	Flush180	28-MAY-16	0.329	ppb
51279	51279-1-113-S10	Main Building, Inside Room 113, Sink 1	Flush180	28-MAY-16	1.070	ppb
51279	51279-1-113-S10	Main Building, Inside Room 113, Sink 1	Flush180	28-MAY-16	1.050	ppb
51279	51279-1-113-S10	Main Building, Inside Room 113, Sink 1	Initial	28-MAY-16	1.210	ppb
51279	51279-1-113-S11	Main Building, Inside Room 113, Sink 2	Flush180	28-MAY-16	1.600	ppb
51279	51279-1-113-S11	Main Building, Inside Room 113, Sink 2	Flush180	28-MAY-16	0.906	ppb
51279	51279-1-113-S11	Main Building, Inside Room 113, Sink 2	Flush180	28-MAY-16	1.140	ppb
51279	51279-1-113-S11	Main Building, Inside Room 113, Sink 2	Flush180	28-MAY-16	1.750	ppb
51279	51279-1-113-S11	Main Building, Inside Room 113, Sink 2	Initial	28-MAY-16	5.430	ppb
51279	51279-1-115-S06	Main Building, Inside Room 115, Sink 1	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-115-S06	Main Building, Inside Room 115, Sink 1	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-115-S06	Main Building, Inside Room 115, Sink 1	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-115-S06	Main Building, Inside Room 115, Sink 1	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-115-S06	Main Building, Inside Room 115, Sink 1	Flush180	28-MAY-16	1.400	ppb
51279	51279-1-115-S06	Main Building, Inside Room 115, Sink 1	Flush180	28-MAY-16	1.060	ppb
51279	51279-1-115-S06	Main Building, Inside Room 115, Sink 1	Flush180	28-MAY-16	1.150	ppb
51279	51279-1-115-S06-0051279-1-115-S06	Main Building, Inside Room 115, Sink 1	Flush180	28-MAY-16	1.220	ppb
51279	51279-1-115-S06	Main Building, Inside Room 115, Sink 1	Initial	28-MAY-16	1.780	ppb
51279	51279-1-115-S06	Main Building, Inside Room 115, Sink 1	Initial	06-DEC-2023	1.180	ug/L
51279	51279-1-115-S07	Main Building, Inside Room 115, Sink 2	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-115-S07	Main Building, Inside Room 115, Sink 2	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-115-S07	Main Building, Inside Room 115, Sink 2	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-115-S07	Main Building, Inside Room 115, Sink 2	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-115-S07	Main Building, Inside Room 115, Sink 2	Flush180	28-MAY-16	1.960	ppb
51279	51279-1-115-S07	Main Building, Inside Room 115, Sink 2	Flush180	28-MAY-16	2.900	ppb
51279	51279-1-115-S07	Main Building, Inside Room 115, Sink 2	Flush180	28-MAY-16	1.770	ppb
51279	51279-1-115-S07	Main Building, Inside Room 115, Sink 2	Flush180	28-MAY-16	1.860	ppb
51279	51279-1-115-S07	Main Building, Inside Room 115, Sink 2	Initial	28-MAY-16	2.810	ppb
51279	51279-1-115-S07	Main Building, Inside Room 115, Sink 2	Initial	06-DEC-2023	1.000	ug/L
51279	51279-1-116-S08	Main Building, Inside Room 116 next to toilet, Sin	Flush	06-DEC-2023	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51279	51279-1-116-S08	Main Building, Inside Room 116 next to toilet, Sin	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-116-S08	Main Building, Inside Room 116 next to toilet, Sin	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-116-S08	Main Building, Inside Room 116 next to toilet, Sin	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-116-S08	Main Building, Inside Room 116 next to toilet, Sin	Flush180	28-MAY-16	0.537	ppb
51279	51279-1-116-S08	Main Building, Inside Room 116 next to toilet, Sin	Flush180	28-MAY-16	0.824	ppb
51279	51279-1-116-S08	Main Building, Inside Room 116 next to toilet, Sin	Flush180	28-MAY-16	0.615	ppb
51279	51279-1-116-S08	Main Building, Inside Room 116 next to toilet, Sin	Flush180	28-MAY-16	1.260	ppb
51279	51279-1-116-S08	Main Building, Inside Room 116 next to toilet, Sin	Initial	28-MAY-16	0.467	ppb
51279	51279-1-116-S08	Main Building, Inside Room 116 next to toilet, Sin	Initial	06-DEC-2023	1.000	ug/L
51279	51279-1-155-WC05	Main Building, Inside Room 155 next to toilet , Fo	Flush180	28-MAY-16	0.525	ppb
51279	51279-1-155-WC05	Main Building, Inside Room 155 next to toilet , Fo	Flush180	28-MAY-16	0.515	ppb
51279	51279-1-155-WC05	Main Building, Inside Room 155 next to toilet , Fo	Flush180	28-MAY-16	0.447	ppb
51279	51279-1-155-WC05	Main Building, Inside Room 155 next to toilet , Fo	Flush180	28-MAY-16	0.420	ppb
51279	51279-1-155-WC05	Main Building, Inside Room 155 next to toilet , Fo	Initial	28-MAY-16	0.176	ppb
51279	51279-1-109-S17	Main Building, Inside Roomv109, Sink 2	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-109-S17	Main Building, Inside Roomv109, Sink 2	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-109-S17	Main Building, Inside Roomv109, Sink 2	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-109-S17	Main Building, Inside Roomv109, Sink 2	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-109-S17	Main Building, Inside Roomv109, Sink 2	Flush180	28-MAY-16	0.249	ppb
51279	51279-1-109-S17	Main Building, Inside Roomv109, Sink 2	Flush180	28-MAY-16	0.277	ppb
51279	51279-1-109-S17	Main Building, Inside Roomv109, Sink 2	Flush180	28-MAY-16	0.167	ppb
51279	51279-1-109-S17	Main Building, Inside Roomv109, Sink 2	Flush180	28-MAY-16	0.284	ppb
51279	51279-1-109-S17	Main Building, Inside Roomv109, Sink 2	Initial	28-MAY-16	0.564	ppb
51279	51279-1-109-S17	Main Building, Inside Roomv109, Sink 2	Initial	06-DEC-2023	1.010	ug/L
51279	51279-1-107-S19	Main Building, Inside Room 107, Sink 1	Flush	06-DEC-2023	2.180	ug/L
51279	51279-1-107-S19	Main Building, Inside Room 107, Sink 1	Flush	06-DEC-2023	2.670	ug/L
51279	51279-1-107-S19	Main Building, Inside Room 107, Sink 1	Flush	06-DEC-2023	3.670	ug/L
51279	51279-1-107-S19	Main Building, Inside Room 107, Sink 1	Flush	06-DEC-2023	3.470	ug/L
51279	51279-1-107-S19	Main Building, Inside Room 107, Sink 1	Flush180	28-MAY-16	1.290	ppb
51279	51279-1-107-S19	Main Building, Inside Room 107, Sink 1	Flush180	28-MAY-16	1.080	ppb
51279	51279-1-107-S19	Main Building, Inside Room 107, Sink 1	Flush180	28-MAY-16	1.000	ppb
51279	51279-1-107-S19	Main Building, Inside Room 107, Sink 1	Flush180	28-MAY-16	1.580	ppb
51279	51279-1-107-S19	Main Building, Inside Room 107, Sink 1	Initial	28-MAY-16	6.120	ppb
51279	51279-1-107-S19	Main Building, Inside Room 107, Sink 1	Initial	06-DEC-2023	1.000	ug/L
51279	51279-1-KIT-KS03	Main Building, Kitchen North Wall Left Sink	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-KIT-KS03	Main Building, Kitchen North Wall Left Sink	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-KIT-KS03	Main Building, Kitchen North Wall Left Sink	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-KIT-	Main Building, Kitchen North Wall	Flush	06-DEC-2023	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS03	Left Sink				
51279	51279-1-KIT-KS03	Main Building, Kitchen North Wall Left Sink	Initial	06-DEC-2023	1.000	ug/L
51279	51279-1-KIT-KS04	Main Building, Kitchen North Wall Right Sink	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-KIT-KS04	Main Building, Kitchen North Wall Right Sink	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-KIT-KS04	Main Building, Kitchen North Wall Right Sink	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-KIT-KS04	Main Building, Kitchen North Wall Right Sink	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-KIT-KS04	Main Building, Kitchen North Wall Right Sink	Initial	06-DEC-2023	1.000	ug/L
51279	51279-1-KIT-KS02	Main Building, Kitchen Sink East, Sink 2	Flush180	28-MAY-16	0.153	ppb
51279	51279-1-KIT-KS02	Main Building, Kitchen Sink East, Sink 2	Flush180	28-MAY-16	0.358	ppb
51279	51279-1-KIT-KS02	Main Building, Kitchen Sink East, Sink 2	Flush180	28-MAY-16	1.130	ppb
51279	51279-1-KIT-KS02	Main Building, Kitchen Sink East, Sink 2	Flush180	28-MAY-16	0.345	ppb
51279	51279-1-KIT-KS02	Main Building, Kitchen Sink East, Sink 2	Initial	28-MAY-16	0.125	ppb
51279	51279-1-KIT-KS01	Main Building, Kitchen Sink West, Sink 1	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-KIT-KS01	Main Building, Kitchen Sink West, Sink 1	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-KIT-KS01	Main Building, Kitchen Sink West, Sink 1	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-KIT-KS01	Main Building, Kitchen Sink West, Sink 1	Flush	06-DEC-2023	1.000	ug/L
51279	51279-1-KIT-KS01	Main Building, Kitchen Sink West, Sink 1	Flush180	28-MAY-16	1.000	ppb
51279	51279-1-KIT-KS01	Main Building, Kitchen Sink West, Sink 1	Flush180	28-MAY-16	1.000	ppb
51279	51279-1-KIT-KS01	Main Building, Kitchen Sink West, Sink 1	Flush180	28-MAY-16	0.134	ppb
51279	51279-1-KIT-KS01	Main Building, Kitchen Sink West, Sink 1	Flush180	28-MAY-16	1.000	ppb
51279	51279-1-KIT-KS01	Main Building, Kitchen Sink West, Sink 1	Initial	28-MAY-16	0.190	ppb
51279	51279-1-KIT-KS01	Main Building, Kitchen Sink West, Sink 1	Initial	06-DEC-2023	1.000	ug/L
51279	59886-1-HAL-RBF02	Pre-K Building, 1st Floor Hallway Across Rm 504, Bottle Filler	Flush	06-DEC-2023	1.000	ug/L
51279	59886-1-HAL-RBF02	Pre-K Building, 1st Floor Hallway Across Rm 504, Bottle Filler	Flush	06-DEC-2023	1.000	ug/L
51279	59886-1-HAL-RBF02	Pre-K Building, 1st Floor Hallway Across Rm 504, Bottle Filler	Flush	06-DEC-2023	1.000	ug/L
51279	59886-1-HAL-RBF02	Pre-K Building, 1st Floor Hallway Across Rm 504, Bottle Filler	Flush	06-DEC-2023	1.000	ug/L
51279	59886-1-HAL-RBF02	Pre-K Building, 1st Floor Hallway Across Rm 504, Bottle Filler	Initial	06-DEC-2023	1.000	ug/L
51279	59886-1-HAL-RBF01	Pre-K Building, 1st Floor Hallway by Exit, Bottle Filler	Flush	06-DEC-2023	1.000	ug/L
51279	59886-1-HAL-RBF01	Pre-K Building, 1st Floor Hallway by Exit, Bottle Filler	Flush	06-DEC-2023	1.000	ug/L
51279	59886-1-HAL-RBF01	Pre-K Building, 1st Floor Hallway by Exit, Bottle Filler	Flush	06-DEC-2023	1.000	ug/L
51279	59886-1-HAL-RBF01	Pre-K Building, 1st Floor Hallway by Exit, Bottle Filler	Initial	06-DEC-2023	1.000	ug/L
55259	55259-1-HAL-F02	1st floor Corridor	Flush180	21-JUN-16	1.000	ppb
55259	55259-1-HAL-F02	1st floor Corridor	Flush180	21-JUN-16	1.000	ppb
55259	55259-1-HAL-F02	1st floor Corridor	Flush180	21-JUN-16	1.000	ppb
55259	55259-1-HAL-F01	1st floor Corridor	Flush180	21-JUN-16	1.000	ppb
55259	55259-1-HAL-F01	1st floor Corridor	Flush180	21-JUN-16	1.000	ppb
55259	55259-1-HAL-F01	1st floor Corridor	Flush180	21-JUN-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01					
55259	55259-1-HAL-F01	1st floor Corridor	Flush180	21-JUN-16	1.000	ppb
55259	55259-1-HAL-F02	1st floor Corridor	Flush180	21-JUN-16	1.000	ppb
55259	55259-1-HAL-F03	1st floor Corridor	Flush180	21-JUN-16	1.000	ppb
55259	55259-1-HAL-F03	1st floor Corridor	Flush180	21-JUN-16	1.000	ppb
55259	55259-1-HAL-F03	1st floor Corridor	Flush180	21-JUN-16	1.000	ppb
55259	55259-1-HAL-F02	1st floor Corridor	Flush180	21-JUN-16	1.000	ppb
55259	55259-1-HAL-F03	1st floor Corridor	Flush180	21-JUN-16	1.000	ppb
55259	55259-1-HAL-F03	1st floor Corridor	Flush180	21-JUN-16	1.000	ppb
55259	55259-1-HAL-F02	1st floor Corridor	Flush180	24-JUL-20	1.000	ug/L
55259	55259-1-HAL-F01	1st floor Corridor	Initial	21-JUN-16	1.000	ppb
55259	55259-1-HAL-F02	1st floor Corridor	Initial	24-JUL-20	1.000	ug/L
55259	55259-1-HAL-F02	1st floor Corridor, Annex #1, Fountain	Flush	06-DEC-2023	1.000	ug/L
55259	55259-1-HAL-F02	1st floor Corridor, Annex #1, Fountain	Flush	06-DEC-2023	1.000	ug/L
55259	55259-1-HAL-F02	1st floor Corridor, Annex #1, Fountain	Flush	06-DEC-2023	1.000	ug/L
55259	55259-1-HAL-F02	1st floor Corridor, Annex #1, Fountain	Flush	06-DEC-2023	1.000	ug/L
55259	55259-1-HAL-F02	1st floor Corridor, Annex #1, Fountain	Initial	06-DEC-2023	1.000	ug/L
59216	59216-1-HAL-F01	1st Floor Corridor	Flush180	21-JUN-16	1.000	ppb
59216	59216-1-HAL-F01	1st Floor Corridor	Flush180	21-JUN-16	1.000	ppb
59216	59216-1-HAL-F01	1st Floor Corridor	Flush180	21-JUN-16	1.000	ppb
59216	59216-1-HAL-F01	1st Floor Corridor	Flush180	21-JUN-16	1.000	ppb
59216	59216-1-HAL-F02	1st Floor Corridor	Flush180	21-JUN-16	1.000	ppb
59216	59216-1-HAL-F02	1st Floor Corridor	Flush180	21-JUN-16	1.000	ppb
59216	59216-1-HAL-F02	1st Floor Corridor	Flush180	21-JUN-16	1.000	ppb
59216	59216-1-HAL-F02	1st Floor Corridor	Flush180	21-JUN-16	1.000	ppb
59216	59216-1-HAL-F02	1st Floor Corridor	Flush180	24-JUL-20	1.000	ug/L
59216	59216-1-HAL-F01	1st Floor Corridor	Initial	21-JUN-16	1.000	ppb
59216	59216-1-HAL-F02	1st Floor Corridor	Initial	24-JUL-20	1.000	ug/L
59216	59216-1-HAL-RFB01	Annex building Hallway	Flush	06-DEC-2023	1.000	ug/L
59216	59216-1-HAL-RFB01	Annex building Hallway	Flush	06-DEC-2023	1.000	ug/L
59216	59216-1-HAL-RFB01	Annex building Hallway	Flush	06-DEC-2023	1.000	ug/L
59216	59216-1-HAL-RFB01	Annex building Hallway	Flush	06-DEC-2023	1.000	ug/L
59216	59216-1-HAL-RFB01	Annex building Hallway	Initial	06-DEC-2023	1.000	ug/L
59216	59216-1-HAL-F01	Annex building Hallway	Flush	06-DEC-2023	1.000	ug/L
59216	59216-1-HAL-	Annex building Hallway	Flush	06-DEC-2023	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01					
59216	59216-1-HAL-F01	Annex building Hallway	Flush	06-DEC-2023	1.000	ug/L
59216	59216-1-HAL-F01	Annex building Hallway	Flush	06-DEC-2023	1.000	ug/L
59216	59216-1-HAL-F01	Annex building Hallway	Initial	06-DEC-2023	1.000	ug/L
59886	59886-1-HAL-F01	1st Floor Corridor, Annex #2 Bottle Filler	Flush	06-DEC-2023	1.000	ug/L
59886	59886-1-HAL-F01	1st Floor Corridor, Annex #2 Bottle Filler	Flush	06-DEC-2023	1.000	ug/L
59886	59886-1-HAL-F01	1st Floor Corridor, Annex #2 Bottle Filler	Flush	06-DEC-2023	1.000	ug/L
59886	59886-1-HAL-F01	1st Floor Corridor, Annex #2 Bottle Filler	Flush	06-DEC-2023	1.000	ug/L
59886	59886-1-HAL-F01	1st Floor Corridor, Annex #2 Bottle Filler	Initial	06-DEC-2023	1.000	ug/L
59886	59886-1-HAL-F02	1st Floor Corridor, Annex #2 Fountain	Flush	06-DEC-2023	1.000	ug/L
59886	59886-1-HAL-F02	1st Floor Corridor, Annex #2 Fountain	Flush	06-DEC-2023	1.000	ug/L
59886	59886-1-HAL-F02	1st Floor Corridor, Annex #2 Fountain	Flush	06-DEC-2023	1.000	ug/L
59886	59886-1-HAL-F02	1st Floor Corridor, Annex #2 Fountain	Flush	06-DEC-2023	1.000	ug/L
59886	59886-1-HAL-F02	1st Floor Corridor, Annex #2 Fountain	Initial	06-DEC-2023	1.000	ug/L
59886	59886-1-HAL-F01	1st Floor Hallway by Exit	Flush180	21-JUN-16	1.000	ppb
59886	59886-1-HAL-F01	1st Floor Hallway by Exit	Flush180	21-JUN-16	1.000	ppb
59886	59886-1-HAL-F01	1st Floor Hallway by Exit	Flush180	21-JUN-16	1.000	ppb
59886	59886-1-HAL-F01	1st Floor Hallway by Exit	Flush180	21-JUN-16	1.000	ppb
59886	59886-1-HAL-F02	1st Floor Hallway by Exit	Flush180	21-JUN-16	1.000	ppb
59886	59886-1-HAL-F02	1st Floor Hallway by Exit	Flush180	21-JUN-16	1.000	ppb
59886	59886-1-HAL-F02	1st Floor Hallway by Exit	Flush180	21-JUN-16	1.000	ppb
59886	59886-1-HAL-F02	1st Floor Hallway by Exit	Flush180	21-JUN-16	1.000	ppb
59886	59886-1-HAL-F02	1st Floor Hallway by Exit	Flush180	21-JUN-16	1.000	ppb
59886	59886-1-HAL-F02	1st Floor Hallway by Exit	Flush180	21-JUN-16	1.000	ppb
59886	59886-1-HAL-F03	1st Floor Hallway by Exit	Flush180	21-JUN-16	1.000	ppb
59886	59886-1-HAL-F03	1st Floor Hallway by Exit	Flush180	21-JUN-16	1.000	ppb
59886	59886-1-HAL-F03	1st Floor Hallway by Exit	Flush180	21-JUN-16	1.000	ppb
59886	59886-1-HAL-F03	1st Floor Hallway by Exit	Flush180	21-JUN-16	1.000	ppb
59886	59886-1-HAL-F03	1st Floor Hallway by Exit	Flush180	24-JUL-20	1.000	ug/L
59886	59886-1-HAL-F01	1st Floor Hallway by Exit	Initial	21-JUN-16	1.000	ppb
59886	59886-1-HAL-F03	1st Floor Hallway by Exit	Initial	24-JUL-20	1.000	ug/L
59886	59886-1-500-S01	Pre-K Building, Rm 500 Sink	Flush	06-DEC-2023	1.000	ug/L
59886	59886-1-500-S01	Pre-K Building, Rm 500 Sink	Flush	06-DEC-2023	1.000	ug/L
59886	59886-1-500-S01	Pre-K Building, Rm 500 Sink	Flush	06-DEC-2023	1.000	ug/L
59886	59886-1-500-S01	Pre-K Building, Rm 500 Sink	Flush	06-DEC-2023	1.000	ug/L
59886	59886-1-500-S01	Pre-K Building, Rm 500 Sink	Initial	06-DEC-2023	1.000	ug/L
59886	59881-1-502-S01	Pre-K Building, Rm 502 Sink	Flush	06-DEC-2023	1.000	ug/L
59886	59881-1-502-S01	Pre-K Building, Rm 502 Sink	Flush	06-DEC-2023	1.000	ug/L

**Water Quality Assessment
Columbia Explorers Elementary Academy**

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S01					
59886	59881-1-502-S01	Pre-K Building, Rm 502 Sink	Flush	06-DEC-2023	1.000	ug/L
59886	59881-1-502-S01	Pre-K Building, Rm 502 Sink	Flush	06-DEC-2023	1.000	ug/L
59886	59881-1-502-S01	Pre-K Building, Rm 502 Sink	Initial	06-DEC-2023	1.000	ug/L
59886	59881-1-504-S01	Pre-K Building, Rm 504 Sink	Flush	06-DEC-2023	1.000	ug/L
59886	59881-1-504-S01	Pre-K Building, Rm 504 Sink	Flush	06-DEC-2023	1.000	ug/L
59886	59881-1-504-S01	Pre-K Building, Rm 504 Sink	Flush	06-DEC-2023	1.000	ug/L
59886	59881-1-504-S01	Pre-K Building, Rm 504 Sink	Initial	06-DEC-2023	1.000	ug/L
59886	59886-1-505-S01	Pre-K Building, Rm 505 Sink	Flush	06-DEC-2023	1.000	ug/L
59886	59886-1-505-S01	Pre-K Building, Rm 505 Sink	Flush	06-DEC-2023	1.000	ug/L
59886	59886-1-505-S01	Pre-K Building, Rm 505 Sink	Flush	06-DEC-2023	1.000	ug/L
59886	59886-1-505-S01	Pre-K Building, Rm 505 Sink	Initial	06-DEC-2023	1.000	ug/L
59886	59886-1-HAL-F08	Second building in strip, Hallway fountain	Flush180	24-JUL-20	1.000	ug/L
59886	59886-1-HAL-F08	Second building in strip, Hallway fountain	Initial	24-JUL-20	1.000	ug/L