



Sep 10, 2024

COOK

8150 S BISHOP ST, Chicago IL 60620.

Dear **COOK** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

COOK

8150 S BISHOP ST, Chicago IL 60620.

Estimadas familias de **COOK**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarle y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51428	51428-1-HAL-F07	Main- Across From Room 106, Left Fountain	Flush180	16-JUN-16	0.970	ppb
51428	51428-1-HAL-F07	Main- Across From Room 106, Left Fountain	Flush180	16-JUN-16	0.907	ppb
51428	51428-1-HAL-F07	Main- Across From Room 106, Left Fountain	Flush180	16-JUN-16	1.220	ppb
51428	51428-1-HAL-F07	Main- Across From Room 106, Left Fountain	Flush180	16-JUN-16	0.934	ppb
51428	51428-1-HAL-F07	Main- Across From Room 106, Left Fountain	Flush180	04-AUG-20	1.140	ug/L
51428	51428-1-HAL-F07	Main- Across From Room 106, Left Fountain	Flush180	29-OCT-20	1.470	ug/L
51428	51428-1-HAL-F07	Main- Across From Room 106, Left Fountain	Flush180	29-OCT-20	1.450	ug/L
51428	51428-1-HAL-F07	Main- Across From Room 106, Left Fountain	Flush180	29-OCT-20	1.490	ug/L
51428	51428-1-HAL-F07	Main- Across From Room 106, Left Fountain	Flush180	29-OCT-20	1.480	ug/L
51428	51428-1-HAL-F07	Main- Across From Room 106, Left Fountain	Flush180	11-SEP-20	3.500	ug/L
51428	51428-1-HAL-F07	Main- Across From Room 106, Left Fountain	Flush180	21-JAN-22	2.150	ug/L
51428	51428-1-HAL-F07	Main- Across From Room 106, Left Fountain	Flush180	21-JAN-22	2.130	ug/L
51428	51428-1-HAL-F07	Main- Across From Room 106, Left Fountain	Flush180	21-JAN-22	3.190	ug/L
51428	51428-1-HAL-F07	Main- Across From Room 106, Left Fountain	Flush180	21-JAN-22	2.400	ug/L
51428	51428-1-HAL-F07	Main- Across From Room 106, Left Fountain	Initial	16-JUN-16	1.410	ppb
51428	51428-1-HAL-F07	Main- Across From Room 106, Left Fountain	Initial	04-AUG-20	2.130	ug/L
51428	51428-1-HAL-F07	Main- Across From Room 106, Left Fountain	Initial	29-OCT-20	1.540	ug/L
51428	51428-1-HAL-F07	Main- Across From Room 106, Left Fountain	Initial	11-SEP-20	10.700	ug/L
51428	51428-1-HAL-F07	Main- Across From Room 106, Left Fountain	Initial	21-JAN-22	3.620	ug/L
51428	51428-1-HAL-F08	Main- Across From Room 106, Right Fountain	Flush180	21-JAN-22	2.670	ug/L
51428	51428-1-HAL-F08	Main- Across From Room 106, Right Fountain	Flush180	21-JAN-22	2.730	ug/L
51428	51428-1-HAL-F08	Main- Across From Room 106, Right Fountain	Flush180	21-JAN-22	2.800	ug/L
51428	51428-1-HAL-F08	Main- Across From Room 106, Right Fountain	Flush180	21-JAN-22	2.490	ug/L
51428	51428-1-HAL-F08	Main- Across From Room 106, Right Fountain	Initial	21-JAN-22	2.820	ug/L
51428	51428-1-HAL-F06	Main- Across From Room 110, Center Fountain	Flush180	16-JUN-16	0.436	ppb
51428	51428-1-HAL-F06	Main- Across From Room 110, Center Fountain	Flush180	16-JUN-16	0.470	ppb
51428	51428-1-HAL-F06	Main- Across From Room 110, Center Fountain	Flush180	16-JUN-16	0.544	ppb
51428	51428-1-HAL-F06	Main- Across From Room 110, Center Fountain	Flush180	16-JUN-16	0.503	ppb
51428	51428-1-HAL-F06	Main- Across From Room 110, Center Fountain	Flush180	21-JAN-22	1.000	ug/L
51428	51428-1-HAL-F06	Main- Across From Room 110, Center Fountain	Flush180	21-JAN-22	1.000	ug/L
51428	51428-1-HAL-F06	Main- Across From Room 110, Center Fountain	Flush180	21-JAN-22	1.000	ug/L
51428	51428-1-HAL-F06	Main- Across From Room 110, Center Fountain	Flush180	21-JAN-22	1.000	ug/L
51428	51428-1-HAL-F06	Main- Across From Room 110, Center Fountain	Initial	16-JUN-16	0.921	ppb
51428	51428-1-HAL-F06	Main- Across From Room 110, Center Fountain	Initial	21-JAN-22	1.050	ug/L
51428	51428-1-HAL-F05	Main- Across From Room 110, Left Fountain	Flush180	16-JUN-16	1.350	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51428	51428-1-HAL-F05	Main- Across From Room 110, Left Fountain	Flush180	16-JUN-16	0.653	ppb
51428	51428-1-HAL-F05	Main- Across From Room 110, Left Fountain	Flush180	16-JUN-16	1.230	ppb
51428	51428-1-HAL-F05	Main- Across From Room 110, Left Fountain	Flush180	16-JUN-16	0.916	ppb
51428	51428-1-HAL-F05	Main- Across From Room 110, Left Fountain	Flush180	21-JAN-22	1.800	ug/L
51428	51428-1-HAL-F05	Main- Across From Room 110, Left Fountain	Flush180	21-JAN-22	2.580	ug/L
51428	51428-1-HAL-F05	Main- Across From Room 110, Left Fountain	Flush180	21-JAN-22	3.220	ug/L
51428	51428-1-HAL-F05	Main- Across From Room 110, Left Fountain	Flush180	21-JAN-22	2.300	ug/L
51428	51428-1-HAL-F05	Main- Across From Room 110, Left Fountain	Initial	16-JUN-16	1.400	ppb
51428	51428-1-HAL-F05	Main- Across From Room 110, Left Fountain	Initial	21-JAN-22	1.650	ug/L
51428	51428-1-HAL-F09	Main- Across From Room 110, Right Fountain	Flush180	21-JAN-22	8.530	ug/L
51428	51428-1-HAL-F09	Main- Across From Room 110, Right Fountain	Flush180	21-JAN-22	3.440	ug/L
51428	51428-1-HAL-F09	Main- Across From Room 110, Right Fountain	Flush180	21-JAN-22	1.970	ug/L
51428	51428-1-HAL-F09	Main- Across From Room 110, Right Fountain	Flush180	21-JAN-22	1.670	ug/L
51428	51428-1-HAL-F09	Main- Across From Room 110, Right Fountain	Flush180	20-APR-23	1.880	ug/L
51428	51428-1-HAL-F09	Main- Across From Room 110, Right Fountain	Flush180	20-APR-23	1.250	ug/L
51428	51428-1-HAL-F09	Main- Across From Room 110, Right Fountain	Flush180	20-APR-23	1.000	ug/L
51428	51428-1-HAL-F09	Main- Across From Room 110, Right Fountain	Flush180	20-APR-23	1.000	ug/L
51428	51428-1-HAL-F09	Main- Across From Room 110, Right Fountain	Flush180	06-OCT-22	11.000	ug/L
51428	51428-1-HAL-F09	Main- Across From Room 110, Right Fountain	Flush180	06-OCT-22	12.700	ug/L
51428	51428-1-HAL-F09	Main- Across From Room 110, Right Fountain	Flush180	06-OCT-22	11.100	ug/L
51428	51428-1-HAL-F09	Main- Across From Room 110, Right Fountain	Flush180	06-OCT-22	8.390	ug/L
51428	51428-1-HAL-F09	Main- Across From Room 110, Right Fountain	Initial	21-JAN-22	12.500	ug/L
51428	51428-1-HAL-F09	Main- Across From Room 110, Right Fountain	Initial	20-APR-23	1.420	ug/L
51428	51428-1-HAL-F09	Main- Across From Room 110, Right Fountain	Initial	06-OCT-22	21.900	ug/L
51428	51428-1-HAL-BF01	Main- Across From Room 116, Bottle Filler	Flush180	21-JAN-22	1.000	ug/L
51428	51428-1-HAL-BF01	Main- Across From Room 116, Bottle Filler	Flush180	21-JAN-22	1.000	ug/L
51428	51428-1-HAL-BF01	Main- Across From Room 116, Bottle Filler	Flush180	21-JAN-22	1.000	ug/L
51428	51428-1-HAL-BF01	Main- Across From Room 116, Bottle Filler	Initial	21-JAN-22	1.000	ug/L
51428	51428-1-HAL-F01	Main- Across From Room 116, Left Fountain	Flush180	16-JUN-16	0.393	ppb
51428	51428-1-HAL-F01	Main- Across From Room 116, Left Fountain	Flush180	16-JUN-16	0.376	ppb
51428	51428-1-HAL-F01	Main- Across From Room 116, Left Fountain	Flush180	16-JUN-16	0.387	ppb
51428	51428-1-HAL-F01	Main- Across From Room 116, Left Fountain	Flush180	16-JUN-16	0.358	ppb
51428	51428-1-HAL-F01	Main- Across From Room 116, Left Fountain	Flush180	04-AUG-20	1.000	ug/L
51428	51428-1-HAL-	Main- Across From Room 116,	Flush180	21-JAN-22	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01	Left Fountain				
51428	51428-1-HAL-F01	Main- Across From Room 116, Left Fountain	Flush180	21-JAN-22	1.000	ug/L
51428	51428-1-HAL-F01	Main- Across From Room 116, Left Fountain	Flush180	21-JAN-22	1.000	ug/L
51428	51428-1-HAL-F01	Main- Across From Room 116, Left Fountain	Flush180	21-JAN-22	1.000	ug/L
51428	51428-1-HAL-F01	Main- Across From Room 116, Left Fountain	Flush180	11-SEP-20	1.850	ug/L
51428	51428-1-HAL-F01	Main- Across From Room 116, Left Fountain	Initial	16-JUN-16	0.694	ppb
51428	51428-1-HAL-F01	Main- Across From Room 116, Left Fountain	Initial	04-AUG-20	4.140	ug/L
51428	51428-1-HAL-F01	Main- Across From Room 116, Left Fountain	Initial	21-JAN-22	1.000	ug/L
51428	51428-1-HAL-F01	Main- Across From Room 116, Left Fountain	Initial	11-SEP-20	1.250	ug/L
51428	51428-1-HAL-F02	Main- Across From Room 116, Right Fountain	Flush180	16-JUN-16	0.399	ppb
51428	51428-1-HAL-F02	Main- Across From Room 116, Right Fountain	Flush180	16-JUN-16	0.394	ppb
51428	51428-1-HAL-F02	Main- Across From Room 116, Right Fountain	Flush180	16-JUN-16	0.385	ppb
51428	51428-1-HAL-F02	Main- Across From Room 116, Right Fountain	Flush180	16-JUN-16	0.359	ppb
51428	51428-1-HAL-F02	Main- Across From Room 116, Right Fountain	Flush180	21-JAN-22	1.000	ug/L
51428	51428-1-HAL-F02	Main- Across From Room 116, Right Fountain	Flush180	21-JAN-22	1.000	ug/L
51428	51428-1-HAL-F02	Main- Across From Room 116, Right Fountain	Flush180	21-JAN-22	1.000	ug/L
51428	51428-1-HAL-F02	Main- Across From Room 116, Right Fountain	Flush180	21-JAN-22	1.000	ug/L
51428	51428-1-HAL-F02	Main- Across From Room 116, Right Fountain	Initial	16-JUN-16	0.786	ppb
51428	51428-1-HAL-F02	Main- Across From Room 116, Right Fountain	Initial	21-JAN-22	1.940	ug/L
51428	51428-2-HAL-F05	Main- Across From Room 206, Left Fountain	Flush180	23-MAY-23	3.260	ug/L
51428	51428-2-HAL-F05	Main- Across From Room 206, Left Fountain	Flush180	23-MAY-23	2.580	ug/L
51428	51428-2-HAL-F05	Main- Across From Room 206, Left Fountain	Flush180	23-MAY-23	2.780	ug/L
51428	51428-2-HAL-F05	Main- Across From Room 206, Left Fountain	Flush180	23-MAY-23	3.030	ug/L
51428	51428-2-HAL-F05	Main- Across From Room 206, Left Fountain	Flush180	16-JUN-16	2.100	ppb
51428	51428-2-HAL-F05	Main- Across From Room 206, Left Fountain	Flush180	16-JUN-16	2.020	ppb
51428	51428-2-HAL-F05	Main- Across From Room 206, Left Fountain	Flush180	16-JUN-16	2.290	ppb
51428	51428-2-HAL-F05	Main- Across From Room 206, Left Fountain	Flush180	16-JUN-16	2.300	ppb
51428	51428-2-HAL-F05	Main- Across From Room 206, Left Fountain	Flush180	21-JAN-22	13.300	ug/L
51428	51428-2-HAL-F05	Main- Across From Room 206, Left Fountain	Flush180	21-JAN-22	14.200	ug/L
51428	51428-2-HAL-F05	Main- Across From Room 206, Left Fountain	Flush180	21-JAN-22	11.100	ug/L
51428	51428-2-HAL-F05	Main- Across From Room 206, Left Fountain	Flush180	21-JAN-22	20.200	ug/L
51428	51428-2-HAL-F05	Main- Across From Room 206, Left Fountain	Flush180	20-APR-23	8.660	ug/L
51428	51428-2-HAL-F05	Main- Across From Room 206, Left Fountain	Flush180	20-APR-23	7.740	ug/L
51428	51428-2-HAL-F05	Main- Across From Room 206, Left Fountain	Flush180	20-APR-23	10.900	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F05	Left Fountain				
51428	51428-2-HAL-F05	Main- Across From Room 206, Left Fountain	Flush180	20-APR-23	22.200	ug/L
51428	51428-2-HAL-F05	Main- Across From Room 206, Left Fountain	Flush180	06-OCT-22	5.090	ug/L
51428	51428-2-HAL-F05	Main- Across From Room 206, Left Fountain	Flush180	06-OCT-22	4.820	ug/L
51428	51428-2-HAL-F05	Main- Across From Room 206, Left Fountain	Flush180	06-OCT-22	4.910	ug/L
51428	51428-2-HAL-F05	Main- Across From Room 206, Left Fountain	Flush180	06-OCT-22	5.490	ug/L
51428	51428-2-HAL-F05	Main- Across From Room 206, Left Fountain	Initial	23-MAY-23	4.540	ug/L
51428	51428-2-HAL-F05	Main- Across From Room 206, Left Fountain	Initial	16-JUN-16	2.460	ppb
51428	51428-2-HAL-F05	Main- Across From Room 206, Left Fountain	Initial	21-JAN-22	12.400	ug/L
51428	51428-2-HAL-F05	Main- Across From Room 206, Left Fountain	Initial	20-APR-23	23.400	ug/L
51428	51428-2-HAL-F05	Main- Across From Room 206, Left Fountain	Initial	06-OCT-22	9.020	ug/L
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Flush	23-MAY-2024	4.710	ug/L
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Flush	23-MAY-2024	6.540	ug/L
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Flush	23-MAY-2024	8.420	ug/L
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Flush	23-MAY-2024	9.070	ug/L
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Flush	01-MAY-2024	9.090	ug/L
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Flush	01-MAY-2024	10.300	ug/L
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Flush	01-MAY-2024	9.890	ug/L
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Flush	01-MAY-2024	12.100	ug/L
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Flush180	06-OCT-22	6.500	ug/L
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Flush180	23-MAY-23	7.700	ug/L
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Flush180	23-MAY-23	8.450	ug/L
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Flush180	23-MAY-23	6.620	ug/L
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Flush180	23-MAY-23	6.180	ug/L
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Flush180	16-JUN-16	1.830	ppb
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Flush180	16-JUN-16	1.310	ppb
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Flush180	16-JUN-16	1.410	ppb
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Flush180	16-JUN-16	1.420	ppb
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Flush180	21-JAN-22	55.200	ug/L
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Flush180	21-JAN-22	49.100	ug/L
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Flush180	21-JAN-22	45.400	ug/L
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Flush180	21-JAN-22	11.200	ug/L
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Flush180	20-APR-23	35.400	ug/L
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Flush180	20-APR-23	27.800	ug/L
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Flush180	20-APR-23	22.500	ug/L
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Flush180	20-APR-23	20.900	ug/L
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Flush180	06-OCT-22	6.400	ug/L
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Flush180	06-OCT-22	5.970	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F06	Right Fountain				
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Flush180	06-OCT-22	5.970	ug/L
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Initial	23-MAY-23	13.500	ug/L
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Initial	16-JUN-16	2.260	ppb
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Initial	21-JAN-22	15.100	ug/L
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Initial	20-APR-23	26.300	ug/L
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Initial	06-OCT-22	5.610	ug/L
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Initial	23-MAY-2024	5.410	ug/L
51428	51428-2-HAL-F06	Main- Across From Room 206, Right Fountain	Initial	01-MAY-2024	17.400	ug/L
51428	51428-2-HAL-F02	Main- Across From Room 212, Center Fountain	Flush180	16-JUN-16	1.270	ppb
51428	51428-2-HAL-F02	Main- Across From Room 212, Center Fountain	Flush180	16-JUN-16	1.220	ppb
51428	51428-2-HAL-F02	Main- Across From Room 212, Center Fountain	Flush180	16-JUN-16	1.180	ppb
51428	51428-2-HAL-F02	Main- Across From Room 212, Center Fountain	Flush180	16-JUN-16	1.220	ppb
51428	51428-2-HAL-F02	Main- Across From Room 212, Center Fountain	Flush180	21-JAN-22	1.300	ug/L
51428	51428-2-HAL-F02	Main- Across From Room 212, Center Fountain	Flush180	21-JAN-22	1.220	ug/L
51428	51428-2-HAL-F02	Main- Across From Room 212, Center Fountain	Flush180	21-JAN-22	1.000	ug/L
51428	51428-2-HAL-F02	Main- Across From Room 212, Center Fountain	Flush180	21-JAN-22	1.000	ug/L
51428	51428-2-HAL-F02	Main- Across From Room 212, Center Fountain	Initial	16-JUN-16	1.430	ppb
51428	51428-2-HAL-F02	Main- Across From Room 212, Center Fountain	Initial	21-JAN-22	1.000	ug/L
51428	51428-2-HAL-F01	Main- Across From Room 212, Left Fountain	Flush180	16-JUN-16	1.210	ppb
51428	51428-2-HAL-F01	Main- Across From Room 212, Left Fountain	Flush180	16-JUN-16	1.310	ppb
51428	51428-2-HAL-F01	Main- Across From Room 212, Left Fountain	Flush180	16-JUN-16	1.130	ppb
51428	51428-2-HAL-F01	Main- Across From Room 212, Left Fountain	Flush180	16-JUN-16	1.240	ppb
51428	51428-2-HAL-F01	Main- Across From Room 212, Left Fountain	Flush180	21-JAN-22	1.000	ug/L
51428	51428-2-HAL-F01	Main- Across From Room 212, Left Fountain	Flush180	21-JAN-22	1.000	ug/L
51428	51428-2-HAL-F01	Main- Across From Room 212, Left Fountain	Flush180	21-JAN-22	1.000	ug/L
51428	51428-2-HAL-F01	Main- Across From Room 212, Left Fountain	Initial	16-JUN-16	1.270	ppb
51428	51428-2-HAL-F01	Main- Across From Room 212, Left Fountain	Initial	21-JAN-22	1.490	ug/L
51428	51428-2-HAL-F07	Main- Across From Room 212, Right Fountain	Flush180	21-JAN-22	1.140	ug/L
51428	51428-2-HAL-F07	Main- Across From Room 212, Right Fountain	Flush180	21-JAN-22	1.000	ug/L
51428	51428-2-HAL-F07	Main- Across From Room 212, Right Fountain	Flush180	21-JAN-22	1.000	ug/L
51428	51428-2-HAL-F07	Main- Across From Room 212, Right Fountain	Flush180	21-JAN-22	1.360	ug/L
51428	51428-2-HAL-F07	Main- Across From Room 212, Right Fountain	Initial	21-JAN-22	1.960	ug/L
51428	51428-1-112-BF01	Main- Inside Room 112, Bottle Filler	Flush180	21-JAN-22	1.180	ug/L
51428	51428-1-112-BF01	Main- Inside Room 112, Bottle Filler	Flush180	21-JAN-22	1.170	ug/L
51428	51428-1-112-BF01	Main- Inside Room 112, Bottle Filler	Flush180	21-JAN-22	1.210	ug/L
51428	51428-1-112-BF01	Main- Inside Room 112, Bottle Filler	Flush180	21-JAN-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51428	51428-1-112-BF01	Main- Inside Room 112, Bottle Filler	Initial	21-JAN-22	2.330	ug/L
51428	51428-1-112-F01	Main- Inside Room 112, Fountain	Flush180	21-JAN-22	1.610	ug/L
51428	51428-1-112-F01	Main- Inside Room 112, Fountain	Flush180	21-JAN-22	1.000	ug/L
51428	51428-1-112-F01	Main- Inside Room 112, Fountain	Flush180	21-JAN-22	1.000	ug/L
51428	51428-1-112-F01	Main- Inside Room 112, Fountain	Flush180	21-JAN-22	1.010	ug/L
51428	51428-1-112-F01	Main- Inside Room 112, Fountain	Initial	21-JAN-22	4.510	ug/L
51428	51428-1-112-S01	Main- Inside Room 112, Sink	Flush180	21-JAN-22	1.000	ug/L
51428	51428-1-112-S01	Main- Inside Room 112, Sink	Flush180	21-JAN-22	1.000	ug/L
51428	51428-1-112-S01	Main- Inside Room 112, Sink	Flush180	21-JAN-22	1.000	ug/L
51428	51428-1-112-S01	Main- Inside Room 112, Sink	Flush180	21-JAN-22	1.000	ug/L
51428	51428-1-112-S01	Main- Inside Room 112, Sink	Initial	21-JAN-22	1.000	ug/L
51428	51428-1-113-BF01	Main- Inside Room 113, Bottle Filler	Flush	01-MAY-2024	19.100	ug/L
51428	51428-1-113-BF01	Main- Inside Room 113, Bottle Filler	Flush	01-MAY-2024	22.000	ug/L
51428	51428-1-113-BF01	Main- Inside Room 113, Bottle Filler	Flush	01-MAY-2024	20.900	ug/L
51428	51428-1-113-BF01	Main- Inside Room 113, Bottle Filler	Flush	01-MAY-2024	24.400	ug/L
51428	51428-1-113-BF01	Main- Inside Room 113, Bottle Filler	Flush180	21-JAN-22	1.420	ug/L
51428	51428-1-113-BF01	Main- Inside Room 113, Bottle Filler	Flush180	21-JAN-22	2.320	ug/L
51428	51428-1-113-BF01	Main- Inside Room 113, Bottle Filler	Flush180	21-JAN-22	2.460	ug/L
51428	51428-1-113-BF01	Main- Inside Room 113, Bottle Filler	Flush180	21-JAN-22	5.460	ug/L
51428	51428-1-113-BF01	Main- Inside Room 113, Bottle Filler	Flush180	20-APR-23	11.200	ug/L
51428	51428-1-113-BF01	Main- Inside Room 113, Bottle Filler	Flush180	20-APR-23	9.010	ug/L
51428	51428-1-113-BF01	Main- Inside Room 113, Bottle Filler	Flush180	20-APR-23	15.800	ug/L
51428	51428-1-113-BF01	Main- Inside Room 113, Bottle Filler	Flush180	20-APR-23	17.700	ug/L
51428	51428-1-113-BF01	Main- Inside Room 113, Bottle Filler	Flush180	23-MAY-23	6.430	ug/L
51428	51428-1-113-BF01	Main- Inside Room 113, Bottle Filler	Flush180	23-MAY-23	5.990	ug/L
51428	51428-1-113-BF01	Main- Inside Room 113, Bottle Filler	Flush180	23-MAY-23	9.230	ug/L
51428	51428-1-113-BF01	Main- Inside Room 113, Bottle Filler	Flush180	23-MAY-23	9.940	ug/L
51428	51428-1-113-BF01	Main- Inside Room 113, Bottle Filler	Flush180	06-OCT-22	5.100	ug/L
51428	51428-1-113-BF01	Main- Inside Room 113, Bottle Filler	Flush180	06-OCT-22	5.400	ug/L
51428	51428-1-113-BF01	Main- Inside Room 113, Bottle Filler	Flush180	06-OCT-22	6.300	ug/L
51428	51428-1-113-BF01	Main- Inside Room 113, Bottle Filler	Flush180	06-OCT-22	9.700	ug/L
51428	51428-1-113-BF01	Main- Inside Room 113, Bottle Filler	Initial	21-JAN-22	3.450	ug/L
51428	51428-1-113-BF01	Main- Inside Room 113, Bottle Filler	Initial	20-APR-23	55.500	ug/L
51428	51428-1-113-BF01	Main- Inside Room 113, Bottle Filler	Initial	23-MAY-23	6.290	ug/L
51428	51428-1-113-BF01	Main- Inside Room 113, Bottle Filler	Initial	06-OCT-22	8.100	ug/L
51428	51428-1-113-BF01	Main- Inside Room 113, Bottle Filler	Initial	01-MAY-2024	45.400	ug/L
51428	51428-1-113-F03	Main- Inside Room 113, Fountain 1	Flush180	16-JUN-16	1.090	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51428	51428-1-113-F03	Main- Inside Room 113, Fountain 1	Flush180	16-JUN-16	0.996	ppb
51428	51428-1-113-F03	Main- Inside Room 113, Fountain 1	Flush180	16-JUN-16	0.745	ppb
51428	51428-1-113-F03	Main- Inside Room 113, Fountain 1	Flush180	16-JUN-16	0.962	ppb
51428	51428-1-113-F03	Main- Inside Room 113, Fountain 1	Flush180	21-JAN-22	3.540	ug/L
51428	51428-1-113-F03	Main- Inside Room 113, Fountain 1	Flush180	21-JAN-22	1.220	ug/L
51428	51428-1-113-F03	Main- Inside Room 113, Fountain 1	Flush180	21-JAN-22	1.000	ug/L
51428	51428-1-113-F03	Main- Inside Room 113, Fountain 1	Flush180	21-JAN-22	1.000	ug/L
51428	51428-1-113-F03	Main- Inside Room 113, Fountain 1	Initial	16-JUN-16	1.250	ppb
51428	51428-1-113-F03	Main- Inside Room 113, Fountain 1	Initial	21-JAN-22	4.400	ug/L
51428	51428-1-113-F04	Main- Inside Room 113, Fountain 2	Flush180	16-JUN-16	1.540	ppb
51428	51428-1-113-F04	Main- Inside Room 113, Fountain 2	Flush180	16-JUN-16	1.110	ppb
51428	51428-1-113-F04	Main- Inside Room 113, Fountain 2	Flush180	16-JUN-16	2.280	ppb
51428	51428-1-113-F04	Main- Inside Room 113, Fountain 2	Flush180	16-JUN-16	0.996	ppb
51428	51428-1-113-F04	Main- Inside Room 113, Fountain 2	Initial	16-JUN-16	8.390	ppb
51428	51428-1-113-S01	Main- Inside Room 113, Left Sink	Flush180	21-JAN-22	1.000	ug/L
51428	51428-1-113-S01	Main- Inside Room 113, Left Sink	Flush180	21-JAN-22	1.000	ug/L
51428	51428-1-113-S01	Main- Inside Room 113, Left Sink	Flush180	21-JAN-22	1.360	ug/L
51428	51428-1-113-S01	Main- Inside Room 113, Left Sink	Flush180	21-JAN-22	1.000	ug/L
51428	51428-1-113-S01	Main- Inside Room 113, Left Sink	Initial	21-JAN-22	2.170	ug/L
51428	51428-1-113-S02	Main- Inside Room 113, Right Sink	Flush180	21-JAN-22	1.370	ug/L
51428	51428-1-113-S02	Main- Inside Room 113, Right Sink	Flush180	21-JAN-22	1.000	ug/L
51428	51428-1-113-S02	Main- Inside Room 113, Right Sink	Flush180	21-JAN-22	1.000	ug/L
51428	51428-1-113-S02	Main- Inside Room 113, Right Sink	Flush180	21-JAN-22	1.000	ug/L
51428	51428-1-113-S02	Main- Inside Room 113, Right Sink	Initial	21-JAN-22	3.210	ug/L
51428	51428-2-HAL-F03	Main- Outside Room 205, Fountain 1	Flush180	16-JUN-16	2.070	ppb
51428	51428-2-HAL-F03	Main- Outside Room 205, Fountain 1	Flush180	16-JUN-16	1.380	ppb
51428	51428-2-HAL-F03	Main- Outside Room 205, Fountain 1	Flush180	16-JUN-16	1.380	ppb
51428	51428-2-HAL-F03	Main- Outside Room 205, Fountain 1	Flush180	16-JUN-16	1.950	ppb
51428	51428-2-HAL-F03	Main- Outside Room 205, Fountain 1	Initial	16-JUN-16	1.730	ppb
51428	51428-2-HAL-F04	Main- Outside Room 218, Fountain	Flush180	06-OCT-22	2.800	ug/L
51428	51428-2-HAL-F04	Main- Outside Room 218, Fountain	Flush180	06-OCT-22	2.210	ug/L
51428	51428-2-HAL-F04	Main- Outside Room 218, Fountain	Flush180	06-OCT-22	3.460	ug/L
51428	51428-2-HAL-F04	Main- Outside Room 218, Fountain	Flush180	06-OCT-22	3.640	ug/L
51428	51428-2-HAL-F04	Main- Outside Room 218, Fountain	Flush180	16-JUN-16	1.730	ppb
51428	51428-2-HAL-F04	Main- Outside Room 218, Fountain	Flush180	16-JUN-16	1.170	ppb
51428	51428-2-HAL-F04	Main- Outside Room 218, Fountain	Flush180	16-JUN-16	2.090	ppb
51428	51428-2-HAL-F04	Main- Outside Room 218, Fountain	Flush180	16-JUN-16	1.570	ppb
51428	51428-2-HAL-F04	Main- Outside Room 218, Fountain	Flush180	21-JAN-22	16.900	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F04	Fountain				
51428	51428-2-HAL-F04	Main- Outside Room 218, Fountain	Flush180	21-JAN-22	12.200	ug/L
51428	51428-2-HAL-F04	Main- Outside Room 218, Fountain	Flush180	21-JAN-22	20.900	ug/L
51428	51428-2-HAL-F04	Main- Outside Room 218, Fountain	Flush180	21-JAN-22	20.400	ug/L
51428	51428-2-HAL-F04	Main- Outside Room 218, Fountain	Initial	06-OCT-22	4.640	ug/L
51428	51428-2-HAL-F04	Main- Outside Room 218, Fountain	Initial	16-JUN-16	2.120	ppb
51428	51428-2-HAL-F04	Main- Outside Room 218, Fountain	Initial	21-JAN-22	12.200	ug/L
51428	51428-2-HAL-RBF01	Main- Outside Room 218, Retrofit Bottle Filler	Flush180	06-OCT-22	15.900	ug/L
51428	51428-2-HAL-RBF01	Main- Outside Room 218, Retrofit Bottle Filler	Flush180	06-OCT-22	9.100	ug/L
51428	51428-2-HAL-RBF01	Main- Outside Room 218, Retrofit Bottle Filler	Flush180	06-OCT-22	3.500	ug/L
51428	51428-2-HAL-RBF01	Main- Outside Room 218, Retrofit Bottle Filler	Flush180	06-OCT-22	3.160	ug/L
51428	51428-2-HAL-RBF01	Main- Outside Room 218, Retrofit Bottle Filler	Flush180	21-JAN-22	3.540	ug/L
51428	51428-2-HAL-RBF01	Main- Outside Room 218, Retrofit Bottle Filler	Flush180	21-JAN-22	4.520	ug/L
51428	51428-2-HAL-RBF01	Main- Outside Room 218, Retrofit Bottle Filler	Flush180	21-JAN-22	4.940	ug/L
51428	51428-2-HAL-RBF01	Main- Outside Room 218, Retrofit Bottle Filler	Flush180	21-JAN-22	5.510	ug/L
51428	51428-2-HAL-RBF01	Main- Outside Room 218, Retrofit Bottle Filler	Flush180	20-APR-23	1.000	ug/L
51428	51428-2-HAL-RBF01	Main- Outside Room 218, Retrofit Bottle Filler	Flush180	20-APR-23	1.140	ug/L
51428	51428-2-HAL-RBF01	Main- Outside Room 218, Retrofit Bottle Filler	Flush180	20-APR-23	1.140	ug/L
51428	51428-2-HAL-RBF01	Main- Outside Room 218, Retrofit Bottle Filler	Flush180	20-APR-23	1.000	ug/L
51428	51428-2-HAL-RBF01	Main- Outside Room 218, Retrofit Bottle Filler	Initial	06-OCT-22	3.510	ug/L
51428	51428-2-HAL-RBF01	Main- Outside Room 218, Retrofit Bottle Filler	Initial	21-JAN-22	4.310	ug/L
51428	51428-2-HAL-RBF01	Main- Outside Room 218, Retrofit Bottle Filler	Initial	20-APR-23	1.530	ug/L
58241	58241-1-KIT-KS02	Annex- 1st Floor Kitchen, Sink, Center	Flush180	21-JAN-22	1.000	ug/L
58241	58241-1-KIT-KS02	Annex- 1st Floor Kitchen, Sink, Center	Flush180	21-JAN-22	1.000	ug/L
58241	58241-1-KIT-KS02	Annex- 1st Floor Kitchen, Sink, Center	Flush180	21-JAN-22	1.000	ug/L
58241	58241-1-KIT-KS02	Annex- 1st Floor Kitchen, Sink, Center	Flush180	21-JAN-22	1.000	ug/L
58241	58241-1-KIT-KS02	Annex- 1st Floor Kitchen, Sink, Center	Initial	21-JAN-22	1.000	ug/L
58241	58241-1-KIT-KS01	Annex- 1st Floor Kitchen, Sink, Left	Flush180	16-JUN-16	0.760	ppb
58241	58241-1-KIT-KS01	Annex- 1st Floor Kitchen, Sink, Left	Flush180	16-JUN-16	0.485	ppb
58241	58241-1-KIT-KS01	Annex- 1st Floor Kitchen, Sink, Left	Flush180	16-JUN-16	0.761	ppb
58241	58241-1-KIT-KS01	Annex- 1st Floor Kitchen, Sink, Left	Flush180	16-JUN-16	0.673	ppb
58241	58241-1-KIT-KS01	Annex- 1st Floor Kitchen, Sink, Left	Flush180	21-JAN-22	1.000	ug/L
58241	58241-1-KIT-KS01	Annex- 1st Floor Kitchen, Sink, Left	Flush180	21-JAN-22	1.000	ug/L
58241	58241-1-KIT-KS01	Annex- 1st Floor Kitchen, Sink, Left	Flush180	21-JAN-22	1.000	ug/L
58241	58241-1-KIT-KS01	Annex- 1st Floor Kitchen, Sink, Left	Flush180	21-JAN-22	1.000	ug/L
58241	58241-1-KIT-KS01	Annex- 1st Floor Kitchen, Sink, Left	Flush180	21-JAN-22	1.000	ug/L
58241	58241-1-KIT-KS01	Annex- 1st Floor Kitchen, Sink, Left	Initial	16-JUN-16	0.409	ppb
58241	58241-1-KIT-KS01	Annex- 1st Floor Kitchen, Sink, Left	Initial	21-JAN-22	1.000	ug/L
58241	58241-1-KIT-KS01	Annex- 1st Floor Kitchen, Sink, Left	Flush180	21-JAN-22	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS04	North				
58241	58241-1-KIT-KS04	Annex- 1st Floor Kitchen, Sink, North	Flush180	21-JAN-22	1.130	ug/L
58241	58241-1-KIT-KS04	Annex- 1st Floor Kitchen, Sink, North	Flush180	21-JAN-22	1.000	ug/L
58241	58241-1-KIT-KS04	Annex- 1st Floor Kitchen, Sink, North	Flush180	21-JAN-22	1.000	ug/L
58241	58241-1-KIT-KS04	Annex- 1st Floor Kitchen, Sink, North	Initial	21-JAN-22	1.000	ug/L
58241	58241-1-KIT-KS03	Annex- 1st Floor Kitchen, Sink, Right	Flush180	21-JAN-22	1.240	ug/L
58241	58241-1-KIT-KS03	Annex- 1st Floor Kitchen, Sink, Right	Flush180	21-JAN-22	2.670	ug/L
58241	58241-1-KIT-KS03	Annex- 1st Floor Kitchen, Sink, Right	Flush180	21-JAN-22	1.000	ug/L
58241	58241-1-KIT-KS03	Annex- 1st Floor Kitchen, Sink, Right	Flush180	21-JAN-22	1.000	ug/L
58241	58241-1-KIT-KS03	Annex- 1st Floor Kitchen, Sink, Right	Initial	21-JAN-22	1.000	ug/L
58241	58241-2-HAL-F01	Annex- 2nd Floor Outside of Boys Room, Left Fountain	Flush180	16-JUN-16	1.040	ppb
58241	58241-2-HAL-F01	Annex- 2nd Floor Outside of Boys Room, Left Fountain	Flush180	16-JUN-16	1.120	ppb
58241	58241-2-HAL-F01	Annex- 2nd Floor Outside of Boys Room, Left Fountain	Flush180	16-JUN-16	0.741	ppb
58241	58241-2-HAL-F01	Annex- 2nd Floor Outside of Boys Room, Left Fountain	Flush180	16-JUN-16	0.285	ppb
58241	58241-2-HAL-F01	Annex- 2nd Floor Outside of Boys Room, Left Fountain	Flush180	21-JAN-22	1.680	ug/L
58241	58241-2-HAL-F01	Annex- 2nd Floor Outside of Boys Room, Left Fountain	Flush180	21-JAN-22	1.550	ug/L
58241	58241-2-HAL-F01	Annex- 2nd Floor Outside of Boys Room, Left Fountain	Flush180	21-JAN-22	1.250	ug/L
58241	58241-2-HAL-F01	Annex- 2nd Floor Outside of Boys Room, Left Fountain	Flush180	21-JAN-22	1.310	ug/L
58241	58241-2-HAL-F01	Annex- 2nd Floor Outside of Boys Room, Left Fountain	Initial	16-JUN-16	0.815	ppb
58241	58241-2-HAL-F01	Annex- 2nd Floor Outside of Boys Room, Left Fountain	Initial	21-JAN-22	1.000	ug/L
58241	58241-1-HAL-F04	Annex- Outside of Boys Room, Fountain 1	Flush180	04-AUG-20	1.000	ug/L
58241	58241-1-HAL-F04	Annex- Outside of Boys Room, Fountain 1	Initial	04-AUG-20	1.000	ug/L
58241	58241-1-HAL-F02	Annex- Outside of Boys Room, Left Fountain	Flush180	16-JUN-16	0.237	ppb
58241	58241-1-HAL-F02	Annex- Outside of Boys Room, Left Fountain	Flush180	16-JUN-16	0.243	ppb
58241	58241-1-HAL-F02	Annex- Outside of Boys Room, Left Fountain	Flush180	16-JUN-16	1.070	ppb
58241	58241-1-HAL-F02	Annex- Outside of Boys Room, Left Fountain	Flush180	16-JUN-16	0.267	ppb
58241	58241-1-HAL-F02	Annex- Outside of Boys Room, Left Fountain	Flush180	21-JAN-22	1.000	ug/L
58241	58241-1-HAL-F02	Annex- Outside of Boys Room, Left Fountain	Flush180	21-JAN-22	1.000	ug/L
58241	58241-1-HAL-F02	Annex- Outside of Boys Room, Left Fountain	Flush180	21-JAN-22	1.000	ug/L
58241	58241-1-HAL-F02	Annex- Outside of Boys Room, Left Fountain	Initial	16-JUN-16	2.090	ppb
58241	58241-1-HAL-F02	Annex- Outside of Boys Room, Left Fountain	Initial	21-JAN-22	1.000	ug/L
58241	58241-1-HAL-F03	Annex- Outside of Boys Room, Right Fountain	Flush180	16-JUN-16	0.684	ppb
58241	58241-1-HAL-F03	Annex- Outside of Boys Room, Right Fountain	Flush180	16-JUN-16	0.682	ppb
58241	58241-1-HAL-F03	Annex- Outside of Boys Room, Right Fountain	Flush180	16-JUN-16	0.703	ppb
58241	58241-1-HAL-F03	Annex- Outside of Boys Room, Right Fountain	Flush180	16-JUN-16	0.689	ppb
58241	58241-1-HAL-F03	Annex- Outside of Boys Room, Right Fountain	Flush180	21-JAN-22	1.000	ug/L
58241	58241-1-HAL-F03	Annex- Outside of Boys Room, Right Fountain	Flush180	21-JAN-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
58241	58241-1-HAL-F03	Annex- Outside of Boys Room, Right Fountain	Flush180	21-JAN-22	1.000	ug/L
58241	58241-1-HAL-F03	Annex- Outside of Boys Room, Right Fountain	Flush180	21-JAN-22	1.000	ug/L
58241	58241-1-HAL-F03	Annex- Outside of Boys Room, Right Fountain	Initial	16-JUN-16	0.686	ppb
58241	58241-1-HAL-F03	Annex- Outside of Boys Room, Right Fountain	Initial	21-JAN-22	1.000	ug/L
58241	58241-2-HAL-F02	Annex-2nd floor Outside of Boys Room, Right Fountain	Flush180	16-JUN-16	0.165	ppb
58241	58241-2-HAL-F02	Annex-2nd floor Outside of Boys Room, Right Fountain	Flush180	16-JUN-16	0.174	ppb
58241	58241-2-HAL-F02	Annex-2nd floor Outside of Boys Room, Right Fountain	Flush180	16-JUN-16	0.985	ppb
58241	58241-2-HAL-F02	Annex-2nd floor Outside of Boys Room, Right Fountain	Flush180	16-JUN-16	0.169	ppb
58241	58241-2-HAL-F02	Annex-2nd floor Outside of Boys Room, Right Fountain	Flush180	04-AUG-20	1.000	ug/L
58241	58241-2-HAL-F02	Annex-2nd floor Outside of Boys Room, Right Fountain	Initial	16-JUN-16	0.179	ppb
58241	58241-2-HAL-F02	Annex-2nd floor Outside of Boys Room, Right Fountain	Initial	04-AUG-20	1.000	ug/L