



Sep 10, 2024

COONLEY

4046 N LEAVITT ST, Chicago IL 60618.

Dear **COONLEY** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

COONLEY

4046 N LEAVITT ST, Chicago IL 60618.

Estimadas familias de **COONLEY**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51055	51055-1-W-HAL-F01	First Floor, Hallway, Outside Room 104	Flush180	13-SEP-16	0.635	ppb
51055	51055-1-W-HAL-F01	First Floor, Hallway, Outside Room 104	Flush180	13-SEP-16	0.693	ppb
51055	51055-1-W-HAL-F01	First Floor, Hallway, Outside Room 104	Flush180	13-SEP-16	0.576	ppb
51055	51055-1-W-HAL-F02	First Floor, Hallway, Outside Room 104	Flush180	13-SEP-16	0.560	ppb
51055	51055-1-W-HAL-F02	First Floor, Hallway, Outside Room 104	Flush180	13-SEP-16	0.547	ppb
51055	51055-1-W-HAL-F01	First Floor, Hallway, Outside Room 104	Flush180	13-SEP-16	0.557	ppb
51055	51055-1-W-HAL-F02	First Floor, Hallway, Outside Room 104	Flush180	13-SEP-16	0.590	ppb
51055	51055-1-W-HAL-F02	First Floor, Hallway, Outside Room 104	Flush180	13-SEP-16	0.549	ppb
51055	51055-1-W-HAL-F01	First Floor, Hallway, Outside Room 104	Flush180	24-JUL-20	3.140	ug/L
51055	51055-1-W-HAL-F01	First Floor, Hallway, Outside Room 104	Flush180	26-FEB-20	1.000	ug/L
51055	51055-1-W-HAL-F01	First Floor, Hallway, Outside Room 104	Flush180	26-FEB-20	1.000	ug/L
51055	51055-1-W-HAL-F01	First Floor, Hallway, Outside Room 104	Flush180	26-FEB-20	1.000	ug/L
51055	51055-1-W-HAL-F01	First Floor, Hallway, Outside Room 104	Flush180	26-FEB-20	1.000	ug/L
51055	51055-1-W-HAL-F02	First Floor, Hallway, Outside Room 104	Flush180	26-FEB-20	1.000	ug/L
51055	51055-1-W-HAL-F02	First Floor, Hallway, Outside Room 104	Flush180	26-FEB-20	1.000	ug/L
51055	51055-1-W-HAL-F02	First Floor, Hallway, Outside Room 104	Flush180	26-FEB-20	1.000	ug/L
51055	51055-1-W-HAL-F02	First Floor, Hallway, Outside Room 104	Flush180	26-FEB-20	1.000	ug/L
51055	51055-1-W-HAL-F02	First Floor, Hallway, Outside Room 104	Flush180	26-FEB-20	1.000	ug/L
51055	51055-1-W-HAL-F01	First Floor, Hallway, Outside Room 104	Initial	13-SEP-16	0.664	ppb
51055	51055-1-W-HAL-F02	First Floor, Hallway, Outside Room 104	Initial	13-SEP-16	0.433	ppb
51055	51055-1-W-HAL-F01	First Floor, Hallway, Outside Room 104	Initial	24-JUL-20	1.780	ug/L
51055	51055-1-W-HAL-F01	First Floor, Hallway, Outside Room 104	Initial	26-FEB-20	1.000	ug/L
51055	51055-1-W-HAL-F02	First Floor, Hallway, Outside Room 104	Initial	26-FEB-20	1.000	ug/L
51055	51055-G-N-CAF-F04	Ground Floor, Cafeteria Fountain, East	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-N-CAF-F04	Ground Floor, Cafeteria Fountain, East	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-N-CAF-F04	Ground Floor, Cafeteria Fountain, East	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-N-CAF-F04	Ground Floor, Cafeteria Fountain, East	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-N-CAF-F04	Ground Floor, Cafeteria Fountain, East	Flush180	13-SEP-16	0.120	ppb
51055	51055-G-N-CAF-F04	Ground Floor, Cafeteria Fountain, East	Flush180	13-SEP-16	0.120	ppb
51055	51055-G-N-CAF-F04	Ground Floor, Cafeteria Fountain, East	Flush180	13-SEP-16	0.120	ppb
51055	51055-G-N-CAF-F04	Ground Floor, Cafeteria Fountain, East	Initial	26-FEB-20	1.000	ug/L
51055	51055-G-N-CAF-F04	Ground Floor, Cafeteria Fountain, East	Initial	13-SEP-16	0.120	ppb
51055	51055-G-N-CAF-F05	Ground Floor, Cafeteria Fountain, Middle	Flush180	13-SEP-16	0.120	ppb
51055	51055-G-N-CAF-F05	Ground Floor, Cafeteria Fountain, Middle	Flush180	13-SEP-16	0.120	ppb
51055	51055-G-N-CAF-F05	Ground Floor, Cafeteria Fountain, Middle	Flush180	13-SEP-16	0.120	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51055	51055-G-N-CAF-F05	Ground Floor, Cafeteria Fountain, Middle	Flush180	13-SEP-16	0.120	ppb
51055	51055-G-N-CAF-F05	Ground Floor, Cafeteria Fountain, Middle	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-N-CAF-F05	Ground Floor, Cafeteria Fountain, Middle	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-N-CAF-F05	Ground Floor, Cafeteria Fountain, Middle	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-N-CAF-F05	Ground Floor, Cafeteria Fountain, Middle	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-N-CAF-F05	Ground Floor, Cafeteria Fountain, Middle	Initial	13-SEP-16	0.120	ppb
51055	51055-G-N-CAF-F05	Ground Floor, Cafeteria Fountain, Middle	Initial	26-FEB-20	1.000	ug/L
51055	51055-G-N-CAF-F06	Ground Floor, Cafeteria Fountain, West	Flush180	13-SEP-16	0.120	ppb
51055	51055-G-N-CAF-F06	Ground Floor, Cafeteria Fountain, West	Flush180	13-SEP-16	0.120	ppb
51055	51055-G-N-CAF-F06	Ground Floor, Cafeteria Fountain, West	Flush180	13-SEP-16	0.120	ppb
51055	51055-G-N-CAF-F06	Ground Floor, Cafeteria Fountain, West	Flush180	13-SEP-16	0.120	ppb
51055	51055-G-N-CAF-F06	Ground Floor, Cafeteria Fountain, West	Flush180	24-JUL-20	1.000	ug/L
51055	51055-G-N-CAF-F06	Ground Floor, Cafeteria Fountain, West	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-N-CAF-F06	Ground Floor, Cafeteria Fountain, West	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-N-CAF-F06	Ground Floor, Cafeteria Fountain, West	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-N-CAF-F06	Ground Floor, Cafeteria Fountain, West	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-N-CAF-F06	Ground Floor, Cafeteria Fountain, West	Initial	13-SEP-16	0.120	ppb
51055	51055-G-N-CAF-F06	Ground Floor, Cafeteria Fountain, West	Initial	24-JUL-20	1.000	ug/L
51055	51055-G-N-CAF-F06	Ground Floor, Cafeteria Fountain, West	Initial	26-FEB-20	1.000	ug/L
51055	51055-G-N-KIT-KS01	Ground Floor, Kitchen Sink, East	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-N-KIT-KS01	Ground Floor, Kitchen Sink, East	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-N-KIT-KS01	Ground Floor, Kitchen Sink, East	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-N-KIT-KS01	Ground Floor, Kitchen Sink, East	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-N-KIT-KS01	Ground Floor, Kitchen Sink, East	Flush180	13-SEP-16	0.335	ppb
51055	51055-G-N-KIT-KS01	Ground Floor, Kitchen Sink, East	Flush180	13-SEP-16	0.335	ppb
51055	51055-G-N-KIT-KS01	Ground Floor, Kitchen Sink, East	Flush180	13-SEP-16	0.392	ppb
51055	51055-G-N-KIT-KS01	Ground Floor, Kitchen Sink, East	Flush180	13-SEP-16	0.335	ppb
51055	51055-G-N-KIT-KS01	Ground Floor, Kitchen Sink, East	Initial	26-FEB-20	1.000	ug/L
51055	51055-G-N-KIT-KS01	Ground Floor, Kitchen Sink, East	Initial	13-SEP-16	0.487	ppb
51055	51055-G-N-KIT-KS02	Ground Floor, Kitchen Sink, Middle	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-N-KIT-KS02	Ground Floor, Kitchen Sink, Middle	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-N-KIT-KS02	Ground Floor, Kitchen Sink, Middle	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-N-KIT-KS02	Ground Floor, Kitchen Sink, Middle	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-N-KIT-KS02	Ground Floor, Kitchen Sink, Middle	Flush180	13-SEP-16	0.178	ppb
51055	51055-G-N-KIT-KS02	Ground Floor, Kitchen Sink, Middle	Flush180	13-SEP-16	0.120	ppb
51055	51055-G-N-KIT-KS02	Ground Floor, Kitchen Sink, Middle	Flush180	13-SEP-16	0.195	ppb
51055	51055-G-N-KIT-KS02	Ground Floor, Kitchen Sink, Middle	Flush180	13-SEP-16	0.318	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51055	51055-G-N-KIT-KS02	Ground Floor, Kitchen Sink, Middle	Initial	26-FEB-20	1.000	ug/L
51055	51055-G-N-KIT-KS02	Ground Floor, Kitchen Sink, Middle	Initial	13-SEP-16	0.315	ppb
51055	51055-G-N-KIT-KS03	Ground Floor, Kitchen Sink, West	Flush180	13-SEP-16	0.120	ppb
51055	51055-G-N-KIT-KS03	Ground Floor, Kitchen Sink, West	Flush180	13-SEP-16	0.120	ppb
51055	51055-G-N-KIT-KS03	Ground Floor, Kitchen Sink, West	Flush180	13-SEP-16	0.120	ppb
51055	51055-G-N-KIT-KS03	Ground Floor, Kitchen Sink, West	Flush180	13-SEP-16	0.120	ppb
51055	51055-G-N-KIT-KS03	Ground Floor, Kitchen Sink, West	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-N-KIT-KS03	Ground Floor, Kitchen Sink, West	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-N-KIT-KS03	Ground Floor, Kitchen Sink, West	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-N-KIT-KS03	Ground Floor, Kitchen Sink, West	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-N-KIT-KS03	Ground Floor, Kitchen Sink, West	Initial	13-SEP-16	0.384	ppb
51055	51055-G-N-KIT-KS03	Ground Floor, Kitchen Sink, West	Initial	26-FEB-20	1.000	ug/L
51055	51055-G-W-HAL-F08	Ground Floor, Outside Gym, East Fountain	Flush180	13-SEP-16	0.177	ppb
51055	51055-G-W-HAL-F08	Ground Floor, Outside Gym, East Fountain	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-W-HAL-F08	Ground Floor, Outside Gym, East Fountain	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-W-HAL-F08	Ground Floor, Outside Gym, East Fountain	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-W-HAL-F08	Ground Floor, Outside Gym, East Fountain	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-W-HAL-F08	Ground Floor, Outside Gym, East Fountain	Flush180	13-SEP-16	0.187	ppb
51055	51055-G-W-HAL-F08	Ground Floor, Outside Gym, East Fountain	Flush180	13-SEP-16	0.120	ppb
51055	51055-G-W-HAL-F08	Ground Floor, Outside Gym, East Fountain	Flush180	13-SEP-16	0.142	ppb
51055	51055-G-W-HAL-F08	Ground Floor, Outside Gym, East Fountain	Initial	26-FEB-20	1.000	ug/L
51055	51055-G-W-HAL-F08	Ground Floor, Outside Gym, East Fountain	Initial	13-SEP-16	0.263	ppb
51055	51055-G-W-HAL-F09	Ground Floor, Outside Gym, Middle Fountain	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-W-HAL-F09	Ground Floor, Outside Gym, Middle Fountain	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-W-HAL-F09	Ground Floor, Outside Gym, Middle Fountain	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-W-HAL-F09	Ground Floor, Outside Gym, Middle Fountain	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-W-HAL-F09	Ground Floor, Outside Gym, Middle Fountain	Flush180	13-SEP-16	0.360	ppb
51055	51055-G-W-HAL-F09	Ground Floor, Outside Gym, Middle Fountain	Flush180	13-SEP-16	0.443	ppb
51055	51055-G-W-HAL-F09	Ground Floor, Outside Gym, Middle Fountain	Flush180	13-SEP-16	0.342	ppb
51055	51055-G-W-HAL-F09	Ground Floor, Outside Gym, Middle Fountain	Flush180	13-SEP-16	0.342	ppb
51055	51055-G-W-HAL-F09	Ground Floor, Outside Gym, Middle Fountain	Initial	26-FEB-20	1.000	ug/L
51055	51055-G-W-HAL-F09	Ground Floor, Outside Gym, Middle Fountain	Initial	13-SEP-16	0.172	ppb
51055	51055-G-W-HAL-F10	Ground Floor, Outside Gym, West Fountain	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-W-HAL-F10	Ground Floor, Outside Gym, West Fountain	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-W-HAL-F10	Ground Floor, Outside Gym, West Fountain	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-W-HAL-F10	Ground Floor, Outside Gym, West Fountain	Flush180	13-SEP-16	0.433	ppb
51055	51055-G-W-HAL-F10	Ground Floor, Outside Gym, West Fountain	Flush180	13-SEP-16	0.433	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F10	Fountain				
51055	51055-G-W-HAL-F10	Ground Floor, Outside Gym, West Fountain	Flush180	13-SEP-16	0.405	ppb
51055	51055-G-W-HAL-F10	Ground Floor, Outside Gym, West Fountain	Flush180	13-SEP-16	0.293	ppb
51055	51055-G-W-HAL-F10	Ground Floor, Outside Gym, West Fountain	Initial	26-FEB-20	1.000	ug/L
51055	51055-G-W-HAL-F10	Ground Floor, Outside Gym, West Fountain	Initial	13-SEP-16	0.301	ppb
51055	51055-G-E-CAF-S07	Ground Floor, Store Room Sink 3	Flush180	13-SEP-16	0.120	ppb
51055	51055-G-E-CAF-S07	Ground Floor, Store Room Sink 3	Flush180	13-SEP-16	0.131	ppb
51055	51055-G-E-CAF-S07	Ground Floor, Store Room Sink 3	Flush180	13-SEP-16	0.120	ppb
51055	51055-G-E-CAF-S07	Ground Floor, Store Room Sink 3	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-E-CAF-S07	Ground Floor, Store Room Sink 3	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-E-CAF-S07	Ground Floor, Store Room Sink 3	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-E-CAF-S07	Ground Floor, Store Room Sink 3	Flush180	26-FEB-20	1.000	ug/L
51055	51055-G-E-CAF-S07	Ground Floor, Store Room Sink 3	Initial	13-SEP-16	0.204	ppb
51055	51055-G-E-CAF-S07	Ground Floor, Store Room Sink 3	Initial	26-FEB-20	1.000	ug/L
51055	51055-2-N-HAL-F04	Second Floor, Hallway, Across Room 211, East Fount	Flush180	13-SEP-16	0.120	ppb
51055	51055-2-N-HAL-F04	Second Floor, Hallway, Across Room 211, East Fount	Flush180	13-SEP-16	0.120	ppb
51055	51055-2-N-HAL-F04	Second Floor, Hallway, Across Room 211, East Fount	Flush180	13-SEP-16	0.120	ppb
51055	51055-2-N-HAL-F04	Second Floor, Hallway, Across Room 211, East Fount	Flush180	13-SEP-16	0.120	ppb
51055	51055-2-N-HAL-F04	Second Floor, Hallway, Across Room 211, East Fount	Flush180	26-FEB-20	1.000	ug/L
51055	51055-2-N-HAL-F04	Second Floor, Hallway, Across Room 211, East Fount	Flush180	26-FEB-20	1.000	ug/L
51055	51055-2-N-HAL-F04	Second Floor, Hallway, Across Room 211, East Fount	Flush180	26-FEB-20	1.000	ug/L
51055	51055-2-N-HAL-F04	Second Floor, Hallway, Across Room 211, East Fount	Flush180	26-FEB-20	1.000	ug/L
51055	51055-2-N-HAL-F04	Second Floor, Hallway, Across Room 211, East Fount	Initial	13-SEP-16	0.120	ppb
51055	51055-2-N-HAL-F04	Second Floor, Hallway, Across Room 211, East Fount	Initial	26-FEB-20	1.000	ug/L
51055	51055-2-N-HAL-F05	Second Floor, Hallway, Across Room 211, Middle Fou	Flush180	13-SEP-16	0.120	ppb
51055	51055-2-N-HAL-F05	Second Floor, Hallway, Across Room 211, Middle Fou	Flush180	13-SEP-16	0.120	ppb
51055	51055-2-N-HAL-F05	Second Floor, Hallway, Across Room 211, Middle Fou	Flush180	13-SEP-16	0.120	ppb
51055	51055-2-N-HAL-F05	Second Floor, Hallway, Across Room 211, Middle Fou	Flush180	26-FEB-20	1.000	ug/L
51055	51055-2-N-HAL-F05	Second Floor, Hallway, Across Room 211, Middle Fou	Flush180	26-FEB-20	1.000	ug/L
51055	51055-2-N-HAL-F05	Second Floor, Hallway, Across Room 211, Middle Fou	Flush180	26-FEB-20	1.000	ug/L
51055	51055-2-N-HAL-F05	Second Floor, Hallway, Across Room 211, Middle Fou	Initial	13-SEP-16	0.120	ppb
51055	51055-2-N-HAL-F05	Second Floor, Hallway, Across Room 211, Middle Fou	Initial	26-FEB-20	1.000	ug/L
51055	51055-2-N-HAL-F06	Second Floor, Hallway, Across Room 211, West Fount	Flush180	13-SEP-16	0.120	ppb
51055	51055-2-N-HAL-F06	Second Floor, Hallway, Across Room 211, West Fount	Flush180	13-SEP-16	0.120	ppb
51055	51055-2-N-	Second Floor, Hallway, Across	Flush180	13-SEP-16	0.120	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F06	Room 211, West Fount				
51055	51055-2-N-HAL-F06	Second Floor, Hallway, Across Room 211, West Fount	Flush180	13-SEP-16	0.120	ppb
51055	51055-2-N-HAL-F06	Second Floor, Hallway, Across Room 211, West Fount	Flush180	26-FEB-20	1.000	ug/L
51055	51055-2-N-HAL-F06	Second Floor, Hallway, Across Room 211, West Fount	Flush180	26-FEB-20	1.000	ug/L
51055	51055-2-N-HAL-F06	Second Floor, Hallway, Across Room 211, West Fount	Flush180	26-FEB-20	1.000	ug/L
51055	51055-2-N-HAL-F06	Second Floor, Hallway, Across Room 211, West Fount	Initial	13-SEP-16	0.120	ppb
51055	51055-2-N-HAL-F06	Second Floor, Hallway, Across Room 211, West Fount	Initial	26-FEB-20	1.000	ug/L
51055	51055-2-E-HAL-F01	Second Floor, Hallway, Outside Room 200, East Foun	Flush180	13-SEP-16	0.120	ppb
51055	51055-2-E-HAL-F01	Second Floor, Hallway, Outside Room 200, East Foun	Flush180	13-SEP-16	0.188	ppb
51055	51055-2-E-HAL-F01	Second Floor, Hallway, Outside Room 200, East Foun	Flush180	13-SEP-16	0.184	ppb
51055	51055-2-E-HAL-F01	Second Floor, Hallway, Outside Room 200, East Foun	Flush180	13-SEP-16	0.194	ppb
51055	51055-2-E-HAL-F01	Second Floor, Hallway, Outside Room 200, East Foun	Flush180	26-FEB-20	1.000	ug/L
51055	51055-2-E-HAL-F01	Second Floor, Hallway, Outside Room 200, East Foun	Flush180	26-FEB-20	1.000	ug/L
51055	51055-2-E-HAL-F01	Second Floor, Hallway, Outside Room 200, East Foun	Flush180	26-FEB-20	1.000	ug/L
51055	51055-2-E-HAL-F01	Second Floor, Hallway, Outside Room 200, East Foun	Initial	13-SEP-16	0.120	ppb
51055	51055-2-E-HAL-F01	Second Floor, Hallway, Outside Room 200, East Foun	Initial	26-FEB-20	1.000	ug/L
51055	51055-2-E-HAL-F02	Second Floor, Hallway, Outside Room 200, West Foun	Flush180	13-SEP-16	0.189	ppb
51055	51055-2-E-HAL-F02	Second Floor, Hallway, Outside Room 200, West Foun	Flush180	13-SEP-16	0.232	ppb
51055	51055-2-E-HAL-F02	Second Floor, Hallway, Outside Room 200, West Foun	Flush180	13-SEP-16	0.120	ppb
51055	51055-2-E-HAL-F02	Second Floor, Hallway, Outside Room 200, West Foun	Flush180	13-SEP-16	0.181	ppb
51055	51055-2-E-HAL-F02	Second Floor, Hallway, Outside Room 200, West Foun	Flush180	26-FEB-20	1.000	ug/L
51055	51055-2-E-HAL-F02	Second Floor, Hallway, Outside Room 200, West Foun	Flush180	26-FEB-20	1.000	ug/L
51055	51055-2-E-HAL-F02	Second Floor, Hallway, Outside Room 200, West Foun	Flush180	26-FEB-20	1.000	ug/L
51055	51055-2-E-HAL-F02	Second Floor, Hallway, Outside Room 200, West Foun	Flush180	26-FEB-20	1.000	ug/L
51055	51055-2-E-HAL-F02	Second Floor, Hallway, Outside Room 200, West Foun	Initial	13-SEP-16	0.120	ppb
51055	51055-2-E-HAL-F02	Second Floor, Hallway, Outside Room 200, West Foun	Initial	26-FEB-20	1.000	ug/L
51055	51055-2-W-HAL-F03	Second Floor, Hallway, Outside Room 204, Fountain	Flush180	13-SEP-16	0.798	ppb
51055	51055-2-W-HAL-F03	Second Floor, Hallway, Outside Room 204, Fountain	Flush180	13-SEP-16	0.845	ppb
51055	51055-2-W-HAL-F03	Second Floor, Hallway, Outside Room 204, Fountain	Flush180	13-SEP-16	0.813	ppb
51055	51055-2-W-HAL-F03	Second Floor, Hallway, Outside Room 204, Fountain	Flush180	13-SEP-16	0.723	ppb
51055	51055-2-W-HAL-F03	Second Floor, Hallway, Outside Room 204, Fountain	Flush180	26-FEB-20	1.000	ug/L
51055	51055-2-W-HAL-F03	Second Floor, Hallway, Outside Room 204, Fountain	Flush180	26-FEB-20	1.000	ug/L
51055	51055-2-W-HAL-F03	Second Floor, Hallway, Outside Room 204, Fountain	Flush180	26-FEB-20	1.000	ug/L
51055	51055-2-W-HAL-F03	Second Floor, Hallway, Outside Room 204, Fountain	Flush180	26-FEB-20	1.000	ug/L
51055	51055-2-W-HAL-F03	Second Floor, Hallway, Outside Room 204, Fountain	Initial	13-SEP-16	0.635	ppb
51055	51055-2-W-HAL-F03	Second Floor, Hallway, Outside Room 204, Fountain	Initial	26-FEB-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51055	51055-3-E-HAL-F01	Third Floor, Hallway, Outside Room 300, East Fount	Flush180	26-FEB-20	1.000	ug/L
51055	51055-3-E-HAL-F01	Third Floor, Hallway, Outside Room 300, East Fount	Flush180	26-FEB-20	1.000	ug/L
51055	51055-3-E-HAL-F01	Third Floor, Hallway, Outside Room 300, East Fount	Flush180	26-FEB-20	1.000	ug/L
51055	51055-3-E-HAL-F01	Third Floor, Hallway, Outside Room 300, East Fount	Flush180	26-FEB-20	1.000	ug/L
51055	51055-3-E-HAL-F01	Third Floor, Hallway, Outside Room 300, East Fount	Flush180	13-SEP-16	0.120	ppb
51055	51055-3-E-HAL-F01	Third Floor, Hallway, Outside Room 300, East Fount	Flush180	13-SEP-16	0.120	ppb
51055	51055-3-E-HAL-F01	Third Floor, Hallway, Outside Room 300, East Fount	Flush180	13-SEP-16	0.120	ppb
51055	51055-3-E-HAL-F01	Third Floor, Hallway, Outside Room 300, East Fount	Flush180	13-SEP-16	0.476	ppb
51055	51055-3-E-HAL-F01	Third Floor, Hallway, Outside Room 300, East Fount	Initial	26-FEB-20	1.000	ug/L
51055	51055-3-E-HAL-F01	Third Floor, Hallway, Outside Room 300, East Fount	Initial	13-SEP-16	0.120	ppb
51055	51055-3-E-HAL-F02	Third Floor, Hallway, Outside Room 300, West Fount	Flush180	24-JUL-20	1.000	ug/L
51055	51055-3-E-HAL-F02	Third Floor, Hallway, Outside Room 300, West Fount	Flush180	26-FEB-20	1.000	ug/L
51055	51055-3-E-HAL-F02	Third Floor, Hallway, Outside Room 300, West Fount	Flush180	26-FEB-20	1.000	ug/L
51055	51055-3-E-HAL-F02	Third Floor, Hallway, Outside Room 300, West Fount	Flush180	26-FEB-20	1.000	ug/L
51055	51055-3-E-HAL-F02	Third Floor, Hallway, Outside Room 300, West Fount	Flush180	13-SEP-16	0.162	ppb
51055	51055-3-E-HAL-F02	Third Floor, Hallway, Outside Room 300, West Fount	Flush180	13-SEP-16	0.169	ppb
51055	51055-3-E-HAL-F02	Third Floor, Hallway, Outside Room 300, West Fount	Flush180	13-SEP-16	0.168	ppb
51055	51055-3-E-HAL-F02	Third Floor, Hallway, Outside Room 300, West Fount	Flush180	13-SEP-16	0.153	ppb
51055	51055-3-E-HAL-F02	Third Floor, Hallway, Outside Room 300, West Fount	Initial	24-JUL-20	1.000	ug/L
51055	51055-3-E-HAL-F02	Third Floor, Hallway, Outside Room 300, West Fount	Initial	26-FEB-20	1.000	ug/L
51055	51055-3-E-HAL-F02	Third Floor, Hallway, Outside Room 300, West Fount	Initial	13-SEP-16	0.228	ppb
51055	51055-3-E-HAL-F04	Third Floor, Hallway, Outside Room 311, Middle Fou	Flush180	26-FEB-20	1.000	ug/L
51055	51055-3-E-HAL-F04	Third Floor, Hallway, Outside Room 311, Middle Fou	Flush180	26-FEB-20	1.000	ug/L
51055	51055-3-E-HAL-F04	Third Floor, Hallway, Outside Room 311, Middle Fou	Flush180	26-FEB-20	1.000	ug/L
51055	51055-3-E-HAL-F04	Third Floor, Hallway, Outside Room 311, Middle Fou	Flush180	13-SEP-16	0.120	ppb
51055	51055-3-E-HAL-F04	Third Floor, Hallway, Outside Room 311, Middle Fou	Flush180	13-SEP-16	0.120	ppb
51055	51055-3-E-HAL-F04	Third Floor, Hallway, Outside Room 311, Middle Fou	Flush180	13-SEP-16	0.120	ppb
51055	51055-3-E-HAL-F04	Third Floor, Hallway, Outside Room 311, Middle Fou	Flush180	13-SEP-16	0.120	ppb
51055	51055-3-E-HAL-F04	Third Floor, Hallway, Outside Room 311, Middle Fou	Initial	26-FEB-20	1.000	ug/L
51055	51055-3-E-HAL-F04	Third Floor, Hallway, Outside Room 311, Middle Fou	Initial	13-SEP-16	0.120	ppb
51055	51055-3-N-HAL-F03	Third Floor, Hallway, Outside Room 311, West Fount	Flush180	13-SEP-16	0.120	ppb
51055	51055-3-N-HAL-F03	Third Floor, Hallway, Outside Room 311, West Fount	Flush180	13-SEP-16	0.120	ppb
51055	51055-3-N-HAL-F03	Third Floor, Hallway, Outside Room 311, West Fount	Flush180	24-JUL-20	1.000	ug/L
51055	51055-3-E-HAL-F05	Third Floor, Hallway, Outside Room 311, West Fount	Flush180	26-FEB-20	1.000	ug/L
51055	51055-3-E-HAL-F05	Third Floor, Hallway, Outside Room 311, West Fount	Flush180	26-FEB-20	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51055	51055-3-E-HAL-F05	Third Floor, Hallway, Outside Room 311, West Fount	Flush180	26-FEB-20	1.000	ug/L
51055	51055-3-E-HAL-F05	Third Floor, Hallway, Outside Room 311, West Fount	Flush180	26-FEB-20	1.000	ug/L
51055	51055-3-N-HAL-F03	Third Floor, Hallway, Outside Room 311, West Fount	Flush180	26-FEB-20	1.000	ug/L
51055	51055-3-N-HAL-F03	Third Floor, Hallway, Outside Room 311, West Fount	Flush180	26-FEB-20	1.000	ug/L
51055	51055-3-N-HAL-F03	Third Floor, Hallway, Outside Room 311, West Fount	Flush180	26-FEB-20	1.000	ug/L
51055	51055-3-N-HAL-F03	Third Floor, Hallway, Outside Room 311, West Fount	Flush180	26-FEB-20	1.000	ug/L
51055	51055-3-E-HAL-F05	Third Floor, Hallway, Outside Room 311, West Fount	Flush180	13-SEP-16	0.120	ppb
51055	51055-3-E-HAL-F05	Third Floor, Hallway, Outside Room 311, West Fount	Flush180	13-SEP-16	0.120	ppb
51055	51055-3-E-HAL-F05	Third Floor, Hallway, Outside Room 311, West Fount	Flush180	13-SEP-16	0.120	ppb
51055	51055-3-E-HAL-F05	Third Floor, Hallway, Outside Room 311, West Fount	Flush180	13-SEP-16	0.120	ppb
51055	51055-3-N-HAL-F03	Third Floor, Hallway, Outside Room 311, West Fount	Flush180	13-SEP-16	0.120	ppb
51055	51055-3-N-HAL-F03	Third Floor, Hallway, Outside Room 311, West Fount	Flush180	13-SEP-16	0.120	ppb
51055	51055-3-N-HAL-F03	Third Floor, Hallway, Outside Room 311, West Fount	Initial	13-SEP-16	0.120	ppb
51055	51055-3-N-HAL-F03	Third Floor, Hallway, Outside Room 311, West Fount	Initial	24-JUL-20	1.000	ug/L
51055	51055-3-E-HAL-F05	Third Floor, Hallway, Outside Room 311, West Fount	Initial	26-FEB-20	1.000	ug/L
51055	51055-3-N-HAL-F03	Third Floor, Hallway, Outside Room 311, West Fount	Initial	26-FEB-20	1.000	ug/L
51055	51055-3-E-HAL-F05	Third Floor, Hallway, Outside Room 311, West Fount	Initial	13-SEP-16	0.120	ppb