



Sep 10, 2024

COOPER

1624 W 19TH ST, Chicago IL 60608.

Dear **COOPER** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

COOPER

1624 W 19TH ST, Chicago IL 60608.

Estimadas familias de **COOPER**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarle y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
50008	50008-1-BAT-S01	50008-1-BAT-S01-01	Flush180	20-AUG-20	1.940	ug/L
50008	50008-1-BAT-S01	50008-1-BAT-S01-01	Initial	20-AUG-20	1.390	ug/L
50008	50008-1-KIT-KS02	Annex- Kitchen North Wall, Sink 2	Flush180	04-JUN-16	0.943	ppb
50008	50008-1-KIT-KS02	Annex- Kitchen North Wall, Sink 2	Flush180	04-JUN-16	1.720	ppb
50008	50008-1-KIT-KS02	Annex- Kitchen North Wall, Sink 2	Flush180	04-JUN-16	2.130	ppb
50008	50008-1-KIT-KS02	Annex- Kitchen North Wall, Sink 2	Flush180	04-JUN-16	1.130	ppb
50008	50008-1-KIT-KS02	Annex- Kitchen North Wall, Sink 2	Initial	04-JUN-16	1.600	ppb
50008	50008-1-KIT-KS01	Annex- Kitchen West, Sink 1	Flush180	04-JUN-16	0.901	ppb
50008	50008-1-KIT-KS01	Annex- Kitchen West, Sink 1	Flush180	04-JUN-16	0.956	ppb
50008	50008-1-KIT-KS01	Annex- Kitchen West, Sink 1	Flush180	04-JUN-16	0.862	ppb
50008	50008-1-KIT-KS01	Annex- Kitchen West, Sink 1	Flush180	04-JUN-16	0.859	ppb
50008	50008-1-KIT-KS01	Annex- Kitchen West, Sink 1	Initial	04-JUN-16	1.950	ppb
50008	50008-1-HAL-F03	Annex- Outside Gym, Fountain 1	Flush180	04-JUN-16	0.901	ppb
50008	50008-1-HAL-F03	Annex- Outside Gym, Fountain 1	Flush180	04-JUN-16	0.916	ppb
50008	50008-1-HAL-F03	Annex- Outside Gym, Fountain 1	Flush180	04-JUN-16	0.832	ppb
50008	50008-1-HAL-F03	Annex- Outside Gym, Fountain 1	Flush180	04-JUN-16	0.852	ppb
50008	50008-1-HAL-F03	Annex- Outside Gym, Fountain 1	Initial	04-JUN-16	0.620	ppb
50008	50008-1-HAL-F04	Annex- Outside Gym, Fountain 2	Flush180	04-JUN-16	0.883	ppb
50008	50008-1-HAL-F04	Annex- Outside Gym, Fountain 2	Flush180	04-JUN-16	1.050	ppb
50008	50008-1-HAL-F04	Annex- Outside Gym, Fountain 2	Flush180	04-JUN-16	1.060	ppb
50008	50008-1-HAL-F04	Annex- Outside Gym, Fountain 2	Flush180	04-JUN-16	0.523	ppb
50008	50008-1-HAL-F04	Annex- Outside Gym, Fountain 2	Initial	04-JUN-16	1.040	ppb
50008	50008-1-HAL-F05	Annex- Outside Room 124, Fountain 1	Flush180	04-JUN-16	0.982	ppb
50008	50008-1-HAL-F05	Annex- Outside Room 124, Fountain 1	Flush180	04-JUN-16	0.797	ppb
50008	50008-1-HAL-F05	Annex- Outside Room 124, Fountain 1	Flush180	04-JUN-16	0.829	ppb
50008	50008-1-HAL-F05	Annex- Outside Room 124, Fountain 1	Flush180	04-JUN-16	1.760	ppb
50008	50008-1-HAL-F05	Annex- Outside Room 124, Fountain 1	Initial	04-JUN-16	0.748	ppb
50008	50008-1-HAL-F06	Annex- Outside Room 124, Fountain 2	Flush180	04-JUN-16	1.330	ppb
50008	50008-1-HAL-F06	Annex- Outside Room 124, Fountain 2	Flush180	04-JUN-16	0.728	ppb
50008	50008-1-HAL-F06	Annex- Outside Room 124, Fountain 2	Flush180	04-JUN-16	0.742	ppb
50008	50008-1-HAL-F06	Annex- Outside Room 124, Fountain 2	Flush180	04-JUN-16	0.787	ppb
50008	50008-1-HAL-F06	Annex- Outside Room 124, Fountain 2	Initial	04-JUN-16	0.713	ppb
50008	50008-2-HAL-F03	Annex- Outside Room 216, Fountain 1	Flush180	04-JUN-16	0.607	ppb
50008	50008-2-HAL-F03	Annex- Outside Room 216, Fountain 1	Flush180	04-JUN-16	0.828	ppb
50008	50008-2-HAL-F03	Annex- Outside Room 216, Fountain 1	Flush180	04-JUN-16	0.912	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
50008	50008-2-HAL-F03	Annex- Outside Room 216, Fountain 1	Flush180	04-JUN-16	0.864	ppb
50008	50008-2-HAL-F03	Annex- Outside Room 216, Fountain 1	Initial	04-JUN-16	0.188	ppb
50008	50008-2-HAL-F04	Annex- Outside Room 216, Fountain 2	Flush180	04-JUN-16	0.555	ppb
50008	50008-2-HAL-F04	Annex- Outside Room 216, Fountain 2	Flush180	04-JUN-16	0.624	ppb
50008	50008-2-HAL-F04	Annex- Outside Room 216, Fountain 2	Flush180	04-JUN-16	0.387	ppb
50008	50008-2-HAL-F04	Annex- Outside Room 216, Fountain 2	Flush180	04-JUN-16	0.529	ppb
50008	50008-2-HAL-F04	Annex- Outside Room 216, Fountain 2	Initial	04-JUN-16	0.197	ppb
50008	50008-2-HAL-F01	Annex- Outside Room 230, Fountain 1	Flush180	04-JUN-16	1.290	ppb
50008	50008-2-HAL-F01	Annex- Outside Room 230, Fountain 1	Flush180	04-JUN-16	1.350	ppb
50008	50008-2-HAL-F01	Annex- Outside Room 230, Fountain 1	Flush180	04-JUN-16	1.640	ppb
50008	50008-2-HAL-F01	Annex- Outside Room 230, Fountain 1	Flush180	04-JUN-16	1.510	ppb
50008	50008-2-HAL-F01	Annex- Outside Room 230, Fountain 1	Initial	04-JUN-16	1.050	ppb
50008	50008-2-HAL-F02	Annex- Outside Room, Fountain 2	Flush180	04-JUN-16	0.965	ppb
50008	50008-2-HAL-F02	Annex- Outside Room, Fountain 2	Flush180	04-JUN-16	1.460	ppb
50008	50008-2-HAL-F02	Annex- Outside Room, Fountain 2	Flush180	04-JUN-16	0.947	ppb
50008	50008-2-HAL-F02	Annex- Outside Room, Fountain 2	Flush180	04-JUN-16	0.907	ppb
50008	50008-2-HAL-F02	Annex- Outside Room, Fountain 2	Initial	04-JUN-16	0.869	ppb
50008	50008-3-HAL-F01	by room 305	Flush180	20-AUG-20	1.000	ug/L
50008	50008-3-HAL-F01	by room 305	Initial	20-AUG-20	2.120	ug/L
51232	51232-1-105-BF01	Main - Inside Room 105, Bottle Filler	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-105-BF01	Main - Inside Room 105, Bottle Filler	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-105-BF01	Main - Inside Room 105, Bottle Filler	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-105-BF01	Main - Inside Room 105, Bottle Filler	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-105-BF01	Main - Inside Room 105, Bottle Filler	Initial	22-SEP-22	1.000	ug/L
51232	51232-1-105-F01	Main - Inside Room 105, Fountain	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-105-F01	Main - Inside Room 105, Fountain	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-105-F01	Main - Inside Room 105, Fountain	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-105-F01	Main - Inside Room 105, Fountain	Initial	22-SEP-22	1.000	ug/L
51232	51232-1-105-S01	Main - Inside Room 105, Left Sink	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-105-S01	Main - Inside Room 105, Left Sink	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-105-S01	Main - Inside Room 105, Left Sink	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-105-S01	Main - Inside Room 105, Left Sink	Initial	22-SEP-22	1.000	ug/L
51232	51232-1-105-S02	Main - Inside Room 105, Right Sink	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-105-S02	Main - Inside Room 105, Right Sink	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-105-S02	Main - Inside Room 105, Right Sink	Flush180	22-SEP-22	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51232	51232-1-105-S02	Main - Inside Room 105, Right Sink	Initial	22-SEP-22	1.700	ug/L
51232	51232-1-106-BF01	Main - Inside Room 106, Bottle Filler	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-106-BF01	Main - Inside Room 106, Bottle Filler	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-106-BF01	Main - Inside Room 106, Bottle Filler	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-106-BF01	Main - Inside Room 106, Bottle Filler	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-106-BF01	Main - Inside Room 106, Bottle Filler	Initial	22-SEP-22	1.000	ug/L
51232	51232-1-106-F02	Main - Inside Room 106, Fountain	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-106-F02	Main - Inside Room 106, Fountain	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-106-F02	Main - Inside Room 106, Fountain	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-106-F02	Main - Inside Room 106, Fountain	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-106-F02	Main - Inside Room 106, Fountain	Initial	22-SEP-22	1.000	ug/L
51232	51232-1-106-S03	Main - Inside Room 106, Left Sink	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-106-S03	Main - Inside Room 106, Left Sink	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-106-S03	Main - Inside Room 106, Left Sink	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-106-S03	Main - Inside Room 106, Left Sink	Initial	22-SEP-22	1.000	ug/L
51232	51232-1-106-S04	Main - Inside Room 106, Right Sink	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-106-S04	Main - Inside Room 106, Right Sink	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-106-S04	Main - Inside Room 106, Right Sink	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-106-S04	Main - Inside Room 106, Right Sink	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-106-S04	Main - Inside Room 106, Right Sink	Initial	22-SEP-22	1.000	ug/L
51232	51232-1-107-BF01	Main - Inside Room 107, Bottle Filler	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-107-BF01	Main - Inside Room 107, Bottle Filler	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-107-BF01	Main - Inside Room 107, Bottle Filler	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-107-BF01	Main - Inside Room 107, Bottle Filler	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-107-BF01	Main - Inside Room 107, Bottle Filler	Initial	22-SEP-22	1.000	ug/L
51232	51232-1-107-F01	Main - Inside Room 107, Fountain	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-107-F01	Main - Inside Room 107, Fountain	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-107-F01	Main - Inside Room 107, Fountain	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-107-F01	Main - Inside Room 107, Fountain	Initial	22-SEP-22	1.000	ug/L
51232	51232-1-107-S01	Main - Inside Room 107, Left Sink	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-107-S01	Main - Inside Room 107, Left Sink	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-107-S01	Main - Inside Room 107, Left Sink	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-107-S01	Main - Inside Room 107, Left Sink	Initial	22-SEP-22	1.000	ug/L
51232	51232-1-107-S02	Main - Inside Room 107, Right Sink	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-107-	Main - Inside Room 107, Right	Flush180	22-SEP-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S02	Sink				
51232	51232-1-107-S02	Main - Inside Room 107, Right Sink	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-107-S02	Main - Inside Room 107, Right Sink	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-107-S02	Main - Inside Room 107, Right Sink	Initial	22-SEP-22	1.310	ug/L
51232	51232-1-108-BF01	Main - Inside Room 108, Bottle Filler	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-108-BF01	Main - Inside Room 108, Bottle Filler	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-108-BF01	Main - Inside Room 108, Bottle Filler	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-108-BF01	Main - Inside Room 108, Bottle Filler	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-108-BF01	Main - Inside Room 108, Bottle Filler	Initial	22-SEP-22	1.000	ug/L
51232	51232-1-108-F01	Main - Inside Room 108, Fountain	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-108-F01	Main - Inside Room 108, Fountain	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-108-F01	Main - Inside Room 108, Fountain	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-108-F01	Main - Inside Room 108, Fountain	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-108-F01	Main - Inside Room 108, Fountain	Initial	22-SEP-22	1.000	ug/L
51232	51232-1-108-S01	Main - Inside Room 108, Sink	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-108-S01	Main - Inside Room 108, Sink	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-108-S01	Main - Inside Room 108, Sink	Flush180	22-SEP-22	1.000	ug/L
51232	51232-1-108-S01	Main - Inside Room 108, Sink	Initial	22-SEP-22	1.000	ug/L
51232	51232-B-KIT-KS01	Main- Basement Kitchen East, Sink	Flush180	04-JUN-16	0.484	ppb
51232	51232-B-KIT-KS01	Main- Basement Kitchen East, Sink	Flush180	04-JUN-16	1.180	ppb
51232	51232-B-KIT-KS01	Main- Basement Kitchen East, Sink	Flush180	04-JUN-16	2.000	ppb
51232	51232-B-KIT-KS01	Main- Basement Kitchen East, Sink	Flush180	04-JUN-16	0.567	ppb
51232	51232-B-KIT-KS01	Main- Basement Kitchen East, Sink	Flush180	20-AUG-20	2.240	ug/L
51232	51232-B-KIT-KS01	Main- Basement Kitchen East, Sink	Initial	04-JUN-16	0.452	ppb
51232	51232-B-KIT-KS01	Main- Basement Kitchen East, Sink	Initial	20-AUG-20	4.170	ug/L
51232	51232-B-HAL-F03	Main- Basement Outside Lunchroom, Fountain 1	Flush180	04-JUN-16	0.755	ppb
51232	51232-B-HAL-F03	Main- Basement Outside Lunchroom, Fountain 1	Flush180	04-JUN-16	0.783	ppb
51232	51232-B-HAL-F03	Main- Basement Outside Lunchroom, Fountain 1	Flush180	04-JUN-16	0.692	ppb
51232	51232-B-HAL-F03	Main- Basement Outside Lunchroom, Fountain 1	Flush180	04-JUN-16	0.842	ppb
51232	51232-B-HAL-F03	Main- Basement Outside Lunchroom, Fountain 1	Initial	04-JUN-16	0.581	ppb
51232	51232-B-HAL-F04	Main- Basement Outside Lunchroom, Fountain 2	Flush180	04-JUN-16	0.472	ppb
51232	51232-B-HAL-F04	Main- Basement Outside Lunchroom, Fountain 2	Flush180	04-JUN-16	0.460	ppb
51232	51232-B-HAL-F04	Main- Basement Outside Lunchroom, Fountain 2	Flush180	04-JUN-16	0.470	ppb
51232	51232-B-HAL-F04	Main- Basement Outside Lunchroom, Fountain 2	Flush180	04-JUN-16	0.475	ppb
51232	51232-B-HAL-F04	Main- Basement Outside Lunchroom, Fountain 2	Initial	04-JUN-16	0.452	ppb
51232	51232-1-105-S06	Main- Inside Room 105, Sink	Flush180	04-JUN-16	1.000	ppb
51232	51232-1-105-	Main- Inside Room 105, Sink	Flush180	04-JUN-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S06					
51232	51232-1-105-S06	Main- Inside Room 105, Sink	Flush180	04-JUN-16	0.137	ppb
51232	51232-1-105-S06	Main- Inside Room 105, Sink	Flush180	04-JUN-16	1.000	ppb
51232	51232-1-105-S06	Main- Inside Room 105, Sink	Initial	04-JUN-16	1.000	ppb
51232	51232-1-106-F01	Main- Inside Room 106, Fountian	Flush180	04-JUN-16	0.123	ppb
51232	51232-1-106-F01	Main- Inside Room 106, Fountian	Flush180	04-JUN-16	0.330	ppb
51232	51232-1-106-F01	Main- Inside Room 106, Fountian	Flush180	04-JUN-16	1.000	ppb
51232	51232-1-106-F01	Main- Inside Room 106, Fountian	Flush180	04-JUN-16	0.436	ppb
51232	51232-1-106-F01	Main- Inside Room 106, Fountian	Initial	04-JUN-16	0.399	ppb
51232	51232-1-106-S02	Main- Inside Room 106, Sink	Flush180	04-JUN-16	0.150	ppb
51232	51232-1-106-S02	Main- Inside Room 106, Sink	Flush180	04-JUN-16	0.458	ppb
51232	51232-1-106-S02	Main- Inside Room 106, Sink	Flush180	04-JUN-16	0.392	ppb
51232	51232-1-106-S02	Main- Inside Room 106, Sink	Flush180	04-JUN-16	0.361	ppb
51232	51232-1-106-S02	Main- Inside Room 106, Sink	Initial	04-JUN-16	0.389	ppb
51232	51232-1-108-F03	Main- Inside Room 108, Fountian	Flush180	04-JUN-16	1.290	ppb
51232	51232-1-108-F03	Main- Inside Room 108, Fountian	Flush180	04-JUN-16	1.080	ppb
51232	51232-1-108-F03	Main- Inside Room 108, Fountian	Flush180	04-JUN-16	1.130	ppb
51232	51232-1-108-F03	Main- Inside Room 108, Fountian	Flush180	04-JUN-16	1.160	ppb
51232	51232-1-108-F03	Main- Inside Room 108, Fountian	Initial	04-JUN-16	2.860	ppb
51232	51232-1-108-S04	Main- Inside Room 108, Sink	Flush180	04-JUN-16	0.202	ppb
51232	51232-1-108-S04	Main- Inside Room 108, Sink	Flush180	04-JUN-16	0.192	ppb
51232	51232-1-108-S04	Main- Inside Room 108, Sink	Flush180	04-JUN-16	0.511	ppb
51232	51232-1-108-S04	Main- Inside Room 108, Sink	Flush180	04-JUN-16	1.000	ppb
51232	51232-1-108-S04	Main- Inside Room 108, Sink	Initial	04-JUN-16	0.174	ppb
51232	51232-2-HAL-F01	Main- Outside Room 203, Fountian 1	Flush180	21-OCT-20	1.190	ug/L
51232	51232-2-HAL-F01	Main- Outside Room 203, Fountian 1	Flush180	21-OCT-20	1.040	ug/L
51232	51232-2-HAL-F01	Main- Outside Room 203, Fountian 1	Flush180	21-OCT-20	1.000	ug/L
51232	51232-2-HAL-F01	Main- Outside Room 203, Fountian 1	Flush180	21-OCT-20	1.000	ug/L
51232	51232-2-HAL-F01	Main- Outside Room 203, Fountian 1	Flush180	20-AUG-20	4.400	ug/L
51232	51232-2-HAL-F01	Main- Outside Room 203, Fountian 1	Flush180	04-JUN-16	0.826	ppb
51232	51232-2-HAL-F01	Main- Outside Room 203, Fountian 1	Flush180	04-JUN-16	1.650	ppb
51232	51232-2-HAL-F01	Main- Outside Room 203, Fountian 1	Flush180	04-JUN-16	1.170	ppb
51232	51232-2-HAL-F01	Main- Outside Room 203, Fountian 1	Flush180	04-JUN-16	1.150	ppb
51232	51232-2-HAL-F01	Main- Outside Room 203, Fountian 1	Initial	21-OCT-20	1.000	ug/L
51232	51232-2-HAL-F01	Main- Outside Room 203, Fountian 1	Initial	20-AUG-20	16.300	ug/L
51232	51232-2-HAL-F01	Main- Outside Room 203, Fountian 1	Initial	04-JUN-16	0.934	ppb
51232	51232-2-HAL-F02	Main- Outside Room 203, Fountian 2	Flush180	04-JUN-16	0.552	ppb
51232	51232-2-HAL-F02	Main- Outside Room 203, Fountian 2	Flush180	04-JUN-16	0.637	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51232	51232-2-HAL-F02	Main- Outside Room 203, Fountain 2	Flush180	04-JUN-16	0.695	ppb
51232	51232-2-HAL-F02	Main- Outside Room 203, Fountain 2	Flush180	04-JUN-16	0.638	ppb
51232	51232-2-HAL-F02	Main- Outside Room 203, Fountain 2	Initial	04-JUN-16	0.284	ppb
51232	51232-3-HAL-F03	Main- Outside Room 303, Fountain 1	Flush180	04-JUN-16	0.835	ppb
51232	51232-3-HAL-F03	Main- Outside Room 303, Fountain 1	Flush180	04-JUN-16	0.570	ppb
51232	51232-3-HAL-F03	Main- Outside Room 303, Fountain 1	Flush180	04-JUN-16	0.704	ppb
51232	51232-3-HAL-F03	Main- Outside Room 303, Fountain 1	Flush180	04-JUN-16	0.800	ppb
51232	51232-3-HAL-F03	Main- Outside Room 303, Fountain 1	Initial	04-JUN-16	0.338	ppb
51232	51232-3-HAL-F04	Main- Outside Room 303, Fountain 2	Flush180	04-JUN-16	0.525	ppb
51232	51232-3-HAL-F04	Main- Outside Room 303, Fountain 2	Flush180	04-JUN-16	0.755	ppb
51232	51232-3-HAL-F04	Main- Outside Room 303, Fountain 2	Flush180	04-JUN-16	0.609	ppb
51232	51232-3-HAL-F04	Main- Outside Room 303, Fountain 2	Flush180	04-JUN-16	0.675	ppb
51232	51232-3-HAL-F51232-3-HAL-F04	Main- Outside Room 303, Fountain 2	Initial	04-JUN-16	0.808	ppb
51232	51232-3-HAL-F01	Main- Outside Room 305, Fountain 1	Flush180	04-JUN-16	0.566	ppb
51232	51232-3-HAL-F01	Main- Outside Room 305, Fountain 1	Flush180	04-JUN-16	0.557	ppb
51232	51232-3-HAL-F01	Main- Outside Room 305, Fountain 1	Flush180	04-JUN-16	0.634	ppb
51232	51232-3-HAL-F01	Main- Outside Room 305, Fountain 1	Flush180	04-JUN-16	0.545	ppb
51232	51232-3-HAL-F01	Main- Outside Room 305, Fountain 1	Initial	04-JUN-16	0.572	ppb
51232	51232-3-HAL-F02	Main- Outside Room 305, Fountain 2	Flush180	04-JUN-16	0.226	ppb
51232	51232-3-HAL-F02	Main- Outside Room 305, Fountain 2	Flush180	04-JUN-16	0.489	ppb
51232	51232-3-HAL-F02	Main- Outside Room 305, Fountain 2	Flush180	04-JUN-16	0.745	ppb
51232	51232-3-HAL-F02	Main- Outside Room 305, Fountain 2	Flush180	04-JUN-16	0.744	ppb
51232	51232-3-HAL-F02	Main- Outside Room 305, Fountain 2	Initial	04-JUN-16	1.000	ppb