



Sep 10, 2024

CRANE MEDICAL HS

2245 W JACKSON BLVD, Chicago IL 60612.

Dear **CRANE MEDICAL HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

CRANE MEDICAL HS

2245 W JACKSON BLVD, Chicago IL 60612.

Estimadas familias de **CRANE MEDICAL HS:**

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51564	51564-1-HAL-F06	1st Floor Hallway Across Rm. 105 Single Fountain	Flush180	27-OCT-16	0.174	ppb
51564	51564-1-HAL-F06	1st Floor Hallway Across Rm. 105 Single Fountain	Flush180	27-OCT-16	0.177	ppb
51564	51564-1-HAL-F06	1st Floor Hallway Across Rm. 105 Single Fountain	Flush180	27-OCT-16	0.162	ppb
51564	51564-1-HAL-F06	1st Floor Hallway Across Rm. 105 Single Fountain	Flush180	27-OCT-16	0.167	ppb
51564	51564-1-HAL-F06	1st Floor Hallway Across Rm. 105 Single Fountain	Flush180	27-JAN-23	1.000	ug/L
51564	51564-1-HAL-F06	1st Floor Hallway Across Rm. 105 Single Fountain	Flush180	27-JAN-23	1.000	ug/L
51564	51564-1-HAL-F06	1st Floor Hallway Across Rm. 105 Single Fountain	Flush180	27-JAN-23	1.000	ug/L
51564	51564-1-HAL-F06	1st Floor Hallway Across Rm. 105 Single Fountain	Flush180	27-JAN-23	1.000	ug/L
51564	51564-1-HAL-F06	1st Floor Hallway Across Rm. 105 Single Fountain	Initial	27-OCT-16	0.232	ppb
51564	51564-1-HAL-F06	1st Floor Hallway Across Rm. 105 Single Fountain	Initial	27-JAN-23	1.000	ug/L
51564	51564-1-HAL-F07	1st Floor Hallway Across Rm. 110 Single Fountain	Flush180	27-JAN-23	15.700	ug/L
51564	51564-1-HAL-F07	1st Floor Hallway Across Rm. 110 Single Fountain	Flush180	27-OCT-16	1.260	ppb
51564	51564-1-HAL-F07	1st Floor Hallway Across Rm. 110 Single Fountain	Flush180	27-OCT-16	1.550	ppb
51564	51564-1-HAL-F07	1st Floor Hallway Across Rm. 110 Single Fountain	Flush180	27-OCT-16	0.750	ppb
51564	51564-1-HAL-F07	1st Floor Hallway Across Rm. 110 Single Fountain	Flush180	27-OCT-16	3.300	ppb
51564	51564-1-HAL-F07	1st Floor Hallway Across Rm. 110 Single Fountain	Flush180	27-JAN-23	14.400	ug/L
51564	51564-1-HAL-F07	1st Floor Hallway Across Rm. 110 Single Fountain	Flush180	27-JAN-23	5.350	ug/L
51564	51564-1-HAL-F07	1st Floor Hallway Across Rm. 110 Single Fountain	Flush180	27-JAN-23	9.530	ug/L
51564	51564-1-HAL-F07	1st Floor Hallway Across Rm. 110 Single Fountain	Flush180	07-APR-23	3.030	ug/L
51564	51564-1-HAL-F07	1st Floor Hallway Across Rm. 110 Single Fountain	Flush180	07-APR-23	1.870	ug/L
51564	51564-1-HAL-F07	1st Floor Hallway Across Rm. 110 Single Fountain	Flush180	07-APR-23	3.290	ug/L
51564	51564-1-HAL-F07	1st Floor Hallway Across Rm. 110 Single Fountain	Flush180	07-APR-23	5.810	ug/L
51564	51564-1-HAL-F07	1st Floor Hallway Across Rm. 110 Single Fountain	Flush180	02-MAY-23	1.000	ug/L
51564	51564-1-HAL-F07	1st Floor Hallway Across Rm. 110 Single Fountain	Flush180	02-MAY-23	1.000	ug/L
51564	51564-1-HAL-F07	1st Floor Hallway Across Rm. 110 Single Fountain	Flush180	02-MAY-23	1.000	ug/L
51564	51564-1-HAL-F07	1st Floor Hallway Across Rm. 110 Single Fountain	Flush180	02-MAY-23	1.000	ug/L
51564	51564-1-HAL-F07	1st Floor Hallway Across Rm. 110 Single Fountain	Initial	27-OCT-16	1.660	ppb
51564	51564-1-HAL-F07	1st Floor Hallway Across Rm. 110 Single Fountain	Initial	27-JAN-23	18.300	ug/L
51564	51564-1-HAL-F07	1st Floor Hallway Across Rm. 110 Single Fountain	Initial	07-APR-23	2.280	ug/L
51564	51564-1-HAL-F07	1st Floor Hallway Across Rm. 110 Single Fountain	Initial	02-MAY-23	1.000	ug/L
51564	51564-1-HAL-F05	1st Floor Hallway Outside Rm. 101 Left Fountain	Flush180	27-OCT-16	0.766	ppb
51564	51564-1-HAL-F05	1st Floor Hallway Outside Rm. 101 Left Fountain	Flush180	27-OCT-16	0.419	ppb
51564	51564-1-HAL-F05	1st Floor Hallway Outside Rm. 101 Left Fountain	Flush180	27-OCT-16	2.000	ppb
51564	51564-1-HAL-F05	1st Floor Hallway Outside Rm. 101 Left Fountain	Flush180	27-OCT-16	0.367	ppb
51564	51564-1-HAL-F05	1st Floor Hallway Outside Rm. 101 Left Fountain	Flush180	27-JAN-23	2.500	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51564	51564-1-HAL-F05	1st Floor Hallway Outside Rm. 101 Left Fountain	Flush180	27-JAN-23	1.850	ug/L
51564	51564-1-HAL-F05	1st Floor Hallway Outside Rm. 101 Left Fountain	Flush180	27-JAN-23	1.320	ug/L
51564	51564-1-HAL-F05	1st Floor Hallway Outside Rm. 101 Left Fountain	Flush180	27-JAN-23	1.240	ug/L
51564	51564-1-HAL-F05	1st Floor Hallway Outside Rm. 101 Left Fountain	Initial	27-OCT-16	1.630	ppb
51564	51564-1-HAL-F05	1st Floor Hallway Outside Rm. 101 Left Fountain	Initial	27-JAN-23	3.540	ug/L
51564	51564-1-HAL-F04	1st Floor Hallway Outside Rm. 101 Right Fountain	Flush180	27-OCT-16	2.810	ppb
51564	51564-1-HAL-F04	1st Floor Hallway Outside Rm. 101 Right Fountain	Flush180	27-OCT-16	2.150	ppb
51564	51564-1-HAL-F04	1st Floor Hallway Outside Rm. 101 Right Fountain	Flush180	27-OCT-16	1.870	ppb
51564	51564-1-HAL-F04	1st Floor Hallway Outside Rm. 101 Right Fountain	Flush180	27-OCT-16	3.550	ppb
51564	51564-1-HAL-F04	1st Floor Hallway Outside Rm. 101 Right Fountain	Flush180	27-JAN-23	1.050	ug/L
51564	51564-1-HAL-F04	1st Floor Hallway Outside Rm. 101 Right Fountain	Flush180	27-JAN-23	1.000	ug/L
51564	51564-1-HAL-F04	1st Floor Hallway Outside Rm. 101 Right Fountain	Flush180	27-JAN-23	1.000	ug/L
51564	51564-1-HAL-F04	1st Floor Hallway Outside Rm. 101 Right Fountain	Flush180	27-JAN-23	1.000	ug/L
51564	51564-1-HAL-F04	1st Floor Hallway Outside Rm. 101 Right Fountain	Initial	27-OCT-16	2.350	ppb
51564	51564-1-HAL-F04	1st Floor Hallway Outside Rm. 101 Right Fountain	Initial	27-JAN-23	1.460	ug/L
51564	51564-1-HAL-F02	1st Floor Hallway Outside Rm. 117 Left Fountain	Flush180	27-OCT-16	0.282	ppb
51564	51564-1-HAL-F02	1st Floor Hallway Outside Rm. 117 Left Fountain	Flush180	27-OCT-16	0.287	ppb
51564	51564-1-HAL-F02	1st Floor Hallway Outside Rm. 117 Left Fountain	Flush180	27-OCT-16	0.265	ppb
51564	51564-1-HAL-F02	1st Floor Hallway Outside Rm. 117 Left Fountain	Flush180	27-OCT-16	0.262	ppb
51564	51564-1-HAL-F02	1st Floor Hallway Outside Rm. 117 Left Fountain	Flush180	27-JAN-23	1.000	ug/L
51564	51564-1-HAL-F02	1st Floor Hallway Outside Rm. 117 Left Fountain	Flush180	27-JAN-23	1.000	ug/L
51564	51564-1-HAL-F02	1st Floor Hallway Outside Rm. 117 Left Fountain	Flush180	27-JAN-23	1.000	ug/L
51564	51564-1-HAL-F02	1st Floor Hallway Outside Rm. 117 Left Fountain	Flush180	27-JAN-23	1.000	ug/L
51564	51564-1-HAL-F02	1st Floor Hallway Outside Rm. 117 Left Fountain	Initial	27-OCT-16	0.282	ppb
51564	51564-1-HAL-F02	1st Floor Hallway Outside Rm. 117 Left Fountain	Initial	27-JAN-23	1.000	ug/L
51564	51564-1-HAL-F03	1st Floor Hallway Outside Rm. 117 Right Fountain	Flush180	27-OCT-16	0.239	ppb
51564	51564-1-HAL-F03	1st Floor Hallway Outside Rm. 117 Right Fountain	Flush180	27-OCT-16	0.226	ppb
51564	51564-1-HAL-F03	1st Floor Hallway Outside Rm. 117 Right Fountain	Flush180	27-OCT-16	0.218	ppb
51564	51564-1-HAL-F03	1st Floor Hallway Outside Rm. 117 Right Fountain	Flush180	27-OCT-16	0.239	ppb
51564	51564-1-HAL-F03	1st Floor Hallway Outside Rm. 117 Right Fountain	Flush180	27-JAN-23	1.000	ug/L
51564	51564-1-HAL-F03	1st Floor Hallway Outside Rm. 117 Right Fountain	Flush180	27-JAN-23	1.000	ug/L
51564	51564-1-HAL-F03	1st Floor Hallway Outside Rm. 117 Right Fountain	Initial	27-OCT-16	0.215	ppb
51564	51564-1-HAL-F03	1st Floor Hallway Outside Rm. 117 Right Fountain	Initial	27-JAN-23	1.000	ug/L
51564	51564-1-LR-F13	1st Floor Inside Boys Locker Rm. Single Fountain	Flush180	27-OCT-16	0.630	ppb
51564	51564-1-LR-F13	1st Floor Inside Boys Locker Rm. Single Fountain	Flush180	27-OCT-16	0.702	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51564	51564-1-LR-F13	1st Floor Inside Boys Locker Rm. Single Fountain	Flush180	27-OCT-16	0.715	ppb
51564	51564-1-LR-F13	1st Floor Inside Boys Locker Rm. Single Fountain	Flush180	27-OCT-16	0.716	ppb
51564	51564-1-LR-F13	1st Floor Inside Boys Locker Rm. Single Fountain	Initial	27-OCT-16	1.040	ppb
51564	51564-1-GYM-F09	1st Floor Inside Gym Right Fountain	Flush180	27-OCT-16	2.960	ppb
51564	51564-1-GYM-F09	1st Floor Inside Gym Right Fountain	Flush180	27-OCT-16	1.840	ppb
51564	51564-1-GYM-F09	1st Floor Inside Gym Right Fountain	Flush180	27-OCT-16	2.110	ppb
51564	51564-1-GYM-F09	1st Floor Inside Gym Right Fountain	Flush180	27-OCT-16	1.820	ppb
51564	51564-1-GYM-F09	1st Floor Inside Gym Right Fountain	Flush180	27-JAN-23	2.790	ug/L
51564	51564-1-GYM-F09	1st Floor Inside Gym Right Fountain	Flush180	27-JAN-23	2.570	ug/L
51564	51564-1-GYM-F09	1st Floor Inside Gym Right Fountain	Flush180	27-JAN-23	2.270	ug/L
51564	51564-1-GYM-F09	1st Floor Inside Gym Right Fountain	Flush180	27-JAN-23	2.280	ug/L
51564	51564-1-GYM-F09	1st Floor Inside Gym Right Fountain	Initial	27-OCT-16	2.850	ppb
51564	51564-1-GYM-F09	1st Floor Inside Gym Right Fountain	Initial	27-JAN-23	2.160	ug/L
51564	51564-1-153-WC08	1st Floor Inside Rm. 153 Single Water Cooler	Flush180	27-OCT-16	0.403	ppb
51564	51564-1-153-WC08	1st Floor Inside Rm. 153 Single Water Cooler	Flush180	27-OCT-16	0.395	ppb
51564	51564-1-153-WC08	1st Floor Inside Rm. 153 Single Water Cooler	Flush180	27-OCT-16	0.443	ppb
51564	51564-1-153-WC08	1st Floor Inside Rm. 153 Single Water Cooler	Flush180	27-OCT-16	0.385	ppb
51564	51564-1-153-WC08	1st Floor Inside Rm. 153 Single Water Cooler	Initial	27-OCT-16	0.475	ppb
51564	51564-2-HAL-F04	2nd Floor Hallway Across Rm. 204 Single Fountain	Flush180	27-OCT-16	1.000	ppb
51564	51564-2-HAL-F04	2nd Floor Hallway Across Rm. 204 Single Fountain	Flush180	27-OCT-16	1.000	ppb
51564	51564-2-HAL-F04	2nd Floor Hallway Across Rm. 204 Single Fountain	Flush180	27-OCT-16	1.000	ppb
51564	51564-2-HAL-F04	2nd Floor Hallway Across Rm. 204 Single Fountain	Flush180	27-OCT-16	1.000	ppb
51564	51564-2-HAL-F04	2nd Floor Hallway Across Rm. 204 Single Fountain	Initial	27-OCT-16	1.000	ppb
51564	51564-2-HAL-RBF01	2nd Floor Hallway Across Rm. 204 Single Fountain	Flush180	27-JAN-23	1.000	ug/L
51564	51564-2-HAL-RBF01	2nd Floor Hallway Across Rm. 204 Single Fountain	Flush180	27-JAN-23	1.000	ug/L
51564	51564-2-HAL-RBF01	2nd Floor Hallway Across Rm. 204 Single Fountain	Flush180	27-JAN-23	1.000	ug/L
51564	51564-2-HAL-RBF01	2nd Floor Hallway Across Rm. 204 Single Fountain	Flush180	27-JAN-23	1.000	ug/L
51564	51564-2-HAL-RBF01	2nd Floor Hallway Across Rm. 204 Single Fountain	Initial	27-JAN-23	1.000	ug/L
51564	51564-2-HAL-F05	2nd Floor Hallway Across Rm. 206 Single Fountain	Flush180	27-JAN-23	2.240	ug/L
51564	51564-2-HAL-F05	2nd Floor Hallway Across Rm. 206 Single Fountain	Flush180	27-JAN-23	2.210	ug/L
51564	51564-2-HAL-F05	2nd Floor Hallway Across Rm. 206 Single Fountain	Flush180	27-JAN-23	4.360	ug/L
51564	51564-2-HAL-F05	2nd Floor Hallway Across Rm. 206 Single Fountain	Flush180	27-JAN-23	2.110	ug/L
51564	51564-2-HAL-F05	2nd Floor Hallway Across Rm. 206 Single Fountain	Initial	27-JAN-23	3.260	ug/L
51564	51564-2-HAL-F01	2nd Floor Hallway Across Rm. 214 Single Fountain	Flush180	27-JAN-23	1.000	ug/L
51564	51564-2-HAL-F01	2nd Floor Hallway Across Rm. 214 Single Fountain	Flush180	27-JAN-23	1.000	ug/L
51564	51564-2-HAL-F01	2nd Floor Hallway Across Rm. 214 Single Fountain	Flush180	27-JAN-23	1.000	ug/L
51564	51564-2-HAL-F01	2nd Floor Hallway Across Rm. 214 Single Fountain	Flush180	27-JAN-23	1.000	ug/L
51564	51564-2-HAL-F01	2nd Floor Hallway Across Rm. 214 Single Fountain	Flush180	27-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01	Single Fountain				
51564	51564-2-HAL-F01	2nd Floor Hallway Across Rm. 214 Single Fountain	Flush180	27-OCT-16	1.000	ppb
51564	51564-2-HAL-F01	2nd Floor Hallway Across Rm. 214 Single Fountain	Flush180	27-OCT-16	1.000	ppb
51564	51564-2-HAL-F01	2nd Floor Hallway Across Rm. 214 Single Fountain	Flush180	27-OCT-16	1.000	ppb
51564	51564-2-HAL-F01	2nd Floor Hallway Across Rm. 214 Single Fountain	Initial	27-JAN-23	1.000	ug/L
51564	51564-2-HAL-F01	2nd Floor Hallway Across Rm. 214 Single Fountain	Initial	27-OCT-16	1.000	ppb
51564	51564-2-HAL-F03	2nd Floor Hallway Next to Rm. 201 Single Fountain	Flush180	27-JAN-23	2.500	ug/L
51564	51564-2-HAL-F03	2nd Floor Hallway Next to Rm. 201 Single Fountain	Flush180	27-JAN-23	2.740	ug/L
51564	51564-2-HAL-F03	2nd Floor Hallway Next to Rm. 201 Single Fountain	Flush180	27-JAN-23	2.980	ug/L
51564	51564-2-HAL-F03	2nd Floor Hallway Next to Rm. 201 Single Fountain	Flush180	27-JAN-23	4.520	ug/L
51564	51564-2-HAL-F03	2nd Floor Hallway Next to Rm. 201 Single Fountain	Flush180	27-OCT-16	4.400	ppb
51564	51564-2-HAL-F03	2nd Floor Hallway Next to Rm. 201 Single Fountain	Flush180	27-OCT-16	4.240	ppb
51564	51564-2-HAL-F03	2nd Floor Hallway Next to Rm. 201 Single Fountain	Flush180	27-OCT-16	4.010	ppb
51564	51564-2-HAL-F03	2nd Floor Hallway Next to Rm. 201 Single Fountain	Flush180	27-OCT-16	13.700	ppb
51564	51564-2-HAL-F03	2nd Floor Hallway Next to Rm. 201 Single Fountain	Initial	27-JAN-23	4.310	ug/L
51564	51564-2-HAL-F03	2nd Floor Hallway Next to Rm. 201 Single Fountain	Initial	27-OCT-16	7.240	ppb
51564	51564-2-TL-S06	2nd Floor Sink Inside Teachers Lounge Rm. 206	Flush180	27-JAN-23	1.000	ug/L
51564	51564-2-TL-S06	2nd Floor Sink Inside Teachers Lounge Rm. 206	Flush180	27-JAN-23	1.000	ug/L
51564	51564-2-TL-S06	2nd Floor Sink Inside Teachers Lounge Rm. 206	Flush180	27-JAN-23	1.000	ug/L
51564	51564-2-TL-S06	2nd Floor Sink Inside Teachers Lounge Rm. 206	Flush180	27-JAN-23	1.000	ug/L
51564	51564-2-TL-S06	2nd Floor Sink Inside Teachers Lounge Rm. 206	Flush180	27-OCT-16	0.698	ppb
51564	51564-2-TL-S06	2nd Floor Sink Inside Teachers Lounge Rm. 206	Flush180	27-OCT-16	0.665	ppb
51564	51564-2-TL-S06	2nd Floor Sink Inside Teachers Lounge Rm. 206	Flush180	27-OCT-16	0.791	ppb
51564	51564-2-TL-S06	2nd Floor Sink Inside Teachers Lounge Rm. 206	Flush180	27-OCT-16	0.751	ppb
51564	51564-2-TL-S06	2nd Floor Sink Inside Teachers Lounge Rm. 206	Initial	27-JAN-23	1.000	ug/L
51564	51564-2-TL-S06	2nd Floor Sink Inside Teachers Lounge Rm. 206	Initial	27-OCT-16	0.551	ppb
51564	51564-3-HAL-F16	3rd Floor Hallway Across Rm. 306	Flush180	27-JAN-23	1.000	ug/L
51564	51564-3-HAL-F16	3rd Floor Hallway Across Rm. 306	Flush180	27-JAN-23	1.000	ug/L
51564	51564-3-HAL-F16	3rd Floor Hallway Across Rm. 306	Flush180	27-JAN-23	1.000	ug/L
51564	51564-3-HAL-F16	3rd Floor Hallway Across Rm. 306	Flush180	27-JAN-23	1.000	ug/L
51564	51564-3-HAL-F16	3rd Floor Hallway Across Rm. 306	Flush180	27-OCT-16	1.000	ppb
51564	51564-3-HAL-F16	3rd Floor Hallway Across Rm. 306	Flush180	27-OCT-16	1.000	ppb
51564	51564-3-HAL-F16	3rd Floor Hallway Across Rm. 306	Flush180	27-OCT-16	1.000	ppb
51564	51564-3-HAL-F16	3rd Floor Hallway Across Rm. 306	Flush180	27-OCT-16	1.000	ppb
51564	51564-3-HAL-F16	3rd Floor Hallway Across Rm. 306	Initial	27-JAN-23	1.000	ug/L
51564	51564-3-HAL-F16	3rd Floor Hallway Across Rm. 306	Initial	27-OCT-16	1.000	ppb
51564	51564-4-HAL-F01	3rd Floor Hallway Across Rm. 433	Flush180	27-JAN-23	1.000	ug/L
51564	51564-4-HAL-	3rd Floor Hallway Across Rm. 433	Flush180	27-JAN-23	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01					
51564	51564-4-HAL-F01	3rd Floor Hallway Across Rm. 433	Flush180	27-JAN-23	1.000	ug/L
51564	51564-4-HAL-F01	3rd Floor Hallway Across Rm. 433	Flush180	27-JAN-23	1.000	ug/L
51564	51564-4-HAL-F01	3rd Floor Hallway Across Rm. 433	Initial	27-JAN-23	1.000	ug/L
51564	51564-3-HAL-F01	3rd Floor Hallway Outside Rm. 301	Flush180	27-JAN-23	2.650	ug/L
51564	51564-3-HAL-F01	3rd Floor Hallway Outside Rm. 301	Flush180	27-JAN-23	3.870	ug/L
51564	51564-3-HAL-F01	3rd Floor Hallway Outside Rm. 301	Flush180	27-JAN-23	2.860	ug/L
51564	51564-3-HAL-F01	3rd Floor Hallway Outside Rm. 301	Flush180	27-JAN-23	3.150	ug/L
51564	51564-3-HAL-F01	3rd Floor Hallway Outside Rm. 301	Initial	27-JAN-23	4.320	ug/L
51564	51564-3-HAL-F13	3rd Floor Hallway Outside Rm. 313	Flush180	27-JAN-23	1.000	ug/L
51564	51564-3-HAL-F13	3rd Floor Hallway Outside Rm. 313	Flush180	27-JAN-23	1.000	ug/L
51564	51564-3-HAL-F13	3rd Floor Hallway Outside Rm. 313	Flush180	27-JAN-23	1.000	ug/L
51564	51564-3-HAL-F13	3rd Floor Hallway Outside Rm. 313	Flush180	27-JAN-23	1.000	ug/L
51564	51564-3-HAL-F13	3rd Floor Hallway Outside Rm. 313	Flush180	27-OCT-16	0.130	ppb
51564	51564-3-HAL-F13	3rd Floor Hallway Outside Rm. 313	Flush180	27-OCT-16	0.135	ppb
51564	51564-3-HAL-F13	3rd Floor Hallway Outside Rm. 313	Flush180	27-OCT-16	0.145	ppb
51564	51564-3-HAL-F13	3rd Floor Hallway Outside Rm. 313	Flush180	27-OCT-16	0.171	ppb
51564	51564-3-HAL-F13	3rd Floor Hallway Outside Rm. 313	Initial	27-JAN-23	1.000	ug/L
51564	51564-3-HAL-F13	3rd Floor Hallway Outside Rm. 313	Initial	27-OCT-16	0.215	ppb
51564	51564-3-KIT-KS04	3rd Floor Kitchen E. Triple Basin S. Wall Left Si	Flush180	27-JAN-23	1.000	ug/L
51564	51564-3-KIT-KS04	3rd Floor Kitchen E. Triple Basin S. Wall Left Si	Flush180	27-JAN-23	1.000	ug/L
51564	51564-3-KIT-KS04	3rd Floor Kitchen E. Triple Basin S. Wall Left Si	Flush180	27-JAN-23	1.000	ug/L
51564	51564-3-KIT-KS04	3rd Floor Kitchen E. Triple Basin S. Wall Left Si	Flush180	27-JAN-23	1.000	ug/L
51564	51564-3-KIT-KS04	3rd Floor Kitchen E. Triple Basin S. Wall Left Si	Flush180	27-OCT-16	0.712	ppb
51564	51564-3-KIT-KS04	3rd Floor Kitchen E. Triple Basin S. Wall Left Si	Flush180	27-OCT-16	0.499	ppb
51564	51564-3-KIT-KS04	3rd Floor Kitchen E. Triple Basin S. Wall Left Si	Flush180	27-OCT-16	1.350	ppb
51564	51564-3-KIT-KS04	3rd Floor Kitchen E. Triple Basin S. Wall Left Si	Flush180	27-OCT-16	0.446	ppb
51564	51564-3-KIT-KS04	3rd Floor Kitchen E. Triple Basin S. Wall Left Si	Initial	27-JAN-23	1.000	ug/L
51564	51564-3-KIT-KS04	3rd Floor Kitchen E. Triple Basin S. Wall Left Si	Initial	27-OCT-16	1.090	ppb
51564	51564-3-KIT-KS05	3rd Floor Kitchen E. Triple Basin S. Wall Right Si	Flush180	27-JAN-23	1.000	ug/L
51564	51564-3-KIT-KS05	3rd Floor Kitchen E. Triple Basin S. Wall Right Si	Flush180	27-JAN-23	1.000	ug/L
51564	51564-3-KIT-KS05	3rd Floor Kitchen E. Triple Basin S. Wall Right Si	Flush180	27-JAN-23	1.000	ug/L
51564	51564-3-KIT-KS05	3rd Floor Kitchen E. Triple Basin S. Wall Right Si	Flush180	27-OCT-16	0.578	ppb
51564	51564-3-KIT-KS05	3rd Floor Kitchen E. Triple Basin S. Wall Right Si	Flush180	27-OCT-16	0.460	ppb
51564	51564-3-KIT-KS05	3rd Floor Kitchen E. Triple Basin S. Wall Right Si	Flush180	27-OCT-16	0.480	ppb
51564	51564-3-KIT-KS05	3rd Floor Kitchen E. Triple Basin S. Wall Right Si	Flush180	27-OCT-16	0.336	ppb
51564	51564-3-KIT-KS05	3rd Floor Kitchen E. Triple Basin S. Wall Right Si	Initial	27-JAN-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51564	51564-3-KIT-KS05	3rd Floor Kitchen E. Triple Basin S. Wall Right Si	Initial	27-OCT-16	0.649	ppb
51564	51564-3-KIT-KS08	3rd Floor Kitchen Island Sink	Flush180	27-OCT-16	1.760	ppb
51564	51564-3-KIT-KS08	3rd Floor Kitchen Island Sink	Flush180	27-OCT-16	2.600	ppb
51564	51564-3-KIT-KS08	3rd Floor Kitchen Island Sink	Flush180	27-OCT-16	1.270	ppb
51564	51564-3-KIT-KS08	3rd Floor Kitchen Island Sink	Flush180	27-OCT-16	1.160	ppb
51564	51564-3-KIT-KS08	3rd Floor Kitchen Island Sink	Initial	27-OCT-16	5.870	ppb
51564	51564-3-KIT-KS02	3rd Floor Kitchen Triple Basin E. Wall Center Sink	Flush180	27-JAN-23	1.020	ug/L
51564	51564-3-KIT-KS02	3rd Floor Kitchen Triple Basin E. Wall Center Sink	Flush180	27-JAN-23	1.050	ug/L
51564	51564-3-KIT-KS02	3rd Floor Kitchen Triple Basin E. Wall Center Sink	Flush180	27-JAN-23	1.000	ug/L
51564	51564-3-KIT-KS02	3rd Floor Kitchen Triple Basin E. Wall Center Sink	Flush180	27-JAN-23	2.100	ug/L
51564	51564-3-KIT-KS02	3rd Floor Kitchen Triple Basin E. Wall Center Sink	Flush180	27-OCT-16	0.743	ppb
51564	51564-3-KIT-KS02	3rd Floor Kitchen Triple Basin E. Wall Center Sink	Flush180	27-OCT-16	1.700	ppb
51564	51564-3-KIT-KS02	3rd Floor Kitchen Triple Basin E. Wall Center Sink	Flush180	27-OCT-16	0.841	ppb
51564	51564-3-KIT-KS02	3rd Floor Kitchen Triple Basin E. Wall Center Sink	Flush180	27-OCT-16	1.300	ppb
51564	51564-3-KIT-KS02	3rd Floor Kitchen Triple Basin E. Wall Center Sink	Initial	27-JAN-23	2.260	ug/L
51564	51564-3-KIT-KS02	3rd Floor Kitchen Triple Basin E. Wall Center Sink	Initial	27-OCT-16	0.879	ppb
51564	51564-3-KIT-KS01	3rd Floor Kitchen Triple Basin E. Wall Left Sink	Flush180	27-JAN-23	1.990	ug/L
51564	51564-3-KIT-KS01	3rd Floor Kitchen Triple Basin E. Wall Left Sink	Flush180	27-JAN-23	3.930	ug/L
51564	51564-3-KIT-KS01	3rd Floor Kitchen Triple Basin E. Wall Left Sink	Flush180	27-JAN-23	2.180	ug/L
51564	51564-3-KIT-KS01	3rd Floor Kitchen Triple Basin E. Wall Left Sink	Flush180	27-JAN-23	1.520	ug/L
51564	51564-3-KIT-KS01	3rd Floor Kitchen Triple Basin E. Wall Left Sink	Flush180	27-OCT-16	0.799	ppb
51564	51564-3-KIT-KS01	3rd Floor Kitchen Triple Basin E. Wall Left Sink	Flush180	27-OCT-16	0.751	ppb
51564	51564-3-KIT-KS01	3rd Floor Kitchen Triple Basin E. Wall Left Sink	Flush180	27-OCT-16	1.100	ppb
51564	51564-3-KIT-KS01	3rd Floor Kitchen Triple Basin E. Wall Left Sink	Flush180	27-OCT-16	0.863	ppb
51564	51564-3-KIT-KS01	3rd Floor Kitchen Triple Basin E. Wall Left Sink	Initial	27-JAN-23	1.720	ug/L
51564	51564-3-KIT-KS01	3rd Floor Kitchen Triple Basin E. Wall Left Sink	Initial	27-OCT-16	0.859	ppb
51564	51564-3-KIT-KS03	3rd Floor Kitchen Triple Basin E. Wall Right Sink	Flush	02-MAY-2024	1.000	ug/L
51564	51564-3-KIT-KS03	3rd Floor Kitchen Triple Basin E. Wall Right Sink	Flush	02-MAY-2024	1.000	ug/L
51564	51564-3-KIT-KS03	3rd Floor Kitchen Triple Basin E. Wall Right Sink	Flush	02-MAY-2024	1.000	ug/L
51564	51564-3-KIT-KS03	3rd Floor Kitchen Triple Basin E. Wall Right Sink	Flush	02-MAY-2024	2.300	ug/L
51564	51564-3-KIT-KS03	3rd Floor Kitchen Triple Basin E. Wall Right Sink	Flush180	08-JUN-23	34.900	ug/L
51564	51564-3-KIT-KS03	3rd Floor Kitchen Triple Basin E. Wall Right Sink	Flush180	08-JUN-23	6.330	ug/L
51564	51564-3-KIT-KS03	3rd Floor Kitchen Triple Basin E. Wall Right Sink	Flush180	08-JUN-23	2.830	ug/L
51564	51564-3-KIT-KS03	3rd Floor Kitchen Triple Basin E. Wall Right Sink	Flush180	08-JUN-23	1.160	ug/L
51564	51564-3-KIT-KS03	3rd Floor Kitchen Triple Basin E. Wall Right Sink	Flush180	27-JAN-23	1.000	ug/L
51564	51564-3-KIT-KS03	3rd Floor Kitchen Triple Basin E. Wall Right Sink	Flush180	27-JAN-23	7.350	ug/L
51564	51564-3-KIT-KS03	3rd Floor Kitchen Triple Basin E. Wall Right Sink	Flush180	27-JAN-23	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51564	51564-3-KIT-KS03	3rd Floor Kitchen Triple Basin E. Wall Right Sink	Flush180	27-JAN-23	1.000	ug/L
51564	51564-3-KIT-KS03	3rd Floor Kitchen Triple Basin E. Wall Right Sink	Flush180	27-OCT-16	1.520	ppb
51564	51564-3-KIT-KS03	3rd Floor Kitchen Triple Basin E. Wall Right Sink	Flush180	27-OCT-16	1.560	ppb
51564	51564-3-KIT-KS03	3rd Floor Kitchen Triple Basin E. Wall Right Sink	Flush180	27-OCT-16	3.450	ppb
51564	51564-3-KIT-KS03	3rd Floor Kitchen Triple Basin E. Wall Right Sink	Flush180	27-OCT-16	1.280	ppb
51564	51564-3-KIT-KS03	3rd Floor Kitchen Triple Basin E. Wall Right Sink	Flush180	07-APR-23	16.400	ug/L
51564	51564-3-KIT-KS03	3rd Floor Kitchen Triple Basin E. Wall Right Sink	Flush180	07-APR-23	9.020	ug/L
51564	51564-3-KIT-KS03	3rd Floor Kitchen Triple Basin E. Wall Right Sink	Flush180	07-APR-23	5.960	ug/L
51564	51564-3-KIT-KS03	3rd Floor Kitchen Triple Basin E. Wall Right Sink	Flush180	07-APR-23	1.500	ug/L
51564	51564-3-KIT-KS03	3rd Floor Kitchen Triple Basin E. Wall Right Sink	Flush180	02-MAY-23	1.000	ug/L
51564	51564-3-KIT-KS03	3rd Floor Kitchen Triple Basin E. Wall Right Sink	Flush180	02-MAY-23	1.260	ug/L
51564	51564-3-KIT-KS03	3rd Floor Kitchen Triple Basin E. Wall Right Sink	Flush180	02-MAY-23	1.000	ug/L
51564	51564-3-KIT-KS03	3rd Floor Kitchen Triple Basin E. Wall Right Sink	Flush180	02-MAY-23	1.000	ug/L
51564	51564-3-KIT-KS03	3rd Floor Kitchen Triple Basin E. Wall Right Sink	Initial	08-JUN-23	26.000	ug/L
51564	51564-3-KIT-KS03	3rd Floor Kitchen Triple Basin E. Wall Right Sink	Initial	27-JAN-23	2.470	ug/L
51564	51564-3-KIT-KS03	3rd Floor Kitchen Triple Basin E. Wall Right Sink	Initial	27-OCT-16	4.490	ppb
51564	51564-3-KIT-KS03	3rd Floor Kitchen Triple Basin E. Wall Right Sink	Initial	07-APR-23	19.300	ug/L
51564	51564-3-KIT-KS03	3rd Floor Kitchen Triple Basin E. Wall Right Sink	Initial	02-MAY-23	5.730	ug/L
51564	51564-3-KIT-KS03	3rd Floor Kitchen Triple Basin E. Wall Right Sink	Initial	02-MAY-2024	1.150	ug/L
51564	51564-3-KIT-KS06	3rd Floor Kitchen W. Triple Basin S. Wall Left Sin	Flush180	27-JAN-23	1.000	ug/L
51564	51564-3-KIT-KS06	3rd Floor Kitchen W. Triple Basin S. Wall Left Sin	Flush180	27-JAN-23	1.000	ug/L
51564	51564-3-KIT-KS06	3rd Floor Kitchen W. Triple Basin S. Wall Left Sin	Flush180	27-JAN-23	1.000	ug/L
51564	51564-3-KIT-KS06	3rd Floor Kitchen W. Triple Basin S. Wall Left Sin	Flush180	27-JAN-23	1.000	ug/L
51564	51564-3-KIT-KS06	3rd Floor Kitchen W. Triple Basin S. Wall Left Sin	Flush180	27-OCT-16	0.240	ppb
51564	51564-3-KIT-KS06	3rd Floor Kitchen W. Triple Basin S. Wall Left Sin	Flush180	27-OCT-16	0.495	ppb
51564	51564-3-KIT-KS06	3rd Floor Kitchen W. Triple Basin S. Wall Left Sin	Flush180	27-OCT-16	0.189	ppb
51564	51564-3-KIT-KS06	3rd Floor Kitchen W. Triple Basin S. Wall Left Sin	Flush180	27-OCT-16	0.573	ppb
51564	51564-3-KIT-KS06	3rd Floor Kitchen W. Triple Basin S. Wall Left Sin	Initial	27-JAN-23	1.000	ug/L
51564	51564-3-KIT-KS06	3rd Floor Kitchen W. Triple Basin S. Wall Left Sin	Initial	27-OCT-16	0.579	ppb
51564	51564-3-KIT-KS07	3rd Floor Kitchen W. Triple Basin S. Wall Right Si	Flush180	27-JAN-23	1.000	ug/L
51564	51564-3-KIT-KS07	3rd Floor Kitchen W. Triple Basin S. Wall Right Si	Flush180	27-JAN-23	1.000	ug/L
51564	51564-3-KIT-KS07	3rd Floor Kitchen W. Triple Basin S. Wall Right Si	Flush180	27-JAN-23	1.000	ug/L
51564	51564-3-KIT-KS07	3rd Floor Kitchen W. Triple Basin S. Wall Right Si	Flush180	27-JAN-23	1.000	ug/L
51564	51564-3-KIT-KS07	3rd Floor Kitchen W. Triple Basin S. Wall Right Si	Flush180	27-OCT-16	0.326	ppb
51564	51564-3-KIT-KS07	3rd Floor Kitchen W. Triple Basin S. Wall Right Si	Flush180	27-OCT-16	1.000	ppb
51564	51564-3-KIT-KS07	3rd Floor Kitchen W. Triple Basin S. Wall Right Si	Flush180	27-OCT-16	1.780	ppb
51564	51564-3-KIT-KS07	3rd Floor Kitchen W. Triple Basin S. Wall Right Si	Flush180	27-OCT-16	4.440	ppb
51564	51564-3-KIT-	3rd Floor Kitchen W. Triple Basin	Initial	27-JAN-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS07	S. Wall Right Si				
51564	51564-3-KIT-KS07	3rd Floor Kitchen W. Triple Basin S. Wall Right Si	Initial	27-OCT-16	1.430	ppb
51564	51564-4-HAL-F04	4th Floor Hallway Across Rm. 408	Flush180	27-OCT-16	0.130	ppb
51564	51564-4-HAL-F04	4th Floor Hallway Across Rm. 408	Flush180	27-OCT-16	0.131	ppb
51564	51564-4-HAL-F04	4th Floor Hallway Across Rm. 408	Flush180	27-OCT-16	1.000	ppb
51564	51564-4-HAL-F04	4th Floor Hallway Across Rm. 408	Flush180	27-OCT-16	0.140	ppb
51564	51564-4-HAL-F04	4th Floor Hallway Across Rm. 408	Initial	27-OCT-16	1.000	ppb
51564	51564-4-HAL-RBF01	4th Floor Hallway Across Rm. 408	Flush180	27-JAN-23	1.000	ug/L
51564	51564-4-HAL-RBF01	4th Floor Hallway Across Rm. 408	Flush180	27-JAN-23	1.000	ug/L
51564	51564-4-HAL-RBF01	4th Floor Hallway Across Rm. 408	Flush180	27-JAN-23	1.000	ug/L
51564	51564-4-HAL-RBF01	4th Floor Hallway Across Rm. 408	Flush180	27-JAN-23	1.000	ug/L
51564	51564-4-HAL-RBF01	4th Floor Hallway Across Rm. 408	Initial	27-JAN-23	1.000	ug/L
51564	51564-4-HAL-F02	4th Floor Hallway Across Rm. 437 N. Wall	Flush	02-MAY-2024	31.200	ug/L
51564	51564-4-HAL-F02	4th Floor Hallway Across Rm. 437 N. Wall	Flush	02-MAY-2024	34.800	ug/L
51564	51564-4-HAL-F02	4th Floor Hallway Across Rm. 437 N. Wall	Flush	02-MAY-2024	37.400	ug/L
51564	51564-4-HAL-F02	4th Floor Hallway Across Rm. 437 N. Wall	Flush	02-MAY-2024	36.000	ug/L
51564	51564-4-HAL-F02	4th Floor Hallway Across Rm. 437 N. Wall	Flush180	08-JUN-23	18.900	ug/L
51564	51564-4-HAL-F02	4th Floor Hallway Across Rm. 437 N. Wall	Flush180	08-JUN-23	19.900	ug/L
51564	51564-4-HAL-F02	4th Floor Hallway Across Rm. 437 N. Wall	Flush180	08-JUN-23	21.900	ug/L
51564	51564-4-HAL-F02	4th Floor Hallway Across Rm. 437 N. Wall	Flush180	08-JUN-23	20.900	ug/L
51564	51564-4-HAL-F02	4th Floor Hallway Across Rm. 437 N. Wall	Flush180	27-JAN-23	4.750	ug/L
51564	51564-4-HAL-F02	4th Floor Hallway Across Rm. 437 N. Wall	Flush180	27-JAN-23	5.550	ug/L
51564	51564-4-HAL-F02	4th Floor Hallway Across Rm. 437 N. Wall	Flush180	27-JAN-23	6.150	ug/L
51564	51564-4-HAL-F02	4th Floor Hallway Across Rm. 437 N. Wall	Flush180	27-JAN-23	5.840	ug/L
51564	51564-4-HAL-F02	4th Floor Hallway Across Rm. 437 N. Wall	Flush180	27-OCT-16	13.500	ppb
51564	51564-4-HAL-F02	4th Floor Hallway Across Rm. 437 N. Wall	Flush180	27-OCT-16	13.200	ppb
51564	51564-4-HAL-F02	4th Floor Hallway Across Rm. 437 N. Wall	Flush180	27-OCT-16	11.400	ppb
51564	51564-4-HAL-F02	4th Floor Hallway Across Rm. 437 N. Wall	Flush180	27-OCT-16	9.140	ppb
51564	51564-4-HAL-F02	4th Floor Hallway Across Rm. 437 N. Wall	Flush180	07-APR-23	32.400	ug/L
51564	51564-4-HAL-F02	4th Floor Hallway Across Rm. 437 N. Wall	Flush180	07-APR-23	37.800	ug/L
51564	51564-4-HAL-F02	4th Floor Hallway Across Rm. 437 N. Wall	Flush180	07-APR-23	43.900	ug/L
51564	51564-4-HAL-F02	4th Floor Hallway Across Rm. 437 N. Wall	Flush180	07-APR-23	49.000	ug/L
51564	51564-4-HAL-F02	4th Floor Hallway Across Rm. 437 N. Wall	Flush180	02-MAY-23	43.000	ug/L
51564	51564-4-HAL-F02	4th Floor Hallway Across Rm. 437 N. Wall	Flush180	02-MAY-23	41.800	ug/L
51564	51564-4-HAL-F02	4th Floor Hallway Across Rm. 437 N. Wall	Flush180	02-MAY-23	35.200	ug/L
51564	51564-4-HAL-F02	4th Floor Hallway Across Rm. 437 N. Wall	Flush180	02-MAY-23	32.600	ug/L
51564	51564-4-HAL-F02	4th Floor Hallway Across Rm. 437 N. Wall	Initial	08-JUN-23	37.100	ug/L
51564	51564-4-HAL-F02	4th Floor Hallway Across Rm. 437 N. Wall	Initial	27-JAN-23	4.390	ug/L

**Water Quality Assessment
Richard T Crane Medical Preparatory HS**

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02	N. Wall				
51564	51564-4-HAL-F02	4th Floor Hallway Across Rm. 437 N. Wall	Initial	27-OCT-16	7.940	ppb
51564	51564-4-HAL-F02	4th Floor Hallway Across Rm. 437 N. Wall	Initial	07-APR-23	29.400	ug/L
51564	51564-4-HAL-F02	4th Floor Hallway Across Rm. 437 N. Wall	Initial	02-MAY-23	42.000	ug/L
51564	51564-4-HAL-F02	4th Floor Hallway Across Rm. 437 N. Wall	Initial	02-MAY-2024	30.800	ug/L