



Sep 10, 2024

CUFFE

8324 S RACINE AVE, Chicago IL 60620.

Dear **CUFFE** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

CUFFE

8324 S RACINE AVE, Chicago IL 60620.

Estimadas familias de **CUFFE**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51436	51436-1-HAL-F01	Hall outside Dining	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-HAL-F01	Hall outside Dining	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-HAL-F01	Hall outside Dining	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-HAL-F01	Hall outside Dining	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-HAL-F01	Hall outside Dining	Flush180	19-AUG-20	1.230	ug/L
51436	51436-1-HAL-F01	Hall outside Dining	Initial	28-SEP-16	1.000	ppb
51436	51436-1-HAL-F01	Hall outside Dining	Initial	19-AUG-20	1.630	ug/L
51436	51436-1-HAL-F03	Hall outside Gym Left	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-HAL-F03	Hall outside Gym Left	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-HAL-F03	Hall outside Gym Left	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-HAL-F03	Hall outside Gym Left	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-HAL-F03	Hall outside Gym Left	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-HAL-F03	Hall outside Gym Left	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-HAL-F03	Hall outside Gym Left	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-HAL-F03	Hall outside Gym Left	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-HAL-F03	Hall outside Gym Left	Initial	28-SEP-16	1.000	ppb
51436	51436-1-HAL-F03	Hall outside Gym Left	Initial	03-OCT-19	1.000	ug/L
51436	51436-1-HAL-F04	Hall outside Gym Right	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-HAL-F04	Hall outside Gym Right	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-HAL-F04	Hall outside Gym Right	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-HAL-F04	Hall outside Gym Right	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-HAL-F04	Hall outside Gym Right	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-HAL-F04	Hall outside Gym Right	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-HAL-F04	Hall outside Gym Right	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-HAL-F04	Hall outside Gym Right	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-HAL-F04	Hall outside Gym Right	Initial	28-SEP-16	1.000	ppb
51436	51436-1-HAL-F04	Hall outside Gym Right	Initial	03-OCT-19	1.000	ug/L
51436	51436-2-HAL-F01	Hall outside Room 215 Left	Flush180	28-SEP-16	1.000	ppb
51436	51436-2-HAL-F01	Hall outside Room 215 Left	Flush180	28-SEP-16	1.000	ppb
51436	51436-2-HAL-F01	Hall outside Room 215 Left	Flush180	28-SEP-16	1.000	ppb
51436	51436-2-HAL-F01	Hall outside Room 215 Left	Flush180	28-SEP-16	1.000	ppb
51436	51436-2-HAL-F01	Hall outside Room 215 Left	Flush180	03-OCT-19	1.000	ug/L
51436	51436-2-HAL-F01	Hall outside Room 215 Left	Flush180	03-OCT-19	1.000	ug/L
51436	51436-2-HAL-F01	Hall outside Room 215 Left	Flush180	03-OCT-19	1.000	ug/L
51436	51436-2-HAL-F01	Hall outside Room 215 Left	Flush180	03-OCT-19	1.000	ug/L
51436	51436-2-HAL-F01	Hall outside Room 215 Left	Flush180	03-OCT-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51436	51436-2-HAL-F01	Hall outside Room 215 Left	Initial	28-SEP-16	1.000	ppb
51436	51436-2-HAL-F01	Hall outside Room 215 Left	Initial	03-OCT-19	1.000	ug/L
51436	51436-2-HAL-F02	Hall outside room 215 Right	Flush180	28-SEP-16	1.000	ppb
51436	51436-2-HAL-F02	Hall outside room 215 Right	Flush180	28-SEP-16	1.000	ppb
51436	51436-2-HAL-F02	Hall outside room 215 Right	Flush180	28-SEP-16	1.000	ppb
51436	51436-2-HAL-F02	Hall outside room 215 Right	Flush180	28-SEP-16	1.000	ppb
51436	51436-2-HAL-F02	Hall outside room 215 Right	Flush180	03-OCT-19	1.000	ug/L
51436	51436-2-HAL-F02	Hall outside room 215 Right	Flush180	03-OCT-19	1.000	ug/L
51436	51436-2-HAL-F02	Hall outside room 215 Right	Flush180	03-OCT-19	1.000	ug/L
51436	51436-2-HAL-F02	Hall outside room 215 Right	Flush180	03-OCT-19	1.000	ug/L
51436	51436-2-HAL-F02	Hall outside room 215 Right	Initial	28-SEP-16	1.000	ppb
51436	51436-2-HAL-F02	Hall outside room 215 Right	Initial	03-OCT-19	1.000	ug/L
51436	51436-1-KIT-KS01	Kitchen	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-KIT-KS01	Kitchen	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-KIT-KS01	Kitchen	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-KIT-KS01	Kitchen	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-KIT-KS01	Kitchen	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-KIT-KS01	Kitchen	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-KIT-KS01	Kitchen	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-KIT-KS01	Kitchen	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-KIT-KS01	Kitchen	Initial	28-SEP-16	1.000	ppb
51436	51436-1-KIT-KS01	Kitchen	Initial	03-OCT-19	1.000	ug/L
51436	51436-1-KIT-KS02	Kitchen Left Sink on West Wall	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-KIT-KS02	Kitchen Left Sink on West Wall	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-KIT-KS02	Kitchen Left Sink on West Wall	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-KIT-KS02	Kitchen Left Sink on West Wall	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-KIT-KS02	Kitchen Left Sink on West Wall	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-KIT-KS02	Kitchen Left Sink on West Wall	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-KIT-KS02	Kitchen Left Sink on West Wall	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-KIT-KS02	Kitchen Left Sink on West Wall	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-KIT-KS02	Kitchen Left Sink on West Wall	Initial	28-SEP-16	1.000	ppb
51436	51436-1-KIT-KS02	Kitchen Left Sink on West Wall	Initial	03-OCT-19	1.000	ug/L
51436	51436-1-KIT-KS03	Kitchen Middle Sink on West Wall	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-KIT-KS03	Kitchen Middle Sink on West Wall	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-KIT-KS03	Kitchen Middle Sink on West Wall	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-KIT-KS03	Kitchen Middle Sink on West Wall	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-KIT-KS03	Kitchen Middle Sink on West Wall	Flush180	03-OCT-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51436	51436-1-KIT-KS03	Kitchen Middle Sink on West Wall	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-KIT-KS03	Kitchen Middle Sink on West Wall	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-KIT-KS03	Kitchen Middle Sink on West Wall	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-KIT-KS03	Kitchen Middle Sink on West Wall	Initial	28-SEP-16	1.000	ppb
51436	51436-1-KIT-KS03	Kitchen Middle Sink on West Wall	Initial	03-OCT-19	1.000	ug/L
51436	51436-1-KIT-KS04	Kitchen Right Sink on West Wall	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-KIT-KS04	Kitchen Right Sink on West Wall	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-KIT-KS04	Kitchen Right Sink on West Wall	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-KIT-KS04	Kitchen Right Sink on West Wall	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-KIT-KS04	Kitchen Right Sink on West Wall	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-KIT-KS04	Kitchen Right Sink on West Wall	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-KIT-KS04	Kitchen Right Sink on West Wall	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-KIT-KS04	Kitchen Right Sink on West Wall	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-KIT-KS04	Kitchen Right Sink on West Wall	Initial	28-SEP-16	1.000	ppb
51436	51436-1-KIT-KS04	Kitchen Right Sink on West Wall	Initial	03-OCT-19	1.000	ug/L
51436	51436-3-HAL-F03	Outside Room 302	Flush180	28-SEP-16	1.000	ppb
51436	51436-3-HAL-F03	Outside Room 302	Flush180	28-SEP-16	1.000	ppb
51436	51436-3-HAL-F03	Outside Room 302	Flush180	28-SEP-16	1.000	ppb
51436	51436-3-HAL-F03	Outside Room 302	Flush180	28-SEP-16	1.000	ppb
51436	51436-3-HAL-F03	Outside Room 302	Flush180	03-OCT-19	1.000	ug/L
51436	51436-3-HAL-F03	Outside Room 302	Flush180	03-OCT-19	1.000	ug/L
51436	51436-3-HAL-F03	Outside Room 302	Flush180	03-OCT-19	1.000	ug/L
51436	51436-3-HAL-F03	Outside Room 302	Initial	28-SEP-16	1.000	ppb
51436	51436-3-HAL-F03	Outside Room 302	Initial	03-OCT-19	1.000	ug/L
51436	51436-3-HAL-F01	Outside Room 315 Left	Flush180	28-SEP-16	1.000	ppb
51436	51436-3-HAL-F01	Outside Room 315 Left	Flush180	28-SEP-16	1.000	ppb
51436	51436-3-HAL-F01	Outside Room 315 Left	Flush180	28-SEP-16	1.000	ppb
51436	51436-3-HAL-F01	Outside Room 315 Left	Flush180	28-SEP-16	1.000	ppb
51436	51436-3-HAL-F01	Outside Room 315 Left	Flush180	03-OCT-19	1.000	ug/L
51436	51436-3-HAL-F01	Outside Room 315 Left	Flush180	03-OCT-19	1.000	ug/L
51436	51436-3-HAL-F01	Outside Room 315 Left	Flush180	03-OCT-19	1.000	ug/L
51436	51436-3-HAL-F01	Outside Room 315 Left	Flush180	03-OCT-19	1.000	ug/L
51436	51436-3-HAL-F01	Outside Room 315 Left	Initial	28-SEP-16	1.000	ppb
51436	51436-3-HAL-F01	Outside Room 315 Left	Initial	03-OCT-19	1.000	ug/L
51436	51436-3-HAL-F02	Outside Room 315 Right	Flush180	28-SEP-16	1.000	ppb
51436	51436-3-HAL-F02	Outside Room 315 Right	Flush180	28-SEP-16	1.000	ppb
51436	51436-3-HAL-F02	Outside Room 315 Right	Flush180	28-SEP-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02					
51436	51436-3-HAL-F02	Outside Room 315 Right	Flush180	28-SEP-16	1.000	ppb
51436	51436-3-HAL-F02	Outside Room 315 Right	Flush180	19-AUG-20	1.000	ug/L
51436	51436-3-HAL-F02	Outside Room 315 Right	Initial	28-SEP-16	1.000	ppb
51436	51436-3-HAL-F02	Outside Room 315 Right	Initial	19-AUG-20	1.000	ug/L
51436	51436-2-HAL-F03	Outside fall room	Flush180	28-SEP-16	1.000	ppb
51436	51436-2-HAL-F03	Outside fall room	Flush180	28-SEP-16	1.000	ppb
51436	51436-2-HAL-F03	Outside fall room	Flush180	28-SEP-16	1.000	ppb
51436	51436-2-HAL-F03	Outside fall room	Flush180	28-SEP-16	1.000	ppb
51436	51436-2-HAL-F03	Outside fall room	Flush180	03-OCT-19	1.000	ug/L
51436	51436-2-HAL-F03	Outside fall room	Flush180	03-OCT-19	1.000	ug/L
51436	51436-2-HAL-F03	Outside fall room	Flush180	03-OCT-19	1.000	ug/L
51436	51436-2-HAL-F03	Outside fall room	Flush180	03-OCT-19	1.000	ug/L
51436	51436-2-HAL-F03	Outside fall room	Initial	28-SEP-16	1.000	ppb
51436	51436-2-HAL-F03	Outside fall room	Initial	03-OCT-19	1.000	ug/L
51436	51436-1-101-F01	Room 101 Pre-K	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-101-F01	Room 101 Pre-K	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-101-F01	Room 101 Pre-K	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-101-F01	Room 101 Pre-K	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-101-F01	Room 101 Pre-K	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-101-F01	Room 101 Pre-K	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-101-F01	Room 101 Pre-K	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-101-F01	Room 101 Pre-K	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-101-F01	Room 101 Pre-K	Initial	28-SEP-16	1.000	ppb
51436	51436-1-101-F01	Room 101 Pre-K	Initial	03-OCT-19	1.000	ug/L
51436	51436-1-101-S02	Room 101 Pre-K Right Sink	Flush180	08-SEP-17	0.241	ppb
51436	51436-1-101-S02	Room 101 Pre-K Right Sink	Flush180	08-SEP-17	0.775	ppb
51436	51436-1-101-S02	Room 101 Pre-K Right Sink	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-101-S02	Room 101 Pre-K Right Sink	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-101-S02	Room 101 Pre-K Right Sink	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-101-S02	Room 101 Pre-K Right Sink	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-101-S02	Room 101 Pre-K Right Sink	Flush180	08-SEP-17	0.500	ppb
51436	51436-1-101-S02	Room 101 Pre-K Right Sink	Flush180	08-SEP-17	0.830	ppb
51436	51436-1-101-S02	Room 101 Pre-K Right Sink	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-101-S02	Room 101 Pre-K Right Sink	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-101-S02	Room 101 Pre-K Right Sink	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-101-S02	Room 101 Pre-K Right Sink	Initial	08-SEP-17	1.490	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S02					
51436	51436-1-101-S02	Room 101 Pre-K Right Sink	Initial	28-SEP-16	29.300	ppb
51436	51436-1-101-S02	Room 101 Pre-K Right Sink	Initial	03-OCT-19	1.370	ug/L
51436	51436-1-101-S01	Room 101 Pre-k Left Sink	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-101-S01	Room 101 Pre-k Left Sink	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-101-S01	Room 101 Pre-k Left Sink	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-101-S01	Room 101 Pre-k Left Sink	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-101-S01	Room 101 Pre-k Left Sink	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-101-S01	Room 101 Pre-k Left Sink	Flush180	03-OCT-19	1.530	ug/L
51436	51436-1-101-S01	Room 101 Pre-k Left Sink	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-101-S01	Room 101 Pre-k Left Sink	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-101-S01	Room 101 Pre-k Left Sink	Initial	28-SEP-16	1.000	ppb
51436	51436-1-101-S01	Room 101 Pre-k Left Sink	Initial	03-OCT-19	4.400	ug/L
51436	51436-1-103-F01	Room 103 Pre-K	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-103-F01	Room 103 Pre-K	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-103-F01	Room 103 Pre-K	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-103-F01	Room 103 Pre-K	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-103-F01	Room 103 Pre-K	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-103-F01	Room 103 Pre-K	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-103-F01	Room 103 Pre-K	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-103-F01	Room 103 Pre-K	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-103-F01	Room 103 Pre-K	Initial	28-SEP-16	1.000	ppb
51436	51436-1-103-F01	Room 103 Pre-K	Initial	03-OCT-19	1.000	ug/L
51436	51436-1-103-S02	Room 103 Pre-K Right Sink	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-103-S02	Room 103 Pre-K Right Sink	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-103-S02	Room 103 Pre-K Right Sink	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-103-S02	Room 103 Pre-K Right Sink	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-103-S02	Room 103 Pre-K Right Sink	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-103-S02	Room 103 Pre-K Right Sink	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-103-S02	Room 103 Pre-K Right Sink	Initial	28-SEP-16	1.000	ppb
51436	51436-1-103-S02	Room 103 Pre-K Right Sink	Initial	03-OCT-19	1.000	ug/L
51436	51436-1-103-S01	Room 103 Pre-k Left Sink	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-103-S01	Room 103 Pre-k Left Sink	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-103-S01	Room 103 Pre-k Left Sink	Flush180	08-SEP-17	0.530	ppb
51436	51436-1-103-S01	Room 103 Pre-k Left Sink	Flush180	08-SEP-17	0.347	ppb
51436	51436-1-103-S01	Room 103 Pre-k Left Sink	Flush180	08-SEP-17	0.280	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51436	51436-1-103-S01	Room 103 Pre-k Left Sink	Flush180	08-SEP-17	0.238	ppb
51436	51436-1-103-S01	Room 103 Pre-k Left Sink	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-103-S01	Room 103 Pre-k Left Sink	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-103-S01	Room 103 Pre-k Left Sink	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-103-S01	Room 103 Pre-k Left Sink	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-103-S01	Room 103 Pre-k Left Sink	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-103-S01	Room 103 Pre-k Left Sink	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-103-S01	Room 103 Pre-k Left Sink	Initial	28-SEP-16	35.900	ppb
51436	51436-1-103-S01	Room 103 Pre-k Left Sink	Initial	08-SEP-17	3.470	ppb
51436	51436-1-103-S01	Room 103 Pre-k Left Sink	Initial	03-OCT-19	1.760	ug/L
51436	51436-1-105-F01	Room 105	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-105-F01	Room 105	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-105-F01	Room 105	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-105-F01	Room 105	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-105-F01	Room 105	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-105-F01	Room 105	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-105-F01	Room 105	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-105-F01	Room 105	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-105-F01	Room 105	Initial	28-SEP-16	1.000	ppb
51436	51436-1-105-F01	Room 105	Initial	03-OCT-19	1.000	ug/L
51436	51436-1-105-S02	Room 105 Left Sink	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-105-S01	Room 105 Left Sink	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-105-S01	Room 105 Left Sink	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-105-S01	Room 105 Left Sink	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-105-S01	Room 105 Left Sink	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-105-S01	Room 105 Left Sink	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-105-S02	Room 105 Left Sink	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-105-S02	Room 105 Left Sink	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-105-S01	Room 105 Left Sink	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-105-S01	Room 105 Left Sink	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-105-S01	Room 105 Left Sink	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-105-S01	Room 105 Left Sink	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-105-S02	Room 105 Left Sink	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-105-S02	Room 105 Left Sink	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-105-S02	Room 105 Left Sink	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-105-S01	Room 105 Left Sink	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-105-S01	Room 105 Left Sink	Flush180	28-SEP-21	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51436	51436-1-105-S01	Room 105 Left Sink	Flush180	28-SEP-21	1.000	ug/L
51436	51436-1-105-S01	Room 105 Left Sink	Flush180	28-SEP-21	1.000	ug/L
51436	51436-1-105-S01	Room 105 Left Sink	Flush180	28-SEP-21	1.000	ug/L
51436	51436-1-105-S01	Room 105 Left Sink	Initial	28-SEP-16	1.000	ppb
51436	51436-1-105-S02	Room 105 Left Sink	Initial	28-SEP-16	1.000	ppb
51436	51436-1-105-S01	Room 105 Left Sink	Initial	03-OCT-19	1.000	ug/L
51436	51436-1-105-S02	Room 105 Left Sink	Initial	03-OCT-19	1.000	ug/L
51436	51436-1-105-S01	Room 105 Left Sink	Initial	28-SEP-21	1.000	ug/L
51436	51436-1-107-F01	Room 107	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-107-F01	Room 107	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-107-F01	Room 107	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-107-F01	Room 107	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-107-F01	Room 107	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-107-F01	Room 107	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-107-F01	Room 107	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-107-F01	Room 107	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-107-F01	Room 107	Initial	28-SEP-16	1.000	ppb
51436	51436-1-107-F01	Room 107	Initial	03-OCT-19	1.000	ug/L
51436	51436-1-107-S01	Room 107 Left Sink	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-107-S01	Room 107 Left Sink	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-107-S01	Room 107 Left Sink	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-107-S01	Room 107 Left Sink	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-107-S01	Room 107 Left Sink	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-107-S01	Room 107 Left Sink	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-107-S01	Room 107 Left Sink	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-107-S01	Room 107 Left Sink	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-107-S01	Room 107 Left Sink	Flush180	28-SEP-21	1.000	ug/L
51436	51436-1-107-S01	Room 107 Left Sink	Flush180	28-SEP-21	1.000	ug/L
51436	51436-1-107-S01	Room 107 Left Sink	Flush180	28-SEP-21	1.000	ug/L
51436	51436-1-107-S01	Room 107 Left Sink	Initial	28-SEP-16	1.000	ppb
51436	51436-1-107-S01	Room 107 Left Sink	Initial	03-OCT-19	1.000	ug/L
51436	51436-1-107-S01	Room 107 Left Sink	Initial	28-SEP-21	1.730	ug/L
51436	51436-1-107-S02	Room 107 Right Sink	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-107-S02	Room 107 Right Sink	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-107-S02	Room 107 Right Sink	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-107-S02	Room 107 Right Sink	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-107-	Room 107 Right Sink	Flush180	03-OCT-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S02					
51436	51436-1-107-S02	Room 107 Right Sink	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-107-S02	Room 107 Right Sink	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-107-S02	Room 107 Right Sink	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-107-S02	Room 107 Right Sink	Flush180	28-SEP-21	1.000	ug/L
51436	51436-1-107-S02	Room 107 Right Sink	Flush180	28-SEP-21	1.000	ug/L
51436	51436-1-107-S02	Room 107 Right Sink	Flush180	28-SEP-21	1.000	ug/L
51436	51436-1-107-S02	Room 107 Right Sink	Flush180	28-SEP-21	1.000	ug/L
51436	51436-1-107-S02	Room 107 Right Sink	Initial	28-SEP-16	1.000	ppb
51436	51436-1-107-S02	Room 107 Right Sink	Initial	03-OCT-19	1.000	ug/L
51436	51436-1-107-S02	Room 107 Right Sink	Initial	28-SEP-21	1.100	ug/L
51436	51436-1-109-S01	Room 109	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-109-S01	Room 109	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-109-S01	Room 109	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-109-S01	Room 109	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-109-S01	Room 109	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-109-S01	Room 109	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-109-S01	Room 109	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-109-S01	Room 109	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-109-S01	Room 109	Initial	28-SEP-16	1.000	ppb
51436	51436-1-109-S01	Room 109	Initial	03-OCT-19	3.570	ug/L
51436	51436-1-112B-S01	Room 112B Workroom	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-112B-S01	Room 112B Workroom	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-112B-S01	Room 112B Workroom	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-112B-S01	Room 112B Workroom	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-112B-S01	Room 112B Workroom	Initial	28-SEP-16	1.000	ppb
51436	51436-1-116-S01	Room 116	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-116-S01	Room 116	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-116-S01	Room 116	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-116-S01	Room 116	Flush180	28-SEP-16	1.000	ppb
51436	51436-1-116-S01	Room 116	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-116-S01	Room 116	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-116-S01	Room 116	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-116-S01	Room 116	Flush180	03-OCT-19	1.000	ug/L
51436	51436-1-116-S01	Room 116	Initial	28-SEP-16	1.000	ppb
51436	51436-1-116-S01	Room 116	Initial	03-OCT-19	1.000	ug/L
51436	51436-2-204-S01	Room 204 Counselors Office	Flush180	28-SEP-16	1.000	ppb
51436	51436-2-204-S01	Room 204 Counselors Office	Flush180	28-SEP-16	1.000	ppb

**Water Quality Assessment
Paul Cuffe Math-Science Technology Academy ES**

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S01					
51436	51436-2-204-S01	Room 204 Counselors Office	Flush180	28-SEP-16	1.000	ppb
51436	51436-2-204-S01	Room 204 Counselors Office	Flush180	28-SEP-16	1.000	ppb
51436	51436-2-204-S01	Room 204 Counselors Office	Flush180	03-OCT-19	1.000	ug/L
51436	51436-2-204-S01	Room 204 Counselors Office	Flush180	03-OCT-19	1.000	ug/L
51436	51436-2-204-S01	Room 204 Counselors Office	Flush180	03-OCT-19	1.000	ug/L
51436	51436-2-204-S01	Room 204 Counselors Office	Flush180	03-OCT-19	1.000	ug/L
51436	51436-2-204-S01	Room 204 Counselors Office	Initial	28-SEP-16	1.000	ppb
51436	51436-2-204-S01	Room 204 Counselors Office	Initial	03-OCT-19	1.000	ug/L