



Sep 10, 2024

DAWES

3810 W 81ST PL, Chicago IL 60652.

Dear **DAWES** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

DAWES

3810 W 81ST PL, Chicago IL 60652.

Estimadas familias de **DAWES**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51291	51291-1-HAL-F06	1st Floor Center of East Wing	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F06	1st Floor Center of East Wing	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F06	1st Floor Center of East Wing	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F06	1st Floor Center of East Wing	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F06	1st Floor Center of East Wing	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F08	1st Floor Hallway - NW Wing	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F08	1st Floor Hallway - NW Wing	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F08	1st Floor Hallway - NW Wing	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F08	1st Floor Hallway - NW Wing	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F08	1st Floor Hallway - NW Wing	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F01	1st Floor Hallway - West	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F01	1st Floor Hallway - West	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F01	1st Floor Hallway - West	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F01	1st Floor Hallway - West	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F01	1st Floor Hallway - West	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F03	1st Floor Hallway - West	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F03	1st Floor Hallway - West	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F03	1st Floor Hallway - West	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F03	1st Floor Hallway - West	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F03	1st Floor Hallway - West	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F04	2nd Floor Hallway - Center	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F04	2nd Floor Hallway - Center	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F04	2nd Floor Hallway - Center	Flush180	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-F04	2nd Floor Hallway - Center	Flush180	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-F04	2nd Floor Hallway - Center	Flush180	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-F04	2nd Floor Hallway - Center	Flush180	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-F03	2nd Floor Hallway - Center	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F03	2nd Floor Hallway - Center	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F03	2nd Floor Hallway - Center	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F03	2nd Floor Hallway - Center	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F04	2nd Floor Hallway - Center	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F04	2nd Floor Hallway - Center	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F04	2nd Floor Hallway - Center	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F04	2nd Floor Hallway - Center	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F04	2nd Floor Hallway - Center	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F03	2nd Floor Hallway - Center	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F04	2nd Floor Hallway - Center	Initial	17-MAR-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51291	51291-2-HAL-F01	2nd Floor Hallway - North	Flush180	28-JUL-20	2.870	ug/L
51291	51291-2-HAL-F02	2nd Floor Hallway - North	Flush180	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-F02	2nd Floor Hallway - North	Flush180	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-F02	2nd Floor Hallway - North	Flush180	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-F02	2nd Floor Hallway - North	Flush180	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-F02	2nd Floor Hallway - North	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F02	2nd Floor Hallway - North	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F02	2nd Floor Hallway - North	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F02	2nd Floor Hallway - North	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F01	2nd Floor Hallway - North	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F01	2nd Floor Hallway - North	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F01	2nd Floor Hallway - North	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F01	2nd Floor Hallway - North	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F01	2nd Floor Hallway - North	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F01	2nd Floor Hallway - North	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F01	2nd Floor Hallway - North	Initial	28-JUL-20	3.460	ug/L
51291	51291-2-HAL-F02	2nd Floor Hallway - North	Initial	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-F05	2nd Floor Hallway - South	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F05	2nd Floor Hallway - South	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F05	2nd Floor Hallway - South	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F05	2nd Floor Hallway - South	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F05	2nd Floor Hallway - South	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F06	2nd Floor Hallway - South	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F06	2nd Floor Hallway - South	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F06	2nd Floor Hallway - South	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F06	2nd Floor Hallway - South	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F06	2nd Floor Hallway - South	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F06	2nd Floor Hallway - South	Flush180	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-F06	2nd Floor Hallway - South	Flush180	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-F06	2nd Floor Hallway - South	Flush180	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-F06	2nd Floor Hallway - South	Initial	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-F07	2nd Floor Hallway - Southwest	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F07	2nd Floor Hallway - Southwest	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F07	2nd Floor Hallway - Southwest	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F07	2nd Floor Hallway - Southwest	Flush180	28-MAY-16	1.000	ppb
51291	51291-2-HAL-F07	2nd Floor Hallway - Southwest	Flush180	28-MAY-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51291	51291-B-KIT-KS02	Basement Kitchen	Flush180	28-MAY-16	1.000	ppb
51291	51291-B-KIT-KS01	Basement Kitchen	Flush180	28-MAY-16	1.000	ppb
51291	51291-B-KIT-KS02	Basement Kitchen	Flush180	28-MAY-16	1.000	ppb
51291	51291-B-KIT-KS02	Basement Kitchen	Flush180	28-MAY-16	1.000	ppb
51291	51291-B-KIT-KS02	Basement Kitchen	Flush180	28-MAY-16	1.000	ppb
51291	51291-B-KIT-KS02	Basement Kitchen	Flush180	28-MAY-16	1.000	ppb
51291	51291-B-KIT-KS03	Basement Kitchen	Flush180	28-MAY-16	1.000	ppb
51291	51291-B-KIT-KS03	Basement Kitchen	Flush180	28-MAY-16	1.000	ppb
51291	51291-B-KIT-KS03	Basement Kitchen	Flush180	28-MAY-16	1.000	ppb
51291	51291-B-KIT-KS03	Basement Kitchen	Flush180	28-MAY-16	1.000	ppb
51291	51291-B-KIT-KS03	Basement Kitchen	Flush180	28-MAY-16	1.000	ppb
51291	51291-B-KIT-KS01	Basement Kitchen	Flush180	28-MAY-16	5.670	ppb
51291	51291-B-KIT-KS01	Basement Kitchen	Flush180	28-MAY-16	1.000	ppb
51291	51291-B-KIT-KS01	Basement Kitchen	Flush180	28-MAY-16	1.000	ppb
51291	51291-B-KIT-KS01	Basement Kitchen	Flush180	17-MAR-22	1.000	ug/L
51291	51291-B-KIT-KS01	Basement Kitchen	Flush180	17-MAR-22	1.000	ug/L
51291	51291-B-KIT-KS01	Basement Kitchen	Flush180	17-MAR-22	1.000	ug/L
51291	51291-B-KIT-KS01	Basement Kitchen	Flush180	17-MAR-22	1.000	ug/L
51291	51291-B-KIT-KS02	Basement Kitchen	Flush180	17-MAR-22	1.000	ug/L
51291	51291-B-KIT-KS02	Basement Kitchen	Flush180	17-MAR-22	1.000	ug/L
51291	51291-B-KIT-KS02	Basement Kitchen	Flush180	17-MAR-22	1.000	ug/L
51291	51291-B-KIT-KS02	Basement Kitchen	Flush180	17-MAR-22	1.000	ug/L
51291	51291-B-KIT-KS03	Basement Kitchen	Flush180	17-MAR-22	1.000	ug/L
51291	51291-B-KIT-KS03	Basement Kitchen	Flush180	17-MAR-22	1.000	ug/L
51291	51291-B-KIT-KS03	Basement Kitchen	Flush180	17-MAR-22	1.000	ug/L
51291	51291-B-KIT-KS01	Basement Kitchen	Initial	17-MAR-22	1.000	ug/L
51291	51291-B-KIT-KS02	Basement Kitchen	Initial	17-MAR-22	1.000	ug/L
51291	51291-B-KIT-KS03	Basement Kitchen	Initial	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-F05	Center/Main Entrance	Flush180	28-JUL-20	1.000	ug/L
51291	51291-1-HAL-F05	Center/Main Entrance	Flush180	25-NOV-20	1.000	ug/L
51291	51291-1-HAL-F05	Center/Main Entrance	Flush180	25-NOV-20	1.000	ug/L
51291	51291-1-HAL-F05	Center/Main Entrance	Flush180	25-NOV-20	1.000	ug/L
51291	51291-1-HAL-F05	Center/Main Entrance	Flush180	25-NOV-20	1.000	ug/L
51291	51291-1-HAL-F05	Center/Main Entrance	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-F05	Center/Main Entrance	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-F05	Center/Main Entrance	Flush180	17-MAR-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F05					
51291	51291-1-HAL-F05	Center/Main Entrance	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-F05	Center/Main Entrance	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F05	Center/Main Entrance	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F05	Center/Main Entrance	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F05	Center/Main Entrance	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F05	Center/Main Entrance	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F05	Center/Main Entrance	Initial	28-JUL-20	63.200	ug/L
51291	51291-1-HAL-F05	Center/Main Entrance	Initial	25-NOV-20	1.000	ug/L
51291	51291-1-HAL-F05	Center/Main Entrance	Initial	17-MAR-22	1.000	ug/L
51291	51291-M10-404-F04	Fountain in RM 404	Flush180	28-JUL-20	1.000	ug/L
51291	51291-M10-404-F04	Fountain in RM 404	Flush180	17-MAR-22	1.000	ug/L
51291	51291-M10-404-F04	Fountain in RM 404	Flush180	17-MAR-22	1.000	ug/L
51291	51291-M10-404-F04	Fountain in RM 404	Flush180	17-MAR-22	1.000	ug/L
51291	51291-M10-404-F04	Fountain in RM 404	Flush180	17-MAR-22	1.000	ug/L
51291	51291-M10-404-F04	Fountain in RM 404	Initial	28-JUL-20	1.000	ug/L
51291	51291-M10-404-F04	Fountain in RM 404	Initial	17-MAR-22	1.000	ug/L
51291	51291-M10-407-F05	Fountain in RM 407	Flush180	28-JUL-20	1.000	ug/L
51291	51291-M10-407-F05	Fountain in RM 407	Flush180	17-MAR-22	1.000	ug/L
51291	51291-M10-407-F05	Fountain in RM 407	Flush180	17-MAR-22	1.000	ug/L
51291	51291-M10-407-F05	Fountain in RM 407	Flush180	17-MAR-22	1.000	ug/L
51291	51291-M10-407-F05	Fountain in RM 407	Flush180	17-MAR-22	1.000	ug/L
51291	51291-M10-407-F05	Fountain in RM 407	Initial	28-JUL-20	1.000	ug/L
51291	51291-M10-407-F05	Fountain in RM 407	Initial	17-MAR-22	1.000	ug/L
51291	51291-B-LUN-BF01	Lunch/Dance Room, Bottle Filler	Flush180	05-JAN-22	15.600	ug/L
51291	51291-B-LUN-BF01	Lunch/Dance Room, Bottle Filler	Flush180	05-JAN-22	6.410	ug/L
51291	51291-B-LUN-BF01	Lunch/Dance Room, Bottle Filler	Flush180	05-JAN-22	4.000	ug/L
51291	51291-B-LUN-BF01	Lunch/Dance Room, Bottle Filler	Flush180	05-JAN-22	3.030	ug/L
51291	51291-B-LUN-BF01	Lunch/Dance Room, Bottle Filler	Flush180	11-FEB-22	1.900	ug/L
51291	51291-B-LUN-BF01	Lunch/Dance Room, Bottle Filler	Flush180	11-FEB-22	1.000	ug/L
51291	51291-B-LUN-BF01	Lunch/Dance Room, Bottle Filler	Flush180	11-FEB-22	1.000	ug/L
51291	51291-B-LUN-BF01	Lunch/Dance Room, Bottle Filler	Flush180	11-FEB-22	1.000	ug/L
51291	51291-B-LUN-BF01	Lunch/Dance Room, Bottle Filler	Flush180	17-MAR-22	1.000	ug/L
51291	51291-B-LUN-BF01	Lunch/Dance Room, Bottle Filler	Flush180	17-MAR-22	1.000	ug/L
51291	51291-B-LUN-BF01	Lunch/Dance Room, Bottle Filler	Flush180	17-MAR-22	1.000	ug/L
51291	51291-B-LUN-BF01	Lunch/Dance Room, Bottle Filler	Flush180	17-MAR-22	1.000	ug/L
51291	51291-B-LUN-BF01	Lunch/Dance Room, Bottle Filler	Flush180	11-MAR-22	1.000	ug/L
51291	51291-B-LUN-BF01	Lunch/Dance Room, Bottle Filler	Flush180	11-MAR-22	1.000	ug/L



Water Quality Assessment Charles Gates Dawes Elementary School

Page
Date Printed

7 of 12
9/10/2024

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	BF01					
51291	51291-B-LUN-BF01	Lunch/Dance Room, Bottle Filler	Flush180	11-MAR-22	1.000	ug/L
51291	51291-B-LUN-BF01	Lunch/Dance Room, Bottle Filler	Flush180	11-MAR-22	1.000	ug/L
51291	51291-B-LUN-BF01	Lunch/Dance Room, Bottle Filler	Initial	05-JAN-22	25.900	ug/L
51291	51291-B-LUN-BF01	Lunch/Dance Room, Bottle Filler	Initial	11-FEB-22	14.000	ug/L
51291	51291-B-LUN-BF01	Lunch/Dance Room, Bottle Filler	Initial	17-MAR-22	1.000	ug/L
51291	51291-B-LUN-BF01	Lunch/Dance Room, Bottle Filler	Initial	11-MAR-22	1.000	ug/L
51291	51291-B-LUN-F01	Lunch/Dance Room, Fountain	Flush180	05-JAN-22	2.180	ug/L
51291	51291-B-LUN-F01	Lunch/Dance Room, Fountain	Flush180	05-JAN-22	2.700	ug/L
51291	51291-B-LUN-F01	Lunch/Dance Room, Fountain	Flush180	05-JAN-22	1.380	ug/L
51291	51291-B-LUN-F01	Lunch/Dance Room, Fountain	Flush180	05-JAN-22	1.000	ug/L
51291	51291-B-LUN-F01	Lunch/Dance Room, Fountain	Flush180	17-MAR-22	1.000	ug/L
51291	51291-B-LUN-F01	Lunch/Dance Room, Fountain	Flush180	17-MAR-22	1.000	ug/L
51291	51291-B-LUN-F01	Lunch/Dance Room, Fountain	Flush180	17-MAR-22	1.000	ug/L
51291	51291-B-LUN-F01	Lunch/Dance Room, Fountain	Flush180	17-MAR-22	1.000	ug/L
51291	51291-B-LUN-F01	Lunch/Dance Room, Fountain	Initial	05-JAN-22	1.000	ug/L
51291	51291-B-LUN-F01	Lunch/Dance Room, Fountain	Initial	17-MAR-22	1.000	ug/L
51291	51291-M12-HAL-BF10	Mobil units Door 12	Flush180	17-MAR-22	1.000	ug/L
51291	51291-M12-HAL-BF10	Mobil units Door 12	Flush180	17-MAR-22	1.000	ug/L
51291	51291-M12-HAL-BF10	Mobil units Door 12	Flush180	17-MAR-22	1.000	ug/L
51291	51291-M12-HAL-BF10	Mobil units Door 12	Flush180	17-MAR-22	1.000	ug/L
51291	51291-M12-HAL-BF10	Mobil units Door 12	Initial	17-MAR-22	1.000	ug/L
51291	51291-M12-HAL-F02	Mobile Units	Flush180	28-MAY-16	1.000	ppb
51291	51291-M-HAL-F03	Mobile Units	Flush180	28-MAY-16	1.000	ppb
51291	51291-M-HAL-F03	Mobile Units	Flush180	28-MAY-16	1.000	ppb
51291	51291-M-HAL-F03	Mobile Units	Flush180	28-MAY-16	1.000	ppb
51291	51291-M-HAL-F03	Mobile Units	Flush180	28-MAY-16	1.000	ppb
51291	51291-M-HAL-F03	Mobile Units	Flush180	28-MAY-16	1.000	ppb
51291	51291-M12-HAL-F01	Mobile Units	Flush180	28-MAY-16	1.000	ppb
51291	51291-M12-HAL-F02	Mobile Units	Flush180	28-MAY-16	1.000	ppb
51291	51291-M12-HAL-F02	Mobile Units	Flush180	28-MAY-16	1.000	ppb
51291	51291-M12-HAL-F02	Mobile Units	Flush180	28-MAY-16	1.000	ppb
51291	51291-M12-HAL-F02	Mobile Units	Flush180	28-MAY-16	1.000	ppb
51291	51291-M12-HAL-F01	Mobile Units	Flush180	28-MAY-16	1.000	ppb
51291	51291-M12-HAL-F01	Mobile Units	Flush180	28-MAY-16	1.000	ppb
51291	51291-M12-HAL-F01	Mobile Units	Flush180	28-MAY-16	1.000	ppb
51291	51291-M12-HAL-F01	Mobile Units	Flush180	28-MAY-16	1.000	ppb
51291	51291-M12-HAL-F01	Mobile Units	Flush180	28-MAY-16	1.000	ppb
51291	51291-M12-HAL-F01	Mobile Units	Flush180	28-JUL-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51291	51291-M12-HAL-F02	Mobile Units	Flush180	28-JUL-20	1.000	ug/L
51291	51291-M12-HAL-F02	Mobile Units	Flush180	17-MAR-22	1.000	ug/L
51291	51291-M12-HAL-F02	Mobile Units	Flush180	17-MAR-22	1.000	ug/L
51291	51291-M12-HAL-F02	Mobile Units	Flush180	17-MAR-22	1.000	ug/L
51291	51291-M12-HAL-F02	Mobile Units	Flush180	17-MAR-22	1.000	ug/L
51291	51291-M-HAL-F03	Mobile Units	Flush180	17-MAR-22	1.000	ug/L
51291	51291-M-HAL-F03	Mobile Units	Flush180	17-MAR-22	1.000	ug/L
51291	51291-M-HAL-F03	Mobile Units	Flush180	17-MAR-22	1.000	ug/L
51291	51291-M-HAL-F03	Mobile Units	Flush180	17-MAR-22	1.000	ug/L
51291	51291-M12-HAL-F01	Mobile Units	Initial	28-JUL-20	1.000	ug/L
51291	51291-M12-HAL-F02	Mobile Units	Initial	28-JUL-20	1.000	ug/L
51291	51291-M12-HAL-F02	Mobile Units	Initial	17-MAR-22	1.000	ug/L
51291	51291-M-HAL-F03	Mobile Units	Initial	17-MAR-22	1.000	ug/L
51291	51291-1-OUT-F02	Outside Main Entrance	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-OUT-F02	Outside Main Entrance	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-OUT-F02	Outside Main Entrance	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-OUT-F02	Outside Main Entrance	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-OUT-F02	Outside Main Entrance	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-OUT-F01	Outside of East End	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-OUT-F01	Outside of East End	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-OUT-F01	Outside of East End	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-OUT-F01	Outside of East End	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-OUT-F01	Outside of East End	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-OUT-F01	Outside of East End	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-OUT-F01	Outside of East End	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-OUT-F01	Outside of East End	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-OUT-F01	Outside of East End	Initial	17-MAR-22	1.000	ug/L
51291	51291-1-OUT-F01	Outside of East End	Initial	28-MAY-16	1.000	ppb
51291	51291-1-102-S01	Room 102	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-102-S01	Room 102	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-102-S01	Room 102	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-102-S01	Room 102	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-102-S01	Room 102	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-102-S01	Room 102	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-102-S01	Room 102	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-102-S01	Room 102	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-102-S01	Room 102	Flush180	17-MAR-22	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51291	51291-1-102-S01	Room 102	Initial	17-MAR-22	1.000	ug/L
51291	51291-1-OUT-BF11	outsid main entrance	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-OUT-BF11	outsid main entrance	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-OUT-BF11	outsid main entrance	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-OUT-BF11	outsid main entrance	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-OUT-BF11	outsid main entrance	Initial	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-BF08	outside room 101	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-BF08	outside room 101	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-BF08	outside room 101	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-BF08	outside room 101	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-F02	outside room 101	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-F02	outside room 101	Flush180	17-MAR-22	1.620	ug/L
51291	51291-1-HAL-F02	outside room 101	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-F02	outside room 101	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-F02	outside room 101	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F02	outside room 101	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F02	outside room 101	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F02	outside room 101	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F02	outside room 101	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F02	outside room 101	Initial	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-BF08	outside room 101	Initial	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-F04	outside room 107	Flush180	08-SEP-22	1.090	ug/L
51291	51291-1-HAL-F04	outside room 107	Flush180	08-SEP-22	1.000	ug/L
51291	51291-1-HAL-F04	outside room 107	Flush180	08-SEP-22	1.000	ug/L
51291	51291-1-HAL-F04	outside room 107	Flush180	08-SEP-22	1.430	ug/L
51291	51291-1-HAL-BF09	outside room 107	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-BF09	outside room 107	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-F04	outside room 107	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-F04	outside room 107	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-F04	outside room 107	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-F04	outside room 107	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-F04	outside room 107	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-BF09	outside room 107	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-BF09	outside room 107	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-F04	outside room 107	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F04	outside room 107	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F04	outside room 107	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F04	outside room 107	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F04	outside room 107	Flush180	28-MAY-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F04					
51291	51291-1-HAL-F04	outside room 107	Initial	08-SEP-22	1.000	ug/L
51291	51291-1-HAL-F04	outside room 107	Initial	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-BF09	outside room 107	Initial	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-F07	outside room 112	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-BF02	outside room 112	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-BF02	outside room 112	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-BF02	outside room 112	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-BF02	outside room 112	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-F07	outside room 112	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-F07	outside room 112	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-F07	outside room 112	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-F07	outside room 112	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-F07	outside room 112	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F07	outside room 112	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F07	outside room 112	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F07	outside room 112	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-BF02	outside room 112	Initial	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-F07	outside room 112	Initial	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-F09	outside room 120	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F09	outside room 120	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F09	outside room 120	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F09	outside room 120	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F09	outside room 120	Flush180	28-MAY-16	1.000	ppb
51291	51291-1-HAL-F09	outside room 120	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-F09	outside room 120	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-F09	outside room 120	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-F09	outside room 120	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-BF03	outside room 120	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-BF03	outside room 120	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-BF03	outside room 120	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-BF03	outside room 120	Flush180	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-F09	outside room 120	Initial	17-MAR-22	1.000	ug/L
51291	51291-1-HAL-BF03	outside room 120	Initial	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-BF06	outside room 204	Flush	24-OCT-2023	1.000	ug/L
51291	51291-2-HAL-BF06	outside room 204	Flush	24-OCT-2023	1.000	ug/L
51291	51291-2-HAL-BF06	outside room 204	Flush	24-OCT-2023	1.000	ug/L
51291	51291-2-HAL-	outside room 204	Flush	24-OCT-2023	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	BF06					
51291	51291-2-HAL-F08	outside room 204	Flush180	08-SEP-22	1.000	ug/L
51291	51291-2-HAL-F08	outside room 204	Flush180	08-SEP-22	1.050	ug/L
51291	51291-2-HAL-F08	outside room 204	Flush180	08-SEP-22	1.000	ug/L
51291	51291-2-HAL-F08	outside room 204	Flush180	08-SEP-22	1.130	ug/L
51291	51291-2-HAL-BF06	outside room 204	Flush180	08-SEP-22	11.500	ug/L
51291	51291-2-HAL-BF06	outside room 204	Flush180	08-SEP-22	9.110	ug/L
51291	51291-2-HAL-BF06	outside room 204	Flush180	08-SEP-22	8.670	ug/L
51291	51291-2-HAL-BF06	outside room 204	Flush180	08-SEP-22	8.570	ug/L
51291	51291-2-HAL-BF06	outside room 204	Flush180	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-BF06	outside room 204	Flush180	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-BF06	outside room 204	Flush180	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-BF06	outside room 204	Flush180	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-F08	outside room 204	Flush180	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-F08	outside room 204	Flush180	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-F08	outside room 204	Flush180	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-F08	outside room 204	Flush180	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-F08	outside room 204	Flush180	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-F08	outside room 204	Initial	08-SEP-22	1.000	ug/L
51291	51291-2-HAL-BF06	outside room 204	Initial	08-SEP-22	34.500	ug/L
51291	51291-2-HAL-BF06	outside room 204	Initial	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-F08	outside room 204	Initial	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-BF06	outside room 204	Initial	24-OCT-2023	1.000	ug/L
51291	51291-2-HAL-BF07	outside room 207	Flush180	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-BF07	outside room 207	Flush180	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-BF07	outside room 207	Flush180	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-BF07	outside room 207	Flush180	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-BF07	outside room 207	Initial	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-BF05	outside room 216	Flush180	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-BF05	outside room 216	Flush180	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-BF05	outside room 216	Flush180	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-BF05	outside room 216	Flush180	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-BF05	outside room 216	Initial	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-BF04	outside room 224	Flush180	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-BF04	outside room 224	Flush180	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-BF04	outside room 224	Flush180	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-BF04	outside room 224	Flush180	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-BF04	outside room 224	Flush180	17-MAR-22	1.000	ug/L
51291	51291-2-HAL-BF04	outside room 224	Initial	17-MAR-22	1.000	ug/L

